**REGULATORY BOCKET FILE COPY** 



Metropolitan Edison Company Post Office Box 480 Middletown, Pennsylvania 17057 717 944-4041

Writer's Direct Dial Number

February , 1980 TLL 043

TMI Support Attn: J. T. Collins, Deputy Director U. S. Nuclear Regualtory Commission c/o Three Mile Island Nuclear Station Middletown, Pa. 17057

Dear Sir:

Three Mile Island Nuclear Station, Unit II (TMI-2) Operating License No. DPR-73 Docket No. 50-320 Proposed Program for Auxiliary Building Sump and Associated Tanks Decontamination


Enclosed please find the Decontamination Plan discussed in our letter dated December 21, 1979, GQL 1509 (Item #13).

The Auxiliary Building sump and associated tanks decontamination will take place over the remainder of 1980. The internal decontamination of these tanks and sump will be performed in accordance with approved procedures that will be submitted for NRC review and approval.

The proposed schedule for accomplishing this decontamination effort will require three hundred (300) working days to accomplish, based on logical steps and manpower availability. The schedule is dependent on the availability of EPICOR II processed water for flushing systems, tanks and components and is a best case plan based on the assumption that no plating of contaminants has taken place in the tanks and that processed water flushing and filtering will remove all contamination. The processed water is also needed to wash down exterior surfaces inside the tank cubicles prior to entry for tank decontamination.

With the exception of the Auxiliary Building sump and sump tank, the amount of decontamination required in the tanks will be determined as each system is flushed and an internal inspection of the tank has been accomplished. This internal inspection will determine the extent of residual contamination, remaining inside, that must be removed.

It is presently planned to circulate the tank water through filters to remove the tank residuals. The system and the operating techniques used will be supported by approved procedures.



The proposed schedule for decontamination of the Auxiliary Building sump and associated tanks, is attached.

Sincerely, Wilson F. Director, TMI-II

RFW:LWH:hah

..

:

Enclosure

cc: R. Vollmer (w/o enc.)