

**DISTRIBUTION:**  
Docket No. 50-320  
NRC PDR  
Local PDR  
DCS  
TMI HQ r/f  
TMI Site r/f  
WDTravers  
MTMasnik  
RHall  
JThomas  
JWhite  
CCowgill  
TMoslak  
LChandler, ELD  
IE  
ACRS  
M-Town Office

July 16, 1986  
NRC/TMI-86-039

Docket No. 50-320

Mr. F. R. Standerfer  
Vice President/Director, TMI-2  
GPU Nuclear Corporation  
P. O. Box 480  
Middletown, PA 17057

Dear Mr. Standerfer:

Subject: Ultrahigh Pressure Water Flush

Reference: Letter 4410-86-L-0043, F. Standerfer to W. Travers, Ultrahigh Pressure Water Flush Safety Evaluation Report, dated March 14, 1986.

This letter is in response to the above referenced letter which forwarded your safety evaluation report (SER) for the proposed decontamination using 75 Ultrahigh Pressure Water Flush in various areas of the TMI-2 Reactor Building. Your SER described the proposed activities and equipment intended for your use in performing the activities, assessed the safety implications of the associated heavy load handling, and assessed the activities impact on criticality, boron dilution, radiological working conditions, environmental releases, and damage to structures and systems.

We have completed our review of your submittal, and based on our safety evaluation which is attached, we have concluded that the proposed activities can be safely performed without presenting any undue risk to the health and safety of the public and the occupational work force, and that they do not involve an unreviewed safety question.

We therefore approve your proposed Ultrahigh Pressure Flush decontamination as described in the reference contingent upon the submittal of the associated procedures subject to Technical Specification 6.8.2.

Sincerely,

**ORIGINAL SIGNED BY:**  
William D. Travers

W. D. Travers  
Director  
TMI-2 Cleanup Project Directorate

Attachment: As stated

OFFICE		8607220738 860716 PDR ADOCK 05000320 P PDR				
SURNAME						
DATE						

Mr. F. R. Standerfer

-2-

July 16, 1986

cc: T. F. Demmitt  
R. E. Rogan  
S. Levin  
W. H. Linton  
J. J. Byrne  
A. W. Miller  
Service Distribution List  
(see attached)

OFFICE	TMICPD	TMICPD	TMICPD				
SURNAME	JThomas:jes	JWhite	WTravers				
DATE	7/16/86	7/16/86	7/16/86				

### Description of System

## Structural and Heavy Load Considerations

Heavy load handling related to the UIIP decontamination program will be performed in accordance with approved procedures which will assure that operations conform to the bounding conditions of the UIIC approved load handling safety evaluations.

[illegible]



The staff has concluded that the licensee's proposed program does not present the potential for damage to components from load handling or water impingement that could result in any undue risk to the health and safety of the public.

### Criticality

Water used for the UHP flush will not be intentionally introduced into the RCS or fuel transfer canal during operations. In addition, the UHP flush flow rate will generally be low, and in the unlikely event of inadvertent introduction of flush water, a rapid boron dilution will not occur and current requirements for RCS and FTC level monitoring and boron analysis will provide for detection of the event before a criticality potential would develop. Water used in the UHP system will be administratively controlled to assure boration in accordance with the requirements of currently approved evaluations relating to reactor building sump criticality control. Therefore, there is reasonable assurance that the UHP decontamination program will not present the potential for any inadvertent criticality in the RCS or the reactor building sump.

### Radiological and Environmental Considerations

A small amount of airborne radioactivity, in the form of particulates and tritium, may be introduced into the reactor building atmosphere during UHP water flush. During initial operations of the system respiratory protection devices with appropriate protection factors will be worn. Normal radiological controls practices will be sufficient to assure worker exposures remain ALARA. Reactor building effluents to the environment will be treated by the purge filtration system prior to release. It is estimated that any increase in airborne releases as a result of UHP water flushing would be a small fraction of the TMI-2 Technical Specification limits for offsite releases. The staff concludes that the proposed operation is within the scope of decontamination activities addressed in the Programmatic Environmental Impact Statement (PEIS).

### Conclusion

Based on our safety review, the proposed Ultrahigh Pressure Flush Decontamination Program does not pose a significant risk to the health and safety of the public or the occupational work force. It does not present the possibility of any accident not previously analyzed nor does it change the consequences of, or likelihood of any previously analyzed accident. Margins of safety as previously analyzed are not reduced. The proposed program does not constitute an unreviewed safety question. The scope of the proposed activities and the associated environmental impact are within those previously considered in the PEIS. The proposed program is therefore approved contingent upon the submittal of the applicable procedures subject to Technical Specification 6.8.2.

OFFICE									
SURNAME									
DATE									

Dr. Thomas Murley  
Regional Administrator  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406

John F. Wolfe, Esq., Chairman  
Administrative Judge  
Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dr. Oscar H. Paris  
Administrative Judge  
Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dr. Frederick H. Shon  
Administrative Judge  
Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dr. Judith H. Johnsrud  
Environmental Coalition on Nuclear Power  
433 Orlando Avenue  
State College, PA 16801

Ernest L. Blake, Jr., Esq.  
Shaw, Pittman, Potts, and Trowbridge  
1800 M. Street, NW  
Washington, D.C. 20036

Atomic Safety and Licensing Board Panel  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Secretary  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Frederick S. Rice, Chairman  
Dauphin County Board of Commissioners  
Dauphin County Courthouse  
Front and Market Streets  
Harrisburg, PA 17101

Thomas M. Gerusky, Director  
Bureau of Radiation Protection  
Department of Environmental Resources  
P.O. Box 2063  
Harrisburg, PA 17120

Ad Crable  
Lancaster New Era  
8 West King Street  
Lancaster, PA 17601

Willis Bixby, Site Manager  
U.S. Department of Energy  
P.O. Box 88  
Middletown, PA 17057-0311

David J. McGoff  
Office of LWR Safety and  
Technology  
NE-23  
U.S. Department of Energy  
Washington, D.C. 20545

William Lochstet  
104 Davey Laboratory  
Pennsylvania State University  
University Park, PA 16802

Frank Lynch, Editorial  
The Patriot  
812 Market Street  
Harrisburg, PA 17105

Robert B. Borsum  
Babcock & Wilcox  
Nuclear Power Division  
Suite 220  
7910 Woodmont Avenue  
Bethesda, MD 20814

Michael Churchhill, Esq.  
PILCOP  
1315 Walnut Street, Suite 1632  
Philadelphia, PA 19107

Marvin I. Lewis  
7801 Roosevelt Blvd. #62  
Philadelphia, PA 19152

Jane Lee  
183 Valley Road  
Etters, PA 17319

Walter W. Cohen, Consumer  
Advocate  
Department of Justice  
Strawberry Square, 14th Floor  
Harrisburg, PA 17127

Mr. Edwin Kintner  
Executive Vice President  
General Public Utilities  
Nuclear Corporation  
100 Interpace Parkway  
Parsippany, NJ 07054