



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

(717) 948-8400

September 15, 1993
C312-93-2063
C000-93-2202

US Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Three Mile Island Nuclear Station Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Contamination Estimate for Two TMI-2 AFHB Cubicles

Dear Sir:

The Post-Defueling Monitored Storage (PDMS) Safety Analysis Report (SAR), Supplement 4, Question No. 1 requested an estimate of the total quantity of contamination in the Auxiliary and Fuel Handling Buildings (AFHB). As agreed, GPU Nuclear would provide an assessment of the quantity of contamination in two AFHB cubicles for NRC review. If the methodology used to assess the contamination was acceptable to the NRC, contamination in the rest of the AFHB would be so estimated.

Enclosure 1 provides the methodology for estimating the curie loading of the TMI-2 AFHB cubicles and other areas. As stated therein, an initial estimate of the curie loading in each cubicle/area will be made using a simplified model. Based on preliminary estimates, approximately 95 % of the contamination in the AFHB is contained in nine cubicles/areas. Those nine cubicles/areas will then be evaluated to determine whether to construct a more precise model based on their propensity for significantly increasing the original curie estimate.

The assessment of the two cubicles/areas chosen for assessment by NRC are included as Enclosures 2 and 3. The enclosures present the calculations of the curie loading in the two makeup demineralizers and the "A" spent fuel pool, respectively. It is noteworthy that these areas represent several of the more difficult cubicles/areas to evaluate.

230063

9309240202 930915
PDR ADOCK 05000320
PDR

GPU Nuclear Corporation is a subsidiary of General Public Utilities Corporation

ACI 11

Document Control Desk

September 15, 1993


C312-93-2063

C000-93-2202

Page 2

As stated above, NRC acceptance of the methodology is necessary for completion of the AFHB contamination estimates. However, GPU Nuclear shall proceed under the assumption that the methodology described in Enclosure 1 is acceptable and will calculate the total quantity of contamination in the AFHB accordingly.

Sincerely,



R. L. Long

Director, Services Division/TMI-2

EDS/dlb

Enclosures

cc: M. Evans - Senior Resident Inspector, TMI
T. T. Martin - Regional Administrator, Region I
M. T. Masnik - Project Manager, PDNP Directorate
L. H. Thonus - Project Manager, TMI

ENCLOSURE 1

Methodology for Estimating the Curie Loading of the TMI-2 Auxiliary and Fuel Handling Building Cubicles and Other Areas

INTRODUCTION

While the majority of the radioactive contamination resulting from the TMI-2 reactor accident of 1979 remains within the TMI-2 Reactor Building, approximately 145 locations within the Auxiliary and Fuel Handling Buildings (AFHB) and other areas are listed in the Post-Defueling Monitored Storage (PDMS) Safety Analysis Report (SAR) as locations (cubicles/areas) containing some levels of radioactive contamination. Some of these cubicles/areas were exposed to radioactive material concentrations that left them severely contaminated. Others were only moderately contaminated, and some cubicles were largely unaffected by the accident and the subsequent defueling operations.

Prior to entering PDMS, GPUNC has committed to provide an estimate of the curie content of these cubicles/areas showing the estimated total activity (fixed and removable), that will be present upon entry into PDMS. To provide specific (room-by-room) estimates that provide the curie content at some level of accuracy is a difficult task if each room or area were to be modeled precisely. Constructing an exact representation of each area/cubicle, including equipment and room size, would expend many man-hours. The end product would still be an estimate with an error band of approximately \pm 50%.

To simplify this task, most of the locations will be modeled using the Microshield radiation shielding computer code, a common geometry for all areas, and the average general area radiation survey reading as the modeling parameters. A few of the areas containing the majority of the contamination will be modeled more precisely. The below listed assumptions are necessary to the simplify this effort.

ASSUMPTIONS

1. The radioactive material within a selected area is composed of typical TMI-2 isotopes than can be classified into one of three groups: Defueling, Make-up and Purification (MUP), or Normal waste. These TMI-2 classifications are used to represent materials for waste shipments and are based on specific isotopic distributions.
2. The "Average General Area" radiation measurement for a selected room is the average of a number of measurements taken from a typical TMI-2 Radiological Controls Survey as described in GPUNC Radiological Controls Procedure 6610-ADM-4200.04 and GPUNC Radiological Controls Standing Order Memorandum 6610-92-53.

3. The geometry used for modeling a cubicle/area having a small quantity of radioactive material (i.e., less than 50 curies) is typically a cylinder with an internal exposure rate point. The cylinder's size is increased or decreased depending on the actual size of the room. For example, a room that is 18 feet wide, 20 feet long and 21 feet high has a total surface area of 2,316 square feet. The internal cylinder model for this room would have a diameter of 19.5 feet $((18+21)/2)$ and a length of 37.8 feet. The total internal surface area for the model is the same, i.e., about 2,316 square feet.
4. Cubicles that do not have a rectangular floor are considered to be rectangular, by choosing the longest path through the room as the length of the room. This path may be diagonal for some areas but will always represent a conservative room size. The width of some cubicles may be determined in a similar fashion.
5. Equipment and other obstructions are ignored in estimating the room size. Only the outermost walls are considered.
6. The equipment or piping in a cubicle is not considered to be the deposition site of the radioactive material.
7. All of the radioactive material is equally distributed over the interior of the cylindrical model.
8. The exposure rate site is about head-high at the center of the room.
9. For those cubicles containing greater than 50 curies based on previous knowledge or the above modeling technique, an engineering evaluation will be made to determine whether to construct a more precise model. The propensity for measurably increasing the original curie estimate will be the determining factor in this decision process. A preliminary estimate indicates that the AFHB contains greater than 10,000 curies; therefore, a "measurable increase" is presumed to be 50 curies (i.e., 0.5% of the total). The more precise model will be developed using the actual room dimensions, specific equipment involved and other relevant information (e.g., contained water).

EFFECT OF ABOVE MODELING TECHNIQUE

The method outlined above will produce a reasonable estimate of activities for the AFHB and other areas since approximately 95 % of the activity is contained in the nine cubicles/areas within the AFHB having greater than 50 curies. Each of these nine cubicles will be evaluated to determine whether a more precise model should be developed. This is an effort to apply the greatest precision to the areas where most of the activity resides. The other cubicles individually contain much less activity; minor inaccuracy in modeling these cubicles will have an insignificant impact on the final total inventory.

The cubicles/areas modeled using the equivalent cylindrical surface area technique will provide a conservative estimate of the activity present, since the activity will be assumed to be on the inside surface of the cylinder and not in the equipment or piping in the room. In addition, the

curies associated with any fuel debris previously determined to be present in a room or area, will be added to the activity estimated from the exposure rate modeling. Since the number of curies present in fuel debris is generally a contributor to the source of the general area exposure rate for that room, a "double-counting" of curies for these locations will take place, resulting in an overestimate of the total activity in the cubicle.

SUMMARY

The methodology described above will optimize the use of GPU Nuclear's time, resources and analytical ability to estimate the number of curies present in the cubicles/areas containing the largest amount of activity (i.e., those accounting for about 95% of the total). The remaining cubicles/areas will be estimated with less accuracy using the equivalent cylindrical technique to reduce the number of modeling problems.

Calculation Sheet

Subject	Calc No.	Rev. No.	Sheet No
FH109/FH300 Curie Estimate	4240-3233-93-020	0	1 of 35
Originator	Date	Reviewed by	Date
B. Brosey <i>B. Brosey</i>	8/27/93	G. Lodde <i>G. Lodde</i>	8/27/93

1.0 PROBLEM STATEMENT

The purpose of this calculation is to estimate the curie loading of the TMI-2 Fuel Pool "A" located in the Fuel Handling Building at the 347' El. Radiological Controls survey data will be used to provide the exposure rate information necessary for this estimate.

2.0 SUMMARY OF RESULTS

Based on the Radiological Controls survey data and isotopic concentrations determined to be present in smear data, the Fuel Pool "A" area contains an upper bound of approximately $135 \text{ Ci} \pm 22 \text{ Ci}$'s of activity. A previous estimate from reference 3.7 (from 9/21/89), reported that about 59 Ci of activity were present in the FHB "A" Fuel Pool. The previous preliminary estimate did not include all the isotopes present in the mixture and was subject to a larger sampling error.

3.0 REFERENCES

- 3.1 Microshield Radiation Shielding Computer Code, Version 4, Grove Engineering, Inc., 15215 Shady Grove Rd., Rockville, MD 20850.
- 3.2 Lotus 1-2-3, Release 2.2, Lotus Development Corporation, 55 Cambridge Parkway, Cambridge, MA 02142.
- 3.3 "The Health Physics and Radiological Health Handbook", Scinta, Inc., Silver Springs, MD., 1992.
- 3.4 Burns & Roe, Inc., Drawing No. 2068, rev 23, "General Arrangement Auxiliary & Fuel Handling Building Floor Plan El. 347'-6", W.O. 2555, 9/17/70.
- 3.5 NES, Drawing No. 83E0950, rev 2, "Spent Fuel Pool Canister Storage Rack Arrangement", Danbury, Connecticut, 11/84.
- 3.6 GPUNC Engineering Calculation No. 4800-4420-89-095, rev. 0, "G.M. Measurements of Fuel Debris (FTS)", 9/21/89.
- 3.7 GPUNC Memorandum No. 4800-89-127, "Fuel Debris in Defueling Canal and Fuel Pool "A""", 10/16/89.
- 3.8 GPUNC Engineering Calculation No. 4240-3233-93-001, rev. 0, "TMI-2 Waste Stream Analysis", 1/11/93.
- 3.9 NES, Drawing No. 83E0943, rev 3, "Top Plate", Danbury, Connecticut, 10/84.
- 3.10 NES, Drawing No. 83E0919, rev 4, "Fuel Canister Storage Rack 7 x 9", Danbury, Connecticut, 10/84.

Calculation Sheet

Subject		Calc No.	Rev. No.	Sheet No
FH109/FH300 Curie Estimate		4240-3233-93-020	0	2 of 35
Originator	Date	Reviewed by		
B. Brosey	8/27/93	G. Lodde	<i>Jim Lohle</i>	8/27/93

4.0 ASSUMPTIONS AND BASIC DATA

4.1 General overview and description of methodology.

- 4.1.1 In general, the Fuel Pool "A" area is modeled in sections. In section one, the activity is assumed to be at the bottom of the Fuel Pool in the region of the north canister handling/dewatering platforms. A three (3) inch deep water shield is assumed to cover the activity in this region at the time of the Radiological Controls survey.
- 4.1.2 The south region or section two of the fuel pool, contains the fuel canister racks. The source term is assumed to occupy only the area of the fuel racks and is homogeneously distributed in the rack volume. This is a conservative assumption since a portion of the source is actually distributed around the rack space as a surface deposition with little shielding. However, it is assumed that a significant portion of the source materials are present within the fuel racks as fuel debris.

4.2 Determination of materials and densities.

- 4.2.1 From review of reference 3.9 and 3.10 the following data table was assembled using the Lotus 1-2-3 spreadsheet system (reference 3.2). These values are used to estimate the effective density of the fuel rack region.

INPUT DENSITY VALUES FOR FUEL POOL "A"

ASSUMED COMPOSITION===== 0.0% LEAD
BY WEIGHT 100.0% IRON

DIMENSIONS OF INTERNALS TO BE SUBTRACTED (ft)

LENGTH==> 0
WIDTH==> 0
HEIGHT==> 0

VOLUME OF INTERNALS TO BE SUBTRACTED (cc's)> 0.00E+00

DIMENSIONS OF SOURCE REGION IN FUEL POOL "A" (ft)

LENGTH==> 44.40625
WIDTH==> 14.125
HEIGHT==> 13.1979

VOLUME OF SOURCE REGION (cc's)===== 2.34E+08

SOURCE REGION IN FUEL POOL A MINUS REGION TO BE SUBTRACTED.

EFFECTIVE SOURCE VOLUME (cc's)> 2.34E+08

FUEL POOL MATERIALS MATERIALS WEIGHT OF WEIGHT OF DENSITY OF DENSITY OF **

APPROXIMATE WEIGHT LEAD IRON LEAD IRON **

MATERIALS	WEIGHT (lbs)	(gms)	(gms)	(g/cc)	(g/cc)	**
-----------	--------------	-------	-------	--------	--------	----

COMPOSITION 1	37646	37057306	0	37057306	0.000000	0.158085 **
---------------	-------	----------	---	----------	----------	-------------

COMPOSITION 2	0	0	0	0	0.000000	0.000000 **
---------------	---	---	---	---	----------	-------------

Calculation Sheet

Subject	Calc No.	Rev. No.	Sheet No
FH109/FH300 Curie Estimate	4240-3233-93-020	0	3 of 35
Originator	Date	Reviewed by	Date
B. Brosey	8/27/93	G. Lodde	8/27/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.2 Determination of materials and densities cont'd.

4.2.2 The Fuel Racks are assumed to be composed of steel with a weight of approximately 17,380 lbs per 7 x 9 section. There are four sections in the pool (reference 3.5 & 3.10).

4.2.3 The steel top plate sections are assumed to weigh approximately 3044 lbs per section. There are four sections (reference 3.9).

4.3 The isotopes, and activity of the isotopes present in one curie of source materials were determined from smear radiochemistry analysis and from the use of the Lotus 1-2-3 spreadsheet from reference 3.8. Isotopes normally found at TMI-2 were scaled in assuming a "Defueling" waste stream (attachment 1-1 to 1-6).

4.4 The following table presents the smear numbers and decayed results for ten (10) smears taken from the Fuel Pool and assayed by GPUNC. Smear results are decayed to 8/24/93.

FH109 SMEAR DATA FILE NAME: SFP-A.WK1
TODAY'S DATE=>8/24/93

SMEAR	SHEAR	SAMPLE	ISOTOPES and ACTIVITY'S (OUTPUT VALUES)						**	WASTE CLASS Based on	ALPHA ACTIVITY			
			UCl's per 100 cm ²											
			**	**	**	**	**	**						
AREA LOCATION	I.D.	NUMBER	DATE	** Cs-137	** Sr-90	** Cs-134	** Cs-125	** Co-60	** Eu-154	** Sr/Cs	** Sr/Cs	ACTIVITY		
1	FHB	FH109	9206003	8	6/3/92	** 8.14E-03	1.77E-02	1.78E-05	0.00E+00	1.21E-04	0.00E+00	** 2.17	DEFUELING 2.162E-04	
2	FHB	FH109	9206002	7	6/3/92	** 4.68E-03	1.14E-02	0.00E+00	0.00E+00	6.12E-05	0.00E+00	** 2.43	DEFUELING 2.207E-04	
3	FHB	FH109	9205016	NONE	5/28/92	** 3.14E-03	6.62E-03	0.00E+00	9.97E-05	3.92E-05	0.00E+00	** 2.11	DEFUELING 1.279E-04	
4	FHB	FH109	9205015	NONE	5/28/92	** 5.10E-03	1.24E-02	2.39E-05	0.00E+00	8.36E-05	0.00E+00	** 2.43	DEFUELING 1.658E-04	
5	FHB	FH109	NONE	12	7/25/92	** 2.45E-03	5.76E-03	0.00E+00	0.00E+00	3.34E-05	0.00E+00	** 2.35	DEFUELING NOT DONE	
6	FHB	FH109	NONE	10	7/25/92	** 9.57E-04	2.11E-03	0.00E+00	0.00E+00	1.18E-05	0.00E+00	** 2.47	DEFUELING NOT DONE	
7	FHB	FH109	NONE	11	7/25/92	** 3.82E-03	1.14E-02	0.00E+00	0.00E+00	8.85E-05	0.00E+00	** 2.98	DEFUELING NOT DONE	
8	FHB	FH109	NONE	14	7/25/92	** 4.15E-04	9.44E-04	0.00E+00	0.00E+00	9.46E-06	0.00E+00	** 2.28	DEFUELING NOT DONE	
9	FHB	FH109	3960-6	7	7/25/92	** 6.07E-04	3.73E-03	0.00E+00	0.00E+00	0.00E+00	0.00E+00	** 6.15	DEFUELING NOT DONE	
10	FHB	FH109	NONE	13	7/25/92	** 1.10E-03	2.53E-03	0.00E+00	0.00E+00	2.00E-05	0.00E+00	** 2.30	DEFUELING NOT DONE	
<hr/>												AVERAGES=> 3.03E-03 7.45E-03 4.17E-06 9.97E-06 4.68E-05 0.00E+00	2.7663 1.827E-04	

4.5 Computer modeling for Fuel Pool "A".

4.5.1 From review of the references the following information represents the basic Microshield 4 input files.

a) Section 1, Basic Microshield 4 input:

Dose point to center of rectangular area (X)...30.48 cm.
 Height of rectangular area (H).....720.09 cm.
 Rectangular area width (W).....387.35 cm.
 Thickness of shield 1 (SH1).....7.62 cm.
 Dose point position along Z axis (Z).....193.67495 cm.
 Dose point from base of area (Y).....360.045 cm.
 Air Gap.....22.86 cm.

Calculation Sheet

Subject		Calc No	Rev. No	Sheet No
FH109/FH300 Curie Estimate		4240-3233-93-020	0	4 of 35
Originator B. Brosey	Date 8/27/93	Reviewed by G. Lodde	<i>B. Brosey</i>	Date 8/27/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.5 Computer modeling for Fuel Pool "A" cont'd.

4.5.1 Cont'd.

b) Section 2, Basic Microshield 4 input:

Dose point to center rectangle (X).....1264.3104 cm.
 Height of rectangle (H).....1353.5025 cm.
 Rectangular vol. width (W).....430.53 cm.
 Rectangular vol. length (L).....402.27199 cm.
 Thickness of shield 1 (SH1).....7.62 cm.
 Dose point position along Z axis (Z).....215.265 cm.
 Dose point from base of source (Y).....676.75125 cm.
 Air Gap.....854.41841 cm.

4.6 Review and interpretation of survey data.

4.6.1 Two (2) Radiological Controls Field Operations surveys were reviewed to determine the average exposure rate at set locations within the FHB Fuel Pool "A" area. Copies of these surveys are shown as attachments 2-1 and 2-2. The average value for the survey locations were determined by spreadsheet analysis (see attachments 3-1 and 3-2).

4.6.2 The estimate of the error from incorrectly determining the vertical distance from a source term, is determined by assuming a \pm six inch error in the radiation measurement reported for section one and that \pm two foot errors could have occurred in section two measurement locations.

4.7 A one curie source term is used to estimate the exposure rate at the same locations reported on the Radiological Controls survey sheets. The calculated output is then compared to the actual measured values. The actual measurement data is converted into the number of curies present in the measurement location. Activities as of 8/24/93.

4.8 The following is a description of the attachments presented in this calculation.

- a) Attachments 1-1 to 1-6, present and scale in the isotopes extracted from section 4.4 and assumed to characterize the "A" Fuel Pool.
- b) Attachments 2-1 & 2-2, present the two Radiological Controls surveys for section 1 and 2 respectively, of the "A" Fuel Pool.
- c) Attachments 3-1 & 3-2, present the Statistical Determination Worksheet for section 1 and 2 respectively, of the "A" Fuel Pool. The average exposure rates for both regions are computed on these attachments.

Calculation Sheet

Subject		Calc No	Rev. No	Sheet No
FH109/FH300 Curie Estimate		4240-3233-93-020	0	5 of 35
Originator	Date	Reviewed by		
B. Brosey	8/27/93	G. Lodde	8m Lode	8/27/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.8 Continued.

- d) Attachments 4-1 & 4-2, present the Microshield 4 output data for a 1 curie "Defueling" mixture of activity for section 1 (De-watering Station), of the "A" Fuel Pool.
- e) Attachments 5-1 & 5-2, present the Microshield 4 output data for a 1 curie "Defueling" mixture of activity for section 2 (Fuel Rack Area), of the "A" Fuel Pool.
- f) Attachments 6-1, Lotus 1-2-3 "Normalization Worksheet", used to compare and estimate from the 1 curie Microshield 4 output to the number of curies present (suggested by actual exposure rate from survey data). This attachment presents the estimated number of curies in section 1 of the "A" Fuel Pool.
- g) Attachments 7-1, Lotus 1-2-3 "Normalization Worksheet", used to compare and estimate from the 1 curie Microshield 4 output to the number of curies present (suggested by actual exposure rate from survey data). This attachment presents the estimated number of curies in section 2 of the "A" Fuel Pool.
- h) Attachments 8-1 to 8-6, are diagrams and sections of drawings for the Fuel Pool storage racks as well as general layouts for the Fuel Pool area.
- i) Attachments 9-1 to 9-7, are Microshield 4 output data for error estimates for this calculation including a graphical presentation.

5.0 CALCULATIONS

5.1 Most of the earlier operations were performed using the Lotus 1-2-3 spreadsheet system or Microshield 4.

5.2 Estimation of error terms.

5.2.1 The combined estimate of error in this analysis includes the following:

- a) The estimate of the uncertainty in the radiation measurements from the radiological surveys, due to incorrectly reported survey locations (in the vertical plane).
- b) An assumed instrumentation response error of $\pm 20\%$.

5.2.2 The distance error estimate assumes that the actual exposure rate point is within ± 2 feet of the correct measurement location for the Fuel Rack section, and ± 6 inches for the De-watering Station location. To estimate this effect the

Calculation Sheet

Subject	Calc No	Rev. No.	Sheet No
FH109/FH300 Curie Estimate	4240-3233-93-020	0	6 of 35
Originator	Date	Reviewed by	Date
B. Brosey <i>B. Brosey</i>	8/27/93	G. Lodde <i>GM Lodde</i>	8/21/93

5.0 CALCULATIONS Cont'd

5.2 Estimation of error terms cont'd.

5.2.2 Cont'd.

Microshield 4 shielding code problems above are again computed but with these distance effects included (see attachments 9-1 to 9-7). The results are shown below:

De-watering Station Exposure rate error term for -6 inch location is $1-(10.23/10.99) \times 100\% = -6.9\%$ and about -4% on the +6 inch side of the one foot measurement. The graph shown on attachment 9-7 shows the exposure rate variation from an area source for the model presented herein. The one foot calculation appears to be about the highest value for this problem. Therefore, 6 inches closer or farther away produce a small reduction in the calculated exposure rate and a resulting increase in the curie estimate. Assume $\pm 5\%$ for this error term.

5.2.3 The error term for the Fuel Rack section is computed in the same manner as above. The Microshield output for a ± 2 foot variation in distance produces the following error.
 $1-(1.088e-1/9.761e-2) \times 100\% = +11.5\%$, for -2 feet and
 $1-(8.795e-2/9.761e-2) \times 100\% = -10\%$, for +2 feet. Assume $\pm 10\%$ for this error term.

5.2.4 Combination of error terms.

Combined error term for De-watering station is:
 $((\pm 20\%)^2 + (\pm 5\%)^2)^{0.5} = \pm 21\%$.

Combined error term for Fuel Rack area is:
 $((\pm 20\%)^2 + (\pm 10\%)^2)^{0.5} = \pm 22\%$.

Combined section error estimate is:

$$(21\%/100\%) \times 49.29 \text{ Ci} = \pm 10.4 \text{ Ci., De-watering Station.}$$

$$(22\%/100\%) \times 86.057 \text{ Ci} = \pm 18.9 \text{ Ci., Fuel Racks area.}$$

Total estimate of error is:

$$((\pm 10.4 \text{ Ci})^2 + (\pm 18.9 \text{ Ci})^2)^{0.5} = \pm 21.6 \text{ Ci's}$$

Attachment 1-1

SAMPLE RESULTS AND VOLUME ACTIVITIES SCALED FROM WEIGHTED ORIGEN2 VALUES

Page 1 of 6

"ALPHA DATE">> 1/1/93 TODAY'S DATE> 8/24/93 Use EPRI

***** SCALED VALUES ? *****
SAMPLE NAME>> DEFUELING WASTE IN FH109 1=YES, 2=NO> 1

Units>> UCI's

Analysis Date>> 8/24/93 0 Days between analysis date and "TODAY'S DATE".
-235 Days between analysis date and "ALPHA DATE".

N/A 843 9/1/93

ISOTOPES	HALF-LIFE (d)	Activity (UCI) at "ALPHA DATE"	% of Total	Normalized		Input Values Checked by:
				to 1	Input Values Reviewed by:	
1 H-3	4.485E+03	0.00E+00	0.00%	0.00E+00		
2 C-14	2.093E+06	0.00E+00	0.00%	0.00E+00		
3 Cr-51	2.770E+01	0.00E+00	0.00%	0.00E+00		
4 Mn-54	3.127E+02	0.00E+00	0.00%	0.00E+00		
5 Fe-55	9.862E+02	9.73E-05	0.45%	4.47E-03		
6 Co-58	7.080E+01	0.00E+00	0.00%	0.00E+00		
7 Co-60	1.925E+03	4.68E-05	5.09E-05	0.23%	2.34E-03	
8 Ni-63	3.656E+04		4.64E-04	2.14%	2.14E-02	
9 Zn-65	2.444E+02	0.00E+00	0.00%	0.00E+00		
10 Sr-89	5.055E+01	0.00E+00	0.00%	0.00E+00		
11 Sr-90	1.045E+04	7.45E-03	7.57E-03	34.79%	3.48E-01	
12 Y-90	2.671E+00		7.57E-03	34.79%	3.48E-01	
13 Tc-99	7.780E+07	0.00E+00	0.00%	0.00E+00		
14 Ru-106	3.682E+02	0.00E+00	0.00%	0.00E+00		
15 Rh-106	3.463E-04		0.00E+00	0.00%	0.00E+00	
16 Ag-110m	2.498E+02	0.00E+00	0.00%	0.00E+00		
17 Ag-110	2.844E-04		0.00E+00	0.00%	0.00E+00	
18 Sb-125	1.012E+03	9.97E-06	9.97E-06	0.05%	5.38E-04	
19 Te-125m	5.800E+01		2.71E-06	0.01%	1.24E-04	
20 I-129	5.734E+09	0.00E+00	0.00%	0.00E+00		
21 Cs-134	7.531E+02	4.17E-06	5.18E-06	0.02%	2.38E-04	
22 Cs-137	1.102E+04	3.03E-03	3.08E-03	14.14%	1.41E-01	
23 Ba-137m	1.772E-03		2.91E-03	13.37%	1.34E-01	
24 Ce-141	3.250E+01		0.00E+00	0.00%	0.00E+00	
25 Ce-144	2.843E+02	0.00E+00	0.00%	0.00E+00		
26 Pr-144	1.200E+02		0.00E+00	0.00%	0.00E+00	
27 Pr-144a	5.000E-03		0.00E+00	0.00%	0.00E+00	
28 Pm-147	9.582E+02	0.00E+00	0.00%	0.00E+00		
29 Eu-154	3.214E+03	0.00E+00	0.00%	0.00E+00		
30 Eu-155	1.812E+03	0.00E+00	0.00%	0.00E+00		
31 Pa-233	2.700E+01	0.00E+00	0.00%	0.00E+00		
32 U-234	8.930E+07	0.00E+00	0.00%	0.00E+00		
33 U-235	2.571E+11	0.00E+00	0.00%	0.00E+00		
34 U-236	1.247E+09	0.00E+00	0.00%	0.00E+00		
35 Np-237	7.816E+08	0.00E+00	0.00%	0.00E+00		
36 U-238	1.632E+12	0.00E+00	0.00%	0.00E+00		
37 Pu-238	3.205E+04	0.00E+00	0.00%	0.00E+00		
38 Pu-239	8.814E+06	0.00E+00	0.00%	0.00E+00		
39 Pu-240	2.388E+05	0.00E+00	0.00%	0.00E+00		
40 Pu-241	5.260E+03	0.00E+00	0.00%	0.00E+00		
41 Am-241	1.579E+05	0.00E+00	0.00%	0.00E+00		
42 Cm-242	1.632E+02	0.00E+00	0.00%	0.00E+00		
43 Cm-243	1.047E+04	0.00E+00	0.00%	0.00E+00		
44 Cm-244	6.615E+03	0.00E+00	0.00%	0.00E+00		

TOTALS UCI's > 1.05E+02 2.19E-02 100.00% 1.00E+00

GTJ Nuclear

Calculation Sheet

Subject	FH109/FH30G Curie Estimate	Date	Reviewed by	Rev. No.	Sheet No.	Date
B. Brosey	B. Brosey	8/27/93	G. Laddie	0	X of 35	8/27/93

Attachment 1-2

9524.695 uCi Alpha/Ci (debris)
as of 1/1/93 "ALPHA DATE"

Alpha %=> 0.776621%

ISOTOPE USED FOR SCALING===== NA SAMPLE NAME=>DEFUELING WASTE IN FH109
RESULTS (Scaled Alpha)===== CAN'T SCALE! Page 2 of 6
1.827E-04 uCi (Sample or Scaled Alpha Results) TODAY'S DATE> 8/24/93

SAMPLE WEIGHTED		Per Ci	Scaled		SUM OF	REAL SAMPLE	SAMPLE WEIGHTED	Columns	Isotopes
Isotopes	Fractions	Alpha	Adjusted Alpha	Remainders	COLUMNS	RESULTS	ORIGEN2	H/F	ORIGEN2
	per Ci	Fraction	Emitters (D)	Using Pu-239 (E)	D & E (uCi)	(uCi)	RESULTS (uCi)		
Ac-227*	1.610E-10	1.610E-10	3.088E-18		3.088E-12	3.088E-12	3.088E-12	1	Ac-227
Ag-108	6.530E-09				1.253E-16	1.253E-10	1.253E-10	1	Ag-108
Ag-108m	7.020E-08				1.347E-15	1.347E-09	1.347E-09	1	Ag-108m
Ag-109m	9.000E-09				1.726E-16	1.726E-10	1.726E-10	1	Ag-109m
Ag-110	1.800E-11				3.453E-19	3.453E-13	3.453E-13	1	Ag-110
Ag-110m	1.360E-09				2.609E-17	2.609E-11	0.000E+00	2.609E-11	1 Ag-110m
Am-241*	1.650E-03	1.650E-03	3.165E-11		3.165E-05	0.000E+00	3.165E-05	1 Am-241	
Am-242	2.160E-07				4.143E-15	4.143E-09	4.143E-09	1 Am-242	
Am-242m*	2.170E-07	2.170E-07	4.162E-15		4.162E-09	4.162E-09	4.162E-09	1 Am-242m	
Am-243*	8.490E-08	8.490E-08	1.629E-15		1.629E-09	1.629E-09	1.629E-09	1 Am-243	
Ba-137m	8.400E-02				1.611E-09	1.611E-03	2.909E-03	2.909E-03	1 Ba-137m
Be-10	1.930E-11				3.702E-19	3.702E-13	3.702E-13	1 Be-10	
Bi-211*	1.590E-10	1.590E-10	3.050E-18		3.050E-12	3.050E-12	3.050E-12	1 Bi-211	
Bi-212*	1.600E-08	1.600E-08	3.069E-16		3.069E-10	3.069E-10	3.069E-10	1 Bi-212	
Bi-214	3.090E-11				5.927E-19	5.927E-13	5.927E-13	1 Bi-214	
C-14	1.030E-05				1.976E-13	1.976E-07	0.000E+00	1.976E-07	1 C-14
Ca-41	1.030E-09				1.976E-17	1.976E-11	1.976E-11	1 Ca-41	
Cd-109	9.000E-09				1.726E-16	1.726E-10	1.726E-10	1 Cd-109	
Cd-113m	9.160E-05				1.757E-12	1.757E-06	1.757E-06	1 Cd-113m	
Ce-144	6.800E-05				1.304E-12	1.304E-06	0.000E+00	1.304E-06	1 Ce-144
Cl-36	6.850E-08				1.314E-15	1.314E-09	1.314E-09	1 Cl-36	
Cm-242*	1.790E-07	1.790E-07	3.434E-15		3.434E-09	0.000E+00	3.434E-09	1 Cm-242	
Cm-243*	1.800E-08	1.800E-08	3.453E-16		3.453E-10	0.000E+00	3.453E-10	1 Cm-243	
Cm-244*	4.290E-07	4.290E-07	8.229E-15		8.229E-09	0.000E+00	8.229E-09	1 Cm-244	
Co-60	1.640E-03				3.146E-11	3.146E-05	5.093E-05	5.093E-05	1.6190171 Co-60
Cs-134	2.690E-04				5.160E-12	5.160E-06	5.177E-06	5.177E-06	1.0032408 Cs-134
Cs-135	2.050E-06				3.932E-14	3.932E-08	3.932E-08	3.932E-08	1 Cs-135
	8.880E-02				1.703E-09	1.703E-03	3.075E-03	3.075E-03	1.8053461 Cs-137
	1.630E-05				3.223E-13	3.223E-07	3.223E-07	3.223E-07	1 Eu-152
	1.290E-03				2.474E-11	2.474E-05	0.000E+00	2.474E-05	1 Eu-154
	1.950E-03				3.740E-11	3.740E-05	0.000E+00	3.740E-05	1 Eu-155
	1.780E-03				3.414E-11	3.414E-05	9.728E-05	9.728E-05	2.8491064 Fe-55
	1.530E-10				2.935E-18	2.935E-12	2.935E-12	2.935E-12	1 Cd-153
	2.600E-03				4.987E-11	4.987E-05	0.000E+00	4.987E-05	1 H-3
	3.300E-10				5.330E-18	5.330E-12	6.330E-12	6.330E-12	1 Ho-166m
	4.150E-08				7.960E-16	7.960E-10	0.000E+00	7.960E-10	1 I-129
	2.420E-07				4.642E-15	4.642E-09	0.000E+00	4.642E-09	1 Mn-54
	1.580E-07				3.031E-15	3.031E-09	3.031E-09	3.031E-09	1 Mo-93
	5.510E-06				1.057E-13	1.057E-07	1.057E-07	1.057E-07	1 Nb-93m
	8.270E-06				1.586E-13	1.586E-07	1.586E-07	1.586E-07	1 Nb-94
	3.110E-05				5.966E-13	5.966E-07	5.966E-07	5.966E-07	1 Ni-59
	3.510E-03				6.733E-11	6.733E-05	4.645E-04	4.645E-04	6.8989050 Ni-63
	6.980E-07	6.980E-07	1.339E-14		1.339E-08	0.000E+00	1.339E-08	1.339E-08	1 Np-237
	1.030E-09				1.976E-17	1.976E-11	1.976E-11	1.976E-11	1 Np-238
	8.490E-08				1.629E-15	1.629E-09	1.629E-09	1.629E-09	1 Np-239
	7.980E-10	7.980E-10	1.531E-17		1.531E-11	1.531E-11	1.531E-11	1.531E-11	1 Pa-231
	6.980E-07				1.339E-14	1.339E-08	0.000E+00	1.339E-08	1 Pa-233
	2.760E-08				5.294E-16	5.294E-10	5.294E-10	5.294E-10	1 Pa-234
	1.720E-05				3.299E-13	3.299E-07	3.299E-07	3.299E-07	1 Pa-236m
	1.590E-10				3.050E-18	3.050E-12	3.050E-12	3.050E-12	1 Pb-211
	1.600E-08				3.069E-16	3.069E-10	3.069E-10	3.069E-10	1 Pb-212
	3.090E-11				5.927E-19	5.927E-13	5.927E-13	5.927E-13	1 Pb-214
	2.110E-07				4.047E-15	4.047E-09	4.047E-09	4.047E-09	1 Pd-107
	5.150E-07				9.879E-15	9.879E-09	9.879E-09	9.879E-09	1 Pm-146
	5.190E-02				9.955E-10	9.955E-04	0.000E+00	9.955E-04	1 Pm-147
	1.020E-08	1.020E-08	1.957E-16		1.957E-10			1.957E-10	1 Po-212
	3.090E-11	3.090E-11	5.927E-19		5.927E-13			5.927E-13	1 Po-214
	1.590E-10	1.590E-10	3.050E-18		3.050E-12			3.050E-12	1 Po-215
	1.600E-08	1.600E-08	1.059E-16		3.069E-10			3.069E-10	1 Po-216
	3.090E-11	3.090E-11	5.927E-19		5.927E-13			5.927E-13	1 Po-218
	6.800E-05				1.304E-12	1.304E-06	0.000E+00	1.304E-06	1 Pr-144

Attachment 1-3

Pr-144m	9.730E-07		1.866E-14	1.866E-08	0.000E+00	1.866E-08	1 Pr-144m
Pu-236*	6.400E-09	6.400E-09	1.228E-16	1.228E-10	0.000E+00	1.228E-10	1 Pu-236
Pu-238*	4.750E-04	4.750E-04	9.111E-12	9.111E-06	0.000E+00	9.111E-06	1 Pu-238
Pu-239*	5.770E-03	5.770E-03	1.107E-10	1.107E-04	0.000E+00	1.107E-04	1 Pu-239
Pu-240*	1.530E-03	1.530E-03	2.935E-11	2.935E-05	0.000E+00	2.935E-05	1 Pu-240
Pu-241	5.300E-02		1.017E-09	1.017E-03	0.000E+00	1.017E-03	1 Pu-241
Pu-242*	9.970E-08	9.970E-08	1.912E-15	1.912E-09		1.912E-09	1 Pu-242
Pu-244*	1.310E-10	1.310E-10	2.513E-18	2.513E-12		2.513E-12	1 Pu-244
Ra-223*	1.590E-10	1.590E-10	3.050E-18	3.050E-12		3.050E-12	1 Ra-223
Ra-224*	1.600E-08	1.600E-08	3.069E-16	3.069E-10		3.069E-10	1 Ra-224
Ra-226*	3.100E-11	3.100E-11	5.946E-19	5.946E-13		5.946E-13	1 Ra-226
Rb-87	1.310E-10		2.513E-18	2.513E-12		2.513E-12	1 Rb-87
Rh-106	1.020E-04		1.957E-12	1.957E-06	0.000E+00	1.957E-06	1 Rh-106
Rn-219*	1.590E-10	1.590E-10	3.050E-18	3.050E-12		3.050E-12	1 Rn-219
Rn-220*	1.600E-08	1.600E-08	3.069E-16	3.069E-10		3.069E-10	1 Rn-220
Rn-222*	3.090E-11	3.090E-11	5.927E-19	5.927E-13		5.927E-13	1 Rn-222
Ru-106	1.020E-04		1.957E-12	1.957E-06	0.000E+00	1.957E-06	1 Ru-106
Sb-125	8.890E-04		1.705E-11	1.705E-05	1.171E-05	1.171E-05 0.6867714	Sb-125
Sb-126	4.470E-07		8.574E-15	8.574E-09		8.574E-09	1 Sb-126
Sb-126m	3.200E-06		6.138E-14	6.138E-08		6.138E-08	1 Sb-126m
Se-79	2.180E-06		4.182E-14	4.182E-08		4.182E-08	1 Se-79
Sm-147	4.900E-11		9.399E-19	9.399E-13		9.399E-13	1 Sm-147
Sm-151	6.290E-03		1.207E-10	1.207E-04		1.207E-04	1 Sm-151
Sn-119m	1.720E-07		3.299E-15	3.299E-09		3.299E-09	1 Sn-119m
Sn-126	3.200E-06		6.138E-14	6.138E-08		6.138E-08	1 Sn-126
Sr-90	3.460E-01		6.637E-09	6.637E-03	7.567E-03	7.567E-03 1.1401536	Sr-90
Tc-99	7.350E-05		1.410E-12	1.410E-06	0.000E+00	1.410E-06	1 Tc-99
Te-125m	2.050E-04		3.932E-12	3.932E-06	2.705E-06	2.705E-06 0.6879741	Te-125m
Th-227*	1.580E-10	1.580E-10	3.031E-18	3.031E-12		3.031E-12	1 Th-227
Th-228*	1.600E-08	1.600E-08	3.069E-16	3.069E-10		3.069E-10	1 Th-228
Th-230*	1.010E-08	1.010E-08	1.937E-16	1.937E-10		1.937E-10	1 Th-230
Th-231	2.550E-06		4.891E-14	4.891E-08		4.891E-08	1 Th-231
Th-234	1.720E-05		3.299E-13	3.299E-07		3.299E-07	1 Th-234
Tl-207	1.590E-10		3.050E-18	3.050E-12		3.050E-12	1 Tl-207
Tl-208	5.740E-09		1.101E-16	1.101E-10		1.101E-10	1 Tl-208
U-232*	1.600E-08	1.600E-08	3.069E-16	3.069E-10		3.069E-10	1 U-232
U-233*	1.960E-10	1.960E-10	3.760E-18	3.760E-12		3.760E-12	1 U-233
U-234*	7.840E-05	7.840E-05	1.504E-12	1.504E-06	0.000E+00	1.504E-06	1 U-234
U-235*	3.170E-06	3.170E-06	6.081E-14	6.081E-08	0.000E+00	6.081E-08	1 U-235
U-236*	2.080E-06	2.080E-06	3.990E-14	3.990E-08	0.000E+00	3.990E-08	1 U-236
U-238*	1.480E-05	1.480E-05	2.839E-13	2.839E-07	0.000E+00	2.839E-07	1 U-238
Y-90	3.460E-01		6.637E-09	6.637E-03	7.567E-03	7.567E-03 1.1401536	Y-90
Zn-65	1.080E-09		2.072E-17	2.072E-11	0.000E+00	2.072E-11	1 Zn-65
Zr-93	1.130E-05		2.168E-13	2.168E-07		2.168E-07	1 Zr-93
TOTAL==>	1.00	9.525E-03	1.827E-10	1.900E-08	1.919E-02	2.175E-02	2.419E-02
TODAY'S DATE=====> 8/24/93 SAMPLE NAME==> DEFUELING WASTE IN FH109							

Page 3 of 6



Calculation Sheet

Subject	Calc No.		Rev. No.	Sheet No.
FH109/FH300 Curie Estimate	4240-3233-93-020		0	9 of 35
Originator B. Brosey <i>B.B.</i>	Date 8/27/93	Reviewed by G. Lodde <i>G.L.</i>	Date 8/27/93	

Attachment 1-4

NOTE: An *** next to an isotope name indicates an alpha emitter.

RADENG Scaled Values

Based on Co-60 & Sb-125

EPRI (1) ORIGEN2 (2)

ISOTOPES	(UCI)	(UCI)	RATIO (1)/(2)
Fe-55	9.73E-05	3.41E-05	2.8491064248
Ni-63	4.64E-04	6.73E-05	6.8989505015

SAMPLE NAME=>DEFUELING WASTE IN FH109

TODAY'S DATE>8/24/93

	WASTE	WASTE	
Sr/Cs	%	BASED ON	BASED ON
RATIO	ALPHA	Sr/Cs	ALPHA
2.4607416	0.776621%	DEFUELING	DEFUELING

Page 4 of 6

GTV Nuclear**Calculation Sheet**

Subject	FH109/FH300 Curie Estimate	Date	Reviewed by	Rev. No.	Sheet No
B. Brosey	B. Brumz	8/27/93	G. Laddie	0	1C of 35 8/27/93

Attachment 1-5

SAMPLE RESULTS AND RESULTING VOLUME ACTIVITIES

SCALED EFRI VALUES?> YES

Page 5 of 6

TODAY'S DATE>> 8/24/93 Volume of Small Container>>> 0.00 gal

SAMPLE NAME>> DEFUELING WASTE IN FH109 0.00 ml

Units>> UCI's

Size to:

0.00 gal

"ALPHA DATE">> 1/1/93

235 Days have elapsed since "ALPHA DATE".

ISOTOPES	HALF-LIFE (d)	"ALPHA DATE"	ACTIVITY (UCI)	TODAY'S DATE	% of Total	Normalized		Rad Eng Activities
						to 1	Rad Eng Isotopes	
1 H-3	4.685E+03	4.99E+05	4.81E+05	0.20%	2.04E-03	Isotopes	UCI's	3.25E-05
2 C-14	2.093E+06	1.98E+07	1.98E+07	0.00%	8.40E-06			2.87E-03
3 Cr-51	2.770E+01	0.00E+00	0.00E+00	0.00%	0.00E+00	Am-241		7.36E-07
4 Mn-54	3.127E+02	4.64E+09	2.76E+09	0.00%	1.17E-07	Ba-137m		4.68E-05
5 Fe-55	9.862E+02	9.73E+05	8.25E+05	0.35%	3.51E-03	Ce-144		3.03E-03
6 Co-58	7.080E+01	0.00E+00	0.00E+00	0.00%	0.00E+00	Co-60		2.35E-05
7 Co-60	1.925E+03	5.09E+05	4.68E+05	0.20%	1.99E-03	Cs-134		1.12E-04
8 Ni-63	3.656E+04	4.64E+04	4.62E+04	1.97%	1.97E-02	Cs-137		9.07E-06
9 Zn-65	2.444E+02	2.07E+11	1.06E+11	0.00%	4.52E-10	Eu-154		3.42E-05
10 Sr-89	5.055E+01	0.00E+00	0.00E+00	0.00%	0.00E+00	Eu-155		2.35E-05
11 Sr-90	1.045E+04	7.57E+03	7.45E+03	31.67%	3.17E-01	I-129		7.96E-10
12 T-90	2.671E+00	*****	7.45E+03	31.67%	3.17E-01	Pm-147		8.40E-04
13 Tc-99	7.780E+07	1.41E+06	1.41E+06	0.01%	5.99E-05	Pr-144		7.36E-07
14 Ru-106	3.682E+02	1.96E+06	1.26E+06	0.01%	5.34E-05	Pu-238		9.07E-06
15 Rh-106	3.433E+04	*****	1.26E+06	0.01%	5.34E-05	Pu-239		1.11E-04
16 Ag-110m	2.498E+02	2.61E+11	1.36E+11	0.00%	5.78E-10	Pu-241		9.86E-04
17 Ag-110	2.844E+04	*****	1.81E+13	0.00%	7.69E-12	Rh-106		1.26E-06
18 Sb-125	1.012E+03	1.17E+05	9.97E+06	0.04%	4.24E-04	Ru-106		1.26E-06
19 Te-125m	5.800E+01	*****	2.30E+06	0.01%	9.79E-05	Sb-125		9.97E-06
20 I-129	5.734E+09	7.96E+10	7.96E+10	0.00%	3.38E-08	Tc-99		1.41E-06
21 Cs-134	7.531E+02	5.18E+06	4.17E+06	0.02%	1.77E-04	Te-125m		2.30E-06
22 Cs-137	1.102E+04	3.08E+03	3.03E+03	12.88%	1.29E-01	T-90		7.45E-03
23 Ba-137m	1.772E+03	*****	2.07E+03	12.18%	1.22E-01	Fe-55		8.25E-05
24 Ce-141	3.250E+01	0.00E+00	0.00E+00	0.00%	0.00E+00	Ni-63		4.62E-04
25 Ce-144	2.843E+02	1.30E+06	7.36E+07	0.00%	3.13E-05	Sr-90		7.45E-03
26 Pr-144	1.200E+02	*****	7.36E+07	0.00%	3.13E-05	U-234		1.50E-06
27 Pr-144m	5.000E-03	*****	1.05E+08	0.00%	4.47E-07	U-235		6.08E-08
28 Pm-147	9.582E+02	9.96E+04	8.40E+04	3.57%	3.57E-02	U-238		2.84E-07
29 Eu-154	3.214E+03	2.47E+05	2.35E+05	0.10%	1.00E-03	Pu-240		2.93E-05
30 Eu-155	1.812E+03	3.74E+05	3.42E+05	0.15%	1.45E-03			
31 Pa-233	2.700E+01	1.34E+08	1.34E+08	0.00%	5.69E-07			
32 U-234	8.930E+07	1.50E+06	1.50E+06	0.01%	6.39E-05			
33 U-235	2.571E+11	6.08E+08	6.08E+08	0.00%	2.58E-06			
34 U-236	1.247E+09	3.99E+08	3.99E+08	0.00%	1.70E-06			
35 Nd-237	7.016E+08	1.34E+08	1.34E+08	0.00%	5.69E-07			
36 U-238	1.632E+12	2.84E+07	2.84E+07	0.00%	1.21E-05			
37 Pu-238	3.205E+04	9.11E+06	9.07E+06	0.04%	3.85E-04			
38 Pu-239	8.814E+06	1.11E+04	1.11E+04	0.47%	4.70E-03			
39 Pu-240	2.388E+06	2.93E+05	2.93E+05	0.12%	1.25E-03			
40 Pu-241	5.260E+03	1.02E+03	9.86E+04	4.19%	4.19E-02			
41 Am-241	1.579E+05	3.16E+05	3.25E+05	0.14%	1.38E-03			
42 Cm-242	1.632E+02	3.43E+09	3.42E+09	0.00%	1.46E-07			
43 Cm-243	1.041E+04	3.45E+10	3.40E+10	0.00%	1.44E-08			
44 Cm-244	6.615E+03	8.23E+09	8.03E+09	0.00%	3.41E-07			
TOTALS UCI's>	1.36E-02	2.35E-02	100.00%	1.00E+00				

GPU Nuclear

Calculation Sheet

Subject	Calc No	Rev. No	Sheet No
FH103/FH300 Curie Estimate	4240-3233-93-020	0	11 of 35
Originator	Date	Reviewed by	Date
S. Brosey	8/27/93	J. Ladd	SM A. Natale
			8/27/93

Attachment 1-6

TODAY'S DATE==>8/24/93 SAMPLE NAME==> DEFUELING WASTE IN FH109
 RADENG VALUES?>YES Total Activity Total Activity NRC
 Activities (in uCi's) (in millicuries) "REPORTABLE"
 ISOTOPES uCi's Small Container LARGE Container(> 1% of TOTAL) Page 6 of 6

1	H-3	4.81E-05	0.00E+00	0.00E+00
2	C-14	1.98E-07	0.00E+00	0.00E+00
3	Cr-51	0.00E+00	0.00E+00	0.00E+00
4	Mn-54	2.76E-09	0.00E+00	0.00E+00
5	Fe-55	8.25E-05	0.00E+00	0.00E+00
6	Co-58	0.00E+00	0.00E+00	0.00E+00
7	Co-60	4.68E-05	0.00E+00	0.00E+00
8	Ni-63	4.62E-04	0.00E+00	0.00E+00 REPORTABLE!!
9	Zn-65	1.06E-11	0.00E+00	0.00E+00
10	Sr-89	0.00E+00	0.00E+00	0.00E+00
11	Sr-90	7.45E-03	0.00E+00	0.00E+00 REPORTABLE!!
12	R-90	7.45E-03	0.00E+00	0.00E+00 *****
13	Tc-99	1.41E-06	0.00E+00	0.00E+00
14	Ru-106	1.26E-06	0.00E+00	0.00E+00
15	Rh-106	1.26E-06	0.00E+00	0.00E+00 *****
16	Ag-110m	1.36E-11	0.00E+00	0.00E+00
17	Ag-110	1.81E-13	0.00E+00	0.00E+00 *****
18	Sb-125	9.97E-06	0.00E+00	0.00E+00
19	Ie-125m	2.30E-06	0.00E+00	0.00E+00
20	I-129	7.96E-10	0.00E+00	0.00E+00
21	Cs-134	4.17E-06	0.00E+00	0.00E+00
22	Cs-137	3.03E-03	0.00E+00	0.00E+00 REPORTABLE!!
23	Ba-137m	2.87E-03	0.00E+00	0.00E+00 *****
24	Ce-141	0.00E+00	0.00E+00	0.00E+00
25	Ce-144	7.36E-07	0.00E+00	0.00E+00
26	Pr-144	7.36E-07	0.00E+00	0.00E+00 *****
27	Pr-144m	1.05E-08	0.00E+00	0.00E+00 *****
28	Pm-147	8.40E-04	0.00E+00	0.00E+00 REPORTABLE!!
29	Eu-154	2.35E-05	0.00E+00	0.00E+00
30	Eu-155	3.42E-05	0.00E+00	0.00E+00
31	Pa-233	1.34E-08	0.00E+00	0.00E+00 *****
32	U-234	1.50E-06	0.00E+00	0.00E+00
33	U-235	6.08E-08	0.00E+00	0.00E+00
34	U-236	3.99E-08	0.00E+00	0.00E+00
35	Np-237	1.34E-08	0.00E+00	0.00E+00
36	U-238	2.84E-07	0.00E+00	0.00E+00
37	Pu-238	9.07E-06	0.00E+00	0.00E+00
38	Pu-239	1.11E-04	0.00E+00	0.00E+00
39	Pu-240	2.93E-05	0.00E+00	0.00E+00
40	Pu-241	9.86E-04	0.00E+00	0.00E+00 REPORTABLE!!
41	Am-241	3.25E-05	0.00E+00	0.00E+00
42	Cm-242	3.42E-09	0.00E+00	0.00E+00
43	Cm-243	3.40E-10	0.00E+00	0.00E+00
44	Cm-244	8.03E-09	0.00E+00	0.00E+00
TOTALS		2.35E-02	0.00E+00	0.00E+00 mCi



Calculation Sheet

Subject:	FH109/FH300 Curie Estimate		
Originalator:	B. Brosey	Date:	8/27/93
Reviewed by:	G. Loddé	Date:	8/27/93


GTU Nuclear

Calculation Sheet

Subject:	FH109/FH300 Curie Estimate
Date:	8/27/93
Originator:	B. Brosey
Reviewed by:	G. Laddie
Calc No:	4240-3233-93-020
Rev. No:	0
Sheet No:	13 of 35

REMARKS: For radiation work, *100' x 100'*
Floor Plan 100' x 100'

ORIGINAL



SURVEY INFORMATION		INSTRUMENT DATA		RADIATION SURVEY		AIR SAMPLE		FILE CODE NUMBER
LOCATION	Field Work	CONFINEMENT SURVEY	N/A	RADIATION SURVEY	DATE	TIME	SHARABLE CONTAMINATION	
REASON	Detention	INST	INST	ACTIVITY				
DATE	7-24-93	SUN	SUN	SAMPLE #				
TIME	1500	DAL	DUE	SPEAR	RT	%	CORRHS	
		DAL	DUE					
		B.C.F.	B.C.F.	NOTE: RADIATION DOSE RATES IN MREM ARE GENERAL AREA, CONTAMINATION RESULTS ARE DETAILED IN DOCUMENTS OTHERWISE NOTED				
TECH	Ted	EFF	EFF					
BAG		HQG	HQG					
POC		PDC	PDC					
TED				NOTE: O = DIRECT READING □ = SPEAR LOCATION				

7/22/93

GTU Nuclear

RADIODICTION SURVEY

□ MI-1 ■ MI-2 □ OC





Calculation Sheet

Subject FH109/FH300 Curie Estimate			Calc No 4240-3233-53-020	Haz No 0	Sheet No 14 of 35
Originator B. Brossey	Date 8/27/93	Reviewed by G. Lodde	Date 8/27/93		

(1) 2.000000E+000
 1.000000E+000
 8.000000E+000
 2.000000E+000
 1.000000E+000
 0.000000E+000

1		2		3		4		5		6		7		8		9		10		11	
1		2		3		4		5		6		7		8		9		10		11	



ORIGINAL

TIME	1.000000E+000																			
------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------

EXPOSURE RATE	1.000000E+000																				
---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------	---------------

AIR GAP: A / ■ ml-1 ■ ml-2 ○ CC

SOURCE COMMUNICATOR:

GRU Nuclear

Attachment 3-1

AUX/FHB PCMS DECONTAMINATION GOALS & STATISTICAL DETERMINATION WORKSHEET

ROOM OR AREA	GENERAL AREA MR/H GOAL		GOAL TOLERANCE VALUE=====	Page 1
FH300-B	LESS THAN	N/A		
NUMBER OF SURVEYS USED TO DETERMINE PCMS STATUS====>				
SURVEY DATE====>	7/24/92	SURVEY NUMBER====>	92J6209	LOCATION OR AREA====>FH300-B
SURVEY DATE====>	N/A	SURVEY NUMBER====>	N/A	LOCATION OR AREA====>N/A
SURVEY DATE====>	N/A	SURVEY NUMBER====>	N/A	LOCATION OR AREA====>N/A
SURVEY DATE====>	N/A	SURVEY NUMBER====>	N/A	LOCATION OR AREA====>N/A
G.A. MR/H	G.A. MR/H	G.A. MR/H		
1	300.0	41	81	1
2	1500.0	42	82	2
3	700.0	43	83	3
4	800.0	44	84	4
5	500.0	45	85	5
6	400.0	46	86	6
7	300.0	47	87	7
8	300.0	48	88	8
9	100.0	49	89	9
10	300.0	50	90	10
11	700.0	51	91	11
12	600.0	52	92	12
13	500.0	53	93	13
14	600.0	54	94	14
15	800.0	55	95	15
16	300.0	56	96	16
17	200.0	57	97	17
18	200.0	58	98	18
19	300.0	59	99	19
20	500.0	60	100	20
21	1000.0	61	101	21
22	900.0	62	102	22
23	400.0	63	103	23
24	300.0	64	104	24
25		65	105	25
26		66	106	26
27		67	107	27
28		68	108	28
29		69	109	29
30		70	110	30
31		71	111	31
32		72	112	32
33		73	113	33
34		74	114	34
35		75	115	35
36		76	116	36
37		77	117	37
38		78	118	38
39		79	119	39
40		80	120	40

MEAN G.A. MR/H===== 543.7
 N OF G.A. POINTS===== 34.0
 1-SIGMA===== 10.1
 T-TEST @ 95% C.L.===== 64.9
 GOAL X TOLERANCE===== 0

GPU Nuclear

Calculation Sheet

Calc No	4240-2233-93-020	Rev No	Sheet No
Reviewed by		Date	Date
B. Brumley	8/27/93	C. Loddie	8/27/93

Submit:

FH300-B Curie Estimate

Original:
B. Brumley

Attachment 3-2

AUX/FHB PDMS DECONTAMINATION GOALS & STATISTICAL DETERMINATION WORKSHEET

ROOM OR AREA	GENERAL AREA mR/h GOAL		Page 1
FH300-A	LESS THAN>	N/A	
NUMBER OF SURVEYS USED TO DETERMINE PDMS STATUS====>	1	GOAL TOLERANCE VALUE=====	1.5
SURVEY DATE====>	8/26/92	SURVEY NUMBER====>	92J07218 LOCATION OR AREA=====FH300-A TODAY'S DATE
SURVEY DATE====>	N/A	SURVEY NUMBER====>	N/A LOCATION OR AREA=====N/A 8/25/93
SURVEY DATE====>	N/A	SURVEY NUMBER====>	N/A LOCATION OR AREA=====N/A
SURVEY DATE====>	N/A	SURVEY NUMBER====>	N/A LOCATION OR AREA=====N/A
G.A. mR/h	G.A. mR/h	G.A. mR/h	
1	8.0	41	8.0 81 1 NOT USED
2	9.0	42	9.0 82 2
3	9.0	43	10.0 83 3
4	9.0	44	8.0 84 4
5	8.0	45	8.0 85 5
6	8.0	46	8.0 86 6
7	8.0	47	10.0 87 7
8	8.0	48	10.0 88 8
9	8.0	49	9.0 89 9
10	6.0	50	8.0 90 10
11	3.0	51	8.0 91 11
12		52	8.0 92 12
13	4.0	53	10.0 93 13
14		54	10.0 94 14
15		55	12.0 95 15
16		56	10.0 96 16
17		57	10.0 97 17
18		58	12.0 98 18
19	7.0	59	8.0 99 19
20	9.0	60	8.0 100 20
21	7.0	61	8.0 101 21
22	9.0	62	8.0 102 22
23	10.0	63	8.0 103 23
24	9.0	64	8.0 104 24
25	8.0	65	8.0 105 25
26	7.0	66	8.0 106 26
27	8.0	67	107 27
28	8.0	68	108 28
29	8.0	69	109 29
30	10.0	70	110 30
31	8.0	71	111 31
32	8.0	72	112 32
33	10.0	73	113 33
34	8.0	74	114 34
35	9.0	75	115 35
36	8.0	76	116 36
37	8.0	77	117 37
38	8.0	78	118 38
39	2.0	79	119 39
40	10.0	80	120 40

MEAN G.A. mR/h=====8.4

OF G.A. POINTS=====30.0

OF HIGHLIGHTS=====0

T TEST @ 95% C.L. =====0.0

TOTAL 4.1 TOLERANCE=====0.0

DOE/Nuclear**Calculation Sheet**

Subject	F1109/FH300 Curie Estimate	Date	Reviewed by	Calc No.
B. Broseby	8/27/93	8/27/93	G. Loddie	4240-3233-93-020 0 16 of 35 Date 8/27/93

Attachment 4-1

MicroShield 4.00 - Serial #4.00-00247
CPU

Page : 1
DOS File: FP-B.MS4
Run Date: August 25, 1993
Run Time: 11:23 a.m. Wednesday
Duration: 0:03:04

File Ref: *FH109*
Date: *8/27/93*
By: *B. Brosey*
Checked: *8/27/93*

Case Title: DEWATERING STATION AREA OF FUEL POOL A

GEOMETRY 4 - Vertical Rectangular Area

	centimeters	feet and inches
Dose point coordinate x:	30.48	1.0 .0
Dose point coordinate y:	360.045	11.0 9.7
Dose point coordinate z:	193.67495	6.0 4.2
Rectangular area height:	720.09	23.0 7.5
Rectangular area width:	387.35	12.0 8.5
Shield 1:	7.62	0.0 3.0
Air Gap:	22.86	0.0 9.0

Source Area: 278927. sq cm 300.234 sq ft. 43233.8 sq in.

MATERIAL DENSITIES (g/cm³)

Material	Shield 1	Air Gap
		Slab
Air		0.00122
Water		1.0

BUILDUP


Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

Z Direction	30
Y Direction	30

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^2$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^2$
Ag-110	7.6900e-012	2.7570e-011	Ag-110m	5.7800e-010	2.0722e-009
Am-241	1.3800e-003	4.9475e-003	Ba-137m	1.2200e-001	4.3739e-001
C-14	8.4000e-006	3.0115e-005	Ce-141	0.0000e+000	0.0000e+000
Ce-144	3.1300e-005	1.1222e-004	Cm-242	1.4600e-007	5.2343e-007
Cm-243	1.4400e-008	5.1626e-008	Cm-244	3.4100e-007	1.2225e-006
Co-58	0.0000e+000	0.0000e+000	Co-60	1.9900e-003	7.1345e-003
Cr-51	0.0000e+000	0.0000e+000	Cs-134	1.7700e-004	6.3457e-004
Cs-137	1.2900e-001	4.6249e-001	Eu-154	1.0000e-003	3.5852e-003
Eu-155	1.4500e-003	5.1985e-003	Fe-55	3.5100e-003	1.2584e-002
H-3	2.0400e-003	7.3137e-003	I-129	3.3800e-008	1.2118e-007
Mn-54	1.1700e-007	4.1946e-007	Ni-63	1.9700e-002	7.0628e-002
Np-237	5.6900e-007	2.0400e-006	Pa-233	5.6900e-007	2.0400e-006
Pm-147	3.5700e-002	1.2799e-001	Pr-144	3.1300e-005	1.1222e-004
Pr-144m	4.4700e-007	1.6026e-006	Pu-238	3.8500e-004	1.3803e-003
Pu-239	4.7000e-003	1.6850e-002	Pu-240	1.2500e-003	4.4815e-003
Pu-241	4.1900e-002	1.5022e-001	Rn-106	5.3400e-005	1.9145e-004
Ru-106	5.3400e-005	1.9145e-004	Sb-125	4.2400e-004	1.5201e-003
Sr-89	0.0000e+000	0.0000e+000	Sr-90	3.1700e-001	1.1365e+000
Tc-99	5.9900e-005	2.1475e-004	Tc-125m	9.7900e-005	3.5099e-004
U-234	6.3900e-005	2.2909e-004	U-235	2.5800e-006	9.2497e-006
U-236	1.7000e-006	6.0948e-006	U-238	1.2100e-005	4.3381e-005
Y-90	3.1700e-001	1.1365e+000	Zn-65	4.5200e-010	1.6205e-009



Calculation Sheet

Subject	Calc No	Rev No	Sheet No
FH109/FN300 Curie Estimate	4240-3233-93-020	0	12 of 35
Originator	Date	Reviewed by	Date
B. Brosey	8/27/93	G. Laddie	<i>B. Brosey</i> <i>G. Laddie</i> <i>8/27/93</i>

Attachment 4-2

Page : 2
 DOS File: FP-B.MS4
 Run Date: August 25, 1993
 Run Time: 11:23 a.m. Wednesday
 Title: DEWATERING STATION AREA OF FUEL POOL A

RESULTS					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup	With Buildup
0.1	2.624e+007	6.400e-001	8.650e+000	9.792e-004	1.323e-002
0.15	1.795e+005	8.244e-003	8.013e-002	1.358e-005	1.319e-004
0.2	3.777e+006	2.719e-001	2.070e+000	4.798e-004	3.653e-003
0.3	7.837e+004	1.070e-002	5.504e-002	2.029e-005	1.044e-004
0.4	5.177e+006	1.116e+000	4.581e+000	2.174e-003	8.926e-003
0.5	2.207e+006	6.764e-001	2.361e+000	1.328e-003	4.635e-003
0.6	4.079e+009	1.666e+003	5.161e+003	3.252e+000	1.007e+001
0.8	2.061e+007	1.321e+001	3.443e+001	2.513e-002	6.548e-002
1.0	8.524e+007	7.733e+001	1.798e+002	1.426e-001	3.314e-001
1.5	8.828e+007	1.492e+002	2.886e+002	2.510e-001	4.855e-001
2.0	8.964e+003	2.329e-002	4.057e-002	3.602e-005	6.273e-005
TOTAL:	4.310e+009	1.708e+003	5.682e+003	3.675e+000	1.099e+001

GRL Nuclear

Calculation Sheet

Subject: FH109/FH300 Curie Estimate	Calc No: 4240-3233-93-020	Rev. No: 0	Sheet No: 18 of 35
Original: B. Brosey	Date: 8/27/93	Reviewed by: G. Loddie	Date: 8/27/93

Attachment 5-1

MicroShield 4.00 - Serial #4.00-00247

CPU

Page : 1
 DOS File: FUELPARA.MS4
 Run Date: August 25, 1993
 Run Time: 1:13 p.m. Wednesday
 Duration: 0:24:42

File Ref: *RTHP*
 Date: *8/25/93*
 By: *RTHP*
 Checked: *8/25/93*

Case Title: FUEL POOL A FUEL RACK AREA

GEOMETRY 11 - Rectangular Volume

	centimeters	feet and inches
Dose point coordinate X:	1264.3104	41.0 5.8
Dose point coordinate Y:	676.75125	22.0 2.4
Dose point coordinate Z:	215.265	7.0 .8
Rectangular volume width:	430.53	14.0 1.5
Rectangular volume length:	402.27199	13.0 2.4
Rectangular volume height:	1353.5025	44.0 4.9
Shield 1:	7.62	0.0 3.0
Air Gap:	854.41841	28.0 .4

Source Volume: 2.34413e+8 cm³ 8278.23 cu ft. 1.43048e+7 cu in.MATERIAL DENSITIES (g/cm³)

Material	Source	Shield 1	Air Gap
		Shield	Slab
Air			0.00122
iron	0.15809		
Water		1.0	

BUILDUP

Method: Buildup Factor Tables
 The material reference is Source

INTEGRATION PARAMETERS

Quadrature Order

X Direction	22
Y Direction	22
Z Direction	22

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ag-110	7.6900e-012	3.2805e-014	Ag-110m	5.7800e-010	2.4657e-012
Am-241	1.3800e-003	5.8870e-006	Ba-137m	1.2200e-001	5.2045e-004
C-14	8.4000e-006	3.5834e-008	Ce-141	0.0000e+000	0.0000e+000
Ce-144	3.1300e-005	1.3352e-007	Cm-242	1.4600e-007	6.2283e-010
Cm-243	1.4400e-008	6.1430e-011	Cm-244	3.4100e-007	1.4547e-009
Co-58	0.0000e+000	0.0000e+000	Co-60	1.9900e-003	8.4893e-006
Cr-51	0.0000e+000	0.0000e+000	Cs-134	1.7700e-004	7.5508e-007
Cs-137	1.2900e-001	5.5031e-004	Eu-154	1.0000e-003	4.2660e-006
Eu-155	1.4500e-003	6.1857e-006	Fe-55	3.5100e-003	1.4974e-005
H-3	2.0400e-003	8.7025e-006	I-129	3.3800e-008	1.4419e-010
Mn-54	1.1700e-007	4.9912e-010	NI-63	1.9700e-002	8.4040e-005
Np-237	5.6900e-007	2.4273e-009	Pa-233	5.6900e-007	2.4273e-009
Pm-147	3.5700e-002	1.5230e-004	Pr-144	3.1300e-005	1.3352e-007
Pr-144m	4.4700e-007	1.9069e-009	Pu-238	3.8500e-004	1.6424e-006
Pu-239	4.7000e-003	2.0050e-005	Pu-240	1.2500e-003	5.3325e-006
Pu-241	4.1900e-002	1.7874e-004	Rh-106	5.3400e-003	2.2780e-007
Ru-106	5.3400e-005	2.2780e-007	Sb-125	6.2400e-004	1.8088e-006
Sr-89	0.4000e+000	0.0000e+000	Sr-90	3.1700e-001	1.3523e-003
Tc-99	5.9900e-005	2.5553e-007	Tc-125m	9.7900e-005	4.1764e-007
U-234	6.3900e-005	2.7260e-007	U-235	2.5800e-006	1.1066e-008
U-236	1.7000e-006	7.2521e-009	U-238	1.2100e-005	5.1618e-008
Y-90	3.1700e-001	1.3523e-003	Zn-65	4.5200e-010	1.9282e-012



Subject	FH109/FH300 Curie Estimate	Date	Reviewed By	Calc No	Rev. No	Sheet No
B. Brosey	8/27/93	G. Loddle	<i>B. Brosey</i>	4240-3233-93-020	0	19 of 35

Attachment 5-2

Page : 2
 DCS File: FUELPARA.MS4
 Run Date: August 25, 1993
 Run Time: 1:13 p.m. Wednesday
 Title : FUEL POOL A FUEL RACK AREA

RESULTS					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)		
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	2.624e+007	2.038e-003	3.450e-003	3.118e-006	5.278e-006
0.15	1.795e+005	4.546e-005	1.040e-004	7.486e-008	1.713e-007
0.2	3.777e+006	1.869e-003	5.127e-003	3.299e-006	9.048e-006
0.3	7.837e+004	8.757e-005	2.678e-004	1.661e-007	5.080e-007
0.4	5.177e+006	9.871e-003	3.009e-002	1.923e-005	5.863e-005
0.5	2.207e+006	6.290e-003	1.843e-002	1.235e-005	3.618e-005
0.6	4.079e+009	1.607e+001	4.484e+001	3.136e-002	8.752e-002
0.8	2.061e+007	1.345e-001	3.424e-001	2.559e-004	6.512e-004
1.0	8.524e+007	8.200e-001	1.928e+000	1.512e-003	3.554e-003
1.5	3.828e+007	1.691e+000	3.436e+000	2.845e-003	5.781e-003
2.0	8.964e+003	2.729e-004	5.081e-004	4.220e-007	7.857e-007
TOTAL:	4.310e+009	1.873e+001	5.060e+001	3.601e-002	9.761e-002

GPU Nuclear

Calculation Sheet

Subject	FH109/FH300 Curie Estimate	Calc No	4240-3233-93-020	Rev. No	Sheet No
Originalator	B. Brosey	Reviewed by	G. Laddie	Date	20 of 35
					8/27/93

Attachment 6-1

NORMALIZATION WORKSHEET (1 Ci)

CALCULATED				ACTUAL				8/25/93	
EXPOSURE RATE PER Ci==>	1.10E+01 mR/h	UNITS IN Ci	5.42E+02 mR/h					Today's Date	
I.D. NUMBER									
OR NAME<<DEFUELING WASTE	IN FUEL POOL "A" AT DEWATERING STATION				ADJUSTED	HRC REPORTABLE			
ISOTOPE	INPUT UNIT	PERCENT (%)	ACTIVITY	ADJUSTED	WITHOUT	IF > 1% OF	TOTAL	ISOTOPES	Sr-90/Cs-137
		of Total	PER CURIE	ACTIVITY (mCi)	DAUGHTERS (mCi)				
1	H-3	2.04E-03 ***	0.20379	2.04E-03 ***	1.00E+02	1.00E+02		H-3	* 2.457 *
2	C-14	8.40E-06 ***	0.00084	8.39E-06 ***	4.14E-01	4.14E-01		C-14	*****
3	Cr-51	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00		Cr-51	
4	Mn-54	1.17E-07 ***	0.00001	1.17E-07 ***	5.76E-03	5.76E-03		Mn-54	
5	Fe-55	3.51E-03 ***	0.35064	3.51E-03 ***	1.73E+02	1.73E+02		Fe-55	
6	Co-58	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00		Co-58	
7	Ca-60	1.99E-03 ***	0.19880	1.99E-03 ***	9.80E+01	9.80E+01		Co-60	
8	Ni-63	1.97E-02 ***	1.96798	1.97E-02 ***	9.70E+02	9.70E+02	REPORTABLE!	Ni-63	
9	Zn-65	4.52E-10 ***	0.00000	4.52E-10 ***	2.23E-05	2.23E-05		Zn-65	
10	Sr-89	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00		Sr-89	
11	Sr-90	3.17E-01 ***	31.66757	3.17E-01 ***	1.56E+04	1.56E+04	REPORTABLE!	Sr-90	
12	Y-90	3.17E-01 ***	31.66757	3.17E-01 ***	1.56E+04	1.56E+04		Y-90	
13	Tc-99	5.99E-05 ***	0.00598	5.98E-05 ***	2.95E+00	2.95E+00		Tc-99	
14	Ru-106	5.34E-05 ***	0.00533	5.33E-05 ***	2.63E+00	2.63E+00		Ru-106	
15	Rh-106	5.34E-05 ***	0.00533	5.33E-05 ***	2.63E+00	2.63E+00		Rh-106	
16	Ag-110m	5.78E-10 ***	0.00000	5.77E-10 ***	2.85E-05	2.85E-05		Ag-110m	
17	Ag-110	7.69E-12 ***	0.00000	7.68E-12 ***	3.79E-07	3.79E-07		Ag-110	
18	Sb-125	4.24E-04 ***	0.04236	4.24E-04 ***	2.09E+01	2.09E+01		Sb-125	
19	Te-125m	9.79E-05 ***	0.00978	9.78E-05 ***	4.82E+00	4.82E+00		Te-125m	
20	I-129	3.38E-08 ***	0.00000	3.38E-08 ***	1.66E-03	1.66E-03		I-129	
21	Cs-134	1.77E-04 ***	0.01768	1.77E-04 ***	8.72E+00	8.72E+00		Cs-134	
22	Cs-137	1.29E-01 ***	12.88680	1.29E-01 ***	6.35E+03	6.35E+03	REPORTABLE!	Cs-137	
23	Ba-137m	1.22E-01 ***	12.18752	1.22E-01 ***	6.01E+03	6.01E+03		Ba-137m	
24	Ce-141	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00		Ce-141	
25	Ce-144	3.13E-05 ***	0.00313	3.13E-05 ***	1.54E+00	1.54E+00		Ce-144	
26	Pr-144m	4.47E-07 ***	0.00004	4.47E-07 ***	2.20E-02	2.20E-02		Pr-144m	
27	Np-237	5.69E-07 ***	0.00006	5.68E-07 ***	2.80E-02	2.80E-02		Np-237	
28	Pu-233	5.69E-07 ***	0.00006	5.68E-07 ***	2.80E-02	2.80E-02		Pu-233	
29	Pu-238	3.85E-04 ***	0.03848	3.85E-04 ***	1.90E+01	1.90E+01		Pu-238	
30	Pu-239	4.70E-03 ***	0.46952	4.70E-03 ***	2.31E+02	2.31E+02		Pu-239	
31	Pu-241	4.19E-02 ***	4.18571	4.19E-02 ***	2.06E+03	2.06E+03	REPORTABLE!	Pu-241	
32	Am-241	1.30E-03 ***	0.13786	1.30E-03 ***	6.80E+01	6.80E+01		Am-241	
33	Cm-243	1.44E-08 ***	0.00000	1.44E-08 ***	7.09E-04	7.09E-04		Cm-243	
34	U-235	2.58E-06 ***	0.00026	2.58E-06 ***	1.27E-01	1.27E-01		U-235	
35	U-238	1.21E-05 ***	0.00121	1.21E-05 ***	5.96E-01	5.96E-01		U-238	
36	Pu-240	1.25E-03 ***	0.12487	1.25E-03 ***	6.15E+01	6.15E+01		Pu-240	
37	U-234	6.39E-05 ***	0.00638	6.38E-05 ***	3.15E+00	3.15E+00		U-234	
38	Pm-147	3.57E-02 ***	3.56635	3.57E-02 ***	1.76E+03	1.76E+03	REPORTABLE!	Pm-147	
39	Eu-154	1.00E-03 ***	0.09990	9.99E-04 ***	4.92E+01	4.92E+01		Eu-154	
40	Eu-155	1.45E-03 ***	0.14485	1.45E-03 ***	7.14E+01	7.14E+01		Eu-155	
41	U-236	1.70E-06 ***	0.00017	1.70E-06 ***	8.37E-02	8.37E-02		U-236	
42	Pr-144	3.13E-05 ***	0.00313	3.13E-05 ***	1.54E+00	1.54E+00		Pr-144	
43	Cm-242	1.44E-07 ***	0.00001	1.44E-07 ***	7.19E-03	7.19E-03		Cm-242	
44	Cm-244	3.41E-07 ***	0.00003	3.41E-07 ***	1.68E-02	1.68E-02		Cm-244	
45	-	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00			

TOTALS==>1.0010E+00 Ci 100.00 1.00000 Ci 49290.264 mCi 27669.755 mCi

GPN Nuclear

Submitted: 8/27/93 Originator: B. Brosey

Calculation Sheet

Calc No	Rev. No	Sheet No
4240-3233-93-020	0	21 of 35

Date: 8/27/93
 By: B. Brosey

Attachment 7-1

NORMALIZATION WORKSHEET (1 C1)

CALCULATED	=====	=====			8/25/93	
EXPOSURE RATE PER Ci==>	9.76E-02 mR/h	ACTUAL==>	8.40E+00 mR/h		=====	
UNITS IN>Ci	=====	=====			Today's Date	
I.D. NUMBER						
OR NAME=>DEFUELING WASTE IN FUEL POOL "A" AT FUEL RACK AREA						
INPUT UNIT	PERCENT (%)	ACTIVITY	ADJUSTED	WITHOUT	NRC REPORTABLE	
ISOTOPE	ACTIVITY	of Total	PER CURIE	ACTIVITY (mCi)	DAUGHTERS (mCi)	
					if > 1% of	
					TOTAL ISOTOPES Sr-90/Cs-137 RATIO	
1 H-3	2.04E-03 ***	0.20379	2.04E-03 ***	1.75E+02	1.75E+02	H-3 * 2.457 *
2 C-14	8.40E-06 ***	0.00084	8.39E-06 ***	7.22E-01	7.22E-01	C-14 *****
3 Cr-51	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00	Cr-51
4 Mn-54	1.17E-07 ***	0.00001	1.17E-07 ***	1.01E-02	1.01E-02	Mn-54
5 Fe-55	3.51E-03 ***	0.35064	3.51E-03 ***	3.02E+02	3.02E+02	Fe-55
6 Co-58	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00	Co-58
7 Co-60	1.99E-03 ***	0.19880	1.99E-03 ***	1.71E+02	1.71E+02	Co-60
8 Ni-63	1.97E-02 ***	1.96798	1.97E-02 ***	1.69E+03	1.69E+03	REPORTABLE! Ni-63
9 Zn-65	4.52E-10 ***	0.00000	4.52E-10 ***	3.89E-05	3.89E-05	Zn-65
10 Sr-89	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00	Sr-89
11 Sr-90	3.17E-01 ***	31.66757	3.17E-01 ***	2.73E+04	2.73E+04	REPORTABLE! Sr-90
12 Y-90	3.17E-01 ***	31.66757	3.17E-01 ***	2.73E+04	2.73E+04	Y-90
13 Tc-99	5.99E-05 ***	0.00598	5.98E-05 ***	5.15E+00	5.15E+00	Tc-99
14 Ru-106	5.34E-05 ***	0.00533	5.33E-05 ***	4.59E+00	4.59E+00	Ru-106
15 Rh-106	5.34E-05 ***	0.00533	5.33E-05 ***	4.59E+00	4.59E+00	Rh-106
16 Ag-110m	5.78E-10 ***	0.00000	5.77E-10 ***	4.97E-05	4.97E-05	Ag-110m
17 Ag-110	7.69E-12 ***	0.00000	7.68E-12 ***	6.61E-07	6.61E-07	Ag-110
18 Sb-125	4.24E-04 ***	0.04236	4.24E-04 ***	3.65E+01	3.65E+01	Sb-125
19 Te-125m	9.79E-05 ***	0.00978	9.78E-05 ***	8.42E+00	8.42E+00	Te-125m
20 I-129	3.38E-08 ***	0.00000	3.38E-08 ***	2.91E-03	2.91E-03	I-129
21 Cs-134	1.77E-04 ***	0.01768	1.77E-04 ***	1.52E+01	1.52E+01	Cs-134
22 Cs-137	1.29E-01 ***	12.88680	1.29E-01 ***	1.11E+04	1.11E+04	REPORTABLE! Cs-137
23 Ba-137m	1.22E-01 ***	12.18752	1.22E-01 ***	1.05E+04	1.05E+04	Ba-137m
24 Ce-141	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00	Ce-141
25 Ce-144	3.13E-05 ***	0.00313	3.13E-05 ***	2.69E+00	2.69E+00	Ce-144
26 Pr-144m	4.47E-07 ***	0.00004	4.47E-07 ***	3.84E-02	3.84E-02	Pr-144m
27 Nd-237	5.69E-07 ***	0.00006	5.68E-07 ***	4.89E-02	4.89E-02	Nd-237
28 Pa-233	5.69E-07 ***	0.00006	5.68E-07 ***	4.89E-02	4.89E-02	Pa-233
29 Pu-238	3.85E-04 ***	0.03846	3.85E-04 ***	3.31E+01	3.31E+01	Pu-238
30 Pu-239	4.70E-03 ***	0.46952	4.70E-03 ***	4.04E+02	4.04E+02	Pu-239
31 Pu-241	4.19E-02 ***	4.18571	4.19E-02 ***	3.60E+03	3.60E+03	REPORTABLE! Pu-241
32 Am-241	1.38E-03 ***	0.13786	1.38E-03 ***	1.19E+02	1.19E+02	Am-241
33 Cm-243	1.44E-08 ***	0.00000	1.44E-08 ***	1.24E-03	1.24E-03	Cm-243
34 U-235	2.58E-06 ***	0.00026	2.58E-06 ***	2.22E-01	2.22E-01	U-235
35 U-238	1.21E-05 ***	0.00121	1.21E-05 ***	1.04E+00	1.04E+00	U-238
36 Pu-240	1.25E-03 ***	0.12487	1.25E-03 ***	1.07E+02	1.07E+02	Pu-240
37 U-234	6.39E-05 ***	0.00638	6.38E-05 ***	5.49E+00	5.49E+00	U-234
38 Pm-147	3.57E-02 ***	3.56635	3.57E-02 ***	3.07E+03	3.07E+03	REPORTABLE! Pm-147
39 Eu-154	1.00E-03 ***	0.09990	9.99E-04 ***	8.60E+01	8.60E+01	Eu-154
40 Eu-155	1.45E-03 ***	0.14485	1.45E-03 ***	1.25E+02	1.25E+02	Eu-155
41 U-236	1.70E-06 ***	0.00017	1.70E-06 ***	1.46E-01	1.46E-01	U-236
42 Pr-144	3.13E-05 ***	0.00313	3.13E-05 ***	2.69E+00	2.69E+00	Pr-144
43 Cm-242	1.46E-07 ***	0.00001	1.46E-07 ***	1.26E-02	1.26E-02	Cm-242
44 Cm-244	3.41E-07 ***	0.00003	3.41E-07 ***	2.93E-02	2.93E-02	Cm-244
45 -	***	0.00000	0.00E+00 ***	0.00E+00	0.00E+00	-
TOTALS==>1.0010E+00 Ci	100.00	1.00000 Ci	86056.756 mCi	48309.122 mCi		

GRU Nuclear

Subject

FH109/FH300 Curie Estimate

Date

Calc No

Reviewed by

Rev No

Sheet No

22 of 35

Date

1-

Calculation Sheet




Figure 2
Revision 1

GRU Nuclear

Calculation Sheet


FIGURE 1

Subject	Calc No	Rev. No	Sheet No
FH109/FH300 Curie Estimate	4240-3233-93-020	0	23 of 35
Originator B. Brosey	Date 8/27/93	Reviewed by G. Lodde	Date 8/25/93

Attachment 8-2

		SEE NOTE RELATIVE DATA TO B HERE. SEE METAL STAND SHOP ADJUSTMENT DIM HERE BOTTOM OF NOTCH HIGH LETTERS TO BE TRANSITED		Date: 8/27/93 Drawn by: J. Laddie Revised by: G. Lodge Date: 8/27/93 Job No: 340135 Calc No: 4240-3233-93-020 Proj No: 340135																																																																																											
△ DETAIL 3 SCALE: 3 1/4"		ELEVATION DETAIL 1 SCALE: HALF		Calculation Sheet TO ITEM 5 (SUPPORT COLUMN) PRIOR TO STRUCTURAL WELDING ONLY IF NECESSARY TO MAINTAIN TOP PLATE FLATNESS.																																																																																											
		△ SEE NOTES 6		△ 6 - BEFORE ASSEMBLY, MODIFY 2 PIECES OF ITEM 3 AS SHOWN IN SECTION C-C AND 2 PIECES AS SHOWN IN SECTION D-D.																																																																																											
△△ VIEW B-B 15131-2-C406A-00037-05				<table border="1"> <thead> <tr> <th rowspan="2">ITEM NUMBER</th> <th rowspan="2">PART NO.</th> <th colspan="2">DESCRIPTION</th> </tr> <tr> <th colspan="2">PARTS LIST</th> </tr> </thead> <tbody> <tr> <td colspan="4">ITEM ASSY</td> </tr> <tr> <td colspan="4">TOLERANCES UNLESS OTHERWISE SPECIFIED</td> </tr> <tr> <td colspan="4">DECIMALS</td> </tr> <tr> <td>1 PLACE</td> <td>2 PLACES</td> <td>3 PLACES</td> <td></td> </tr> <tr> <td>FRACTIONS</td> <td>ANGLES</td> <td>CHARACTERS</td> <td></td> </tr> <tr> <td>1/8</td> <td>2 —</td> <td>2 —</td> <td></td> </tr> <tr> <td colspan="4">LEVELING PLATE 20MM</td> </tr> <tr> <td colspan="4">LEVELING PAD</td> </tr> <tr> <td colspan="4">SUPPORT COLUMN-TYPE B</td> </tr> <tr> <td colspan="4">TOP GUIDE-TYPE B</td> </tr> <tr> <td colspan="4">SIDE PANEL</td> </tr> <tr> <td colspan="4">BOTTOM GUIDE</td> </tr> <tr> <td colspan="4">TOP GUIDE-TYPE A</td> </tr> <tr> <td colspan="4">TIE STRIP-TYPE 2</td> </tr> <tr> <td colspan="4">TIE STRIP-TYPE 1</td> </tr> <tr> <td colspan="4">TIE ANGLE</td> </tr> <tr> <td colspan="4">SUPPORT COLUMN-TYPE A</td> </tr> <tr> <td colspan="4">TOP PLATE</td> </tr> <tr> <td colspan="4">BASE PLATE</td> </tr> <tr> <td colspan="4">BASE WELDMENT-TYPE R</td> </tr> <tr> <td colspan="4">FUEL CANISTER STORAGE RACK 7X9</td> </tr> </tbody> </table>		ITEM NUMBER	PART NO.	DESCRIPTION		PARTS LIST		ITEM ASSY				TOLERANCES UNLESS OTHERWISE SPECIFIED				DECIMALS				1 PLACE	2 PLACES	3 PLACES		FRACTIONS	ANGLES	CHARACTERS		1/8	2 —	2 —		LEVELING PLATE 20MM				LEVELING PAD				SUPPORT COLUMN-TYPE B				TOP GUIDE-TYPE B				SIDE PANEL				BOTTOM GUIDE				TOP GUIDE-TYPE A				TIE STRIP-TYPE 2				TIE STRIP-TYPE 1				TIE ANGLE				SUPPORT COLUMN-TYPE A				TOP PLATE				BASE PLATE				BASE WELDMENT-TYPE R				FUEL CANISTER STORAGE RACK 7X9			
ITEM NUMBER	PART NO.	DESCRIPTION																																																																																													
		PARTS LIST																																																																																													
ITEM ASSY																																																																																															
TOLERANCES UNLESS OTHERWISE SPECIFIED																																																																																															
DECIMALS																																																																																															
1 PLACE	2 PLACES	3 PLACES																																																																																													
FRACTIONS	ANGLES	CHARACTERS																																																																																													
1/8	2 —	2 —																																																																																													
LEVELING PLATE 20MM																																																																																															
LEVELING PAD																																																																																															
SUPPORT COLUMN-TYPE B																																																																																															
TOP GUIDE-TYPE B																																																																																															
SIDE PANEL																																																																																															
BOTTOM GUIDE																																																																																															
TOP GUIDE-TYPE A																																																																																															
TIE STRIP-TYPE 2																																																																																															
TIE STRIP-TYPE 1																																																																																															
TIE ANGLE																																																																																															
SUPPORT COLUMN-TYPE A																																																																																															
TOP PLATE																																																																																															
BASE PLATE																																																																																															
BASE WELDMENT-TYPE R																																																																																															
FUEL CANISTER STORAGE RACK 7X9																																																																																															
		THREE MILE ISLAND-UNIT 2		<table border="1"> <thead> <tr> <th rowspan="2">MATERIAL</th> <th rowspan="2">FINISH</th> <th colspan="2">APPROVALS</th> </tr> <tr> <th>INITIAL</th> <th>DATE</th> </tr> </thead> <tbody> <tr> <td colspan="4">NOT ASSEMBLED</td> </tr> <tr> <td colspan="4">FINAL ASSEMBLY</td> </tr> <tr> <td colspan="4">APPLICATION</td> </tr> <tr> <td colspan="4">SEE NOTES 1</td> </tr> <tr> <td colspan="4">MATERIAL</td> </tr> <tr> <td colspan="4">FINISH</td> </tr> </tbody> </table>		MATERIAL	FINISH	APPROVALS		INITIAL	DATE	NOT ASSEMBLED				FINAL ASSEMBLY				APPLICATION				SEE NOTES 1				MATERIAL				FINISH																																																															
MATERIAL	FINISH	APPROVALS																																																																																													
		INITIAL	DATE																																																																																												
NOT ASSEMBLED																																																																																															
FINAL ASSEMBLY																																																																																															
APPLICATION																																																																																															
SEE NOTES 1																																																																																															
MATERIAL																																																																																															
FINISH																																																																																															
DETAIL 2 SCALE: 1 1/4" (SHOWING TYPICAL WELDING OF ITEM 13 TO ITEM 3)																																																																																															

17,380 Pts



Attachment 8-3

Bottom of fuel C 38' 0.25" HEP
Top of fuel C 39' 6"

Difference is 41.48'

PLAN VIEW



gru Nuclear

Calculation Sheet

Subject	Calc No	Rev. No	Sheet No
FH109/FH300 Curie Estimate	4240-3233-93-020	0	25 of 35
Originator B. Brosey	Date 8/27/93	Reviewed by G. Lodde	Date 8/27/93

15737-2-C40

ENT CHAMFERED CORNER
LUG TOWARD CENTER
PLATE AS SHOWN



Calculation Sheet

DOC LAT 13 SYI NONE

GEAR NORTH AMERICAN
MANUFACTURATION

ABN 13-37

Rev. No. 0 Sheet No. 26 of 35

Date 8/27/93

Subject FH109/FH300 Curie Estimate

Calc No. 4240-3233-93-020

Originator B. Brosey

Date 8/27/93

Reviewed by G. Lodde

B. Brosey

1125

B

QTY/ASST	ITEM	PART NO.	DESCRIPTION	MATERIAL	SOURCE
TOLERANCES UNLESS OTHERWISE SPECIFIED					

DECIMALS		
1 PLACE	2 PLACE	3 PLACE
= .03	= —	= —
FRACTIONS	ANGLES	CHAMFERS

SURFACE FINISH AA OR BETTER

FILLETS .02 TO .03 RADIUS

BREAK EDGES .02 RADIUS OR CHAMFERED

NATIONAL STANDARD TOLERANCES APPLY TO COMMERCIAL MILLS

THREADS UNI-ED CL 24-2B PER ASA B1.1

DIMENSIONS ARE IN INCHES BASED ON 60° (1PC)

DIMS DO NOT INCLUDE ALLOWANCE FOR FAB OR WELD SHRINKAGE

DIMS AND TOLERANCES ARE TO BE INTERPRETED IN ACCORDANCE WITH ANSI B14.5 1973

APPROVALS	DATE
DRAWN <i>R. E. Kirby</i>	10-8-89
CHECKED <i>A. R. Meete</i>	8/10/93
PHOTO <i>A. R. Meete</i>	8/26/86
PROD <i>R. E. Kirby</i>	8/1/89
STAL <i>R. E. Kirby</i>	10/1/89
ENGR <i>R. E. Kirby</i>	10/1/89
DESIGNING <i>R. E. Kirby</i>	10/1/89
PROJ <i>R. E. Kirby</i>	8/1/89
TYPE <i>R. E. Kirby</i>	8/1/89
GA <i>R. E. Kirby</i>	8/1/89
MAP <i>R. E. Kirby</i>	8/1/89

1125

THIS DRAWING IS THE PROPERTY OF
NUCLEAR ENERGY SERVICES, INC.
DANBURY, CONNECTICUT
AND CONTAINS CONFIDENTIAL INFORMATION RELATING TO
THE DRAWINGS. THE USER AGREES THAT IT IS FOR THE USER'S OWN
USE AND THAT THE DRAWINGS AND THE INFORMATION CONTAINED
HEREIN WILL NOT BE USED IN ANY MANNER DETERMINED BY
NUCLEAR ENERGY SERVICES, INC.

83E0919	83E0919
NEWT ASSEMBLY	FINAL ASSEMBLY
APPLICATION	
SEE NOTE1	SEE NOTE2
MATERIAL	FINISH

TOP PLATE


SIZE	PCMC NO.	CHAMFER NO.	REV.
D	53603		3
SCALE	1-1-0	WEIGHT APPROX 3044 LBS	
(SOLID PLATE WEIGHT)			

24 X


Attachment 8-4

**SUPPLEMENTAL SHEET
FIELD CHANGE REQUEST
FIELD QUESTIONNAIRE**

NO. 85-257
PAGE 2 OF 2





Partial



Calculation Sheet		Rev No	Sheet No
Calc No	4240-3233-93-020	0	2701 35
Reviewed By	G. Loddie	Date	5/27/93

Subject	FH109/FH300 Curie Estimate		
Originator	B. Brosey	Date	8/27/93

PLANELEVATION VIEW

(FUEL HANDLING BUILDING)

FUEL CANISTER STORAGE RACKSFigure 4
Revision 1**GRU Nuclear**

Calculation Sheet		Calc No	Rev No	Sheet No
Subject	FR109/FH300 Curie Estimate	4240-3233-93-020	0	28 of 35
Revised by				Date
Originator	B. Brusey	8/27/93	G. Laddie	5/27/93

Attachment 9-1

MicroShield 4.00 - Serial #4.00-00247

Page : 1
 DOS File: FUEL PARA.MS4
 Run Date: August 26, 1993
 Run Time: 2:05 p.m. Thursday
 Duration: 0:24:45

File Ref: *STP*
 Date: *8/27/93*
 By:
 Checked: *8/27/93*

Case Title: FUEL POOL A FUEL RACK AREA

GEOMETRY 11 - Rectangular Volume

	centimeters	feet and inches
Dose point coordinate X:	1203.3504	39.0 5.8
Dose point coordinate Y:	676.75125	22.0 2.4
Dose point coordinate Z:	215.265	7.0 .7
Rectangular volume width :	430.53	14.0 1.5
Rectangular volume length:	402.27199	13.0 2.6
Rectangular volume height:	1353.5025	44.0 4.9
Shield 1:	7.62	0.0 3.0
Air Gap:	793.45841	26.0 .4

Source Volume: 2.34413e+8 cm³ 8278.23 cu ft. 1.43048e+7 cu in.

Material	Source	MATERIAL DENSITIES (g/cm ³)	
		Shield	Air Gap
Air			0.00122
Iron	0.15809		
Water		1.0	

BUILDDUP

Method: Buildup Factor Tables
 The material reference is Source

INTEGRATION PARAMETERS

Quadrature Order

X Direction	22
Y Direction	22
Z Direction	22

SOURCE NUCLIDES		NUCLIDES			
Nuclide	curies	μCi/cm ³	Nuclide	curies	μCi/cm ³
Ag-110	7.6900e-012	3.2805e-014	Ag-110m	5.7800e-010	2.4657e-012
Am-241	1.3800e-003	5.8870e-006	Ba-137m	1.2200e-001	5.2045e-004
C-14	8.4000e-006	3.5834e-008	Ce-141	0.0000e+000	0.0000e+000
Ce-144	3.1300e-005	1.3352e-007	Cm-242	1.4600e-007	6.2283e-010
Cm-243	1.4400e-008	6.1430e-011	Cm-244	3.4100e-007	1.4547e-009
Co-58	0.0000e+000	0.0000e+000	Co-60	1.9900e-003	8.4893e-006
Cr-51	0.0000e+000	0.0000e+000	Cs-134	1.7700e-004	7.5508e-007
Cs-137	1.2900e-001	5.5031e-004	Eu-154	1.0000e-003	4.2660e-006
Eu-155	1.4500e-003	6.1857e-006	Fe-55	3.5100e-003	1.4974e-005
H-3	2.0400e-003	8.7026e-006	I-129	3.3800e-008	1.4419e-010
Mn-54	1.1700e-007	4.9912e-010	Ni-63	1.9700e-002	8.4040e-005
Pd-237	5.6900e-007	2.4273e-009	Pa-233	5.6900e-007	2.4273e-009
Pm-147	3.5700e-002	1.5230e-004	Pr-144	3.1300e-005	1.3352e-007
Pr-144m	4.4700e-007	1.9069e-009	Pu-238	3.8500e-004	1.6424e-006
Pu-239	4.7000e-003	2.0050e-005	Pu-240	1.2500e-003	5.3325e-006
Pu-241	4.1900e-002	1.7874e-004	Rh-106	5.3400e-005	2.2780e-007
Ru-106	5.3400e-005	2.2780e-007	Sb-125	4.2400e-004	1.8088e-006
Sr-89	0.0000e+000	0.0000e+000	Sr-90	3.1700e-001	1.3523e-003
Tc-99	5.9900e-005	2.5553e-007	Te-125m	9.7900e-005	4.1764e-007
U-234	6.3900e-005	2.7260e-007	U-235	2.5800e-006	1.1006e-008
U-236	1.7000e-006	7.2521e-009	U-238	1.2100e-005	5.1618e-008
Y-90	3.1700e-001	1.3523e-003	Zn-65	4.5200e-010	1.9282e-012

GPU Nuclear

Calculation Sheet

Subject	FH109/FH300 Curie Estimate	Calc No	4240-3233-93-020	Reviewed by	<i>B. Brumley</i>	Sheet No	29 of 33
Original	Date	Rev. No	0	Date	<i>G. Lodde</i>	Date	<i>8/27/93</i>

Attachment 9-2

Page : 2
 DOS File: FUEL PARA.MSD
 Run Date: August 26, 1993
 Run Time: 2:05 p.m. Thursday
 Title : FUEL POOL A FUEL RACK AREA

RESULTS					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)		
		No Buildup	With Buildup	No Buildup	With Buildup
0.1	2.624e+007	2.279e-003	3.858e-003	3.486e-006	5.902e-006
0.15	1.795e+005	5.081e-005	1.162e-004	8.367e-008	1.914e-007
0.2	3.777e+006	2.089e-003	5.726e-003	3.686e-006	1.011e-005
0.3	7.837e+004	9.780e-005	2.988e-004	1.855e-007	5.669e-007
0.4	5.177e+006	1.102e-002	3.357e-002	2.147e-005	6.540e-005
0.5	2.207e+006	7.021e-003	2.055e-002	1.378e-005	4.035e-005
0.6	4.079e+009	1.793e+001	4.999e+001	3.500e-002	9.758e-002
0.8	2.061e+007	1.501e-001	3.816e-001	2.855e-004	7.258e-004
1.0	8.524e+007	9.147e-001	2.149e+000	1.686e-003	3.961e-003
1.5	8.828e+007	1.886e+000	3.828e+000	3.172e-003	6.440e-003
2.0	8.964e+003	3.042e-004	5.659e-004	4.704e-007	8.751e-007
TOTAL:	4.310e+009	2.090e+001	5.641e+001	4.018e-002	1.088e-001



Calculation Sheet

Subject	FH109/FH300 Curie Estimate	Calc No	4240-3233-93-020	Rev. No	0	Sheet No	30 of 35
Original	B. Brosey	Revised by	G. Loddie	Date	8/27/93	Date	8/27/93

Attachment 9-3

MicroShield 4.00 - Serial #4.00-00247

Page : 1 File Ref: *HTA*
 DOS File: FUELPARA.MS4 Date: *8/27/93*
 Run Date: August 26, 1993 By:
 Run Time: 2:38 p.m. Thursday Checked: *HTA*
 Duration: 0:24:45

Case Title: FUEL POOL A FUEL RACK AREA

GEOMETRY 11 - Rectangular Volume

	centimeters	feet and inches
Dose point coordinate X:	1325.2704	43.0 5.8
Dose point coordinate Y:	676.75125	22.0 2.4
Dose point coordinate Z:	215.265	7.0 .7
Rectangular volume width :	430.53	14.0 1.5
Rectangular volume length:	402.27199	13.0 2.4
Rectangular volume height:	1353.5025	44.0 4.9
Shield 1:	7.62	0.0 3.0
Air Gap:	915.37841	30.0 .4

Source Volume: 2.34413e+8 cm³ 8278.23 cu ft. 1.43048e+7 cu in.

MATERIAL DENSITIES (g/cm ³)			
Material	Source	Shield 1	Air Gap
Air		Shield	Slab
Iron	0.15809		
Water			1.0

BUILDUP

Method: Buildup Factor Tables
 The material reference is Source

INTEGRATION PARAMETERS

Quadrature Order

X Direction	22
Y Direction	22
Z Direction	22

SOURCE NUCLIDES					
Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ag-110	7.6900e-012	3.2805e-014	Ag-110m	5.7800e-010	2.4657e-012
Am-241	1.3800e-003	5.8870e-006	Ba-137m	1.2200e-001	5.2045e-004
C-14	8.4000e-006	3.5834e-008	Ce-141	0.0000e+000	0.0000e+000
Ce-144	3.1300e-005	1.3352e-007	Cm-242	1.4600e-007	6.2283e-010
Cm-243	1.4400e-008	6.1430e-011	Cm-244	3.4100e-007	1.4547e-009
Co-58	0.0000e+000	0.0000e+000	Co-60	1.9900e-003	8.4893e-006
Cr-51	0.0000e+000	0.0000e+000	Cs-134	1.7700e-004	7.5508e-007
Cs-137	1.2900e-001	5.5031e-004	Eu-154	1.0000e-003	4.2660e-006
Eu-155	1.4500e-003	6.1857e-006	Fe-55	3.5100e-003	1.4974e-005
H-3	2.0400e-003	8.7026e-006	I-129	3.3800e-008	1.4419e-010
Mn-54	1.1700e-007	4.9912e-010	Ni-63	1.9700e-002	8.4040e-005
No-237	5.6900e-007	2.4273e-009	Pa-233	5.6900e-007	2.4273e-009
Pm-147	3.5700e-002	1.5230e-004	Pr-144	3.1300e-005	1.3352e-007
Pr-144m	4.4700e-007	1.9069e-009	Pu-238	3.8500e-004	1.6424e-006
Pu-239	4.7000e-003	2.0050e-005	Pu-240	1.2500e-003	5.3325e-006
Pu-241	4.1900e-002	1.7874e-004	Rh-106	5.3400e-005	2.2780e-007
Ru-106	5.3400e-005	2.2780e-007	Sb-125	4.2400e-004	1.8088e-006
Sr-89	0.0000e+000	0.0000e+000	Sr-90	3.1700e-001	1.3523e-003
Tc-99	5.9900e-005	2.5553e-007	Tc-125m	9.7900e-005	4.1764e-007
U-234	6.3900e-005	2.7260e-007	U-235	2.5800e-006	1.1006e-008
U-236	1.7000e-006	7.2521e-009	U-238	1.2100e-005	5.1618e-008
Y-90	3.1700e-001	1.3523e-003	Zn-65	4.5200e-010	1.9282e-012

GPI Nuclear

Subject	FH109/FH100 Curie Estimate	Date	Reviewed by	Rev. No.	Sheet No.	Date
B. Brosey	<i>B. Brosey</i>	8/27/93	G. Laddie	0	31	8/27/93

Attachment 9-4

Page : 2
 DCS File: FUELPARA.MS4
 Run Date: August 26, 1993
 Run Time: 2:38 p.m. Thursday
 title : FUEL POOL A FUEL RACK AREA

RESULTS					
Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup	With Buildup
0.1	2.624e+007	1.829e-003	3.097e-003	2.798e-006	4.738e-006
0.15	1.795e+005	4.082e-005	9.344e-005	6.722e-008	1.539e-007
0.2	3.777e+006	1.679e-003	4.609e-003	2.964e-006	8.135e-006
0.3	7.837e+004	7.872e-005	2.410e-004	1.493e-007	4.571e-007
0.4	5.177e+006	8.877e-003	2.709e-002	1.730e-005	5.279e-005
0.5	2.207e+006	5.658e-003	1.660e-002	1.111e-005	3.259e-005
0.6	4.079e+009	1.446e+001	4.040e+001	2.822e-002	7.885e-002
0.8	2.061e+007	1.211e-001	3.086e-001	2.303e-004	5.869e-004
1.0	8.524e+007	7.383e-001	1.738e+000	1.361e-003	3.204e-003
1.5	8.828e+007	1.523e+000	3.099e+000	2.563e-003	5.213e-003
2.0	8.964e+003	2.459e-004	4.583e-004	3.803e-007	7.087e-007
TOTAL:	4.310e+009	1.686e+001	4.559e+001	3.240e-002	8.795e-002

GRU Nuclear

Calculation Sheet

Subject	FH109 FH300 Curie Estimate	Calc No	4240-3233-93-020	Rev. No	0	Sheet No	32 of 35
Originator	B. Brosey	Reviewed by	G. Lodde	Date	8/27/93	8/27/93	

Attachment 9-5

Page : 2

DCS File: FP-B.MS4

Run Date: August 26, 1993

Run Time: 3:35 p.m. Thursday

Title : DEWATERING STATION AREA OF FUEL POOL A

***** RESULTS FOR SENSITIVITY REFERENCE CASE (X = 30.48) *****

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup	With Buildup	No Buildup	With Buildup	No Buildup	With Buildup
0.1	2.624e+007	6.400e-001	8.650e+000	9.792e-004	1.323e-002				
0.15	1.795e+005	8.244e-003	8.013e-002	1.358e-005	1.319e-004				
0.2	3.777e+006	2.719e-001	2.070e+000	4.798e-004	3.653e-003				
0.3	7.837e+004	1.070e-002	9.504e-002	2.029e-005	1.044e-004				
0.4	5.177e+006	1.116e+000	4.581e+000	2.174e-003	8.926e-003				
0.5	2.207e+006	6.764e-001	2.361e+000	1.328e-003	4.635e-003				
0.6	4.079e+009	1.666e+003	5.161e+003	3.252e+000	1.007e+001				
0.8	2.061e+007	1.321e+001	3.443e+001	2.513e-002	6.548e-002				
1.0	8.524e+007	7.733e+001	1.798e+002	1.426e-001	3.314e-001				
1.5	8.828e+007	1.492e+002	2.886e+002	2.510e-001	4.855e-001				
2.0	8.964e+003	2.329e-002	4.057e-002	3.602e-005	6.273e-005				
TOTAL:	4.310e+009	1.908e+003	5.682e+003	3.675e+000	1.099e+001				

SENSITIVITY RESULTS For: X (cm)

Case Number	Sensitivity Variable	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup	With Buildup	No Buildup	With Buildup	No Buildup	With Buildup
1	15.24	1.593e+003	5.289e+003	3.065e+000	1.023e+001				
2	23.70667	1.860e+003	5.666e+003	3.582e+000	1.096e+001				
3	32.17333	1.912e+003	5.670e+003	3.683e+000	1.096e+001				
4	40.64	1.910e+003	5.555e+003	3.679e+000	1.074e+001				
5	49.10667	1.890e+003	5.385e+003	3.640e+000	1.042e+001				
6	57.57333	1.859e+003	5.185e+003	3.582e+000	1.003e+001				
7	66.04	1.822e+003	4.968e+003	3.511e+000	9.610e+000				
8	74.50667	1.779e+003	4.745e+003	3.429e+000	9.179e+000				
9	82.97333	1.735e+003	4.522e+003	3.339e+000	8.749e+000				
10	91.44	1.683e+003	4.304e+003	3.244e+000	8.326e+000				

Use the Display Menu For Energy Group Results For All Cases.

GRU Nuclear

Subject	FH109 / FH300 Curie Estimate	Calc No	4240-3233-93-020	Rev No	0	Sheet No	33 of 35
Original	B. Brussey	Date	8/27/93	Reviewed by	G. Laddie	Date	8/27/93

Calculation Sheet

MicroShield 4.00 - Serial #4.00-00247
CPU

Page : 1

DOS File: FP-B.M54

Run Date: August 26, 1993

Run Time: 3:35 p.m. Thursday

Duration: 0:28:02

File Ref:

Date:

By:

Checked:

PPX
8/27/93
2:35pm

Case Title: DEWATERING STATION AREA OF FUEL POOL A

GEOMETRY 4 - Vertical Rectangular Area

	centimeters	feet and inches
Dose point coordinate X:	30.48	1.0 .0
Dose point coordinate Y:	360.045	11.0 9.7
Dose point coordinate Z:	193.57495	6.0 4.2
Rectangular area height:	720.09	23.0 7.5
Rectangular area width:	387.35	12.0 8.5
Shield 1:	7.62	0.0 3.0
Air Gap:	22.66	0.0 9.0

Source Area: 278927. sq cm 300.234 sq ft. 43233.8 sq in.

MATERIAL DENSITIES (g/cm³)

Material	Shield 1	Air Gap
	Slab	
Air		0.00122
Water		1.0

BUILDUP

Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

Z Direction	30	Quadrature Order
Y Direction	30	

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ag-110	7.6900e-012	2.7570e-011	Ag-110m	5.7800e-010	2.0722e-009
Am-241	1.3800e-003	4.9475e-003	Ba-137m	1.2200e-001	4.3739e-001
C-14	8.4000e-006	3.0115e-005	Ce-141	0.0000e+000	0.0000e+000
Ce-144	3.1300e-005	1.1222e-004	Cm-242	1.4600e-007	5.2343e-007
Cm-243	1.4400e-008	5.1626e-008	Cm-244	3.4100e-007	1.2225e-006
Co-58	0.0000e+000	0.0000e+000	Co-60	1.9900e-003	7.1345e-003
Cr-51	0.0000e+000	0.0000e+000	Cs-134	1.7700e-004	6.3457e-004
Cs-137	1.2900e-001	4.6249e-001	Eu-154	1.0000e-003	3.5852e-003
Eu-155	1.4500e-003	5.1985e-003	Fe-55	3.5100e-003	1.2584e-002
H-3	2.0400e-003	7.3137e-003	I-129	3.3800e-008	1.2118e-007
Mn-54	1.1700e-007	4.1946e-007	Ni-63	1.9700e-002	7.0628e-002
Np-237	5.6900e-007	2.0400e-006	Pa-233	5.6900e-007	2.0400e-006
Pm-147	3.5700e-002	1.2799e-001	Pt-144	3.1300e-005	1.1222e-004
Pr-144m	4.4700e-007	1.6026e-006	Pu-238	3.8500e-004	1.3803e-003
Pu-239	4.7000e-003	1.6850e-002	Pu-240	1.2500e-003	4.4815e-003
Pu-241	4.1900e-002	1.5022e-001	Rh-106	5.3400e-005	1.9145e-004
Ru-106	5.3400e-005	1.9145e-004	Sb-125	4.2400e-004	1.5201e-003
Sr-89	0.0000e+000	0.0000e+000	Sr-90	3.1700e-001	1.1365e-000
Tc-99	5.9900e-005	2.1475e-004	Tc-125m	9.7900e-005	3.5099e-004
U-234	6.3900e-005	2.2909e-004	U-235	2.5800e-006	9.2497e-006
U-236	1.7000e-006	6.0948e-006	U-238	1.2100e-005	4.3381e-005
Y-90	3.1700e-001	1.1365e+000	Zn-65	4.5200e-010	1.6205e-009

GRU Nuclear


Calculation Sheet

Subject	FH109/FH300 Curie Estimate	Calc No	Reviewed by	Rev. No.	Sheet No	Date
Originator B. Brosey	8/27/93	4240-3233-93-020	G. Lodde	0	of	8/27/93

EXPOSURE RATE IN mR/h

EXPOSURE RATE FROM AREA SOURCE

FH109 FUEL POOL-1 Curie Source



Calculation Sheet

Subject	FH109/FH300 Curie Estimate	Calc No	4240-1233-93-020	Rev. No	0	Sheet No	35 of 35
Originator	B. Brosey B. Brumley	Reviewed by		Date		Date	
B. Brosey	8/27/93	G. Laddie	Kim Kille	8/27/93	E/27/93		

Calculation Sheet

Subject AX114 and AX115 Curie Loading	Calc No 4240-3233-93-015	Rev. No. i	Sheet No 1 of 54
Originator B. Brosey <i>B. Brown</i>	Date 9/8/93	Reviewed by <i>G. Lodde</i>	Date 9/10/93

1.0 PROBLEM STATEMENT

The purpose of this preliminary calculation is to estimate the curie loading of the "A" & "B" Makeup Demineralizers located in the Auxiliary bldg. cubicles AX114 & AX115. Radiological survey data will be used to provide the exposure rate information necessary for this estimate.

2.0 SUMMARY OF RESULTS

Based on the Radiological Controls survey data, the "A" & "B" Demineralizers contain the following total activities.

"A" DEMINERALIZER3663 Curies ± -38%**"B" DEMINERALIZER**6706 Curies + -50% - -77%

Isotopic concentrations per curie are listed in attachments 2-1 & 2-2.

The following table contains the results from previous estimates of the activity contained in the TMI-2 Demineralizers (see references).

7/16/93

REPORT	DATE	"A" DEMIN			"B" DEMIN				
		No. Ci's	Cs-134	No. Ci's	Sr-90	No. Ci's	Cs-134	No. Ci's	Sr-90
1 GEND-TNF-013, Vol. II, POST ACCIDENT ESTIMATES	9/86	286		3677		543		7035	
2 HEDL-7285, Fuel Assessment of the TMI-2 Makeup Demin's ...	10/83			3400+cr-74%					
3 TMI-2, TPB 85-10, rev 0, PRE ELUTION	4/22/85			1140				4365+or-12%	
4 TMI-2, TPB 85-10, rev 0, POST ELUTION	4/22/85			317				813	
5 TMI-2, TPB 85-10b, rev 1, POST ELUTION	7/10/85			380+or-20%				440+or-20%	
6 TMI-2, DIVISION SER, 15737-2-G07-117, rev 0	11/2/88					7.3		530	100
7 THIS ESTIMATE	7/12/93	3		978		875		9	3266
									168

3.0 REFERENCES

- 3.1 Microshield Radiation Shielding Computer Code, Version 4, Grove Engineering, Inc., 15215 Shady Grove Rd., Rockville, MD 20850.
- 3.2 Lotus 1-2-3, Release 2.2, Lotus Development Corporation, 55 Cambridge Parkway, Cambridge, MA 02142.
- 3.3 "The Health Physics and Radiological Health Handbook", Scinta, Inc., Silver Springs, MD., 1992.
- 3.4 LA-9795-MS, "NDA Measurements of the Demineralizers at TMI-2", Los Alamos National Laboratory, Los Alamos, New Mexico 87545, 8/83.
- 3.5 GPUNC Engineering Calculation No. 4249-3211-90-069, "MU & P Demineralizer Fuel Estimates", 11/16/90.

Calculation Sheet

Subject		Calc No	Rev. No	Sheet No
AX114 and AX115 Curie Loading		4240-3233-93-015	1	2 of 59
Originator	Date	Reviewed by		Date
B. Brosey <i>B. Brosey</i>	9/8/93	G. Lodde <i>gm lodde</i>		9/10/93

3.0 REFERENCES Cont'd

- 3.6 TMI-2 Technical Planning Bulletin, TPB-85-10, rev 0, "Estimates of TMI-2 Letdown Demineralizer Resin Retained and Eluted Fission Products and Fuel", 4/22/85.
- 3.7 TMI-2 Technical Planning Bulletin, TPB-85-10b, rev 1, "Post Elution Estimates of Cs-137 in Letdown Demineralizer Resin", 7/10/85.
- 3.8 TMI-2 Division Safety Evaluation Report, SER 15737-2-G07-117, "In-Place Storage of Makeup and Purification Demineralizer Resins During PDMS", 11/2/88.
- 3.9 HEDL-7285, "Fuel Assessment of the Three Mile Island Unit 2 Makeup Demineralizers by Compton Recoil Continuous Gamma-ray Spectrometry" U.S. Department of Energy, Hanford Engineering Development Laboratory, Richland, WA 99352, 10/83.
- 3.10 GEND-INF-013, "TMI-2 Purification Demineralizer Resin Study", U.S. Department of Energy, EG&G Idaho, Inc., Idaho Falls, Idaho 83415, 5/84.
- 3.11 GEND-INF-013, Vol. II, "Development of a Process...TMI-2 Makeup and Purification Demineralizers", U.S. Department of Energy, EG&G Idaho, Inc., Idaho Falls, Idaho 83415, 5/84.
- 3.12 GPUNC Memorandum No. 4200-88-585, "Resin Material in MU-K-1A & B", 1/3/89.
- 3.13 GPUNC Technical Plan, "Makeup and Purification Demineralizers Resin Removal", TPO/TMI-072, rev 0, 8/83.
- 3.14 Burns & Roe, Inc., Drawing No. 2066, rev 23, "General Arrangement Auxiliary & Fuel Handling Building Floor Plan El. 305'-0\"", W.O. 2555. 9/17/70.
- 3.15 3-D Visions Corporation graphing program "GRAFTOOL", Ver. 3.3, 12/16/90.

4.0 ASSUMPTIONS AND BASIC DATA

4.1 General overview of methodology.

- 4.1.1 In general, the two demineralizers are modeled as right circular cylinders. The activity is assumed to be at the bottom of each cylinder based on referenced data. Other locations in the cubicles are also modeled to determine the effect of differing source locations. Finally, exposure rate estimates are determined at several distances from each tank. All exposure rate information is calculated from one curie of isotopic distribution assumed to be present in the indicated demineralizer. Data in section 4.0 is preliminary in nature.

Subject AX114 and AX115 Curie Loading		Calc No. 4240-3233-93-015	Rev. No. 1	Sheet No. 3 of 54
Originator B. Brosey	B. Brosey	Date 9/8/93	Reviewed by G. Lodde	Date 9/10/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.2 Determination of materials and densities.

4.2.1 From review of reference 3.12 and 3.13 the following data table was assembled using the Lotus 1-2-3 spreadsheet system (reference 3.2).

A & B DEMIN DENSITY ESTIMATE

LOADING ESTIMATE FROM REPORTED VALUES	LBS		DENSITY ESTIMATE (MIN) g/cc		DENSITY ESTIMATE (MID) g/cc		DENSITY ESTIMATE (MAX) g/cc	
	A DEMIN	B DEMIN	A DEMIN	B DEMIN	A DEMIN	B DEMIN	A DEMIN	B DEMIN
RESIN WEIGHT (lbs)	1025	1025	0.7463	0.7463	1.4927	1.4927	2.2390	2.2390
WATER WEIGHT (lbs)	193	193	0.1405	0.1405	0.2811	0.2811	0.4216	0.4216
CORE DEBRIS Fe (lbs)	95	19	0.0692	0.0138	0.1383	0.0277	0.2075	0.0415
URANIUM WEIGHT (lbs)	5	1	0.0036	0.0007	0.0073	0.0015	0.0109	0.0022
BOT,LAT,ASS. Fe (lbs) OVER LOWER 6" OF TANK	38.4	38.4	0.0978	0.0978	0.0978	0.0978	0.0978	0.0978
TOTALS==>			1.0575	0.9992	2.0172	1.9007	2.9768	2.8021

TANK VOLUME "560 gallon"=74.9 cubic feet

"RESIN DENSITY (g/cc)"=0.7463

INITIAL RESIN VOLUME "22 cubic feet"= 522970.62 cc's

POST ELUTION

VOLUME ESTIMATE ft'3> 0.2 7.1
IN CC's===== 5663.36 201049

ESTIMATED DIAMETER OF

SOURCE TERM ft.====> 2.0 4.0

"A"	"B"
ESTIMATED	INCHES
HEIGHT OF SOURCE TERM	INCHES

0.764 5.780

DATA FROM TECHNICAL PLAN, IPO/TMI-072, 8/83
AND SPUND Memorandum 4200-88-585, 1/3/89.

4.2.2 Three postulated densities are presented for each demineralizer: a minimum value, a middle value and a maximum value. The middle value was chosen as the most likely density for the demineralizer materials. The other two densities are presented to project other possibilities and provide an error term for density variations.

The middle and maximum densities are estimated by multiplying the minimum density values by a factor of 2 and 3 respectively.

Subject	Calc No.	Rev No	Sheet No
AIX14 and AIX15 Curie loading	4240-3237-93-015	1	4 of 54
Originator	Date	Reviewed by	Date
B. Brosey	9/6/93	D. Ladd	Shm Ladd 9/10/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.2 Determination of materials and densities cont'd.

4.2.3 The minimum density values for all materials except the bottom laterals are projected by dividing the mass of the originally loaded materials listed in the reference 3.13, by the volume of the resin (22 cubic feet), listed in reference 3.13.

The effective density of the bottom laterals located in the tanks, is calculated by assuming that each lateral assembly is located in the lower 6 inches of each tank. This places the laterals in the source region making them a component of the overall density term for each tank.

4.2.4 The tanks are assumed to be composed of 0.25 inch stainless steel with a density of 7.86 g/cc.

4.2.5 The vertical exit piping near center at the bottom of each tank is assumed to be 3 inch schedule 40 stainless steel.

4.2.6 The horizontal run of piping in the "B" Demineralizer room is assumed to be 2 inch schedule 40 stainless steel.

4.2.7 The bottom lateral assembly is assumed to be composed of 12 pieces, 21 inches long by 3/4 inch, schedule 40 stainless steel piping with one section of 5" diameter by 6" long schedule 40 piping at the center. The total weight of this assembly is assumed to be approximately 31.1 lbs (see attachment 11-1).

4.3 The isotopes, and activity of the isotopes present in one curie of source materials for each demineralizer is assumed to be the same as that presented in reference 3.13. The activities from reference 3.13 were decayed to 7/12/93 and normalized to 1.

SOURCE TERMS FOR DEMINS (in Ci's)

ISOTOPES	DEMIN "A"	DEMIN "B"
Co-60	7.97e-4	-----
Sr-90	2.39e-1	2.51e-2
Y-90	2.39e-1	2.51e-2
Sb-125	8.91e-4	-----
Te-125m	2.06e-4	-----
Cs-134	7.55e-4	1.35e-3
Cs-137	2.67e-1	4.87e-1
Ba-137m	2.52e-1	4.61e-1
Ce-144	1.79e-6	-----
Pr-144	1.79e-6	-----
Pr-144m	2.55e-8	-----

4.3.1 For purposes of this calculation the source term is assumed to be homogeneously distributed throughout the volume of the source region.

Subject AX114 and AX115 Curie Loading	Calc No 4240-3233-93-015	Rev. No	Sheet No 5 of 54
Originator B. Brosey	Date 9/8/93	Prepared by G. Lodde	Date 9/10/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.4 Computer modeling for "A" & "B" Demineralizers.

4.4.1 From review of reference No. 3.13 and discussions with TMI-2 Engineering personnel, the following information represents the basic Microshield input data.

a) Demineralizer "A" Basic Microshield 4 input:

Dose point to center of cylinder (X).....	176.34 cm.
Height of cylinder (H).....	1.94056 cm.
Radius of cylinder (R).....	30.48 cm.
Thickness of cylinder shell (SH1).....	0.635 cm.
Dose point position along Z axis (Z).....	0.0 cm.
Dose point from base of cylinder (Y).....	68.58 cm.
Air Gap.....	145.225 cm.

b) Demineralizer "B" Basic Microshield 4 input:

Dose point to center of cylinder (X).....	270.97 cm.
Height of cylinder (H).....	17.2212 cm.
Radius of cylinder (R).....	60.96 cm.
Thickness of cylinder shell (SH1).....	0.635 cm.
Dose point position along Z axis (Z).....	0.0 cm.
Dose point from base of cylinder (Y).....	68.58 cm.
Air Gap.....	209.375 cm.

4.5 Review and interpretation of survey data.

4.5.1 Six (6) Radiological Controls Field Operations surveys and one (1) Engineering survey were reviewed to determine the true exposure rate at set locations within the "A" & "B" Demineralizer cubicles (see attachments 10-1 to 10-9). The data was analyzed and incorporated into a spreadsheet for manipulation purposes. The spreadsheet data table is shown below.

Subject AX114 and AX115 Curie Loading	Calc No 4240-3233-93-015	Rev No I	Sheet No 6 of 54
Originator B. Brosey	Date 9/8/93	Reviewed by G. Lodge	Date 9/10/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.5 Review and interpretation of survey data cont'd.

4.5.1 Cont'd.

A & B DEMINERALIZER DATA ANALYSIS

7/16/93

ROOM NUMBER	SURVEY DATE	SURVEY NUMBER	SURVEY RESULT			FEET			POSSIBLE ERROR IN Y FEET	
			'4 FOOT FLOOR DISTANCE IN FEET		ESTIMATED DISTANCE IN FEET	FROM TANK CENTER LINE	D	E CALC. M (mR/h)	TOTAL Ci's AT D ft	
			(mR/h)	(X)	(Y)	(D)	N	PER CI ESTIMATE X FEET		
AX115	9/28/88	BB19796	125000	6.78	5.75	8.89	B	5.10	24511	0.75
AX114*	3/13/85	NONE	90000	4.6	1.75	4.92	A	23.29	3865	0.75
AX115	4/6/85	3N-85	35000	6.78	5.75	8.89	B	5.10	5863	0.75
AX115	4/6/85	3N-85	70000	6.78	1.25	6.89	B	10.88	6432	0.75
AX115	4/6/85	3N-85	30000	6.78	3.25	7.52	B	8.59	3494	0.75
AX115	6/5/85	4N-85	37000	6.78	5.75	8.89	B	5.10	7255	0.75
AX114*	6/5/85	2N-85	60600	4.6	2.75	5.36	A	19.94	3040	0.75
AX115	9/28/88	NONE	42900	5.73	5.75	8.12	B	6.84	6273	0.75
AX114*	4/24/90	90J04347	70000	5.09	2.75	5.79	A	17.14	4085	0.75

* DENOTES INTERPOLATED EXPOSURE RATE VALUES

ROOM NUMBER	DISTANCE LONG (ft)	DISTANCE SHORT (ft)	COMBINED & AVERAGED ABSOLUTE VALUE											
			TERM	TERM	CALC. mR/h/Ci									
AX115	9.9	7.8	3.41	7.62	0.67	1.49	-33%	49%	41%	N/A	24511	<NOT USED		
AX114*	5.9	4.0	16.42	32.55	0.71	1.40	-29%	40%	35%	3865	N/A			
AX115	9.9	7.8	3.41	7.62	0.67	1.49	-33%	49%	41%	N/A	6863			
AX115	7.8	6.1	7.74	15.00	0.71	1.38	-29%	38%	33%	N/A	6432			
AX115	8.5	6.5	5.85	12.51	0.68	1.46	-32%	46%	39%	N/A	3494	<NOT USED		
AX115	9.9	7.8	3.41	7.62	0.67	1.49	-33%	49%	41%	N/A	7255			
AX114*	6.4	4.3	13.81	28.64	0.69	1.44	-31%	44%	37%	3040	N/A			
AX115	9.2	7.1	4.57	10.23	0.67	1.50	-33%	50%	41%	N/A	6273			
AX114*	6.8	4.8	11.92	24.50	0.70	1.43	-30%	43%	37%	4085	N/A			

AVERAGED CURIE VALUES=> 3663 6706

ESTIMATED ERROR + or - 36.2% A-Demin Avg.

ESTIMATED ERROR + or - 39.3% B-Demin Avg.

Subject		Calc No	Rev No	Sheet No
AX114 and AX115 Curie Loading		4240-1233-93-015	1	7 of 54
Originator	Date	Reviewed by	Date	
B. Brosey <i>B. Brosey</i>	9/8/93	G. Lodde <i>G. Lodde</i>	9/10/93	

4.0 ASSUMPTIONS AND BASIC DATA Cont'd.

4.5 Review and interpretation of survey data cont'd.

- 4.5.2 The table in section 4.5.1 presents distance estimates; calculated exposure rate estimates based on these distances, total curies present, and an estimate of error due to incorrect distance determinations. Sections 4.5.3 to 4.5.9 describes the methodology used to calculate these parameters.
- 4.5.3 The distance estimates were determined by review and scaling from current GPUNC drawings (see reference No. 3.14), diagrams from other references in section 3.0, and RADCON survey sheets (see attachments 10-1 to 10-9). Since the demineralizers are at approximately the center of the cubicles, an X and Y coordinate can be used to calculate the approximate horizontal distance from a dose point to the tank vertical centerline.
- 4.5.4 When their location is unspecified, all exposure rate values are assumed to have been taken about 4 feet above the cubicle floor. However, the first survey listed in the table (section 4.5.1), presents a value that is at least 3 times higher than measurements taken at similar horizontal (X,Y) locations shown in other surveys. For purposes of this calculation, this value is assumed to be either in error or taken at other than 4' above the cubicle floor.
- 4.5.5 Several 4' radiation values presented in the table in section 4.5.1, have been interpolated from the actual survey data. These interpolated values are marked with an asterisk.
- 4.5.6 The distance values in the table ("D"), are calculated by determining the hypotenuse of a right triangle.
- 4.5.7 The calculated mR/h per curie values shown in the table, are determined by curve fitting the Microshield 4 calculated exposure rates for the "A" & "B" Demineralizers for several distances out from the source regions, using the sensitivity analysis option in Microshield 4. These distances use the base Microshield inputs listed in section 4.4.1 as the reference values. The functions used in the spreadsheet table seen in section 4.5.1 were determined by the curve fitting routine in the computer program "Graftool" (reference 3.15). These functions are listed below.

"A" Demineralizer Correlation Coefficient
 $Y=133.6 \cdot 0.7012^x$ -0.966758

"B" Demineralizer -0.89348
 $Y=149.339 \cdot 0.683949^x$

WHERE: Y is the mR/h/Ci value and X is the number of horizontal feet from the demineralizers vertical centerline.

Subject AX114 and AX115 Curie Loading	Calc No. 4240-3233-43-015	Rev No. 8	Sheet No. of 54
Originator B. Brosby <i>B. Brosby</i>	Date 9/8/93	Reviewed by G. Ladd <i>M. Ladd</i>	Date 9/10/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.5 Review and interpretation of survey data cont'd.

4.5.8 The total curie column in the table is calculated by dividing the measured or interpolated exposure rate by the mR/h/Ci value determined by the method shown in section 4.5.7.

4.5.9 The estimate of the error from incorrectly determining the X & Y horizontal distances where a measurement was taken, is determined by assuming that the X and Y distance measurements could be incorrect by as much as 0.75 feet. The maximum distance from the source would be $((X'+0.75')^2+(Y'+0.75')^2)^{0.5}$. The minimum would be $((X'-0.75')^2+(Y'-0.75')^2)^{0.5}$. From these two distances, differing mR/h values may be estimated using the same method previously described in previous sections. The differences between the mR/h estimates for correct vs incorrect distances both long and short, are averaged and converted to percentage differences and are presented as one component of the overall estimate of error for this analysis.

4.6 The following is a description of the attachments presented in this calculation.

- a) Attachments 1-1 & 1-2, present and decay the isotopes extracted from reference 3.13 assumed to characterize the "A" & "B" Demineralizers.
- b) Attachments 2-1 to 2-2, present the decayed isotopes from attachments 1-1 & 1-2 normalized to 1.
- c) Attachments 3-1 & 3-4, present the demineralizer cubicle locations with actual and estimated dimensions.
- d) Attachments 4-1 to 4-4, present the demineralizer tanks with estimated dimensions including associated piping.
- e) Attachments 5-1 to 5-7, Microshield 4 base case output for high, middle and low density materials modeling.
- f) Attachments 6-1 to 6-5, Microshield 4 sensitivity analysis using middle density materials from 91.44 cm to 213.36 cm for the "A" and from 91.44 cm to 304.8 cm for "B" Demineralizer.
- g) Attachment 7-1, Microshield 4 output for pipe source at base of "A" Demineralizer.
- h) Attachments 8-1, Microshield 4 output for horizontal run of pipe section in the "B" Demineralizer cubicle (base case geometry).
- i) Attachments 9-1 to 9-6, Graftool output from curve fitting Microshield 4 sensitivity analysis data for "A" & "B" Demineralizer for various X distances.

Subject		Calc No.	Rev. No.	Sheet No.
AX114 and AX115 Curie Loading		4240-3233-93-015	1	9 of 54
Operator	Date	Reviewed by		
B. Brosey	9/8/93	G. Lode	Jm Lode	9/10/93

4.0 ASSUMPTIONS AND BASIC DATA Cont'd

4.6 Attachments cont'd.

- j) Attachments 10-1 to 10-9, Radiological surveys that present the survey information used to estimate the curie loading of the "A" & "B" Demineralizers.
- k) Attachment 11-1, dimensions and weights of seamless and welded steel pipe, Williams and Company, inc. catalog # 23, pp D-30 & 31.

5.0 CALCULATIONS

5.1 Most of the earlier operations were performed using the Lotus 1-2-3 spreadsheet system.

5.2 In section 4.2.2 three (3) possible densities were estimated for modeling purposes. In attachments 5-1 to 5-7 the Microshield 4 output from the differing density computer analysis are shown.

For the "A" Demineralizer, the calculated exposure rate for the 3 density estimates using the Microshield base case input is:

HIGH DENSITY (2.96 g/cc).....	15.26 mR/h.
MIDDLE DENSITY (2.00 g/cc).....	16.73 mR/h.
LOW DENSITY (1.04) g/cc).....	18.22 mR/h.

For the "B" Demineralizer, the calculated exposure rate for the 3 density estimates using the Microshield base case input is:

HIGH DENSITY (2.78 g/cc).....	3.619 mR/h.
MIDDLE DENSITY (1.88 g/cc).....	5.107 mR/h.
LOW DENSITY (0.98) g/cc).....	8.496 mR/h.

Using the above listed data and calculating the estimated error due to possible variations in density gives the following results.

"A" DEMINERALIZER

$$(1-(15.26/16.73)) \times 100\% = + 8.8\%$$

$$(1-(18.22/16.73)) \times 100\% = - 8.9\%, \text{ for the "A" DEMIN.}$$

"B" DEMINERALIZER

$$(1-(3.619/5.107)) \times 100\% = + 29.1\%$$

$$(1-(8.496/5.107)) \times 100\% = - 66\%, \text{ for the "B" DEMIN.}$$

Subject AX114 and AX115 Curie Loading	Calc No 4240-3233-93-015	Rev No 1	Sheet No 10 of 54
Originator B. Brosey	Date 9/8/93	Reviewed by G. Lodde	Date 9/10/93

5.0 CALCULATIONS Cont'd

5.3 Location of the base case Microshield 4 exposure rate point relative to the demineralizers.

The diagram on attachment 4-3 shows the relative position of the base case Microshield 4 exposure rate points to the demineralizers and to the base pipe connections.

5.4 Placement of other source terms.

5.4.1 "A" Demineralizer.

5.4.1.1 The "A" Demineralizer source term is assumed to be a 2' diameter cylinder with a height of about 0.764 cm (section 4.2.1). If it is assumed that the majority of the source term is located in the 3" resin sluice line below the tank, the geometry for this case would then be as follows.

Assuming the vertical pipe length at base of the tank is about 9" long, then the lowest section or the elbow of this pipe is at approximately the -306' El. The location for the highest exposure rate measurements were taken approximately 3' above the floor at the 308' El. The elevational difference is about 2'. Assuming the horizontal distance is within a few inches of the base case horizontal distance or about 5.8 feet, the Microshield 4 output for a pipe segment containing one curie would be 17.37 mR/h (see attachment 7-1). Since the base case Microshield output for the "A" Demineralizer tank was 16.73 mR/h (section 5.2), the relative difference in activity is:

$$(1 - (100,000 \text{ mR/h} / 17.37 \text{ mR/h/Ci}) / (70,000 \text{ mR/h} / 16.73 \text{ mR/h/Ci})) \times 100\% = -38\%$$

The possibility that all of the activity is in the this lower pipe section is remote and therefore will not be considered further.

5.4.2 "B" Demineralizer.

5.4.2.1 The 2" diameter pipe run connected to the resin sluice outlet nozzle located in the "B" Demineralizer cubicle may also contain resin and high activity levels. This pipe run is shown in attachments 3-3 and 4-3 and is present in both cubicles. However the majority of the activity located in the "B" Demineralizer cubicle is assumed to be located in the tank, based on the

Subject AX114 and AX115 Curie Loading	Calc No 4240-3233-93-015	Rev. No 11	Sheet No of 54
Originator B. Brosey	Date 9/8/93	Revised by G. Ladd	Date 9/10/93

5.0 CALCULATIONS Cont'd

5.4 Placement of other source terms cont'd

5.4.2 "B" Demineralizer cont'd.

Radiological Engineering survey data shown on attachments 10-6 to 10-8. However, if one (1) curie of activity is placed in a single pipe run located at the center of the two pipe sections running east and west (shown on attachment 4-3), the mR/h/Ci value would be approximately 20.77 mR/h/Ci (see attachment 8-1). The Microshield 4 model would be as shown below:

"B" Demineralizer 2" pipe run input file

Dose point to center of pipe section (X).....217.17 cm.
 Height of cylinder (H).....228.6 cm.
 Radius of cylinder (R).....2.62509 cm.
 Thickness of cylinder shell (SH1).....0.39116 cm.
 Dose point position along Z axis (Z).....87.63 cm.
 Dose point from base of cylinder (Y).....44.81 cm.
 Air Gap.....214.15375 cm.

5.4.2.1 The pipe is 2" schedule 40 stainless steel and is located at approximately the 306' 1.5" El. The pipe starts about 9" east of the vertical centerline of the "B" Demin and runs east for about 7.5 feet. The elevational difference would be about 309'-306' 1.5" or about 2.875'. The exposure rate point is at the center of the entrance to the "B" Demin cubicle about 4' above the floor.

5.4.2.2 Based on the two models, the relative difference between one curie of activity in the demineralizer and one curie in the pipe section is shown below.

$$(1 - (20.77 \text{ mR/h/Ci} / 5.107 \text{ mR/h/Ci})) \times 100\% = 307\%$$

This indicates that if the activity were predominately located in the 2" line, about 1/4 th of the calculated number of curies would be present. This is not the case since the "B" Demin retains the higher exposure rate as evidenced by the survey information. Therefore, the best estimate is that most of the activity is still retained at the "B" Demin location and not in the 2" line.

Subject		Calc No.	Rev No.	Sheet No.
AX114 and AX115 Curie Loading		4240-3233-91-015		12 of 54
Originator	Date	Reviewed by	Date	
B. Brosey <i>B. Brosey</i>	9/8/93	G. Loddie <i>G. Loddie</i>	9/10/93	

5.0 CALCULATIONS Cont'd

5.5 Combination of Error Terms.

5.5.1 The combined estimate of error in this analysis includes the following:

- a) The estimate of the uncertainty in the radiation measurements from the radiological surveys, due to incorrectly reported survey locations (in the X and Y directions, north-south/east-west).
- b) The estimate of the uncertainty in the density of the source term materials.
- c) An assumed instrumentation response error.

5.5.2 The distance error estimate assumes that the actual exposure rate point is within \pm one foot of the correct measurement location ($((9''^2+9''^2)^{0.5}) = 12.7''$). Since there is a similar difference in the effect of \pm distance error for the individual curie values presented in the table in section 4.5.1, and some uncertainty in the exact measurement locations, the absolute values of the error terms as well as the curie estimates were summed and averaged for several measurements.

The error estimate for the survey locations for the "A" Demin is:

$$(35\% + 37\% + 37\%) / 3 = - \pm 36\%.$$

The error estimate for the survey locations for the "B" Demin is:

$$(41\% + 33\% + 41\% + 41\%) / 4 = - \pm 39\%.$$

5.5.3 From section 5.2, the uncertainty in the source term density is assumed to be:

$- \pm 9\%$ for the "A" Demineralizer and, $- \pm 29\% - 66\%$ for the "B" Demineralizer.

5.5.4 The instrumentation calibration error is assumed to be approximately $\pm 10\%$.

5.5.5 The combined error estimate is approximately:

$$\pm (36\%^2 + 9\%^2 + 10\%^2)^{0.5} = - 38\% \text{ for the "A" Demineralizer and,}$$

$$+ (39\%^2 + 29\%^2 + 10\%^2)^{0.5} = - + 50\%$$

$$- (39\%^2 + 66\%^2 + 10\%^2)^{0.5} = - - 77\% \text{ for the "B" Demineralizer.}$$

Attachment 1-1

SAMPLE SUMMARY SHEET NUMBER OF SAMPLES==== 1
 7/12/93

Today's Date SAMPLE No. SAMPLE No. SAMPLE No. SAMPLE No. SAMPLE No.

"AM DEMIN

DATE	DATE	DATE	DATE	DATE	DATE
5/15/83	7/12/93	7/12/93	7/12/93	7/12/93	7/12/93

ELAPSED (d) ELAPSED (d) ELAPSED (d) ELAPSED (d) ELAPSED (d)

ISOTOPES

ISOTOPES	3711	0	0	0	0	0 Decayed Totals
H-3						0.00000E+00 H-3
Be-7						0.00000E+00 Be-7
C-14						0.00000E+00 C-14
Cr-51						0.00000E+00 Cr-51
Mn-54						0.00000E+00 Mn-54
Fe-55						0.00000E+00 Fe-55
Co-57						0.00000E+00 Co-57
ca-58						0.00000E+00 ca-58
Fe-59						0.00000E+00 Fe-59
Ni-59						0.00000E+00 Ni-59
Co-60	1.9800E+00					5.20636E-01 Co-60
Ni-63						0.00000E+00 Ni-63
Zn-65						0.00000E+00 Zn-65
Sr-89						0.00000E+00 Sr-89
Sr-90	2.0000E+02					1.56355E+02 Sr-90
Zr-95						0.00000E+00 Zr-95
Tc-99						0.00000E+00 Tc-99
Ru-103						0.00000E+00 Ru-103
Ru-106						0.00000E+00 Ru-106
Ag-110m						0.00000E+00 Ag-110m
Sb-124						0.00000E+00 Sb-124
Sb-125	7.6000E+00					5.82514E-01 Sb-125
Te-125m						0.00000E+00 Te-125m
I-129						0.00000E+00 I-129
I-131						0.00000E+00 I-131
I-133						0.00000E+00 I-133
Cs-134	1.5000E+01					4.93321E-01 Cs-134
Cs-136						0.00000E+00 Cs-136
Cs-137	2.2000E+02					1.74208E+02 Cs-137
Ce-139						0.00000E+00 Ce-139
Ba-140						0.00000E+00 Ba-140
Ce-141						0.00000E+00 Ce-141
Co-144	9.9000E+00					1.16705E-03 Co-144
Pm-147						0.00000E+00 Pm-147
Eu-154						0.00000E+00 Eu-154
Eu-155						0.00000E+00 Eu-155
U-233						0.00000E+00 U-233
U-234						0.00000E+00 U-234
U-235						0.00000E+00 U-235
U-236						0.00000E+00 U-236
Np-237						0.00000E+00 Np-237
Pu-238						0.00000E+00 Pu-238
U-238						0.00000E+00 U-238
Pu-239						0.00000E+00 Pu-239
Pu-240						0.00000E+00 Pu-240
Am-241						0.00000E+00 Am-241
Pu-241						0.00000E+00 Pu-241
Cm-242						0.00000E+00 Cm-242
Pu-242						0.00000E+00 Pu-242
Cm-243						0.00000E+00 Cm-243
Cm-244						0.00000E+00 Cm-244

TOTAL=> 3.3216E+02



Calculation Sheet

Subject	Ax114 and Ax115 Curie Loading	Date	Calc No	Rev No	Sheet No
Originator	B. Brumley	9/8/93	4240-3213-93-015	1	13 of 54

Attachment 1-2

SAMPLE SUMMARY SHEET NUMBER OF SAMPLES====> 1
 7/12/93 *****

Today's Date SAMPLE No. SAMPLE No. SAMPLE No. SAMPLE No. SAMPLE No. SAMPLE No.
 "8" DEMIN

	DATE	DATE	DATE	DATE	DATE	DATE	ISOTOPES
	ELAPSED (d)	ISOTOPES					
ISOTOPES	3711	0	0	0	0	0	0 Decayed Totals
H-3							0.00000E+00 H-3
Be-7							0.00000E+00 Be-7
C-14							0.00000E+00 C-14
Cr-51							0.00000E+00 Cr-51
Mn-54							0.00000E+00 Mn-54
Fe-55							0.00000E+00 Fe-55
Co-57							0.00000E+00 Co-57
Ca-58							0.00000E+00 Ca-58
Fe-59							0.00000E+00 Fe-59
Ni-59							0.00000E+00 Ni-59
Co-60							0.00000E+00 Co-60
Ni-63							0.00000E+00 Ni-63
Zn-65							0.00000E+00 Zn-65
Sr-89							0.00000E+00 Sr-89
Sr-90	8.8000E+02						6.87961E+02 Sr-90
Zr-95							0.00000E+00 Zr-95
Tc-99							0.00000E+00 Tc-99
Ru-103							0.00000E+00 Ru-103
Ru-106							0.00000E+00 Ru-106
Ag-110m							0.00000E+00 Ag-110m
Sb-124							0.00000E+00 Sb-124
Sb-125							0.00000E+00 Sb-125
Te-125m							0.00000E+00 Te-125m
I-129							0.00000E+00 I-129
I-131							0.00000E+00 I-131
I-133							0.00000E+00 I-133
Cs-134	1.1300E+03						3.71635E+01 Cs-134
Cs-136							0.00000E+00 Cs-136
Cs-137	1.6900E+04						1.33823E+04 Cs-137
Ce-139							0.00000E+00 Ce-139
Ba-140							0.00000E+00 Ba-140
Ce-141							0.00000E+00 Ce-141
Ce-144							0.00000E+00 Ce-144
Pm-147							0.00000E+00 Pm-147
Eu-154							0.00000E+00 Eu-154
Eu-155							0.00000E+00 Eu-155
U-233							0.00000E+00 U-233
U-234							0.00000E+00 U-234
U-235							0.00000E+00 U-235
U-236							0.00000E+00 U-236
Np-237							0.00000E+00 Np-237
Pu-238							0.00000E+00 Pu-238
U-238							0.00000E+00 U-238
Pu-239							0.00000E+00 Pu-239
Pu-240							0.00000E+00 Pu-240
Am-241							0.00000E+00 Am-241
Pu-241							0.00000E+00 Pu-241
Cm-242							3.00000E+00 Cm-242
Pu-242							0.00000E+00 Pu-242
Cm-243							0.00000E+00 Cm-243
Cm-244							0.00000E+00 Cm-244
TOTAL====							1.41075E+04

GRU Nuclear

Subject	Ax114 and Ax115 Curie Loading	Calc No	Reviewed by	Date	Rev No	Sheet No	Date
E. Brosey	3. Brumy	4240-1-1233-93-015	G. Laddie	9/8/93	1	1X of 5Y	9/10/93

Attachment 2-1

NORMALIZATION WORKSHEET (1 Ci)

CALCULATED

EXPOSURE RATE PER Ci<=>

mR/h

ACTUAL=>

mR/h

UNITS IN><Ci

I.D. NUMBER

OR NAME="A" DEMIN, AX114

7/12/93

Today's Date

NRC REPORTABLE

Sr-90/Cs-137

ISOTOPE	INPUT UNIT	PERCENT (%) of Total	ACTIVITY PER CURIE	ADJUSTED ACTIVITY (mCi)	ADJUSTED WITHOUT DAUGHTERS (mCi)	IF > 1% OF TOTAL	ISOTOPES	RATIO
1 H-3	***	0.00000	0.00E+00 ***	ERR	ERR	ERR H-3	*	ERR *
2 C-14	***	0.00000	0.00E+00 ***	ERR	ERR	ERR C-14	*****	
3 Cr-51	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Cr-51		
4 Mn-54	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Mn-54		
5 Fe-55	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Fe-55		
6 Co-58	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Co-58		
7 Co-60	5.21E-01 ***	0.07967	7.97E-04 ***	ERR	ERR	ERR Co-60		
8 Ni-63	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ni-63		
9 Zn-65	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Zn-65		
10 Sr-89	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Sr-89		
11 Sr-90	1.56E+02 ***	23.92754	2.39E-01 ***	ERR	ERR	ERR Sr-90		
12 Y-90	1.56E+02 ***	23.92754	2.39E-01 ***	ERR	*****	***** Y-90		
13 Tc-99	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Tc-99		
14 Ru-106	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ru-106		
15 Rh-106	***	0.00000	0.00E+00 ***	ERR	*****	***** Rh-106		
16 Ag-110m	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ag-110m		
17 Ag-110	***	0.00000	0.00E+00 ***	ERR	*****	***** Ag-110		
18 Sb-125	5.83E-01 ***	0.08914	8.91E-04 ***	ERR	ERR	ERR Sb-125		
19 Te-125m	1.35E-01 ***	0.02059	2.06E-04 ***	ERR	ERR	ERR Te-125m		
20 I-129	***	0.00000	0.00E+00 ***	ERR	ERR	ERR I-129		
21 Cs-134	4.93E-01 ***	0.07549	7.55E-04 ***	ERR	ERR	ERR Cs-134		
22 Cs-137	1.74E+02 ***	26.65964	2.67E-01 ***	ERR	ERR	ERR Cs-137		
23 Ba-137m	1.65E+02 ***	25.22002	2.52E-01 ***	ERR	*****	***** Ba-137m		
24 Ce-141	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ce-141		
25 Ce-144	1.17E-03 ***	0.00018	1.79E-06 ***	ERR	ERR	ERR Ce-144		
26 Pr-144m	1.57E-05 ***	0.00000	2.55E-08 ***	ERR	*****	***** Pr-144m		
27 Np-237	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Np-237		
28 Pa-233	***	0.00000	0.00E+00 ***	ERR	*****	***** Pa-233		
29 Pu-238	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pu-238		
30 Pu-239	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pu-239		
31 Pu-241	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pu-241		
32 Am-241	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Am-241		
33 Cm-243	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Cm-243		
34 U-235	***	0.00000	0.00E+00 ***	ERR	ERR	ERR U-235		
35 U-238	***	0.00000	0.00E+00 ***	ERR	ERR	ERR U-238		
36 Pu-240	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pu-240		
37 U-234	***	0.00000	0.00E+00 ***	ERR	ERR	ERR U-234		
38 Pm-147	***	0.00000	3.00E+00 ***	ERR	ERR	ERR Pm-147		
39 Eu-154	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Eu-154		
40 Eu-155	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Eu-155		
41 U-236	***	0.00000	0.00E+00 ***	ERR	ERR	ERR U-236		
42 Pr-144	1.17E-03 ***	0.00018	1.79E-06 ***	ERR	*****	***** Pr-144		
43 Cm-242	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Cm-242		
44 Cm-244	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Cm-244		
45	***	0.00000	0.00E+00 ***	ERR	ERR	ERR		

TOTALS==>6.5345E+02 Ci 100.00 1.00000 Ci ERR mCi ERR mCi

CPU Nuclear

Subject: Ax114 and Ax115 Curie Loading

Entered By: B. Brown

Calculation Sheet

Calc No: 4240-3233-93-015

Reviewed By: R. L. Hall

Date: 9/8/93

Sheet No: 1 / 3 of 54

Date: 9/11/93

NORMALIZATION WORKSHEET (1 Ci)

CALCULATED		EXPOSURE RATE PER Ci==>		ACTUAL==>		7/12/93	
UNITS IN>Ci		mR/h		mR/h		Today's Date	
I.D. NUMBER OR NAME=>HB DEMIN, AX115							
INPUT UNIT ISOTOPE	UNIT ACTIVITY	PERCENT (%) of Total	ACTIVITY PER CURIE	ADJUSTED ACTIVITY (mCi)	ADJUSTED WITHOUT DAUGHTERS (mCi)	NRC REPORTABLE If > 1% of TOTAL	Sr-90/Cs-137 ISOTOPES RATIO
1 H-3	***	0.00000	0.00E+00 ***	ERR	ERR	ERR H-3 *	ERR *
2 C-14	***	0.00000	0.00E+00 ***	ERR	ERR	ERR C-14	*****
3 Cr-51	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Cr-51	
4 Mn-54	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Mn-54	
5 Fe-55	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Fe-55	
6 Co-58	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Co-58	
7 Co-60	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Co-60	
8 Ni-63	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ni-63	
9 Zn-65	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Zn-65	
10 Sr-89	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Sr-89	
11 Sr-90	6.88E+02 ***	2.50577	2.51E-02 ***	ERR	ERR	ERR Sr-90	
12 Y-90	6.88E+02 ***	2.50577	2.51E-02 ***	ERR	ERR	***** Y-90	
13 Tc-99	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Tc-99	
14 Ru-106	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ru-106	
15 Rh-106	***	0.00000	0.00E+00 ***	ERR	ERR	***** Rh-106	
16 Ag-110m	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ag-110m	
17 Ag-110	***	0.00000	0.00E+00 ***	ERR	ERR	***** Ag-110	
18 Sb-125	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Sb-125	
19 Te-125m	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Te-125m	
20 I-129	***	0.00000	0.00E+00 ***	ERR	ERR	ERR I-129	
21 Cs-134	3.72E+01 ***	0.13536	1.35E-03 ***	ERR	ERR	ERR Cs-134	
22 Cs-137	1.34E+04 ***	48.74260	4.87E-01 ***	ERR	ERR	ERR Cs-137	
23 Ba-137m	1.27E+04 ***	46.11050	4.61E-01 ***	ERR	ERR	***** Ba-137m	
24 Ce-141	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ce-141	
25 Ce-144	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Ce-144	
26 Pr-144m	***	0.00000	0.00E+00 ***	ERR	ERR	***** Pr-144m	
27 Np-237	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Np-237	
28 Pa-233	***	0.00000	0.00E+00 ***	ERR	ERR	***** Pa-233	
29 Pu-238	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pu-238	
30 Pu-239	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pu-239	
31 Pu-241	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pu-241	
32 Am-241	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Am-241	
33 Cm-243	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Cm-243	
34 U-235	***	0.00000	0.00E+00 ***	ERR	ERR	ERR U-235	
35 U-238	***	0.00000	0.00E+00 ***	ERR	ERR	ERR U-238	
36 Pu-240	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pu-240	
37 U-234	***	0.00000	0.00E+00 ***	ERR	ERR	ERR U-234	
38 Pm-147	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Pm-147	
39 Eu-154	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Eu-154	
40 Eu-155	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Eu-155	
41 U-236	***	0.00000	0.00E+00 ***	ERR	ERR	ERR U-236	
42 Pr-144	***	0.00000	0.00E+00 ***	ERR	ERR	***** Pr-144	
43 Cm-242	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Cm-242	
44 Cm-244	***	0.00000	0.00E+00 ***	ERR	ERR	ERR Cm-244	
45	***	0.00000	0.00E+00 ***	ERR	ERR	ERR	
TOTALS==>2.7455E+04 Ci		100.00	1.00000 Ci	ERR mCi	ERR mCi		

GRU Nuclear

Calculation Sheet

Subject:	Activity and Axial Curie Loading	
Date:	9/8/93	G. Loddie
Entered by:	B. Broseby	
Revised by:	B. Broseby	
Printed by:	B. Broseby	


Date:	9/10/93
Show No:	16 of 5X
Calc No:	4240-3231-93-015
Entered by:	G. Loddie

GPU Nuclear

Calculation Sheet

Subject	Allis and Allis Curie Loading	Date	Calc No	Rev No	Sheet No
Originator	B. Brosey	Date	4240-1233-93-015	1	17 of 54
		Reviewed by			Date 9/8/93 G. Lodge

By Hand
B. Brosey



GPU Nuclear**Calculation Sheet**

Subject AX114 and AX115 Curie
Loading

Calc No.
4240-3233-93-015

Rev. No.
1


Sheet No.
18 of 54

Originator
B. Brosey

Date
9/8/93

Reviewed by
G. Lodde


Date
9/10/93



GPU Nuclear**Calculation Sheet**

Subject AX114 and AX115 Curie Loading	Calc No. 4240-3233-93-015	Rev. No. 1	Sheet No. 19 of 54
Originator B. Brosey	Date 9/8/93	Reviewed by G. Lodde	Date 9/10/93

**TMI-2
MAKE-UP & PURIFICATION
DEMINERALIZERS**




Isometric view of the makeup demineralizer cells.



Calculation Sheet

Subject	AX114 and AX115 Curie Loading	Calc No	Rev. No	Sheet No
		4240-3233-93-015	1	20 of 54
Originator	B. Brose	Date	Reviewed by	Date
B. Brose		9/8/93	G. Lodde	SMW/LL 9/10/93

PENETRATION
#891
(6 in. x 9 in.)




Plan view of the "A" demineralizer cell.

GRU Nuclear**Calculation Sheet**

Subject	Axial 14 and Axial 24 Loading	Date	Calc No	Rev No	Sheet No
Originator	B. Brosey	Date	4240-1233-93-015	1	21 of 54
	B. Brosey	Revised by	G. Laddie		

Smith 9/10/93



MU-K-1A, B MAKE-UP AND PURIFICATION DEMINERALIZERS	
TOP CONNECTIONS	
• PROCESS INLET	
• VENT	
• RESIN ADDITION	
• ACCESS COVER	
BOTTOM CONNECTIONS	
• PROCESS OUTLET	
• RESIN SLUICE	
TOP LATERALS	
• 12 TOTAL	
• 18-in. LONG	
• 3/4-in. O. 304 SS	
• 21 HOLES, 3/16-in. PER LATERAL	
BOTTOM LATERALS	
• 12 TOTAL	
• 20-in. LONG	
• 3/4-in. O. 304 SS	
• 21 HOLES, 3/16-in. PER LATERAL	
• 100 MESH WIRE SCREEN	
TANK VOLUME	
• 580 GALLONS	

HEDL 8302 003 3

Dimensions of demineralizer vessel.




Attachment 4-2

Calculation Sheet

Subject	Axial 4 and Axial 5 Curie Loading	Calc No	Sheet No
Operator	B. Brown	4240-3233-93-015	1
	G. Lodge	Date	22 of 54

"B" CUBICLE DOSE RATES

324-ft CEILING
321-ft - 9-in. PENETRATION





Gamma dose rates in cubicle B.

GPU Nuclear**Calculation Sheet**


Subject	AX114 and AX115 Curie Loading	Calc No.	Rev. No.	Sheet No.
		4240-3233-93-015	1	23 of 54
Originator	B. Brosey	Date	Reviewed by	Date

B. Brosey *B.B.* 9/8/93 G. Lodde *GM Lode* 9/10/93





FACSIMILE NOZZLES & LATERALS
TO RESEMBLE ORIGINAL AS
CLOSE AS POSSIBLE



GRU Nuclear

Calculation Sheet

Subject	4X114 and AX115 Carrie loading	Date	Calc No	Rev. No.	Sheet No	Date
		9/8/93	4240-3233-93-015	1	24 of 30	9/10/93
			Reviewed by	G. Lodge		

Attachment 5-1

MicroShield Batch Run Log

Batch Run Started on Wednesday, September 8, 1993 at 1:02 p.m.

Six cases initially in the queue.

CASE	FILE	GEOM	START TIME	ELAPSED	mR/hr w/BUILDUP	SENS. CYCLE
****	*****	****	*****	*****	*****	*****
1	AHIGHDEM	7	1:02 p.m.	0:26:06	1.526e+001	(n/a)
2	ALODOMIN	7	1:28 p.m.	0:25:06	1.822e+001	(n/a)
3	AMIDOMIN	7	1:54 p.m.	0:25:52	1.673e+001	REFERENCE
4	AMIDOMIN	7	1:54 p.m.	0:51:11	4.767e+001	1 of 5
5	AMIDOMIN	7	1:54 p.m.	1:16:21	3.178e+001	2 of 5
6	AMIDOMIN	7	1:54 p.m.	1:41:30	2.185e+001	3 of 5
7	AMIDOMIN	7	1:54 p.m.	2:06:42	1.561e+001	4 of 5
8	AMIDOMIN	7	1:54 p.m.	2:31:56	1.153e+001	5 of 5
9	BHIGHDEM	7	4:26 p.m.	0:17:06	3.619e+000	(n/a)
10	BLIDDEM1	7	4:43 p.m.	0:16:54	8.496e+000	(n/a)
11	BMIDDEM1	7	5:00 p.m.	0:17:01	5.107e+000	(n/a)

Batch run completed on Wednesday, September 8, 1993 at 5:17 p.m.

TOTAL EXECUTION TIME: 4:15:22

GPU Nuclear

Calculation Sheet

Subject	Case No	Rev. No	Sheet No
AX114 and Axils Curie Loading	4240-3233-93-015	1	250154
Organizer	Renamed by	G. Loddie	Date
B. Brosey	B. Brosey	<i>John Loddie</i>	<i>9/10/93</i>

MicroShield 4.00 - Serial #4.00-00247

Page : 1
 DOS File: ALWDHM.M54
 Run Date: July 27, 1993
 Run Time: 11:07 a.m. Tuesday
 Duration: 0:25:06

File Ref: *1A3*
 Date: *7/27/93*
 By: *M. Brosy*
 Checked: *7/27/93*

Case Title: MAKEUP DEMIN AX114 & AX115

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches
Dose point coordinate X:	176.34	5.0 9.4
Dose point coordinate Y:	68.58	2.0 3.0
Dose point coordinate Z:	0.0	0.0 .0
Cylinder height:	1.94056	0.0 .8
Cylinder radius:	30.48	1.0 .0
Shield 1:	0.635	0.0 .3
Air Gap:	145.225	4.0 9.2

Source Volume: 5663.79 cm³ .200015 cu ft. 345.625 cu in.

MATERIAL DENSITIES (g/cm ³)					
Material	Source	Shield 1	Transition	Air Gap	Immersion
		Shield	Cylinder	Shield	Shield
Air			0.00122	0.00122	0.00122
Carbon	0.7463				
Iron	0.1485	7.86			
Uranium	0.0036				
Water	0.1405				

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

	Quadrature Order
Radial	22
Circumferential	22
Axial (along Z)	22

SOURCE NUCLIDES					
Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ba-137m	2.5200e-001	4.4493e+001	Ce-144	1.7900e-006	3.1604e-004
Co-60	7.9700e-004	1.4072e-001	Cs-134	7.5500e-004	1.3330e-001
Cs-137	2.6700e-001	4.7142e+001	Pr-144	1.7900e-006	3.1604e-004
Pr-144m	2.5500e-008	4.5023e-006	Sb-125	8.9100e-004	1.5732e-001
Sr-90	2.3900e-001	4.2198e+001	Tc-125m	2.0600e-004	3.6371e-002
T-90	2.3900e-001	4.2198e+001			

***** RESULTS *****

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (r ² /hr)		
	No Buildup	With Buildup	No Buildup	With Buildup	
0.1	1.076e+005	1.756e-003	2.975e-003	2.686e-006	4.552e-006
0.15	8.989e+004	6.280e-003	1.212e-002	1.034e-005	1.995e-005
0.2	2.502e+006	3.236e-001	6.507e-001	5.711e-004	1.148e-003
0.3	1.474e+005	3.688e-002	7.199e-002	6.995e-005	1.366e-004
0.4	1.032e+007	3.898e+000	7.198e+000	7.595e-003	1.403e-002
0.5	3.821e+006	1.958e+000	3.417e+000	3.843e-003	6.708e-003
0.6	8.436e+009	5.514e+003	9.161e+003	1.076e+001	1.788e+001
0.8	2.630e+007	2.506e+001	3.857e+001	4.767e-002	7.336e-002
1.0	3.027e+007	3.846e+001	5.608e+001	7.088e-002	1.034e-001
1.5	3.034e+007	6.414e+001	8.563e+001	1.079e-001	1.441e-001
2.0	5.126e+002	1.535e-003	1.955e-003	2.373e-006	3.023e-006
TOTAL:	8.539e+009	5.548e+003	9.353e+003	1.100e+001	1.822e+001

GPU Nuclear

Subject	AX114 and AX115 Curie Loading	Date	Reviewed by	Calc No	Rev. No	Sheet No	Date
B. Brosy	<i>B. Brosy</i>	9/8/93	G. Lodde	4240-3233-91-015	1	26 of 54	9/10/93

Calculation Sheet

Attachment 5-3

MicroShield 4.00 - Serial #4.00-00247

GPU

Page : 1
 DOS File: AMIDMIN.M54
 Run Date: July 27, 1993
 Run Time: 11:33 a.m. Tuesday
 Duration: 0:25:50

File Ref: *SPR*
 Date: *7/27/93*
 By: *SPR*
 Checked: *SPR*

Case Title: MAKEUP DEMIN AX114 & AX115

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches
Dose point coordinate X:	176.34	5.0 9.4
Dose point coordinate Y:	68.58	2.0 3.0
Dose point coordinate Z:	0.0	0.0 .0
Cylinder height:	1.94056	0.0 .8
Cylinder radius:	30.48	1.0 .0
Shield 1:	0.635	0.0 .3
Air Gap:	145.225	4.0 9.2

Source Volume: 5663.79 cm³ .200015 cu ft. 345.625 cu in.

Material	Source	MATERIAL DENSITIES (g/cm ³)			
		Shield	Shield 1	Transition	Air Gap
		Cylinder	Shield		Immersion
Air			0.00122	0.00122	0.00122
Carbon	1.4927				
Iron	0.2176	7.86			
Uranium	0.0073				
Water	0.2811				

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

Quadrature Order

Radial	22
Circumferential	22
Axial (along Z)	22

SOURCE NUCLIDES	
Nuclide	curies $\mu\text{Ci}/\text{cm}^3$
Ba-137m	2.5200e-001 4.493e+001
Co-60	7.9700e-004 1.4072e-001
Cs-137	2.6700e-001 4.7142e+001
Pr-144m	2.5500e-008 4.5023e-006
Sr-90	2.3900e-001 4.2198e+001
Y-90	2.3900e-001 4.2198e+001

***** RESULTS *****

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	
	No Buildup	With Buildup	No Buildup	With Buildup
0.1	1.076e+005	1.267e-003	2.196e-003	1.938e-006 3.359e-006
0.15	8.989e+004	4.673e-003	9.486e-003	7.696e-006 1.562e-005
0.2	2.502e+006	2.479e-001	5.369e-001	4.376e-004 9.476e-004
0.3	1.474e+005	2.924e-002	6.274e-002	5.546e-005 1.190e-004
0.4	1.032e+007	3.159e+000	6.444e+000	6.156e-003 1.256e-002
0.5	3.821e+006	1.613e+000	3.106e+000	3.166e-003 6.097e-003
0.6	8.436e+009	4.602e+003	8.405e+003	8.983e+000 1.641e+001
0.8	2.630e+007	2.134e+001	3.578e+001	4.058e-002 6.806e-002
1.0	3.027e+007	3.323e+001	5.234e+001	6.125e-002 9.648e-002
1.5	3.034e+007	5.684e+001	9.079e+001	9.563e-002 1.359e-001
2.0	5.126e+002	1.382e-003	1.858e-003	2.137e-006 2.874e-006
TOTAL:	8.539e+009	4.2198e+003	8.584e+003	9.191e+000 1.573e+001

GPU Nuclear

Calculation Sheet

Subject	AX114 and AX115 Curie Loading	Date	Calc No	Rev. No	Sheet No	Date
Originator	<i>B. Brosey</i>	9/8/93	4240-3233-93-015	1	27 of 54	<i>G. Loddie</i> 9/8/93

Attachment 5-4

MicroShield 4.00 - Serial #4.00-00247
GPUPage : 1
DOS File: AHIGHDEM.M54
Run Date: July 27, 1993
Run Time: 10:42 a.m. Tuesday
Duration: 0:26:07File Ref: *27/7/93*
Date: *27/7/93*
By: *B. Brose*
Checked: *27/7/93*

Case Title: MAKEUP DEMIN AX114 & AX115

GEOMETRY 7 - Cylinder Volume + Side Shields

	centimeters	feet and inches
Dose point coordinate X:	176.34	5.0 9.4
Dose point coordinate Y:	68.58	2.0 3.0
Dose point coordinate Z:	0.0	0.0 .0
Cylinder height:	1.94056	0.0 .8
Cylinder radius:	30.48	1.0 .0
Shield 1:	0.635	0.0 .3
Air Gap:	145.225	4.0 9.2

Source Volume: 5663.79 cm³ .200015 cu ft. 345.625 cu in.MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Cylinder	Transition Shield	Air Gap	Immersion Shield
Air			0.00122	0.00122	0.00122
Carbon	2.239				
Iron	0.2868	7.86			
Uranium	0.0109				
Water	0.4216				

BUILDUP

Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

Quadrature Order

Radial	22
Circumferential	22
Axial (along Z)	22

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ba-137m	2.5200e-001	4.4493e+001	Ce-144	1.7900e-006	3.1604e-004
Co-60	7.9700e-004	1.4072e-001	Cs-134	7.5500e-004	1.3330e-001
Cs-137	2.6700e-001	4.7142e+001	Pr-144	1.7900e-006	3.1604e-004
Pr-144m	2.5500e-008	4.5023e-006	Sb-125	8.9100e-004	1.5732e-001
Sr-90	2.3900e-001	4.2198e+001	Tc-125m	2.0600e-004	3.6371e-002
Y-90	2.3900e-001	4.2198e+001			

***** RESULTS *****

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air No Buildup	With Buildup	No Buildup With Buildup	With Buildup
0.1	1.076e+005	9.647e-004	1.694e-003	1.476e-006	2.591e-006	
0.15	8.989e+004	3.629e-003	7.609e-003	5.975e-006	1.253e-005	
0.2	2.502e+006	1.964e-001	4.472e-001	3.467e-004	7.393e-004	
0.3	1.474e+005	2.376e-002	5.456e-002	4.506e-005	1.035e-004	
0.4	1.032e+007	2.611e+000	5.736e+000	5.088e-003	1.118e-002	
0.5	3.821e+006	1.351e+000	2.805e+000	2.652e-003	5.506e-003	
0.6	8.436e+009	3.896e+003	7.665e+003	7.605e-000	1.496e+001	
0.8	2.630e+007	1.837e+001	3.305e+001	3.493e-002	6.286e-002	
1.0	3.027e+007	2.397e+001	4.871e+001	5.340e-002	8.978e-002	
1.5	3.034e+007	5.067e+001	7.603e+001	8.525e-002	1.279e-001	
2.0	5.126e+002	1.249e-003	1.761e-003	1.932e-006	2.724e-006	
TOTAL:	8.539e+009	3.799e+003	7.832e+003	7.100e+000	1.526e+001	

GRU Nuclear

Calculation Sheet

Subject	AX114 and AX115 Curie Loading	Calc No
		4240-3233-93-015
B. Brose	9/8/93	G. Loddie

Attachment 5-5

MicroShield 4.00 - Serial #4.00-00247

GPU

Page : 1
 DOS File: BLOWDEM1.MS4
 Run Date: September 8, 1993
 Run Time: 5:00 p.m. Wednesday
 Duration: 0:16:54

File Ref: *P118*
 Date: *9/8/93*
 By: *R. Brumley*
 Checked: *9/8/93*

Case Title: MAKEUP DEMIN AX114 & AX115

GEOMETRY 7 - Cylinder Volume + Side Shields

	centimeters	feet and inches	
Dose point coordinate X:	270.97	8.0	10.7
Dose point coordinate Y:	68.58	2.0	3.0
Dose point coordinate Z:	0.0	0.0	0.0
Cylinder height:	17.2212	0.0	6.8
Cylinder radius:	60.96	2.0	0.0
Shield 1:	0.635	0.0	.3
Air Gap:	209.375	6.0	10.4

Source Volume: 201050. cm³ 7.1 cu ft. 12268.8 cu in.

Material	Source	MATERIAL DENSITIES (g/cm ³)			
		Shield	Cylinder	Transition	Air Gap
				Immersion	Shield
Air				0.00122	0.00122
Carbon	0.7463				
Iron	0.0931	7.86			
Uranium	0.0007				
Water	0.1405				

BUILDUP

Method: Buildup Factor Tables
 The material reference is Source

***** CAUTION *****

This buildup reference material is a mixed material with a high atomic number element (91). Buildup factors less than and somewhat greater than 113 keV may be incorrect. Please understand your results!

INTEGRATION PARAMETERS

Quadrature Order

Radial	22
Circumferential	22
Axial (along Z)	22

SOURCE NUCLIDES					
Nuclide	curies	μCi/cm ³	Nuclide	curies	μCi/cm ³
Ba-137m	4.6100e-001	2.2930e+000	Cs-134	1.3500e-003	6.7148e-003
Cs-137	4.8700e-001	2.4223e+000	Sr-90	2.5100e-002	1.2484e-001
T-90	2.5100e-002	1.2484e-001			

***** RESULTS *****

Energy (MeV)	Activity (photons/sec.)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)		
			No Buildup	With Buildup	No Buildup
0.3	1.768e+004	5.282e-004	2.415e-003	1.002e-006	4.582e-006
0.5	7.293e+005	5.063e-002	1.693e-001	9.937e-005	3.323e-004
0.6	1.541e+010	1.434e+003	4.334e+003	2.799e+000	8.459e+000
0.8	4.702e+007	6.925e+000	1.802e+001	1.317e-002	3.428e-002
1.0	1.399e+006	2.937e-001	6.892e-001	5.413e-004	1.270e-003
1.5	1.518e+006	6.021e-001	1.192e+000	1.013e-003	2.006e-003
TOTAL:	1.546e+010	1.442e+003	4.354e+003	2.814e+000	8.496e+000

GPU Nuclear

Calculation Sheet

Subject	Date	Reviewed by	Date
AX114 and AX115 Curie Loading	4/24/0-3213-93-015	G. Lodge	
B. Brossy	9/8/93	B. Brossy	

MicroShield 4.00 - Serial #4.00-00247

Page : 1
 DOS File: BMIDDEMI.MS4
 Run Date: September 8, 1993
 Run Time: 5:17 p.m. Wednesday
 Duration: 0:17:02

File Ref: *4240-3233-93-015*
 Date: *9/8/93*
 By: *G. Lodge*
 Checked: *10/9/93*

Case Title: MAKEUP DEMIN AX114 & AX115

GEOMETRY 7 - Cylinder Volume - Side Shields

		centimeters	feet and inches
Dose point coordinate X:	270.97	8.0	10.7
Dose point coordinate Y:	68.58	2.0	3.0
Dose point coordinate Z:	0.0	0.0	.0
Cylinder height:	17.2212	0.0	6.8
Cylinder radius:	60.96	2.0	.0
Shield 1:	0.635	0.0	.3
Air Gap:	209.375	6.0	10.4

Source Volume: 201050. cm³ 7.1 cu ft. 12268.8 cu in.

Material	Source	MATERIAL DENSITIES (g/cm ³)			
		Shield 1	Transition	Air Gap	Immersion
Air	Shield	Cylinder	Shield	Shield	Shield
Air			0.00122	0.00122	0.00122
Carbon	1.4927				
Iron	0.107	7.86			
Uranium	0.0015				
Water	0.2811				

BUILDUP

Method: Buildup Factor Tables
 The material reference is Source

***** CAUTION *****

This buildup reference material is a mixed material with a high atomic number element (91). Buildup Factors less than and somewhat greater than 113 keV may be incorrect. Please understand your results!

INTEGRATION PARAMETERS		
Quadrature Order		
Radial	22	
Circumferential	22	
Axial (along Z)	22	

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ba-137m	4.6100e-001	2.2930e+000	Cs-134	1.3500e-003	6.7148e-003
Cs-137	4.8700e-001	2.4223e+000	Sr-90	2.5100e-002	1.2484e-001
Y-90	2.5100e-002	1.2484e-001			

***** RESULTS *****

Energy (MeV)	Activity (photons/sec.)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup	With Buildup	No Buildup	With Buildup
0.3	1.768e+004	2.907e-004	1.414e-003	5.514e-007	2.682e-006		
0.5	7.293e+005	2.822e-002	1.009e-001	5.539e-005	1.981e-004		
0.6	1.541e+010	8.042e+002	2.605e+003	1.570e+000	5.084e+000		
0.8	4.702e+007	3.930e+000	1.100e+001	7.475e-003	2.092e-002		
1.0	1.399e+006	1.686e-001	4.264e-001	3.107e-004	7.860e-004		
1.5	1.518e+006	3.546e-001	7.602e-001	5.967e-004	1.279e-003		
TOTAL:	1.546e+010	8.087e+002	2.617e+003	1.578e+000	5.107e+000		

GTJ Nuclear

Submitted by	AX114 and AX115 Curie Loading	Date	Reviewed by
B. Brosky	<i>B. Brosky</i>	9/8/93	G. Lodge

Calculation Sheet

MicroShield 4.00 - Serial #4.00-00247

GPU

Page : 1
 DOS File: BHIGHDEM.M54
 Run Date: September 8, 1993
 Run Time: 4:43 p.m. Wednesday
 Duration: 0:17:06

File Ref: *A/13*
 Date: *1/13/93*
 By:
 Checked: *1/13/93*

Case Title: MAKEUP DEMIN AX114 & AX115

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches
Dose point coordinate X:	270.97	8.0 10.7
Dose point coordinate Y:	68.58	2.0 3.0
Dose point coordinate Z:	0.0	0.0 .0
Cylinder height:	17.2212	0.0 6.8
Cylinder radius:	60.96	2.0 .0
Shield 1:	0.635	0.0 .3
Air Gap:	209.375	6.0 10.4

Source Volume: 201050. cm³ 7.1 cu ft. 12268.8 cu in.

Material	Source	MATERIAL DENSITIES (g/cm ³)			
		Shield 1	Transition	Air Gap	Immersion
	Shield	Cylinder	Shield	Shield	Shield
Air				0.00122	0.00122
Carbon	2.239				
Iron	0.1208	7.86			
Uranium	0.0022				
Water	0.4216				

BUILDUP

Method: Buildup Factor Tables
 The material reference is Source

***** CAUTION *****

This buildup reference material is a mixed material with a high atomic number element (91). Buildup Factors less than and somewhat greater than 113 keV may be incorrect. Please understand your results!

INTEGRATION PARAMETERS

Quadrature Order

Radial	22
Circumferential	22
Axial (along Z)	22

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ba-137m	4.6100e-001	2.2930e+000	Cs-134	1.3500e-003	6.7148e-003
Cs-137	4.8700e-001	2.4223e+000	Sr-90	2.5100e-002	1.2484e-001
Y-90	2.5100e-002	1.2484e-001			

***** RESULTS *****

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup	With Buildup	No Buildup	With Buildup
0.3	1.768e+004	2.003e-004	9.941e-006	3.800e-007	1.886e-006		
0.5	7.293e+005	1.952e-002	7.133e-002	3.832e-005	1.400e-004		
0.6	1.541e+010	5.575e+002	1.846e+003	1.088e+000	3.603e+000		
0.8	4.702e+007	2.735e+000	7.331e+000	5.202e-003	1.490e-002		
1.0	1.399e+006	1.177e-001	3.050e-001	2.170e-004	5.623e-004		
1.5	1.518e+006	2.498e-001	5.496e-001	4.203e-004	9.247e-004		
TOTAL:	1.546e+010	5.606e+002	1.855e+003	1.094e+000	3.619e+000		

GPU Nuclear

Submitted by	Ax114 and Ax115 Curie Loading
Operator	B. Brosey

Calculation Sheet	Date No.	Sheet No.
4240-32133-93-015	3/1	31 of 54

Revised by	G. Loddle
------------	-----------

Date	9/19/93
------	---------

Attachment 6-1

MicroShield Batch Run Log

Batch Run Started on Wednesday, September 8, 1993 at 1:02 p.m.

Six cases initially in the queue.

CASE	FILE	GEOM	START TIME	ELAPSED	mR/hr w/BUILDUP	SENS. CYCLE
=====	=====	=====	=====	=====	=====	=====
1	AHIGHDEM	7	1:02 p.m.	0:26:06	1.526e+001	(n/a)
2	ALOWDEM	7	1:28 p.m.	0:25:06	1.822e+001	(n/a)
3	AMIDDEM	7	1:56 p.m.	0:25:52	1.673e+001	REFERENCE
4	AMIDDEM	7	1:54 p.m.	0:51:11	4.767e+001	1 of 5
5	AMIDDEM	7	1:54 p.m.	1:16:21	3.178e+001	2 of 5
6	AMIDDEM	7	1:54 p.m.	1:41:30	2.185e+001	3 of 5
7	AMIDDEM	7	1:54 p.m.	2:06:42	1.561e+001	4 of 5
8	AMIDDEM	7	1:54 p.m.	2:31:56	1.153e+001	5 of 5
9	BHIGHDEM	7	4:26 p.m.	0:17:06	3.619e+000	(n/a)
10	BLONDEM	7	4:43 p.m.	0:16:54	8.496e+000	(n/a)
11	SMIDDEM	7	5:00 p.m.	0:17:01	5.107e+000	(n/a)

Batch run completed on Wednesday, September 8, 1993 at 5:17 p.m.

TOTAL EXECUTION TIME: 4:15:22

Page : 2
 DOS File: SMIDDEM.MS4
 Run Date: September 9, 1993
 Run Time: 9:17 a.m. Thursday
 Title : MAKEUP DEMIN AX114 & AX115

SENSITIVITY RESULTS For: X (cm)

Case Number	Sensitivity Variable	Energy Fluence Rate (MeV/sq cm/sec)		Exposure Rate In Air (mR/hr)	
	Value	No Buildup	With Buildup	No Buildup	With Buildup
1	304.8	6.057e+002	1.969e+003	1.182e+000	3.843e+000
2	251.46	9.714e+002	3.136e+003	1.896e+000	6.121e+000
3	198.12	1.737e+003	5.587e+003	3.390e+000	1.090e+001
4	144.78	3.607e+003	1.166e+004	7.039e+000	2.276e+001
5	91.44	8.406e+003	2.835e+004	1.640e+001	5.534e+001

Use the Display Menu For Energy Group Results For All Cases.



Calculation Sheet

Case No	Run No	Sheet No
4240-3233-93-015	1	32 of 54
Submitted By	Date	Date
G. Loddle	9/8/93	9/10/93

Attachment 6-2

Microshield 4.00 - Serial #4.00-00247

Page : 1
 DOS File: AMIDOMIN.MS4
 Run Date: July 27, 1993
 Run Time: 3:45 p.m. Tuesday
 Duration: 2:57:58

File Ref: *P175*
 Date: *7/27/93*
 By: *B. Brosey*
 Checked: *P175*

Case Title: MAKEUP DEMIN AX114 & AX115

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches
Dose point coordinate X:	176.34	5.0 9.4
Dose point coordinate Y:	68.58	2.0 3.0
Dose point coordinate Z:	0.0	0.0 .0
Cylinder height:	1.94056	0.0 .8
Cylinder radius:	30.48	1.0 .0
Shield 1:	0.635	0.0 .3
Air Gap:	145.225	4.0 9.2

Source Volume: 5663.79 cm³ .200015 cu ft. 345.625 cu in.MATERIAL DENSITIES (g/cm³)

Material	Source	Shield 1	Transition	Air Gap	Immersion
		Shield	Cylinder	Shield	Shield
Air				0.00122	0.00122
Carbon	1.4927				
Iron	0.2176	7.86			
Uranium	0.0073				
Water	0.2811				

BUILDUP

Method: Buildup Factor Tables
 The material reference is Shield 1

INTEGRATION PARAMETERS

Quadrature Order

Radial	22
Circumferential	22
Axial (along Z)	22

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ba-137m	2.5200e-001	4.4493e+001	Ce-166	1.7900e-006	3.1604e-004
Co-60	7.9700e-004	1.4072e-001	Cs-134	7.5500e-004	1.3330e-001
Cs-137	2.6700e-001	4.7142e+001	Pr-144	1.7900e-006	3.1604e-004
Pr-144m	2.5500e-008	4.5023e-006	Sb-125	8.9100e-004	1.5732e-001
Sr-90	2.3900e-001	4.2198e+001	Tc-125m	2.0600e-004	3.6371e-002
T-90	2.3900e-001	4.2198e+001			

***** RESULTS FOR SENSITIVITY REFERENCE CASE (X = 176.34) *****

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup With Buildup	No Buildup With Buildup
0.1	1.076e+005	1.267e-003	2.196e-003	1.938e-006	3.359e-006
0.15	8.989e+004	4.673e-003	9.486e-003	7.696e-006	1.562e-005
0.2	2.502e+005	2.479e-001	5.369e-001	4.376e-004	9.476e-004
0.3	1.474e+005	2.924e-002	6.274e-002	5.546e-005	1.190e-004
0.4	1.032e+007	3.159e+000	6.444e+000	6.156e-003	1.256e-002
0.5	3.821e+006	1.613e+000	3.106e+000	3.166e-003	6.097e-003
0.6	8.436e+009	4.602e+003	8.405e+003	8.983e+000	1.641e+001
0.8	2.630e+007	2.134e+001	3.578e+001	4.058e-002	6.806e-002
1.0	3.027e+007	3.323e+001	5.234e+001	6.125e-002	9.648e-002
1.5	3.034e+007	5.684e+001	8.079e+001	9.563e-002	1.359e-001
2.0	5.126e+002	1.382e-003	1.858e-003	2.137e-006	2.874e-006
TOTAL:	8.539e+009	4.719e+003	8.584e+003	9.191e+000	1.673e+001

GPU Nuclear

Calculation Sheet

Subject	AX114 and AX115 Curie Loading	Date	4240-3233-93-015	Calc No	33	Sheet No	33 of 54
Originator	<i>B. Brumley</i>	Date	9/8/93	Revised by	<i>G. Loddle</i>	Date	<i>9/8/93</i>

Attachment 6-3

Page : 2
 DOS File: AMIDDMIN.MS4
 Run Date: July 27, 1993
 Run Time: 3:45 p.m. Tuesday
 Title : MAKEUP DEMIN AX114 & AX115

Case Number	Sensitivity Variable	SENSITIVITY RESULTS For: x (cm)			
		Energy Fluence Rate (MeV/sq cm/sec)	No Buildup With Buildup	Exposure Rate In Air (mR/hr)	No Buildup With Buildup
1	91.44	1.382e+004	2.447e+004	2.692e+001	4.767e+001
2	121.92	9.231e+003	1.631e+004	1.798e+001	3.178e+001
3	152.4	6.260e+003	1.122e+004	1.219e+001	2.185e+001
4	182.88	4.384e+003	8.011e+003	8.539e+000	1.561e+001
5	213.36	3.173e+003	5.920e+003	6.179e+000	1.153e+001

Use the Display Menu for Energy Group Results For All Cases.

GRU Nuclear
 Subject: Ax114 and Ax115 Curie Loading
 Case No.: 4240-1233-93-015
 Date Entered By: G. Loddet
 Date: 9/19/93
 Operator: B. Brose
 Signatures: B. Brose, G. Loddet, B. Brose, G. Loddet

Calculation Sheet	
Date:	9/18/93

Attachment 6-4

MicroShield 4.00 - Serial #4.00-00247

Page : 1
 DOS File: BMIDDEMI.MS4
 Run Date: September 8, 1993
 Run Time: 5:17 p.m. Wednesday
 Duration: 0:17:02

GPU File Ref: *10/10/93*
 Date: *9/8/93*
 By: *B. Brosey*
 Checked: *9/8/93*

Case Title: MAKEUP DEMIN AX114 & AX115

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches
Dose point coordinate X:	270.97	8.0 10.7
Dose point coordinate Y:	68.58	2.0 3.0
Dose point coordinate Z:	0.0	0.0 .0
Cylinder height:	17.2212	0.0 6.8
Cylinder radius:	60.96	2.0 .0
Shield 1:	0.635	0.0 .3
Air Gap:	209.375	6.0 10.4

Source Volume: 201050. cm³ 7.1 cu ft. 12268.8 cu in.

Material	Source	MATERIAL DENSITIES (g/cm ³)			
		Shield	Shield 1	Transition	Air Gap
Air	Shield	Cylinder	Shield	Immersion	Shield
Carbon	1.4927		0.00122	0.00122	0.00122
Iron	0.107	7.86			
Uranium	0.0015				
Water	0.2811				

BUILDUP

Method: Buildup Factor Tables
 The material reference is Source

***** CAUTION *****

This buildup reference material is a mixed material with a high atomic number element (91). Buildup Factors less than and somewhat greater than 113 keV may be incorrect. Please understand your results!

INTEGRATION PARAMETERS

Quadrature Order

Radial	22
Circumferential	22
Axial (along Z)	22

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ba-137m	4.6100e-001	2.2930e+000	Cs-134	1.3500e-003	6.148e-003
Cs-137	4.8700e-001	2.4223e+000	Sr-90	2.5100e-002	1.2484e-001
T-90	2.5100e-002	1.2484e-001			

***** RESULTS *****

Energy (MeV)	Activity (photons/sec)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	
			No Buildup	With Buildup
0.3	1.768e+004	2.907e-004	1.414e-003	5.514e-007
0.5	7.293e+005	2.822e-002	1.009e-001	5.539e-005
0.6	1.541e+010	8.042e+002	2.605e+003	1.570e+000
0.8	4.702e+007	3.930e+000	1.100e+001	7.475e-003
1.0	1.399e+006	1.686e-001	4.264e-001	3.107e-004
1.5	1.518e+006	3.546e-001	7.602e-001	5.967e-004
TOTAL:	1.546e+010	8.087e+002	2.617e+003	1.578e+000

CPJ Nuclear

Subject	Calc No	Reviewed by	Date
AX114 and AX115 Curie Loading	4240-3233-93-015	G. Laddie	9/10/93

Subject

AX114 and AX115 Curie Loading

Originator

B. Brosey

Attachment 6-5

Page : 2
 DOS File: BMIDDEMI.MS4
 Run Date: September 9, 1993
 Run Time: 9:17 a.m. Thursday
 Title : MAKEUP DEMIN AX114 & AX115

Case Number	Sensitivity Variable	SENSITIVITY RESULTS For: X (cm)			
		Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup With Buildup	No Buildup With Buildup
1	304.8	6.057e+002	1.969e+003	1.182e+000	3.843e+000
2	251.46	9.714e+002	3.136e+003	1.896e+000	6.121e+000
3	198.12	1.737e+003	5.587e+003	3.390e+000	1.090e+001
4	146.78	3.607e+003	1.166e+004	7.039e+000	2.276e+001
5	91.44	8.406e+003	2.835e+004	1.640e+001	5.534e+001

Use the Display Menu For Energy Group Results for All Cases.

GRU Nuclear

Calculation Sheet

Subject	Calc No.	Rev No.	Sheet No
AX114 and AX115 Curie Loading	4240-3233-93-015	1	36 of 54
Operator	Performed by		Date
B. Brosey	B. Brosey		9/10/93

Attachment 7-1

MicroShield 4.00 - Serial #4.00-00247
GPUPage : 1
DOS File: ADPIPE2.MSA
Run Date: July 27, 1993
Run Time: 2:44 p.m. Tuesday
Duration: 0:25:43File Ref: *7/27/93*
Date: *7/27/93*
By:
Checked: *7/27/93*

Case Title: PIPE AT BASE OF A DEMIN

GEOMETRY 7 - Cylinder Volume - Side Shields

	centimeters	feet and inches
Dose point coordinate X:	176.784	5.0 9.6
Dose point coordinate Y:	60.96	2.0 .0
Dose point coordinate Z:	0.0	0.0 .0
Cylinder height:	22.86	0.0 9.0
Cylinder radius:	3.89636	0.0 1.5
Shield 1:	0.54864	0.0 .2
Air Gap:	172.339	5.0 7.9

Source Volume: 1090.3 cm³ 3.85034e-2 cu ft. 66.5339 cu in.MATERIAL DENSITIES (g/cm³)

Material	Source Shield	Shield 1 Cylinder	Transition Shield	Air Gap	Immersion Shield
Air			0.00122	0.00122	0.00122
Carbon	1.4927				
Iron	0.2176	7.86			
Uranium	0.0073				
Water	0.2811				

BUILDUP

Method: Buildup Factor Tables
The material reference is Shield 1

INTEGRATION PARAMETERS

Quadrature Order

Radial	22
Circumferential	22
Axial (along Z)	22

SOURCE NUCLIDES

Nuclide	curies	µCi/cm ³	Nuclide	curies	µCi/cm ³
Ba-137m	2.5200e-001	2.3113e+002	Ce-144	1.7900e-006	1.6418e-003
Co-60	7.9700e-004	7.3099e-001	Cs-134	7.5500e-004	6.9247e-001
Cs-137	2.6700e-001	2.4489e+002	Pr-144	1.7900e-006	1.6418e-003
Pr-144m	2.5500e-008	2.3388e-005	Sb-125	8.9100e-004	8.1721e-001
Sr-90	2.3900e-001	2.1921e+002	Tc-125m	2.0600e-004	1.8894e-001
T-90	2.3900e-001	2.1921e+002			

RESULTS					
Energy (MeV)	Activity (photons/sec.)	Energy Fluence Rate (MeV/sa cm/sec.)	Exposure Rate In Air (R/hr)		
0.1	1.076e+005	1.573e-003	2.672e-003	2.406e-006	4.088e-006
0.15	8.989e+004	5.112e-003	1.019e-002	8.419e-006	1.679e-005
0.2	2.502e+006	2.635e-001	5.624e-001	4.651e-004	9.927e-004
0.3	1.474e+005	3.060e-002	6.513e-002	5.804e-005	1.236e-004
0.4	1.032e+007	3.292e+000	6.685e+000	6.415e-003	1.303e-002
0.5	3.821e+006	1.578e+000	3.224e+000	3.294e-003	6.328e-003
0.6	8.436e+009	4.784e+003	8.728e+003	9.338e+000	1.704e+001
0.8	2.630e+007	2.217e+001	3.720e+001	4.216e-002	7.075e-002
1.0	3.027e+007	3.452e+001	5.445e+001	6.363e-002	1.004e-001
1.5	3.034e+007	5.909e+001	8.413e+001	9.942e-002	1.416e-001
2.0	5.126e+002	1.438e-003	1.937e-003	2.224e-006	2.996e-006
TOTAL:	5.539e+009	4.905e+003	8.915e+003	9.554e+000	1.737e+001

GPI Nuclear

Subject	AX114 and AX115 Curie Loading	Date	Reviewed by	Sheet No.	Date
Organizer	<i>B. Brosey</i>	9/8/93	G. Laddie	<i>John Laddie</i>	21/10/93

Calculation Sheet

MicroShield 4.00 - Serial #4.00-00247

Page : 1

DOS File: B2INLINE.MS4

Run Date: September 9, 1993

Run Time: 9:45 a.m. Thursday

Duration: 0:11:33

CPU

File Ref:

Date:

By:

Checked:

A
1/2
9/8/93

Case Title: PIPE AT BASE OF B DEMIN

GEOMETRY 7 - Cylinder Volume - Side Shields

		centimeters	feet and inches
Dose point coordinate X:	217.17	7.0	1.5
Dose point coordinate Y:	44.81	1.0	5.6
Dose point coordinate Z:	87.63	2.0	10.5
Cylinder height:	228.6	7.0	6.0
Cylinder radius:	2.62509	0.0	1.0
Shield 1:	0.39116	0.0	.2
Air Gap:	214.15375	7.0	.3

Source Volume: 4948.97 cm³ .174771 cu ft. 302.004 cu in.

Material	Source	MATERIAL DENSITIES (g/cm ³)		
		Shield	Shield 1	Transition
Air	Shield	0.00122	0.00122	
Carbon	1.4927			
Iron	0.0277	7.86		
Uranium	0.0015			
Water	0.2811			

BUILDDUP

Method: Buildup Factor Tables
 The material reference is Source

***** CAUTION *****

This buildup reference material is a mixed material with a high atomic number element (91). Buildup Factors less than and somewhat greater than 113 keV may be incorrect. Please understand your results!

INTEGRATION PARAMETERS

Quadrature Order

Radial	20
Circumferential	20
Axial (along Z)	20

SOURCE NUCLIDES

Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$	Nuclide	curies	$\mu\text{Ci}/\text{cm}^3$
Ba-137m	4.6100e-001	9.3151e+001	Ce-144	0.0000e+000	0.0000e+000
Co-60	0.0000e+000	0.0000e+000	Cs-134	1.3500e-003	2.7278e-001
Cs-137	4.8700e-001	9.8404e+001	Pr-144	0.0000e+000	0.0000e+000
Pr-144m	0.0000e+000	0.0000e+000	Sb-125	0.0000e+000	0.0000e+000
Sr-90	2.5100e-002	5.0718e+000	Te-125m	0.0000e+000	0.0000e+000
T-90	2.5100e-002	5.0718e+000			

***** RESULTS *****


Energy (MeV)	Activity (photons/sec.)	Energy Fluence Rate (MeV/sq cm/sec)	Exposure Rate In Air (mR/hr)	No Buildup	With Buildup	No Buildup	With Buildup
0.3	1.768e+004	2.820e-003	6.725e-003	5.349e-006	1.276e-005		
0.5	7.293e+005	2.297e-001	4.260e-001	4.510e-004	8.363e-004		
0.6	1.541e+004	6.141e+003	1.059e+004	1.199e+001	2.068e+001		
0.8	4.702e+007	2.702e+001	4.203e+001	5.139e-002	7.995e-002		
1.0	1.399e+006	1.063e+000	1.557e+000	1.960e-003	2.870e-003		
1.5	1.518e+006	1.900e+000	2.517e+000	3.197e-003	4.236e-003		
TOTAL:	1.546e+010	6.171e+003	1.064e+004	1.204e+001	2.077e+001		

GRJ Nuclear

Calculation Sheet

Subject	Date	Rev No	Sheet No
A1114 and A1115 Curie Loading	4/20/12/33-93-015	1	38 of 57
Operator	Handed by G. Lodge		9/10/93

"A" DEMIN EXPOSURE RATE PER CURIE

**GRU Nuclear****Calculation Sheet**

Subject:	Avail and Axial Curie loading	Calc No:	4240-3233-93-015	Rev. No:	1	Sheet No:	379 of 54
Original:	B. Brosky	Date:	9/8/93	Reviewed by:	G. Loddie	Date:	9/10/93

Attachment 9-2

```

\Exponential regression
\Correlation statistics:
\correlation coefficient = -0.966758
\mean of x = 5
\mean of y = 25.688
\standard deviation of x = 1.41421
\standard deviation of y = 12.9388
\variance of x = 2
\variance of y = 167.413
\covariance of x and y = -17.69
\Data format: Curve
\Variable format: Non-parametric
\Angular units: Radians
\x=3,7,100,0
\y=133.6 + 0.7012*x
100 2
3 46.061
3.0404 45.4051
3.08081 44.7585
3.12121 44.1212
3.16162 43.4929
3.20202 42.8736
3.24242 42.2631
3.28283 41.6613
3.32323 41.0681
3.36364 40.4833
3.40404 39.9068
3.44444 39.3385
3.48485 38.7784
3.52525 38.2262
3.56566 37.6819
3.60606 37.1453
3.64646 36.6164
3.68687 36.095
3.72727 35.581
3.76768 35.0743
3.80808 34.5749
3.84848 34.0826
3.88889 33.5972
3.92929 33.1188
3.9697 32.6672
4.0101 32.1823
4.05051 31.7241
4.09091 31.2723
4.13131 30.827
4.17172 30.3881
4.21212 29.9554
4.25253 29.5288
4.29293 29.1083
4.33333 28.6938
4.37374 28.2853
4.41414 27.8825
4.45455 27.4855
4.49495 27.0941
4.53535 26.7083
4.57576 26.3279
4.61616 25.953
4.65657 25.5835
4.69697 25.2192
4.73737 24.8601
4.77778 24.5061
4.81818 24.1571
4.85859 23.8131
4.89899 23.4741
4.93939 23.1373
4.9798 22.8103
5.0202 22.4855
5.06061 22.1653

```



Calculation Sheet

Subject	AX111 and AX115 Curie Loading	Calc No	Rev. No	Sheet No
		4240-3233-93-015	1	SC of SY
B. Brosey	9/8/93	G. Laddie		9/8/93

Attachment 9-3


5.10101 21.8497
 5.14141 21.5385
 5.18182 21.2318
 5.22222 20.9295
 5.26263 20.6315
 5.30303 20.3377
 5.34343 20.0481
 5.38384 19.7626
 5.42424 19.4812
 5.46465 19.2038
 5.50505 18.9304
 5.54545 18.6608
 5.58586 18.3951
 5.62626 18.1331
 5.66667 17.8749
 5.70707 17.6204
 5.74747 17.3695
 5.78788 17.1222
 5.82828 16.8783
 5.86869 16.638
 5.90909 16.4011
 5.94949 16.1675
 5.9899 15.9373
 6.0303 15.7104
 6.07071 15.4867
 6.11111 15.2662
 6.15152 15.0488
 6.19192 14.8345
 6.23232 14.6232
 6.27273 14.415
 6.31313 14.2098
 6.35354 14.0074
 6.39394 13.808
 6.43434 13.6113
 6.47475 13.4175
 6.51515 13.2265
 6.55556 13.0381
 6.59596 12.8525
 6.63636 12.6694
 6.67677 12.489
 6.71717 12.3112
 6.75758 12.1359
 6.79798 11.9631
 6.83838 11.7927
 6.87879 11.6248
 6.91919 11.4593
 6.95956 11.2961
 7 11.1353



Calculation Sheet

Subject	AX114 and AX115 Curie Loading	Calc No	Rev No	Sheet No
		4240-1233-93-015	1	Y1 of 54
Originator	B. Brosey	Reviewed by G. Lodge	Date 9/8/93	Date 9/10/93

"B" DEMIN EXPOSURE RATE PER CURIE


GPU Nuclear

 Subject: AX114 and AX115 Curie Loading
 Originator: B. Brossey

Calculation Sheet

Calc. No.	Rev. No.	Sheet No.
4240-1233-93-015	1	1 of 54
Prepared by		Date
G. Loddie		9/10/93
<i>[Signature]</i>		

Attachment 9-5

\Exponential regression
 \Correlation statistics:
 \correlation coefficient = -0.89348
 \mean of x = 6.5
 \mean of y = 19.7928
 \standard deviation of x = 2.47487
 \standard deviation of y = 18.9357
 \variance of x = 6.125
 \variance of y = 358.561
 \covariance of x and y = -41.8716
 \Data format: Curve
 \Variable format: Non-parametric
 \Angular units: Radians
 \x=3,10,100,0
 $y=169.339 + 0.683969 \cdot x$
 100 2
 3 47.7797
 3.07071 46.5135
 3.14161 45.2808
 3.21212 44.0807
 3.28283 42.9125
 3.35354 41.7752
 3.42424 40.6681
 3.49495 39.5903
 3.56566 38.5411
 3.63636 37.5196
 3.70707 36.5253
 3.77778 35.5573
 3.84848 34.6149
 3.91919 33.6976
 3.9899 32.8045
 4.06061 31.9351
 4.13131 31.0888
 4.20202 30.2649
 4.27273 29.4628
 4.34343 28.6819
 4.41414 27.9218
 4.48485 27.1818
 4.55556 26.4614
 4.62626 25.7602
 4.69697 25.0775
 4.76768 24.4129
 4.83838 23.7659
 4.90909 23.136
 4.9798 22.5229
 5.05051 21.926
 5.12121 21.3449
 5.19192 20.7792
 5.26263 20.2285
 5.33333 19.6924
 5.40404 19.1705
 5.47475 18.6624
 5.54545 18.1679
 5.61616 17.6864
 5.68687 17.2176
 5.75758 16.7613
 5.82828 16.3171
 5.89899 15.8847
 5.9697 15.4637
 6.0404 15.0539
 6.11111 14.6549
 6.18182 14.2665
 6.25253 13.8884
 6.32323 13.5204
 6.39394 13.1623
 6.46465 12.8132
 6.53535 12.4737
 6.60606 12.1431

GPU Nuclear**Calculation Sheet**

Subject	Date No.	Rev. No.	Sheet No.
A1114 and A1115 Curie Loading	4210-12/33-93-015	1	43 of 54
Operator B. Brosey	Date 9/18/93	Reviewed by <i>G. Lodd</i>	Date 9/19/93

Attachment 9-6

6.67677 11.8213
 6.74747 11.508
 6.81818 11.203
 6.88889 10.9061
 6.9596 10.617
 7.0303 10.3357
 7.10101 10.0618
 7.17172 9.79509
 7.24242 9.5355
 7.31313 9.28279
 7.38384 9.03678
 7.45455 8.79728
 7.52525 8.56414
 7.59596 8.33717
 7.66667 8.11622
 7.73737 7.90112
 7.80808 7.69172
 7.87879 7.48788
 7.94949 7.28943
 8.0202 7.09625
 8.09091 6.90818
 8.16162 6.7251
 8.23232 6.54687
 8.30303 6.37336
 8.37374 6.20446
 8.44444 6.04002
 8.51515 5.87995
 8.58586 5.72412
 8.65657 5.57242
 8.72727 5.42474
 8.79798 5.28097
 8.86869 5.14101
 8.93939 5.00476
 9.0101 4.87213
 9.08081 4.74301
 9.15152 4.61731
 9.22222 4.49494
 9.29293 4.37581
 9.36364 4.25984
 9.43434 4.14695
 9.50505 4.03705
 9.57576 3.93006
 9.64646 3.8259
 9.71717 3.72451
 9.78788 3.6258
 9.85859 3.52971
 9.92929 3.43616
 10 3.3451

GRU Nuclear**Calculation Sheet**

Subject	AX114 and AX115 Curie Loading		Date No	Sheet No
Operator	B. Brosey	Date	4250-3233-93-015	54 of 54
		9/8/93	G. Laddie	9/10/93

Original	E. E. Miller	Date	9/8/93	C. Lotte	9/10/93
		Revised by		Dose	
Subpage AXI14 and AXI15 Curve		Date	4240-3233-93-015	Rev. No.	1
Loadings		Sheet No.	X-10-SY		

Calculation Sheet

GFD Nuclear


RADIOLOGICAL SURVEY

Survey Information		Instrument Data		Air Sample		File Code Number: AXI15-B4-5-1975G	
Location "B" MAKE-UP DEMINERALIZER ROOM Reason PENE ROBE INTO DEMINER Date 9-28-93 Time 1030 Tech. I.D. 14-1000 Survey Requested ✓ Reviewed by <i>B.E. Miller</i>		Contamination Survey Inst. MT S/N 4337 Cal. Due 10-21-93 Eff. EEF Bkg. Tech.		Radiation Survey Inst. MT S/N 4337 Cal. Due 10-21-93 Cal. Due B.C.F. B.C.F. Tech. 1000-1000 Note: Contact Readings Circled <input type="checkbox"/> Smear Location		Date MT Activity MT Sample # Note: Radiation dose rates in $\mu\text{R/hr}$ are general area, contamination results are dpm/ 100cm^2 unless otherwise noted	
						Smearable Contamination Location B3 & Comments MT	

B.E. Miller SEP 28 1993

ORIGINAL

MJ-K-3B



Remarks: none

GPU Nuclear**Calculation Sheet**Subject AX114 and AX115 Curie
LoadingCalc No.
4240-3233-93-015Rev No
1 Sheet No
46 of 54

Originator

B. Brosey

Date


9/8/93

Reviewed by

G. Lodge

Date

B. Miller 9/10/93

MAKE UP AND PURIFICATION DEMIN. 1A ROOM
FILE CODE NO. AX114PAGE 1 OF 1
DATE 03-12-85
TECHNICIAN B. Miller
SURVEY REQUEST NO. _____

000001

Subject	AX11 and AX115 Curie	Date	9/8/93
Load Date	4280-3233-93-015	Sheet No.	520154
Entered by	<i>E. Brune</i>	Date	9/10/93
GRU Nuclear			

Calculation Sheet


RADIONUCLIDE SURVEY

Survey Information		Instrument Data	
Location	305A or B - Downwind	Inst	Radiation Survey
Reason	Post Elevation	Inst	Telex
Date Surveyed	11/29	S/N	11224
Tech.	3rd	Cal Due	11/29
Survey Required	None	Eff	B.C.F.
Reviewed By	<i>E. Brune</i>	Cal Due	B.C.F.
Notes:			
□ = Contact Readings Circled unless otherwise noted.			



** All Roads 4' Above Floor*


Make Up Demineralizing Room 18



Remarks:

0000045


Survey Information		Instrument Data		Air Sample		File Code Number: AX115 - 4A-85	
: Location	: 305' Make up	: Contamination Survey	: Radiation Survey	: Date	: Time	Smearable Contamination	
: S/N	: Inst	: Inst	: Inst	: Activity	: Time	Comments	
: Reason	: S/N	: S/N	: S/N	: Air Sample No			
: Robot Entry	: Cal.Due	: Cal.Due	: Cal.Due	: Note: Radiation in $\mu\text{R}/\text{hr}$			
: Date of entry Time	: Eff	: Eff	: B.C.F.	: dose rates are general			
: Tech.	: Bkg	: Bkg	: B.C.F.	: area, and contamination			
: Survey Request No.			: Tech Bkg	: results in $\text{dpm}/100 \text{ cm}^2$			
: Reviewed By	: Tech		: Notes:	: Contact Readings Circled unless otherwise noted.			
				: □ = Smear Location			



Make Up Demineralizing Room 1B

▲ R-7 Data questionable due to
Take readings on previous survey being greater by
a factor of Two.

ORIGINAL



Remarks:	
500000	

Subject	Axi14 and Axi15 Curve	Calc No	Row No	Shuttle No	Date	Performed By	B. Brosey	G. Laddie
		4240-3233-93-015	1	Y8 01 57	9/8/93			

Calculation Sheet

GPI Nuclear

GPN Nuclear

B. Brosey E. Sherry
Drae 9/8/93 Rec'd by Date 9/10/93

Surveyor AX114 and AX115 Curve	Curve No.	Rev. No.	Sheet No.	Date 4240-3233-93-015	Rec'd 9/8/93	Q.C. Ladder 8m tall
--------------------------------	-----------	----------	-----------	-----------------------	--------------	---------------------

Calculation Sheet



RADIOLOGICAL SURVEY

Survey Information		Instrument Data		Air Sample		File Code Number: AX114-2A-85	
Location 305 Hwy Make up	Contamination Survey	Inst.	Radiation Survey	Date	Time	Smearable Contamination	Comments
Reason Demol RM 1A	Inst. S/N	Inst. S/N	Inst. S/N	Activity	Activity	Location:	
Robot Entry	Cal.Due	Cal.Due	Cal.Due	Air Sample No.			
Date 08-05-93 Time 1310	Eff.	Eff.	Eff.	Note: Radiation in mr/hr			
Tech. Regular John	Bkg	Bkg	Bkg	Close rates are general			
Survey Request No.	Tech	Tech	Tech	area, and contamination			
Reviewed By abel				Results in dpm/100 cm ²			
				Notes: Contact Readings Circled unless otherwise noted.			
				<input type="checkbox"/> Smear Location			

Make Up Demineralizing Room

20 R-07 Data questionable due to Take Readings on previous survey being greater by A Factor of Two.

ORIGINAL



Remarks:



A Y - 115
Attachment 10-6

Memorandum

Subject: MAKE-UP AND PURIFICATION DEMINERALIZER MU-K-18
AND CUBICLE RADIATION SURVEY

Date: October 21, 1988
1345a

From: B. M. Trachim
Radiological Engineer

Location: TMI-2
9240-88-4745

To: J. E. Tarpinian
Manager, Radiological Engineering, TMI-2

On 9-28-88 a robotic radiation survey of the "B" Make-up and Purification Demineralizer and cubicle was performed using Louie I. The radiation instrument used on the robot was a SAM-II #323 remote readout with a tungsten shielded 180° probe. A response curve was developed to convert K cpm to R/HR on 9-21-88 at the Radiological Controls Instrument Shop using a Cs¹³⁷ source #310. The only problem encountered was the response curve was only plotted out to 800 R/HR.

The highest survey point in the Make-Up Demin cubicle was 947.5 R/HR; this was calculated by extrapolating the response curve (attached). The response curve becomes somewhat linear over 500 R/HR.

After the "A" Make-up and Purification Demin cubicle is surveyed the instrument will be returned to the Radiological Controls Instrument Shop to measure the response beyond 1K R/HR, using the same Cs¹³⁷ #310 source as used in the previous response measurements.

This survey was performed to provide radiological information associated with the resin content in the "B" Make-up and Purification Demineralizer. By our procedures, these results cannot constitute an official documented radiological controls survey.

B. M. Trachim
B. M. Trachim
Radiological Engineer

b1b

Attachment

cc: G. A. Kuehn - Site Operations Director
D. W. Turner - Radiological Controls Director, TMI-2

Calculation Sheet					
Subject	Calc No	Rev No	Sheet No		
Organizer	Reviewed by	Date	Date		
AX114 and AX115 Cubicle Loading	4240-3233-93-015	1	50 of 54		
B. Brossey	<i>R. Brum</i>	9/8/93	<i>S. Miller</i>	9/10/93	




GPU Nuclear**Calculation Sheet**

Subject	AX114 and AX115 Curie Loading	Calc No.	Rev. No.	Sheet No
		4240-3233-93-015	1	51 of 54
Originator	B. Brosey	Date	Reviewed by	Date
	<i>B. Brosey</i>	9/8/93	G. Lodde	<i>SM Liddle</i> 9/10/93

LOCATIONS OF SURVEY POINTS

		CPM	R/HR
1.	Inside MU-K-1B Cubicle Doorway probe face horizontal up	117.2 K	4.1
2.	Inside MU-K-1B Cubicle Doorway probe face verticle forward	439.3 K	18.6
3.	Inside MU-K-1B Cubicle 3' Level probe face verticle forward	791.7 K	42.9
4.	Probe contact with Discharge Line Valve probe face verticle forward	901.0 K	54.7
5.	Probe contact with Discharge Line Reducer probe face verticle forward	1,780.5 K	278.8
6.	Probe contact with Tank Conicle Bottom Weld probe face verticle forward	2,392.0 K	775.7
7.	Probe contact 3" above Tank Conicle Bottom Weld probe face verticle forward	2,547.7 K	947.5
8.	Probe contact 8" above Tank Conicle Bottom Weld probe face verticle forward	2,331.9 K	709.5
9.	Probe contact 2' above Tank Conicle Bottom Weld probe face verticle forward	1,929.8 K	351.1
10.	Probe contact 2'6" above Tank Conicle Bottom Weld probe face verticle forward	1,736.1 K	257.3



MAKE-UP AND PURIFICATION
DEMINERALIZER
MU-K-18 CUBICLE

1/23/93 RAD REV

Calculation Sheet

GRU Nuclear

Subject	Card No.	Date	Revised By
---------	----------	------	------------

Designator	1240 - 100414	52 of 74
------------	---------------	----------

Originator	Date	Revised By	Date
GRU-N	9/8/93	L. Lodge	John Lode

33 Mmm

9/8/93

John Lode

9/8/93

GPU Nuclear

Calculation Sheet


Survey AXI14 and AXI15 Curve	Date 9/8/93	Revered by <i>Jim Will</i>	6. Loader <i>Jim Will</i>
Load Date 4240-323-93-015	Rev. No. 1	Shade No. 53015Y	Date 9/10/93
Originator T. E. Burns			

RADIOLOGICAL SURVEY TM-1 TM-2 DC

GPU Nuclear ORIGINAL

Survey Information		Instrument Data		Air Sample		File Code Number: AXI14-FO-01-1																													
Location MAKE-UP DEMIN "1A" ROOM Reason Positive Reader Date 4-24-90 Time 10:40 Tech. K. BURGESS Reviewed by <i>John</i>		N Contamination Survey Radiation Survey <table border="1"> <tr> <td>Inst. A</td> <td>Inst.</td> <td>Inst. B</td> <td>Inst. C</td> </tr> <tr> <td>S/N</td> <td>S/N</td> <td>S/N</td> <td>S/N</td> </tr> <tr> <td>Cal. Due</td> <td>Cal. Due</td> <td>Cal. Due</td> <td>Cal. Due</td> </tr> <tr> <td>Eff.</td> <td>Eff.</td> <td>B.C.F.</td> <td>B.C.F.</td> </tr> <tr> <td>Bkg.</td> <td>Bkg.</td> <td>Tech. <i>x</i> <i>circle</i></td> <td>Tech. <i>x</i> <i>circle</i></td> </tr> <tr> <td>Tech.</td> <td></td> <td colspan="2">Note: Contact Readings Circled</td> </tr> <tr> <td></td> <td></td> <td colspan="2"><input type="checkbox"/> = Smear Location</td> </tr> </table>		Inst. A	Inst.	Inst. B	Inst. C	S/N	S/N	S/N	S/N	Cal. Due	Cal. Due	Cal. Due	Cal. Due	Eff.	Eff.	B.C.F.	B.C.F.	Bkg.	Bkg.	Tech. <i>x</i> <i>circle</i>	Tech. <i>x</i> <i>circle</i>	Tech.		Note: Contact Readings Circled				<input type="checkbox"/> = Smear Location		Date / / Time / / Activity _____ Sample # _____		Smearable Contamination Location 83 = Comments	
Inst. A	Inst.	Inst. B	Inst. C																																
S/N	S/N	S/N	S/N																																
Cal. Due	Cal. Due	Cal. Due	Cal. Due																																
Eff.	Eff.	B.C.F.	B.C.F.																																
Bkg.	Bkg.	Tech. <i>x</i> <i>circle</i>	Tech. <i>x</i> <i>circle</i>																																
Tech.		Note: Contact Readings Circled																																	
		<input type="checkbox"/> = Smear Location																																	
Note: Radiation dose rates in mr/hr are general area, contamination results are dpm/100cm ² unless otherwise noted.																																			

W. Stoenel
4-24-90



Remarks:
None

D-30

WILLIAMS AND COMPANY, INC.

The House of Metals

DIMENSIONS AND WEIGHTS OF SEAMLESS AND WELDED STEEL PIPE

UPPER FIGURES—Wall Thickness in inches

A. S. A. PIPE SCHEDULES

LOWER FIGURES—Weight Per Foot in Pounds

Pipe Size	30 in inches	5	10	20	30	40	Std.	60	80	EH	100	120	140	160	Double EH
V ₈	.405	.035	.049				.068	.068		.095	.095				
		1383	1863				2447	2447		3145	3145				
V ₄	.540	.049	.065				.088	.088		.119	.119				
		2570	3297				4248	4248		5351	5351				
V ₂	.675	.049	.065				.091	.091		.126	.126				
		3276	4235				5676	5676		7388	7388				
V ₁	.840	.065	.083				.109	.109		.147	.147				.187 .294
		5383	6710				8310	8310		1.088	1.088				1.304 1.714
V _{1/2}	1.050	.065	.083				.113	.113		.154	.154				.218 .308
		6838	8572				1.131	1.131		1.474	1.474				1.937 2.441
1	1.315	.065	.109				.133	.133		.179	.179				.230 .358
		8678	1404				1.679	1.679		2.172	2.172				2.844 3.659
1 ^{1/2}	1.660	.065	.109				.140	.140		.191	.191				.230 .382
		1107	1806				2.273	2.273		2.997	2.997				3.765 5.214
1 ^{3/4}	1.900	.065	.109				.145	.145		.200	.200				.281 .400
		1.274	2.085				2.718	2.718		3.631	3.631				4.859 6.408
2	2.375	.065	.109				.154	.154		.218	.218				.343 .436
		1.604	2.638				3.653	3.653		5.022	5.022				7.444 9.029
2 ^{1/2}	2.875	.083	.120				.203	.203		.276	.276				.375 .552
		2.475	3.531				5.793	5.793		7.661	7.661				10.01 13.70
3	3.500	.083	.120				.216	.216		.300	.300				.437 .600
		3.029	4.332				7.576	7.576		10.25	10.25				14.32 18.58
3 ^{1/2}	4.000	.083	.120				.226	.226		.318	.318				.636
		3.472	4.973				9.109	9.109		12.51	12.51				22.85

4	4.500	.083	.120				.237	.237	.281	.337	.337		.437		.531 .674
		3.915	5.613				10.79	10.79	12.66	14.98	14.98		19.01		22.51 27.54
4 ^{1/2}	5.000							.247			.355				.710
											17.61				32.53
5	5.563	.109	.134				.258	.258		.375	.375		.500		.625 .750
		6.349	7.770				14.62	14.62	20.78	20.78	20.78		27.04		32.96 38.55
6	6.625	.109	.134				.280	.280		.432	.432		.562		.718 .864
		7.385	9.289				18.97	18.97	28.57	28.57	28.57		36.39		45.30 53.16
7	7.625							.301			.500				.875
											38.05				63.08
8	8.625	.109	.148	.250	.277	.322	.322	.406	.500	.500	.593	.718	.812	.906	.875
		9.914	13.40	22.36	24.70	28.55	28.55	35.64	43.39	43.39	50.87	60.93	67.76	74.69	72.42
9	9.625							.342			.500				
											48.72				
10	10.750	.134	.165	.250	.307	.365	.365	.500	.593	.593	.718	.843	1.000	1.125	
		15.19	18.70	28.04	34.24	40.48	40.48	54.74	64.38	54.74	76.93	89.20	104.1	115.7	
11	11.750							.375			.500				
											60.07				
12	12.750	.165	.180	.250	.330	.406	.375	.562	.687	.500	.843	1.000	1.125	1.312	
		22.18	24.20	33.38	43.77	53.53	49.56	73.16	88.51	65.42	107.2	125.5	139.7	160.3	
14	14.000			.250	.312	.375	.437	.375	.593	.750	.500	.937	1.093	1.250	1.406
				36.71	45.68	54.57	63.37	54.57	84.91	106.1	72.09	130.7	150.2	170.2	189.1
16	16.000			.250	.312	.375	.500	.375	.656	.843	.500	1.31	1.218	1.437	1.593
				42.05	52.36	62.58	82.77	62.58	107.5	136.5	82.77	164.8	192.3	223.5	245.1
18	18.000			.250	.312	.375	.562	.375	.750	.937	.500	1.156	1.375	1.562	1.781
				47.39	59.03	82.06	104.8	70.59	138.2	170.8	93.45	208.0	244.1	274.2	308.5
20	20.000			.250	.375	.500	.593	.375	.812	1.031	.500	1.280	1.500	1.750	1.968
				52.73	78.60	104.1	122.9	78.60	166.4	208.9	104.1	236.1	296.4	341.1	379.0
24	24.000			.250	.375	.500	.687	.375	.968	1.218	.500	1.331	1.812	2.062	2.343
				63.41	94.62	140.8	171.2	94.62	238.1	296.4	125.5	367.4	429.4	483.1	541.9

GPI Nuclear Calculation Sheet

Subject	Calc No	Rev No	Sheet No
AX114 and AX115 Curie Loading	4240-3233-93-015	1	54 of 54
Originator	B. Brosey	Date	Reviewed by
	B. Brosey	9/8/93	G. Lodge