



Submerged Demineralizer System Processing of TMI-2 Accident Waste Water

Herbert F. Sanchez Geoffrey J. Quinn

February 1983

Prepared for the U.S. Department of Energy Three Mile Island Operations Office Under DOE Contract No. DE-AC07-76IDO1570



Printed in the United States of America

Available from National Technical Information Service U.S. Department of Commerce 5285 Port Royal Road Springfield, VA 22161 NTIS Price Codes: Printed Copy A04 Microfiche A01

DISCLAIMER

This book was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product or process disclosed, or represents that its use would not infringe privately owned rights. References herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise, does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

DISCLAIMER

Portions of this document may be illegible in electronic image products. Images are produced from the best available original document.

GEND--031

DE83 009223

GEND 031 Distribution Category: UC-78 TMI Supplement

DISCLAIMER

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

SUBMERGED DEMINERALIZER SYSTEM PROCESSING OF TAM'2 ACCIDENT WASTE WATER

Herbert F. Sanchez Geoffrey J. Quinn

Published February 1983

NOTICE PORTIONS OF THIS REPORT ARE ILLEGIBLE."

It has been reproduced from the best available copy to permit the broadest possible availability.

> EG&G Idaho, Inc. Idaho Falls, Idaho 83415

Prepared for the U.S. Department of Energy Three Mile Island Operations Office Under DOE Contract No. DE-AC07-76ID01570

TO MASIER

ABSTRACT

Accident-generated radioactive waste at Three Mile Island Unit 2 includes a variety of high and low specific-activity waste. The high-specific~activity waste, particularly over one million gallons of contaminated water, required special processing and secondary waste handling. General Public Utilities and its contractors, with technical assistance from the U.S. Department of Energy, developed a zeolite-based ion-exchange system called the Submerged Demineralizer System to reduce contamination levels in the water to below allowable limits. Testing and modifications resulted in an operating system that had successfully processed waste water from the Reactor Coolant Bleed Tanks, the Reactor Building Basement, and the Reactor Coolant System as of August 1982. System design objectives were met and decontamination criteria established in 10 CFR 20 were attained.

Additional wastes that could not be handled routinely were generated by another water-processing system, called EPICOR II. EPICOR II wastes are discussed in Appendix A.

Low-specific-activity (LSA) wastes such as that and resin-bed waste canisters are also included in waste handling at Three Mile Island Unit 2. LSA wastes are routinely handled and shipped according to existing industry practice. Plant records are summarized in Appendix B to provide approximate yearly volumes and curie loadings of low-specific-activity wastes being shipped off the Island to a commercial burial site.

ii

ACKNOWLEDGMENTS

The authors gratefully acknowledge the following individuals who provided careful review of technical data and many helpful suggestions on overall organization: S. J. Eichfeld, J. J. Galanto, M. W. Herlihy, C. G. Hitz, T. Lookabill, and T. E. Rekart of GPUNC; and J. H. Flaherty and R. E. Ogle of EG&G Idaho, Inc. They especially wish to thank B. A. Ettinger of EG&G Idaho, Inc. for providing thorough technical editing and for organizing materials for this report.

CONTENTS

.

ł

ABSTRACT	ii
ACKNOWLEDGMENTS	iii
INTRODUCTION	ı
HISTORY OF SUBMERGED DEMINERALIZER SYSTEM DEVELOPMENT	3
Conceptual Design	3
Selection of Ion Exchange Media	4
Testing of Flowsheet at ORNL	5
Increased Cesium Loading Studies	8
SYSTEM DESCRIPTION	9
System Components	9
Feed Filtering System Tank Farm Ion Exchange System Sampling and Monitoring System Monitor Tank System Off-gas and Liquid Separation System	9 11 11 14 16 16
Arrangement of the System in the Spent Fuel Pool	19
Preoperational Tests	19
System Changes	21
SYSTEM OPERATIONS	25
Processing Flowpaths	27
Reactor Coolant Bleed Tank Water Processing Reactor Building Basement Water Processing Reactor Coolant System Water Processing	28 28 31 、
Radiation Protection	31
Radiation Protection Design FeaturesOccupational Dose	33 34

Processing History	35
Contamination Levels Before Processing Vessel Performance and Analysis Sand and Cellulose Filter Analysis	35 37 42
REFERENCES	47
APPENDIX ATMI-2 EPICOR II WASTE MANAGEMENT	49
APPENDIX BLOW SPECIFIC ACTIVITY WASTE	55
APPENDIX C10 CFR 20 CONCENTRATION LIMITS IN WATER ABOVE NATURAL BACKGROUND	59
APPENDIX DSDS VESSEL NOMENCLATURE	63

FIGURES

1.	Original SDS flowsheet showing flowrates	7
2.	Cutaway view of cellulose and sand filter vessels	10
3.	Cutaway view of a SDS ion exchange vessel	12
4.	Sampling locations for monitoring SDS operation and performance	15
5.	Flowpath through the monitoring tank system	17
6.	Off-gas and liquid separation system	18
7.	Arrangement of SDS components in and around the spent fuel pools	20
8.	Functional areas testing sequence for SDS startup	22
9.	Final flowsheet for water processing through the SDS	26
10.	Final flowsheet for RCBT water processing through the SDS	29
11.	Final flowsheet for Reactor Building Basement water processing through the SDS	30
12.	Final flowsheet for RCS water processing through the SDS	32

TABLES

1.	Ratios of Zeolite IE-96 to A-51 in SDS vessels	13
2.	Sample line locations and water streams monitored	14

3.	Composition of contaminated water before SDS processing	36
4.	Solids in one-liter sample of Reactor Building Basement water	38
5.	Volumetric flow through SDS vessels	39
6.	SDS batch processing history	40
7.	Curie loadings on SDS zeolite liners after processing	43
8.	Volumetric flow through sand and cellulose filters	44
9.	Sand filter contents by grain particle size	45
10.	Cellulose and sand filter radioisotope analysis	46

SUBMERGED DEMINERALIZER SYSTEM PROCESSING OF TMI-2 ACCIDENT WASTE WATER

INTRODUCTION

Radioactive waste handling at Three Mile Island Unit 2 (TMI-2) has required adaptation and development of waste processing technology to handle the special wastes generated as a result of the March 28, 1979, acccident at the nuclear plant. This report discusses the accident radioactive waste handling system developed specifically for use at TMI-2.

The report discusses the Submerged Demineralizer System (SDS), developed to process accident-generated water predominantly contaminated with the radionuclides 134,137 Cs and 90 Sr. Commercial nuclear waste processing companies developed the SDS for General Public Utilities, a TMI-2's owner, with technical assistance from U.S. Department of Energy (DOE) national laboratories. The system uses inorganic zeolites to remove radionuclides from the contaminated water and concentrates them in a form suitable for safe shipment and disposition off-site.

Benefits from Submerged Demineralizer System operations at TMI include:

o The development and demonstration of a zeolite-based ion exchange system for removal of radionuclides. Zeolites permit higher specific activity waste loadings--without radiation-induced damage--than do the organic ion exchange resins now used by the commercial light water reactor industry.¹

a. General Public Utilities (GPU) is the parent company of General Public Utilities Nuclear Corporation (GPUNC), formed after SDS operations were well underway at TMI-2. GPUNC now supervises operation of GPU's nuclear facilities at TMI. All references to the operating utility will hereafter use the current name (GPUNC).

- The development and demonstration of safe handling and disposition of highly loaded zeolite bed vessels. The handling, shipping, and disposition of zeolites loaded with large quantities of radionuclides required development of state-of-the-art technology.
- Decontamination of a large quantity of TMI-2 accident wastes to within decontamination criteria set forth in regulation 10 CFR 20. The decontamination of this water represented a significant milestone in the cleanup at the Unit 2 plant.
- The availability of highly loaded zeolite ion exchange media for research and development studies at DOE national laboratories.

This report covers SDS history, development, and operations through August 1982, including processing of the first six batches of Reactor Coolant System water and Reactor Coolant Bleed Tank and Reactor Building Basement water.

Other GEND reports discuss handling and shipping of wastes generated by the EPICOR II system, an earlier radioactive waste processing system installed at TMI-2 after the accident. Appendix A of this report briefly discusses EPICOR II wastes and lists GEND reports on EPICOR II waste management.

This report also contains a table on low specific activity wastes, in Appendix B. These wastes include trash from the Unit 2 cleanup and spent organic ion exchange resins. These low specific activity wastes are being shipped off the island for disposal at a commercial burial site.

HISTORY OF SUBMERGED DEMINERALIZER SYSTEM DEVELOPMENT

As a result of the accident at TMI-2, GPUNC needed to decontaminate accident-generated water while minimizing the amount of waste such decontamination would yield. A demineralizer system based on the use of inorganic zeolites was considered the most promising alternative. The system eventually designed and developed to process accident water is submerged in the TMI-2 spent fuel pool and is called the Submerged Demineralizer System, or SDS.

GPUNC developed the SDS in consultation with the TMI-2 Waste Management Technical Advisory Group (TAG), a group of technical experts assembled by the U.S. Department of Energy (DOE) Technical Integration Office at TMI-2. GPUNC's subcontractors were Chem-Nuclear Systems, Inc. and Allied General Nuclear Services. The U.S. DOE provided technical assistance through the Oak Ridge National Laboratory (ORNL) and Savannah River Laboratory (SRL). These groups combined efforts to design, evaluate, and test the SDS, resulting in successful hot operations at TMI-2.

GPUNC's accident waste management efforts began with processing of water in the Unit 2 Auxiliary Building Basement using a system called EPICOR II. The EPICOR II system was designed to purify medium-specificactivity-level water. By December 1981, EPICOR II generated 50 prefilters and 22 resin liners while removing approximately 55,000 Ci from 565,000 gal of contaminated water in the Auxiliary and Fuel Handling Buildings.² EPICOR II is now used in conjunction with SDS operations as the final polishing unit.

Conceptual Design

GPUNC and the TMI-2 Waste Management TAG determined that the 650,000 gal of high specific activity water in the Reactor Building Basement, and the 90,000 gal in the Reactor Coolant System (RCS) required a demineralizer system besides EPICOR II to reconcentrate radioisotopes released from the core during the accident. The system design requirements were:

- A totally integrated system as independent as possible from existing waste and off-gas systems at TMI
- A system that would remove the fission products in the water to levels meeting release requirements
- A system that would be operable with minimal exposure to operating personnel and pose a negligible risk to the general public
- A system that would accomplish these objectives in a timely and cost effective manner.

Tests and analyses performed by ORNL and SRL showed that these criteria could be met with a zeolite-based system.³ Personnel from both national labs worked with members of the TMI-2 TAG to develop a proposed process flowsheet. Allied General Nuclear Services designed a detailed processing system flowsheet for Chem-Nuclear Systems, Inc. based on the TMI-2 TAG flow-sheet. The resulting system was designed to decontaminate high specific activity water so that the concentrations of nuclides (except tritium) would be less than 10% of the concentrations listed in 10 CFR 20 for aqueous effluents in unrestricted areas. (The 10 CFR 20 concentrations are listed in Appendix C of this report.)

Selection of Ion Exchange Media

To minimize waste product generation, inorganic zeolite media were selected for use instead of the organic ion exchange media used in EPICOR II. Inorganic zeolite is a molecular sieve material highly selective for electrolytic absorption of Cs and Sr from waste water.

There are two main advantages of using zeolites rather than organic resins for ion exchange beds at TMI-2. First, zeolites show good stability to doses of 10^{11} rads and higher,⁴ while organic resins are limited to integrated radiation doses of less than 10^{8} rads before they become

significantly degraded (Reference 1). This stability at high doses is an important criterion in designing a system to absorb high concentrations of radioisotopes.

Second, certain kinds of zeolites have a superior selectivity for both cesium ions (Cs+) and strontium ions (Sr++) when processing water with high sodium ion (Na+) concentrations. Zeolites are hydrated silicates of aluminum and can contain either sodium or calcium or both. The sodium zeolites demonstrate the superior selectivity for Cs+ and Sr++. Na+, like Cs+ and Sr++, is also an ionic species in aqueous solution, and competes actively for absorption sites with Cs+ and Sr++ in either organic resin or calcium zeolite media. Sodium zeolites, by reducing the absorption of Na+, reduce the total number of expended ion exchange vessels. This lowers operation and disposition costs.

To confirm these two advantages, the TAG asked ORNL to recommend which ion exchange media to use to remove the radioisotopes Cs and Sr from the TMI-2 accident-generated water. Of the many zeolites and resins tested by ORNL, the ion exchange media recommended were zeolite Linde Ionsiv IE- 96^{a} (formerly called AW-500) and resin HCR-S (DOWEX- 50^{b}). Both were then used in flowsheet testing at ORNL. Zeolite IE-96 was selected for use in the SDS on the basis of the ORNL flowsheet tests. Later testing showed that mixing IE-96 with another zeolite called A-51 would improve Sr decontamination. This mixture was eventually used in the SDS.

Testing of Flowsheet at ORNL

The SDS flowsheet for decontamination of the water at TMI-2 was evaluated at ORNL in a study that included filtration tests, ion exchange column loading tests, and ion exchange distribution tests.⁵ The tests were performed at 10^{-5} scale on zeolites and organic resins. The tests confirmed that the SDS flowsheet using zeolites would in fact meet the design objectives of decontaminating the water, such that if the effluents would be

a. Trademark of Union Carbide Corporation, Linde Division.

b. Trademark of Dow Chemical Company.

mixed with normal plant discharges the concentrations of nuclides (except tritium) would be less than 10% of the concentrations listed in 10 CFR 20.

The original flowsheet is shown in Figure 1. In this flowsheet, the contaminated water would be filtered before transfer into the ion exchange feed tanks. The filtered water would then be pumped through either or both of two duplicate trains of ion exchange bed vessels. Each train consists of a series of three vessels containing zeolite Ionsiv IE-95 in the Na⁺ form. The effluent from either train of zeolite vessels would then pass through one of two duplicate vessels containing an organic cation exchange resin, Nalcite HCR-S, in the H⁺ form. Finally, the effluent from both cation resin vessels would be combined and passed through a single large polishing vessel containing layers of cation resin (HCR-S, in the H⁺ form), anion resin (Nalcite SBR, in the OH⁻ form), and mixed resin (Nalcite MR-3, a 1:1 volume mixture of HCR-S and SBR).

This original flowsheet provided for a 5-gpm flowrate through the SDS vessels. On the basis of a water residence time in each vessel corresponding to a flow rate of 5 gpm, ORNL determined that each vessel should contain 8 cubic ft of zeolite. Changeout of a zeolite ion exchange vessel was estimated to be required after every 220 to 250 vessel volumes of flow through each vessel. System operating pressure was set between 80 to 100 psig with a design pressure of 150 psig, the maximum pressure the piping could safely withstand.

Laboratory-scale studies of the proposed SDS process recommended possible modifications to the reference SDS flowsheet for potentially improving performance by lowering the expected effluent radionuclide concentrations.⁶ The most promising method for reducing the Cs and Sr concentrations below $10^{-4} \, \mu \, \text{Ci/ml}$ was to hold (age) the zeolite vessel effluent for at least 2 hr at 167°F before passing the effluent through another zeolite column. This would provide time for the colloidal (solid form) radionuclide species in the effluent to dissolve into the soluble ionic form for removal by the zeolite vessel downstream. Another suggested alternative was control of the pH of the water, since pH influences the selectivity of certain radionuclides, particularly that of Sr. As the pH is lowered the colloidal, or



.

.

Figure 1. Original SDS flowsheet showing flowrates.

solid, form of Sr tends to dissolve into aqueous solution. However, after further testing neither the aging process nor pH control proved necessary for overall SDS process efficiency in full-scale operations at TMI.

During testing at ORNL, no improved method was found for removing the anionic contaminants, 125 Sb and 106 Ru. The only satisfactory method for removing these radionuclides would require deionizing the water by removing Na+ on a cation exchange resin prior to sorption of the 125 Sb and 106 Ru on anionic exchange resins. However, such treatment was expected to generate relatively large amounts of low activity level solid waste. This solution would have been costly, and since it would not have added significantly to the system's overall efficiency in removing the trace contaminants 125 Sb and 106 Ru, it was not considered prerequisite for construction and operation of the SDS system at TMI. Sb and Ru are removed effectively by treatment of SDS effluent through EPICOR II.

Increased Cesium Loading Studies

The SDS flowsheet design specification originally limited each zeolite bed to 10,000 Ci of Cs and Sr before vessel changeout would have been required. However, a DOE study (Reference 4), completed before system startup, evaluated the technical and financial benefits of loading each vessel to higher levels of radioactivity. The DOE study concluded that optimum loading for each vessel be 60,000 Ci of Cs and 2,000 Ci of Sr. The DOE study recognized that these liners could technically handle even higher levels of activity, but for reasons including safety and economics, the vessels should be limited to 60,000 Ci of Cs and 2,000 Ci of Sr. The flowsheet modifications appropriate for the new loadings permitted a volumetric throughput of about 1500 vessel volumes before changeout of a vessel was required, as opposed to 220 to 250 vessel volumes permitted in the original flowsheet. The increased loading factor was expected to reduce by a factor of 6 the expected number of vessels required to process the Reactor Building Basement water, and at the same time substantially increase their research and development value to DOE as highly loaded ion exchange media vessels.

SYSTEM DESCRIPTION

GPUNC managed SDS construction and installation with Catalytic Inc., the craft labor subcontractor. Many of the major components of the system were designed by Permutit Inc. and Allied General Nuclear Services, built by Applied Engineering Company at their facilities, and shipped to TMI-2 for installation.

System Components

The SDS consists of the following systems, all of which are located in or around the Unit 2 A and B spent fuel pools.

- Feed filtering system
- Feed tank system, or "tank farm"
- Ion exchange system
- Sampling and monitoring system
- Monitor tank system
- Off-gas and liquid separation and ventilation system.

Each system is briefly described below. A more detailed discussion of system components is available in GPUNC's SDS design description. 7

Feed Filtering System

The feed filtering system includes two filters: a pre- and final filter. As shown in Figure 2, the filter vessels are 24 in. in diameter and 53-1/2 in. high; they have 3/8-in.-thick stainless steel walls. There are two types of filters: cellulose and sand. Cellulose cartridge filters, manufactured by the Cuno Division of AMF, Inc., were used first in the SDS.



Figure 2. Cutaway view of cellulose and sand filter vessels.

ь r

r

,

.

The cellulose prefilter had 125_{-1} mesh while the cellulose final filter had a 10_{-1} mesh. After system functional startup testing, problems with cellulose filters during dewatering prompted a switch to sand bed filters. The cellulose filter cartridges in the prefilter weigh about 18 lb; the final filter cartridges weigh about 40 lb. Sand in each sand filter weighs approximately 900 lb. The filtering system flow rate is nominaly 25 gpm when water flows to the tank farm. When the filtered water flows directly to the ion exchange vessels, the flowrate reflects the SDS process flow rate of 5 gpm.

Tank Farm

The SDS feed tank system, known as the tank farm, consists of four 15,000-gal storage tanks interconnected in parallel with no valves between tanks. The four tanks function as one 60,000-gal storage system. The tanks are primarily used for holding contaminated water after it has been filtered and before it is processed in the SDS ion exchange vessels. Level indicators monitor water levels in the tanks.

Ion Exchange System

The ion exchange system uses six zeolite vessels arranged in two trains. Train One consists of two vessels, one in the 1A and one in the 1B position, and bypass piping (jumpers) in the 1C and Cation A positions. Train Two consists of four vessels in the 2A, 2B, 2C, and Cation B positions. Figure 3 shows a cutaway view of one of these vessels. They are 53-1/2 in. high and 24 in. in diameter with 3/8-in.-thick stainless steel walls. These vessels were designed to withstand 350 psig at 400°F and hydrostatically tested to 540 psig. An empty vessel weighs about 730 lb, which is heavy enough to ensure that a vessel will not float even when empty. When loaded with approximately 300 lb of zeolite and saturated with 420 lb of water, the vessel may weigh up to 1500 lb.

The ion exchange vessels were constructed by three different companies using the same design. (See Appendix D for vessel nomenclature.) Each vessel contains approximately 8 ft³ of a zeolite mixture combining



Figure 3. Cutaway view of a SDS ion exchange vessel.

Linde Ionsiv IE-96 with Linde Ionsiv A-51. IE-96 is an alkali metal alumino-silicate zeolite of the chabazite structure type with the following chemical composition:

$$Na_20 \cdot Al_20_3 \cdot 4Si0_2 \cdot H_20$$
 .

Ion exchange capacity of IE-96 is 2.0-2.5 meq/gm anhydrous. It has a water content of 12 to 17 wt% in the hydrated form.⁸

Linde Ionsiv A-51, a high-aluminic crystalline zeolite, has the following composition:

$$Na_{2}0 \cdot Al_{2}0_{3} \cdot 2Si0_{2} \cdot 4.5H_{2}0_{3}$$

Ion exchange capacity of A-51 is 5.0-5.5 meq/gm anhydrous, and it has a water content of 16 to 20 wt%, hydrated (see Reference 8). The ratio of 1E-96 to A-51 used in each vessel is shown in Table 1. The ratios selected for use in each vessel was based on expected Cs-to-Sr ratios in the influent water. The mixtures were homogeneous.

TABLE 1. A	RATIOS C	DF	ZEOLITE	IE-96	T0	A-51	ΙN	SDS	VESSELS
------------	----------	----	---------	-------	----	------	----	-----	---------

				-
<u>Vessel</u>	Mix Ratio IE-96:A-51	<u>Vessel</u>	Mix Ratio IE-96:A-51	
D10011 D10012	3:2 3:2	D20022 D20026	1:1 1:1	
D10013 D10014	3:2 3:2	D20027 D20028	3:2 3:2	
D10015 D10016	2:1 3:2	D20029 D2003 1	3:2 3:2	
D10017 D10018	3:2 2:1	D20037	1:1	

Leakage Containment. To ensure that leakage from submerged components does not introduce activity from the process streams into the pool water, SDS components are enclosed in secondary containments into which pool water is continuously drawn. Each containment is an underwater cubicle connected to a pump intake manifold which maintains a continuous flow of approximately 10 gpm through openings in each cubicle. This flow prevents water that enters a cubicle from returning to the spent fuel pool. The combined flow from the ten containment cubicles is processed through a separate organic resin ion exchange vessel known as the leakage containment vessel. Following processing in the leakage containment vessel, the containment cubicle flush water returns to the spent fuel pool. The organic resin leakage containment ion exchange vessels are standard vessels, identical in size to the SDS zeolite vessels (see Figure 3).

Sampling and Monitoring System

Samples of the SDS process stream can be taken to monitor performance and estimate curie loadings on ion exchange beds at each step in the process. Figure 4 shows where in the process samples can be taken. Table 2 lists which effluent and influent lines are monitored at each sample location.

The sampling lines are connected to lead-shielded sample glove boxes where intermediate and high level radioactive samples can be taken for evaluating system performance. Sample lines A and C connect to the high radiation level (high rad) filter sample glove box, sample line D to the high rad feed sample glove box, and lines F, G, and H to the intermediate radiation level (intermediate rad) feed sample glove box. Sample line E connects to both the intermediate and high rad feed glove boxes. The high rad feed and filter glove boxes have more lead shielding than the intermediate rad feed glove box and also have remotely operated spigots from which to obtain samples.



* Jumper positions 1C and Cat A could hold zeolite vessels if operators so desired. They are normally not used.

† Sample point E may be sampled from either location subject to activity level expected in sample.

INEL 3 0160

Figure 4. Sampling locations for monitoring SDS operation and performance.

Sample	Effluent	Influent
Location	Monitored	Monitored
A C D E F G H	Filter units Tank farm 1A or 2A 1B or 2B 1C or 2C Cat A or Cat B	Filter units Tank farm 1A or 2A 1B or 2B 1C or 2C Cat A or Cat B Monitor tanks

TABLE 2. SAMPLE LINE LOCATIONS AND WATER STREAMS MONITORED

Samples may also be taken at the Leakage Containment Pump and the Monitor Tank Pump Area. These locations are not part of the process stream and thus do not require special sample boxes to protect personnel from high level radiation. In addition to liquid sampling, in-line radiation detectors are available to monitor SDS processing.

Monitor Tank System

The monitor tanks are two 12,000-gal stainless steel storage vessels located in the Fuel Handling Building Model Room on the 305-ft elevation. The vessels are 8 ft in diameter and 32 ft high. The monitor tank system holds processed water until it is either transferred back to SDS for reprocessing or sent on to EPICOR II for polishing and eventual storage in the processed water storage tanks on the island. See Figure 5 for a schematic of water flow through the monitor tanks.

Off-gas and Liquid Separation System

An off-gas and liquid separation system collects gaseous and vaporous wastes resulting from SDS operation. The off-gas system is illustrated in Figure 6. A centrifugal blower rated at 1000 ft^3 /min moves air through the system. Moisture condensed from the off-gas and liquid separation system is returned via the separator tank to the SDS tank farm for processing. The separator tank is located in the surge pit and is covered with a concrete and lead shield.



INEL 3 0155

Figure 5. Flowpath through the monitoring tank system.



Figure 6. Off-gas and liquid separation system.

Arrangement of the System in the Spent Fuel Pool

Figure 7 illustrates the arrangement of the SDS in the spent fuel pool as viewed from above. The tank farm is located at the south end of the fuel handling building in the A spent fuel pool and is covered with concrete slabs. The filters and zeolite ion exchange vessels are located under water in leakage containment cubicles in the B spent fuel pool. These cubicles and the exchangers rest on the pool floor and are supported along one side of the pool by a structural steel rack. The racks support the system and also provide an operating platform from which the connections to the vessels can be made remotely. The off-gas system is mounted on the curb near the surge pit area.

The dewatering station is an underwater platform in the B spent fuel pool cask pit and is used for removing water from expended zeolite vessels and filters by blowing nitrogen through the vessels. Dewatered vessels are then placed in an underwater storage rack that is designed to handle 60 expended vessels. This storage capacity allows SDS processing to continue without interruption until the expended vessels can be shipped from TMI-2. Stored vessels are vented through a common header connected to the off-gas and liquid separation system. This arrangement allows continual venting of gas generated in the vessels during storage.

Preoperational Tests

System testing before SDS operations began involved construction and functional tests. Construction tests determined if each system component performed as designed under normal operating conditions. These tests included checks of the system's integrity at piping interfaces and weld joints and also provided electrical continuity and component operability checks for major system components such as pumps and valves.

Functional tests were conducted once the construction tests were complete. A testing sequence was established by dividing the SDS into five



Figure 7. Arrangement of SDS components in and around the spent fuel pools.

.

,

· ·

functional areas outlined in Figure 8. Pretests measured the performance of a portion of each functional area before major functional testing started. The functional areas were as follows:

- The off-gas system
- The ion exchange process flow system
- The monitor tank system
- The leakage containment system
- The dewatering system.

Each major functional area was tested both before and after the fuel pool was filled and the system was submerged. Hold points were established to provide adequate review before the pool was filled to ensure that prefill testing had been satisfactorily completed.

System Changes

As a result of preoperational testing and early system operations, several system changes were incorporated. The following paragraphs describe these modifications and the problems which gave rise to them.

One system sampling line (line E, see Figure 4), monitoring the effluent of the first ion exchange bed, could possibly obtain samples that exceeded the personnel shielding capabilities of the intermediate rad feed sample glove box to which it was connected. (This possibility existed because the first bed is most likely to become expended and permit high activity waste to pass through it.) To preclude this potential problem and protect personnel in accordance with dose reduction considerations, GPUNC modified the sampling stream so that samples could be taken from a high rad feed sample glove box.



Figure 8. Functional areas testing sequence for SDS startup.

.

.

A change was made in the procedure for controlling contamination of the monitor tanks caused by small particles of zeolites called fines. Initially, a postfilter was installed in the system between the zeolite beds and the postprocessing monitor tanks. This $3-\mu$ filter was installed to prevent zeolite fines released from new zeolite beds from excessively contaminating the monitor tanks each time a new bed was installed. However, after start of hot operations, these fines were still passing the filter in significant quantities. The new procedure addressing this problem requires flushing approximately 1000 gal of demineralized water through each new zeolite vessel. The vessel is then installed into the SDS and a second batch of 1000 gal is flushed through and discharged to the B Reactor Coolant Bleed Tank, to be processed at a later date. This flushing continues until sampling confirms that zeolite fines are no longer being released from the new zeolite bed. At this point, water passing through the system returns to the normal flow course.

The original flowsheet recommended that both a cation exchanger and a polishing unit be part of the SDS. The cation exchanger's primary function was to remove any residual strontium from the zeolite bed effluents. However, tests showed that the resin cation beds (HCR-S, H+ form) readily absorb sodium ions from the contaminated water, competing directly with the strontium for exchange sites on the cationic bed. Due to the high level of sodium in the process water, the cation exchange beds were expected to become spent too quickly and would have required frequent replacement. As a result, the cation vessel was replaced by a fourth zeolite bed vessel.

The polishing unit, also recommended in the original flowsheet, was never installed. The unit would have required changeout after every 25,000 gal of water, a frequency which greatly interrupted the efficiency of the overall system. Frequent changeouts also affected personnel exposures and raised safety concerns. Installation and design engineers solved the problem by deciding to use the EPICOR II system, which was already in place. This system could not only accomplish what the polishing unit was designed to do, but could also remove the 125 Sb and 106 Ru not readily absorbable in the SDS zeolite beds. Any effluent requiring polishing was processed through the EPICOR II system.

The filters through which the water passes before being processed in the SDS zeolite beds were originally cellulose filters. During the dewatering process, the contaminants trapped in the cellulose filters could potentially be released out of the filters. For this reason it was decided to change from cellulose to sand filters. Sand was chosen as a substitute due to its availability and lower cost, and to the fact that it did not have the same potential radionuclide release problem in dewatering as did the cellulose filters.

SYSTEM OPERATIONS

The SDS was designed to process the Reactor Building Basement and Reactor Coolant System (RCS) water. It was also used to process contaminated water from the Reactor Coolant Bleed Tanks (RCBT). In conjunction with the SDS, the EPICOR II system provides final polishing for removal of trace quantities of radionuclides. Figure 9 shows the final flowsheet for the SDS process. The contaminated water passes through a pre- and final sand filter to remove particulates. Filtered water is then pumped to the ion exchange system where it is processed through a train of inorganic zeolite vessels.

The SDS ion exchange vessels are arranged in two parallel trains, with two vessels in Train One and four vessels in Train Two. Train One is reserved for RCBT and RCS water processing. Train Two is used solely for Reactor Building Basement water processing.

Once the water has passed through the ion exchange media, it travels through the postfilter and on to monitoring tanks. Water samples taken from these tanks help determine if the water needs to be returned to the SDS to be reprocessed, sent on to the EPICOR II system for final polishing, or transferred elsewhere (e.g., returned to the Bleed Tanks for storage).

Influent and effluent sample analysis and continuous in-line radiation monitoring are used to estimate curie loadings on each zeolite vessel. Actual curie loading of each vessel is controlled by feed batch size and residence time. Sample connections on the influent and effluent lines of the two filtration vessels and on the influent and effluent lines to each zeolite ion exchange bed monitor SDS efficiency and provide parameters for process control.

Samples are taken to determine radionuclide concentrations before and after each stage in the process and to determine if radionuclide breakthrough has occurred. "Breakthrough" occurs when the zeolites are spent and can no longer remove a particular radionuclide. When breakthrough occurs or when the desired curie loading is achieved on the first bed of a train,



Figure 9. Final flowsheet for water processing through the SDS.

.

the feed flow to the train stops, and the bed is disconnected and moved to the dewatering station and then to the storage rack in the spent fuel pool using the Fuel Handling Building crane. Downstream vessels are also disconnected and moved upstream one position. A new ion exchange vessel is then installed in the empty position as the replacement vessel. Following installation and flushing of the new ion exchange vessel, the treatment of the contaminated water recommences. This operational concept of rearranging the vessels instead of using a valving system maintains the same flowpath and eliminates the potential for valving errors. Installing a new vessel at the end of the line also minimizes the possibility of an unexpected radionuclide breakthrough, which could possibly recontaminate water already processed.

The spent SDS ion exchangers and filters remain underwater in the spent fuel pool until they are shipped. Spent ion exchange and filter vessels are loaded into a shielded transportation cask underwater and then are removed from the spent fuel pool in the cask. Once the transportation cask is sealed and decontaminated, it is loaded onto a trailer for shipment. Some of the SDS zeolite vessels will be sent to a DOE national laboratory for disposition research and development.

Processing Flowpaths

The SDS had processed water from three sources as of August 31, 1982, totaling about 1,200,000 gal, and removing approximately 650,000 Ci. Water from each source followed process flow paths which will be discussed below.

All operations consisted of pumping a batch of liquid waste from the source, processing it through the SDS, and then transferring it to a receiving location. A processing batch is defined as the continuous processing of a staged amount of water through specific zeolite beds. If, during processing, a vessel requires changeout, the flow is stopped for that batch and the vessel changeout occurs. A new batch number is assigned when processing resumes. Labelling batches in this way permits accurate record keeping for water decontamination analysis and vessel curie loading.
Reactor Coolant Bleed Tank Water Processing

Contaminated water deposited during the accident in the RCBTs followed the flowpath shown in Figure 10 as it went through the SDS. RCBT water flowed through the prefilter and final filter to the tank farm where the water was held until it was ready to be processed. A process batch contained anywhere from 5,000 to 44,000 gal depending on processing conditions.

RCBT accident water held in the tank farm was processed through Train One containing only two ion exchange vessels. RCBT water was not as highly contaminated as Basement water and did not need to pass through four ion exchange beds in order to be decontaminated.

After passing through Train One, RCBT water went to the monitor tanks where it was either recycled to SDS for reprocessing or sent to the EPICOR II polishing demineralizers. Sampling points A, C, D, E, and F were monitored during RCBT processing (see Figure 4). Both points C and D were monitored because the filtered water was held at the tank farm, which is between these two sample points, before it went through Train One of the SDS.

Reactor Building Basement Water Processing

Contaminated Basement water flowed from the Reactor Building Basement to the tank farm and was held there as was done with the original RCBT water. Its flowpath is drawn in Figure 11. Samples were obtained from points A and C as the Basement water flowed to the tank farm. After approximately 50,000 gal were secured in the tank farm storage system, ion exchange processing commenced through the four ion exchange vessels in Train Two. Basement water had higher activity than did the RCBT water and had to meet stricter decontamination requirements because it was to leave the Reactor Building for storage. Therefore, more ion exchange steps were required for processing the basement water.



Figure 10. Final flowsheet for RCBT water processing through the SDS.



Figure 11. Final flowsheet for Reactor Building Basement water processing through the SDS.

Since four ion exchange vesssels were used (vessel positions 2A through 2C plus position Cation B), additional sampling locations were also needed. Sampling from locations D, E, F, G, and H monitored effluent conditions. Sample results were evaluated to determine water quality and vessel curie loading.

Once the batch water was processed it was held in the monitor tank and was then either recycled or batched through the EPICOR II polishing resin beds. After EPICOR II polishing, the water was stored in the processed water storage tanks at TMI-2.

Reactor Coolant System Water Processing

RCS water processing began after processing of accident-generated basement water was complete. RCS processing uses a "feed and bleed" method: as each 50,000-gal batch of water is removed or "bled" from the RCS for processing, 50,000 gal of processed RCS water feeds back into the RCS. This feed and bleed method keeps the RCS full and ensures that the reactor core remains covered.

The RCS processing flow path is shown in Figure 12. The RCS water is let down from the Reactor Coolant System into RCBT C. The water then passes through the filtration system, bypasses the tank farm, and is processed immediately by the Train One ion exchangers. Unlike RCBT and Basement water, RCS water undergoes no holding sequences at the tank farm. Samples for the RCS processing are obtained from locations A, C, E, and F. Since the water is not held in the tank farm, location D is not monitored. (Samples C and D are essentially the same when the tank farm is bypassed.) The effluent from Train One then goes through the postfilter and on to RCBT A where it is held to be fed back into the RCS "feed and bleed" process.

Radiation Protection

The SDS was specifically designed to limit operating personnel exposure levels to as low as reasonably achievable (ALARA). The components containing high activity level water were either provided with additional shielding



Figure 12. Final flowsheet for RCS water processing through the SDS.

.

.

.

or submerged in the spent fuel pool. Shielding was designed to limit whole body exposure rates in operating areas to approximately 1 mR/hr. In addition, gaseous exhaust from components carrying high activity level water was routed to the SDS off-gas system. Component shielding and off-gas treatment minimized the potential for high exposure levels and airborne releases in the work areas.

Radiation Protection Design Features

The SDS has inherent features for reduction of occupational exposures and environmental releases. The SDS is submerged in the spent fuel pool for several reasons: (a) to provide shielding during operation, (b) to permit access to the system during vessel changeout, (c) to minimize the potential hazard from possible accidents, (d) to use an existing Seismic Category I facility, and (e) to provide temporary shielded storage for the used vessels.

The Fuel Handling Building, which houses the entire SDS, is a Seismic Category I structure with air handling and ventilation systems designed to mitigate the consequences of radiological accidents. The SDS ion exchange vessels are under approximately 16 ft of water in the TMI-2 B spent fuel pool. Where necessary for personnel protection, lead or equivalent shielding is provided for pipes, valves, and vessels not located underwater. Operating panels and instrumentation racks are located away from potential sources of radiation or are provided with adequate shielding to meet radiological exposure limits. The entire process is designed with appropriate pressure indicators and with remotely operated, valved, quick-release couplings for inlet, outlet, and vent line connections. Effluent from the offgas system, the system which filters gases generated in the SDS process, is filtered and monitored before it passes into the existing ventilation exhaust systems.

The SDS is equipped with various alarm systems (Reference 7), which warn operators of potentially hazardous conditions during normal operations or maintenance activities. The SDS is also equipped with four automatic shutdown alarms:

- Off-gas header influent high pressure monitor
- Ion exchange manifold general area radiation monitor
- Ion exchange manifold effluent in-line radiation monitor
- Leakage containment system influent radiation monitor.

Each of these automatic shutdown alarms can trip the Feed Isolation Valve Solenoid, which stops the water flow through the SDS, either instanteously or after a predetemined 5-to-30-minute time delay. Instantaneous closure is affected by placing the "Auto-trip" selector switch in the "Trip" position. Otherwise the Solenoid deenergizes and closes within 5 to 30 min as preset.

The SDS is designed with the primary ion exchange beds in series to preclude breakthrough and contamination of the outlet stream. Should a leak in the system occur inspite of design safety features, SDS equipment is operated within containment cubicles to prevent contamination of the spent fuel pool water.

The SDS vessels are transported out of the fuel pool in shielded transfer casks. These casks are designed to reduce radiation levels to less than 200 mR/hr on contact, in accordance with the shipping criteria found in 173.393 Title 49 of the Code of Federal Regulations.

Occupational Dose

Some SDS operations involved personnel occupational dose exposures. Major operational activities involving such exposures were as follows:

- Feed tank filling valve alignment
- Sampling operations
- System start-up valve alignment

- Spent vessel changeout
- Cask removal, decontamination, and survey operations
- System maintenance
- Vessel dewatering.

Precautions were taken to minimize these personnel exposures. Personnel shields were tested before water from each source was processed. Test results were well within design criteria. The area readings were generally well below 0.5 mR/hr, with an estimated average dose of 0.1 to 0.2 mR/hr. When certain identified hot spots reached between 2 to 5 mR/hr access was restricted or the areas were shielded accordingly.

Processing History

As of August 31, 1982, over one million gals of contaminated water had been processed by SDS from the RCBT, the Reactor Building Basement, and the RCS. During this processing, overall system performance met the design objective of SDS, and also decontaminated the waste water to within the limits specified in 10 CFR 20 (with the exception of limits for tritium, since the SDS could not remove tritium from the water). The composition of the contaminated water and performance of SDS in treating this water are discussed in the following section.

Contamination Levels Before Processing

Table 3 lists the concentrations and total amounts of the significant radioisotopes in the RCS and Reactor Building Basement water before SDS processing. These amounts were used in developing the original SDS processing flowsheet. The values in the table for the RCS water are composites of analytical data from several samples analyzed by ORNL. The values for the Basement water were obtained from analyzing the samples that ORNL used in the flowsheet evaluation.

System Nuclide	Reactor ^a Coolant System (µCi/mL)	Reactor ^b Building Basement <u>(μCi/mL)</u>
3 _H	0.17	1.0
89 _{Sr}	5C	0.53
90 _{Sr}	25 ^C	2.3
106 _{Ru}	0.1	0.002
125 _{Sb}	0.01	0.02
134 _{Cs}	10	26
137 _{Cs}	57	160
¹⁴⁴ Ce	0.03	0.0005
	97.31	189.8525

TABLE 3. COMPOSITION OF CONTAMINATED WATER BEFORE SDS PROCESSING (Values are corrected for radioactive decay to July 1, 1980)

a. Reactor Coolant System water volume is approximately 90,000 gal.

b. Reactor Building Basement water volume is approximately 650,000 gal.

c. Values vary, probably because of precipitation.

The two most predominant radionulide contaminants were 137 Cesium (half-life = 30.2 yrs) and 90 Sr (half-life = 29.0 yrs). Both the RCS and Reactor Building waters contain sodium borate and boric acid with a pH of 8.2 in the RCS water and 8.6 in the Basement water. An additional contaminant is tritium (half-life = 12.3 yrs). This heavy isotope of hydrogen was present as tritiated water in minute concentrations after processing, which nevertheless exceeded 10 CFR 20 concentrations. The tritium was not removed by the SDS ion exchange process. It remains in the processed water stored on-site in the processed water storage tanks.

A significant concentration of insoluble strontium was found in samples of water taken from near the Reactor Building Basement floor. In a oneliter sample, the concentration of solids in the slurry (liquid plus solids) was approximately 0.5 vol%, as determined by centrifuging the slurry. However, both the amount and nature of the solid material in the slurry sample cannot be extrapolated to be representative of all solids in the water since the sample could be taken from only one location.

The key chemical and radiochemical constitutents in the solids from the basement sample are listed in Table 4, along with the calculated percentage of each element and nuclide in the total sample (liquid plus solid) that was insoluble. Although Sr was the predominant radionuclide in the solids, 92% of the Sr in the total sample was in the liquid phase. Essentially all of the Cs was in the liquid phase. Thus, even if these solids were dissolved during the decontamination process, the total amount of radioactive materials in the water would not have increased significantly. The majority of the radionuclide contaminate sources were found as solute and required ion exchange methods for effective removal.

Vessel Performance and Analysis

SDS processing commenced July 12, 1981. As of August 1982, the SDS had processed 296,470 gal of RCBT water, 655,165 gal of Basement water, and 249,852 gal of RCS water, removing a total of approximately 650,000 Ci (on island analysis) from 1,201,487 gal of processed water. Table 5 provides the processed volume flow through each SDS vessel. Vessel D10011, for instance, processed a total of 229,782 gal of water before it was taken off line.

Table 6 provides a processing history by SDS batch. This is a more detailed processing history which includes results of water sample analyses for influent and effluent, decontamination factors (DF), service dates, and vessel identification numbers and processing positions during the batch. As an example, batch 5, which commenced 9/22/81, processed a total of 15,559 gal of Basement water through Train Two. Prefilter and final filter

	Element Analysis			Nuclide Analysis	
<u>Element</u> Copper Nickel Aluminum	Concentration (g/mL solids ^a) 7500 2500 1450	Percent Insoluble ^b 99 <u>></u> 98 88	Nuclide 90Sr 89Sr 137cs	Concentration (<u>uCi/mL solids a,c)</u> 38 8.7 4.7	Percent _b Insoluble 8 8 0.04
Iron Silicon Calcium	850 650 450	81 10 7	125 _{Sb} 144 _{Ce} 134 _{Cs}	1.5 1.4 0.82	28 93 9.04
Zinc Chlorine Magnesium	400 400 150	>87 10 10	106 _{Ru} 95 _{Nb} 60 _{Co}	0.76 0.14 0.073	66 97 88
Manganese Phosphorus Chromium	90 30 25	<u>>69</u> 20 12	⁵⁸ Co 103 _{Ru}	0.020 0.010	88 66
Potassium Cobalt Barium	15 3.5 2.5	1 ≥8 ≥11			
Strontium Cesium	2.5 0.5	<u>≥11</u> 0.04			

TABLE 4. SOLIDS IN ONE-LITER SAMPLE OF REACTOR BUILDING BASEMENT WATER

a. Based on volume of solids after centrifugation.

b. Percentage of element or nuclide in the total sample (liquid plus solid) that is insoluble. The Calculations are based on a total solids content of 0.5 vol in the centrifuged sample.

c. Concentration on July 1, 1980.

. .

Vessel	Water Types	Batch Number Processed	Volumes Processed (gal)
D10011	Basement	7,11	229,782 ^a
D10012	RCBT, Basement	4,9	208,512 ^a
D10013	RCBT, Basement	4,11 14,16	406,008 ^a
D10014	Basement, RCS	14,22 33,34	371,583
D10015	RCBT	1,3,12	190,518 ^a
D10016	RCBT, Basement	4,11 14,22	616,037ª
D10017	RCBT, Basement	5,6	60,870ª
D10018	RCBT, Basement	1,3,12,13 22,33	287,743
D20022	RCS	34	18,945
D20023	Basement	23	20,120
D20026	Basement, RCBT, RCS	13,23 33,34	116,170
D20027	Basement, RCBT, RCS	17,22,24 26,28,30	389,455 ^a
D20028	Basement	10,11,14,19	297,034 a
D20029	Basement, RCBT	20,24 26,28,30,32	409,373
D20031	RCS	31,32	99,336

TABLE 5. VOLUMETRIC FLOW THROUGH SDS VESSELS

a. Vessel removed from service, as of August 1982.

		Process						Vessel P	osition			Influen	t Samples	(µCı/m1)	Ffflue	nt Sampl	es (10 ⁻	³ μ(1/ml)
Batch <u>Number</u>	Date	Flow (gal)	Water Type	Prefilter	Final Filter	<u> 1a </u>	18	2A	28	20	Cat B	Sr	Cs	Total	<u>Sr</u>	Cs	Total	DF
1 2	6/30-7/19 7/2 ⁹ -7/31	49,451 48,519	RCBT RCBT	F 10002 F 10002	F20001 F20001	D10015 D10015	D10018 D10018					0.86 0.94	$1.85 \\ 1.84$	2.71 2.78	9.06 3.45	6.10 9.810	15.16 13.26	178 209
3 4	9/1-3/9 9/7-9/7	49,301 5,521	RCBT RCBT	F 10002 D00005	F20001 D00007	D10015	D10018	D10017	D10012	D10013	D10016	0.44 0.18	0.60 0.47	1.04 0.65	7.06 11.51	8.180 1.220	15.24 12.72	57 51
5 6	9/22-9/25 9/26-10/4	15,559 45,311	Basement Basement	F10001 F10001	D00007 D00007			D10017 D10017	D10012 D10012	D10013 D10013	D10016 D10016	3.23 3.78	91.00 112.07	94.23 115.85	15.00 12.60	0.952 0.870	15.95 13.50	5,908 8,581
7 8	10/4~10/18 10/18-10/31	50,168 44,237	Basement Basement	F10001 F10001	D00007 D00007			D10012 D10012	D10011 D10011	D10013 D10013	D10016 D10016	3.91 4.19	112.58 114.05	116.48 118.24	15.60 8.71	1.036 0.683	16.70 9.39	6,975 12,592
9	10/31-11/9	7,070	RCBT	F10001	D00007			D10012	D10011	D10013	D10016	2.85	86.13	88.98	7.36	0.844	8.21	10,838
10	11/10-11/19	40,646 44,213	Basement Basement	F10001	000007			D10011	D10013	D20028	D10016	5.13	116.79	171.91	8.76	0.927	9.70	12,568
11 12	11/20-11/28 11/28-12/9	43,448 43,247	Basement RCBT	F10001 F10001	D00007 D00007	D10015	D10018	D10011	D10013	D20028	D10016	4.69 0.92	111.20 20.70	115.89 21.62	9.17 22.50	0.790 0.362	9.96 26.12	11,635 828
13 14	12/9-12/18 12/19-12/27	44,331 44,699	RCBT Basement	F10001 D00002	D00007 D00009	D10018	D20026	D10013	D20028	D10016	D10014	0.59 2.66	6.23 90.24	6.83 92.89	20.94 8.33	0.576 1.414	26.70 9.74	2,256 9,537
15 16	12/28-1/4 1/6-1/10	43,269 21,867	Basement Basement	D00002 D00002	D00009 D00009			D10013 D10013	D20028 D20028	D10016 D10016	D10014 D10014	2.96 2.49	101.39 84.25	104.35 86.74	7.65 7.38	0.917 1.037	8,56 8,42	12,190 10,302
17 18	1/10-1/29 1/30-2/6	44,764 43,789	Basement Basement	D00002	D00009 D00009			D20028 D20028	D10016 D10016	D10014 D10014	D20027 D20027	3.02 4.18	103.24 122.18	106.27 126.37	7.57 6.68	0.986 0.681	8.55 7.36	12,429 17,170
19 20	2/7-2/9 2/10-2/16	10,935 33,498	Basement Basement	D00002 D00002	D00009 D00009	-		D20028 D10016	D10016 D10014	D10014 D20027	D20027 D20029	4.80 4.36	127.00 117.40	131.80 121.76	6.38 6.15	0.604 0.788	6.98 6.94	18,883 17,545
21 22	2/17-2/27 2/27-3/5	43,844 33,149	Basement Basement	000002 000002	D00009 D00009			D10016 D10016	D10014 D10014	D20027 D20027	D20029 D20029	4.43 4.71	128.83 135.70	133.27 140.41	5.97 5.67	0.727 0.596	6.69 6.27	19,921 22,394

. .

TABLE 6. SDS BATCH PROCESSING HISTORY (AS OF 8/31/82)

• •

TABLE 6. (Continued)

.

•

		Process						Vessel (Position			Influe	nt Samples	(µCi/ml)	Effluer	t Sample	s (10 ⁻³	µCı/m l)
Batch Number	Date	Flow (gal)	Water Type	Prefilter	Final Filter	1A	18	2A	2B	20	Cat B	Sr	<u></u> s	Total	Sr	Cs	<u>Total</u>	DF
23 24	3/9-3/12 4/28-4/29	20,120 10,901	RCBT RCBT	D00002 D00002	D00009 D00009	010018 D20027	D20026 D20029				D20023	0.88 0.06	15.34 1.53	16.22 1.59	13.67 7.53	14.230 0.910	27.90 8.44	581 188
25ª 26	4/30-6/2 5/5-5/8	18,009	Basement RCBT	D00002 U00001	D00009 U00002	D20027	D20029					0.06	 1.01	1.07	 9.80	 1.55	11.35	 94
2 7 28	5/21-5/29 6/5-6/12	50,152 50,240	RCS RCS	U00001 U00001 ^b U00004	000002 000002	D20027 D200 27	D20029 D20029					9.15 8.43	10.40 7.40	19.55 15.84	46.70 42.50	0.942 0.883	47.60 51.30	411 309
29a 30	6/14-6/14 6/19-6/25	50,124	Basement RCS	U00004 D20030C	000002 020034 ^c	D20027	D20029					9.71	3.98	13.70	26.77	0.613	27.40	 500
31 32	7/1-7/9 7/19-7/26	51,284 48,052	RCS RCS	D200 30 D200 3 0	D20034 D20034	D20029 D20029	D20031 D20031					8.03 10.26	4.89 3.28	12.92 13.54	41.80 32.93	0.508 0.466	42.30 33.40	305 405
33	8/19-8/24	32,774	Basement					D10014	D10018	D20026		7.00	106.70	113.70	24.00	3.00	27.00	4211
34	8/27-8/30	18,945	Basement					D10014	D10018	D20026		5.32	76.20	81.52	7.80	2.80	10.10	8071

,

.

a. Batch 25 and 29 were combined after filtration and processed as batches 33 and 34.

b. Liner U00001 was replaced by liner U00004 part way through batch 28 due to excessively high differential pressure.

c. Modified ion-exchange vessel used as a filter.

vessels were F10001 and D00007 respectively. Ion exchange vessels were D10017, D10012, and D10013 for positions 2A, 2B, and 2C respectively. D10016 occupied the Cation B position. The average influent radioactivity for batch 5 was 94.23 μ Ci/ml and the average effluent was 15.95 x 10⁻³ μ Ci/ml for a total DF of 5908. Batches 25 and 29 were staged from the Basement, filtered, and were combined into batches 33 and 34.

SDS zeolite liner loadings were limited to 60,000 Ci of Cs and 2000 Ci of Sr (see Reference 3). Table 7 provides the spent liner curie estimates for Cs, Sr, and their daughter products. The table also forecasts curie estimates for liners still in use as of August 31, 1982. At no time have the liner loading criteria been exceeded for Cs and Sr.

Design objectives of SDS were satisfied and decontamination criteria set forth in 10 CFR 20 were attained. Overall system performance has been good, with an average RCS/RCBT decontamination factor of 507 and an average Basement water decontamination factor of 13,248. The decontamination factor is the ratio of the radionuclide concentration in the process feed solution to its concentration in the product solution.

Sand and Cellulose Filter Analysis

The sand and cellulose filter vessels are a part of the SDS pre- and final filtration system. The process flow history of the filters are found in Table 8, which shows the total volumetric flow through each filter as of August 31, 1982. Filter vessel DO0009, for instance, filtered a total of 362,137 gal of water before it was taken off line.

Cellulose cartridge filters were no longer used after GPUNC discovered that the filters could potentially release radioactive filtrate during the cartridge dewatering process. Sand filters composed of various grain sizes as listed in Table 9 were used as replacements for the cellulose filters. Table 10 provides the radioisotope on-island analysis estimates of each expended cellulose or sand filter.

		·	Curie	Loading		
Liner	Water	Cs	<u>Sr</u>	Total	Total	TRUa
Number	Type	(134,137)		<u>Cs+Sr</u>	w/Daughters	nCi/g
D10015	RCBT	5,767	1,012	6,779	12,896	0.130
D10017	Basement	30,312	1,021	31,333	59,549	9.893E-2
D10012	Basement	57,176	2,003	59,179	112,635	0.244
D10011	Basement	44,317	2,061	46,378	88,158	0.178
D10013	Basement	49,281	1,974	51,255	97,151	0.385
D20028	Basement	43,333	1,660	44,993	86,334	0.1414
D10016	Basement	57,156	1,869	59,025	112,622	1.136
D20027b	Basement/RCS	4,289	5,096	9,385	18,380	
D20029C D20031C	RCS RCS				12,000 <3,000	
D10014C D10018C	RCS RCS				30,000 12,000	
D20026 ^C	RCS/RCBT				<3,000	

TABLE 7. CURIE LOADINGS ON SDS ZEOLITE LINERS AFTER PROCESSING (As of 8/31/82)

a. Total TRU curie content provided by GPUNC. Converts into nanocuries per gram. Assumes 338 lb of zeolite in each liner at 10% water content (dry weight basis).

b. D20027 calculations are a result of on-island analysis only. These estimates may vary as much as $\pm 15\%$ when compared with off-island analysis when available. All other values are the result of off-island analysis.

c. Liners still in service at the time of writing: estimated final values.

Filter	Filter Type	Water Type	Batch Number Processed	Volume Through (gal)
F10002	Cellulose Prefilter	RCBT	1-3	158,276
D00005	Sand Prefilter	RCBT	4	2,759
F10001	Cellulose Prefilter	Basement RCBT	5-13	384,627
D00002	Sand Prefilter	Basement	14-23,25	362,238
000001	Sand Prefilter	RCS	27,28	104,635
U00004	Sand Prefilter	RCS	29-32	55,233
D20030	Sand Prefilter	RCS	30-32	153,885
F20001	Cellulose Final filter	RCBT	1-3	158,276
D00007	Sand Final filter	RCBT Basement	4,5-13	387,386
D00009	Sand Final filter	Basement	14-23,25	362,137
U00002	Sand Final filter	RCS	27-32	263,238

.

TABLE 8. VOLUMETRIC FLOW THROUGH SAND AND CELLULOSE FILTERS

Particle				Sand Filte	er Volumes i	n Cubic Feet	a		
Size (mm)	<u>U00001</u>	<u>U00002</u>	<u>U00004</u>	D00002	D00005	D00007	D00009	D20030	D20034
1.20	2	2	3	0	0	0	0	3	0
0.85	1	1	3	2	200 lbs	200 1bs	2	3	3
0.45	6	<u>6</u>	3	7.2	700 lbs	700 lbs	7.2	3	<u>6</u>
	9	9	9	9.2	900 lbs	900 lbs	9.2	9	9

.

ŧ

٠

.

TABLE 9. SAND FILTER CONTENTS BY GRAIN PARTICLE SIZE

÷

,

a. Volumes are in cubic feet unless otherwise indicated.

					Estimated Cu at Sr	Estimated Curie Content ^b at Shipment				
Liner	Type ^a	Batches	Media Wt (g)	137 (Ci)	90 Sr (Ci)	Total (Ci)	TRU ^C (nCi/gm)			
F10002	C, PF	1-3	8165	5.3	9.5	29.4	4.8E+3			
F20001	C, FF	1-3	17962	0.2	3.3E-1	1.0	2.2E+3			
D00005 D00007	S, PF S, FF	4 4–13	317513 317513	9.4 9.4	22.4	65.0				
F10001	C, PF	5–13	8165	15.8	37.5	108.8	2.7			
D00002	S, PF	14–25	419117	330.2	384.4	1466.1				
D00009	S, FF	14–25	419117	188.7	219.7	837.8	2.7			
U00001	S, PF	26–28	442250	9.4	37.9	98.2				
U00002	S, FF	26–29	442250	18.9	75.8	196.3				
U00004	S, PF	28–29	442250	18.9	75.8	196.3				
D20030 D20034	S, PF S, FF	30–35 30–35	442250 442250							

TABLE 10. CELLULOSE AND SAND FILTER RADIOISOTOPE ANALYSIS

a. C: cellulose filter; S: sand filter; PF: prefilter; FF: final filter.

b. Calculated using Recovery Support Engineering Calculation 176, 8/25/82, to determine ¹³⁷Cs loading.

c. TRU numbers generated using off-site or Mobile Research Lab analysis, not modified by dose rate from note b calculation. Numbers portray 100 deposition of total TRU across filter pair on each vessel.

1 f

.

d. Still in service at time of writing; values not available.

REFERENCES

- K. K. S. Pillay, <u>Radiation Effects on Ion Exchangers Used in Radioactive Waste Management</u>, Pennsylvania State University, DOE Contract 520483-S.
- H. Sanchez (EG&G Idaho) conversation with T. Lookabill (General Public Utilities).
- 3. J. Massey ltr to Distribution, "Ion Exchange Material Selection Meeting Minutes of July 2, 1979," Chem Nuclear Systems, Inc., Technical Integration Office Doc. No. 007014015, July 24, 1979.
- 4. U.S. Department of Energy Submerged Demineralizer System Task Force, Evaluation of Increased Cesium Loading on Submerged Demineralizer System (SDS) Zeolite Beds, U.S. Department of Energy, DOE-NE-0012, May 1981.
- 5. D. O. Campbell, E. D. Collins, L. J. King, J. B. Knauer, <u>Evaluation of</u> <u>the Submerged Demineralizer System (SDS) Flowsheet for Decontamination</u> <u>of High-Activity-Level Water at the Three Mile Island Unit 2 Nuclear</u> <u>Power Station</u>, Oak Ridge National Laboratory (Union Carbide), <u>ORNL/TM-7448</u>, July 1980.
- 6. D. O. Campbell, E. D. Collins, L. J. King, J. B. Knauer, <u>Process</u> <u>Improvement Studies for the Submerged Demineralizer System at the</u> <u>Three Mile Island Nuclear Power Station Unit 2</u>, Oak Ridge National Laboratory (Union Carbide), ORNL/IM-7756, May 1982.
- GPU Service Corporation, "Division III System Design Description for Submerged Demineralizer System for TMI Unit II Recovery," SAD 527-A Rev. 2, May 11, 1981.
- 8. Union Carbide Corp., Linde Division, "Linde Molecular Sieves Ion Exchange Bulletin IE-95 and A-50 Series."

.

-

•

-

.

.

APPENDIX A TMI-2 EPICOR II WASTE MANAGEMENT

.

-

•

.

.

.

.

. •

APPENDIX A TMI-2 EPICOR II WASTE MANAGEMENT

The EPICOR II ion exchange system began operating late in 1979 to process the contaminated water in the Auxiliary and Fuel Handling Buildings. Figure A-1 shows the flowpath of water through the EPICOR II system. Of the 50 highly loaded first-stage liners (called prefilters) generated by the processing, two were selected for characterization to determine the condition of the ion exchange media, any residual liquid, the composition of contained gases, and the condition of the carbon steel liner. Figure A-2 shows a cutaway view of an EPICOR II prefilter liner. PF-16, the first liner selected for characterization, was shipped to Battelle Columbus Laboratories, and the examination completed. Characterization on the second liner, PF-3, is due to be completed shortly. The following reports discuss EPICOR II processing and the efforts to date in characterizing and shipping the EPICOR liners:

McGoey, R. J., "Processing Three Mile Island Unit 2 Accident Radioactive Waste," <u>88th National Meeting of the American Institute of</u> Chemical Engineers, June 9-12, 1980.

Battelle Columbus Laboratories, <u>Preliminary Characterization of</u> EPICOR II Prefilter 16 Liner, GEND INF-015, November 1981.

John M. Bower, <u>Development of a Prototype Gas Sampler for EPICOR II</u> Prefilter Liners, GEND INF-025, September 1982.

J. L. Buelt, <u>Feasibility of Vitrifying EPICOR II Organic Resins</u>, GEND 012, December 1982.

J. David Yesso, V. Pasupathi, and Larry Lowry, <u>Final Characterization</u> of PF-16 Liner, GEND 015, August 1982.



Figure A-1. Flowpath of water through the TMI-2 EPICOR II processing system.

٠

٩

,

.



Figure A-2. Cross-sectional view of a typical EPICOR II liner.

•

•

APPENDIX B LOW SPECIFIC ACTIVITY WASTE

.

•

,

.

APPENDIX B LOW SPECIFIC ACTIVITY WASTE

The low specific activity (LSA) waste generated at TMI-2 since the accident is routinely shipped to a commercial low-level waste burial site. Table B-1 lists approximate quantities of LSA wastes shipped from TMI-2 between 1979 and 1982. LSA waste is defined per 49 CFR 173.392 and includes compacted and uncompactable trash, and spent resin materials.

GPUNC has a drum compactor for volume reduction of TMI-2 LSA waste. Uncompactable waste is generally shipped in LSA boxes. Resins are shipped both unsolidified and solidified in cement depending upon curie loading.

Year	Volume <u>(ft³)</u>	<u>Curie</u>
1979 ^a	20,600	27
1980	26,800	119
1981	14,800	400
1982	6,200	12
Total	68,400	558

TABLE B-1.	APPROXIMATE QUANTITIES OF LOW SPECIFIC ACTIVITY WASTES ?	SHIPPED
	TO COMMERCIAL BURIAL SITES	

a. Postaccident wastes only.

.

•

,

•

•

APPENDIX C 10 CFR 20 CONCENTRATION LIMITS IN WATER ABOVE NATURAL BACKGROUND

APPENDIX C 10 CFR 20 CONCENTRATION LIMITS IN WATER

		Concentrations in Aqueous Effluents in Unrestricted Areas (10 ⁻⁵ µCi/ml)				
Element (Atomic Number)	Isotope	Soluble	Insoluble			
Antimony (51)	125 Sb	10.00	10.00			
Cerium (58)	¹⁴⁴ Ce	1.00	1.00			
Cesium (55)	134 _{Cs}	0.90	4.00			
	137 _{Cs}	2.00	4.00			
Hydrogen (1)	3 _H	300.00	300.00			
Ruthenium (44)	106 _{Ru}	1.00	1.00			
Strontium (38)	89 _{Sr}	0.30	3.00			
	90 _{Sr}	0.03	4.00			

TABLE C-1. 10 CFR 20 CONCENTRATIONS IN WATER ABOVE NATURAL BACKGROUND

• ł. ı. • APPENDIX D SDS VESSEL NOMENCLATURE

•

.

.

.
<u>Letter</u>	First Digit	Number Made	Number Used	Manufacturing Company	Vessel Description and Use
D	0	11	4	Applied Engineering Company (APCO)	Sand pre- and final filter and leak- age contaimment vessel
F	1	2	2	APCO	Cellulose prefilter (1st position)
F	2	1	1	APCO	Cellulose final filter (2nd position)
D	1	8	8	Permutit	Ion exchange vessel
D	2	16	7	Buffalo Tank Division	Ion exchange vessel
D	2	3	2	Buffalo Tank Division	Ion Exchange vessel: vessels D-20030, 34, 36 are modified Buffalo, which were used as pre- and final filter substitutes
U	0	5	3	Buffalo Tank Division	Universal sand pre and final filter and leakage containment vessel: influent manifold is modified eliminating the internal strainer, which restricts stream flow

• •

.

4

Υ.

TABLE D-1. SDS VESSEL NOMENCLATURE

. .