

GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057-0191
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

(717) 948-8461

4410-87-L-0092 Document ID 0193P

June 10, 1987

US Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

Dear Sirs:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Filter Canister Media Modification

In an effort to reduce the potential for clogging of the filter canister filter elements, the pore size of the filter bundle in some of the filter canisters has been increased from 0.5 microns nominal (2 microns absolute) to 16 microns nominal (25 microns absolute). The new filter elements will be installed in filter canisters and will be used in a manner identical to the previous design.

Attached for the information of the NRC TMICPD is an evaluation which demonstrates that the safety aspects of the canisters containing the new filter media are bounded by previous structure and criticality safety analyses.

Sincerely.

8706160385 870610 PDR ADDCK 05000320

F. R. Standerfer Director, TMI-2

FRS/RDW/eml

Attachment

cc: Regional Administrator, Region 1 - W. T. Russell Director, TMI-2 Cleanup Project Directorate - Dr. W. D. Travers 1001

EVALUATION OF THE FILTER CANISTER MEDIA MODIFICATION

In an effort to reduce the potential for clogging of the filter canister filter elements, the pore size of the filter bundle in some of the filter canisters has been increased from 0.5 microns nominal (2 microns absolute) to 16 microns nominal (25 microns absolute). The new media is similar to that previously utilized in that it is comprised of sintered stainless steel. The new media also is designed to allow backflushing at higher pressure differentials (a maximum of 25 psid). The new filter elements will be installed in the filter canisters and will be used in a manner identical to those currently in-service. As a result of the change in the design of the filter media, it was found that the overall filter bundle weight increased slightly. The below evaluation demonstrates that the safety aspects of canisters containing the new filter media are bounded by previous structural and criticality safety analyses.

To ensure that the structural analyses performed for the previous filter media are conservative when applied to the new media, a series of bench tests were performed by Babcock and Wilcox (B&W) (Attachment 2) to assess the load carrying capability of the new elements. In these tests, new production filter elements were subjected to a series of axial and lateral forces. The load carrying capability and overall element deflections resulting from these forces were then compared to similar tests performed on the original filter elements. This comparison showed that the axial and lateral load carrying capabilities of the new elements exceeded those of the earlier design. Additionally, the deflections resulting from the applied loads were less than those experienced earlier. Thus, GPU Nuclear concludes that the previous structural analyses are bounding then applied to the new filter elements.

Regarding previously performed criticality analyses, it is noteworthy that the only change to the internals of the filter canister is the change in the filter media design. As previously described, the filter bundle with the new media design is slightly heavier than the previous bundle. This increase, resulting from an increase in the quantity of stainless steel within the canister, should result in a greater neutron poisoning effect. This conclusion is based on previous canister evaluations which have shown that an increase in stainless steel within a canister will result in a lower neutron multiplication ($k_{\rm eff}$). Therefore, GPU Nuclear concludes that, in the normal configuration, canisters employing the new media will have a $k_{\rm eff}$ less than that calculated for the original media design.

In the design accident configuration, the internals of the filter canister are deflected to one side as a result of the dropping of the canister. The increase in the canister $k_{\mbox{eff}}$ as a result of this deflection has been shown to increase with increasing deflection. Attachment 2 indicates that the new elements have greater load carrying capabilities; therefore, less deflection will result. Thus, the potential increase in $k_{\mbox{eff}}$, resulting from the design accident, will be bounded by that expected for the original filter media design.

Based on the results reported in Attachment 2, GPU Nuclear has determined that the new filter media will have no adverse impact on existing analyses. Therefore, the normal and accident $k_{\mbox{eff}}$'s for the filter canisters as calculated for the original filter design (i.e., 0.839 and 0.892 respectively) are bounding for filter canisters containing the new filter media (i.e., 16 micron nominal). This modification will be addressed in the next annual update to the Defueling Canister Technical Evaluation Report.

TMI-2 CANISTER FILTER ELEMENT EVALUATION (REVISED FILTER MEDIA)

B&W COCIMENT NO. 77-1168130-00

Published: June 3, 1987

Prepared for GFU Nuclear Corporation

Babonek & Wilcox Company
Nuclear Power Division
P.O. Box 10935

Lynchburg, Virginia 24506-0935

8706160390 870610 PDR ADOCK 05000320 P PDR

34 .

TMI-2 CANISTER FILTER ELEMENT EVALUATION (REVISED FILTER MEDIA) 77-1168130-00

Prepared by:	H. D. Ross, B&W	6/1/87 Date
Approved by:	E. J. McGuinn, Senior Engineer, B&W	6/2/87 Date
Approved by:	P.C. Childress P. C. Childress, Project Manager, B&W	6/2/87 Date

CONTENTS

		Page
1.	SUMMARY/CONCLUSIONS	1
2.	BACKGROUND	2
3.	EVALUATION	3
4.	RESULTS	4

1. SUMMARY/CONCLUSIONS

B&W has evaluated the adequacy of GPUN's new canister filter module with regards to the existing criticality and structural analysis used in licensing.

The results of bench tests indicate that the axial and lateral load carrying capability of the new module exceeds that of the previous module. Also, the deformations under load are less. The margins of safety under accident condition shipping loads are 423% for a 100g lateral load and 72% for a 40g axial load.

Based on these results, the new module design will have no adverse impact on existing analyses.

2. BACKGROUND

GRUN has revised the performance specification of their canister filter media from .1 micron nominal to .16 micron nominal in an effort to improve the canister's total flow capacity. Their vendor, Pall Trinity Corporation, has changed the details of element construction to allow the revised performance levels to be met. The original filter element was an important structural contributor in determining the accident geometry of the canister internals for criticality evaluation; bench tests showing the element's structural performance were a crucial part of the evidence leading to NRC licensing. It is important to ensure that the use of the new element does not invalidate the conclusions of existing canister criticality and structural analyses.

Bench tests run on the previous production filter modules indicated that an axial force of 3450 pounds was needed to initiate buckling. The total axial deflection at that load was 0.045 inches and the plastic set, after the load was removed, was 0.020 inches. The module tested was not mounted on the center core tube which would have increased its rigidity. The lateral crush test performed on two modules compressed against each other with their endcaps offset yielded a load of 2290 pounds and a total overlap of nearly 0.5 inch. At that point, the center tube, were it in place, would have started picking up the load and increased the crush resistance.

3. EVALUATION

Bench tests were performed on the four canister filter modules supplied by GPUN. Test tests were carried out at the B&W Commercial Nuclear Fuel Plant using the same equipment and method of testing as in previous module tests by B&W.

Two tests were performed. In the first test, the module was placed axially in a Baldwin machine and incremental compression loads were applied until buckling seemed to initiate. The test was then terminated. Deflection measurements reported in Tables 1 and 2 were recorded at each load step. Two modules were tested in this manner. In the second test, two modules were positioned laterally against each other with their endcaps in-line. The modules were then incrementally compressed up to a load of 1500 pounds. Deflection measurements reported in Table 3 were recorded at each load step. The modules were then offset the width of an endcap and again incrementally compressed against each other until the deflection became non-linear. The test was then terminated. Deflection measurements reported in Table 4 were recorded at each load step.

Pictures were taken of the modules. Figures 1-7 show the modules before and after tests.

4. RESULTS

The new modules proved to be superior to the original module both in load carrying capability and in overall deformation under load.

In the axial test on two modules, loads of 4300 and 4040 pounds resulted in deflections of 0.045 and 0.0485 inches, respectively. Both modules had a permanent set of 0.023 inches. These values compare to 3450 pounds, 0.045 inches, and 0.020 inches, respectively, as reported for the original module. In the lateral test with the endcap in-line, the deflection was 0.0185 inches for the 1500 pound applied load and the permanent set was 0.014 inches. The endcap in-line test was not performed on the original module. In the lateral test with endcaps offset, the maximum load and deflection was 2800 pounds and 0.117 inches. These values compare to 2290 pounds and 0.405 inches reported for the original module. The figure on page 15 shows three pleats of the filter media under the endcap to be crushed. This was the only damage to the module.

The recorded load/deflections for the axial and lateral tests are given in the tables on pages 5-11.

The test results yield large margins of safety for the accident condition shipping loads. Based on a payload of 1000 pounds at a lateral load of 100g's being evenly distributed on the 187 modules (17 elements, 11 modules/element), the load per module is 535 pounds and the margin of safety is 423%. With the 1000 payload and a 40g axial load evenly distributed to 17 elements, the load per module of 2353 pounds would result in a margin of safety of 72%.

FORM NO: QC-R-102 . THE BABCOCK & WILCOX-CO.

PAGE ___ OF ___

C. N. F. P. Approved By: Use

QUALITY CONTROL SECTION 133 400

LYNCHBURG, VA.

Date: 5-4-82

MISCELLAREOUS INSPECTION REPORT

DWG. NO. SECTOSTA.
SPEC. NO. WA

IR

AXIAL TEST

JOB NO. PROC. NO. SPEC INSTE

PART NAME: FILTER CANISTER ELEMENT

			TABLE 1			
L.AD (185)	DEFASETION (IM)	20AD (1.85)	08818c7120 (in)		LORD (485.)	PESIECTION (in)
0	0	1800	.011		3 600	.025
100	.0015	1900	,0115		3200	.028
200	1003	2000	,012		3800	.030
300	.0035	2100	.0125		3900	10345
400	10045	2200	.013		4000	.037
500	.005	2300	,0135	: .	4100	.039
600	.006	2400	.014		4150	.040
700	.0065	2500	.0145		4200	.041
800	.007	. 2600	.015		4250	.0425
900	.0075	2700	1016		4300	.045
1000	.008	2800	.0165			
1100	.008	2900	.017			
1200	.0085	3000	.018			
1300	.009	3100	.019			
1400	,0095	1200	.000			
1500	1010	3300	10205			
1600	.010	3400	.022			
1700	.0105	3500	1.023			

INSPECTED BY: REDANDATE: 5.2087 RELEASED BY: DATE:

FORM NO: QC-R-102 THE BABCOCK & WILCOX CO.

PAGE ___ OF ___

C. N. F. P. Approved By:

QUALITY CONTROL SECTION

LYNCHBURG, VA.

20

Date: 3.4-82 MISCELLANEOUS INSPECTION REPORT

AXIAL TEST.

DWG. NO. SPEC. INSTR.
SPEC. NO. NA JOB NO. SC. 1525 PROC. NO. SELS INSTE

PART NAME: FILTER CAMISTER ELEMENT

			TABLE 2			
Lono. (85)	DEFLECTION (in)	40AD (485)	Officetion (in)		(185)	(24)
B	0	1800	.016		3600	.0365
100	.005	1900	.016		3700	.039
200	.007	2000	.017		3800	. 0405
300	missee	2100	.0175		3900	.0425
400	.0085	2200	.018		4000	.045
500	.009	2300	.0185		4040	.0485
600	.010	2400	.019			
700	.0105	2500	.020			
800	.011	2600	,0205	*		
900	.0115	2708	.021		Tarret.	
1000	.012	2800	. 022			
1100	.0125	2900	.023			
1200	,013	3000	.024			
1300	.0135	2100	.0255			
1400	.014	3200	.027			
1500	.0145	3300	.0285			
1600	.015	3400	.0305			
1700	1015	3500	1.034			

INSPECTED BY: RELEASED BY: DATE: FORM NO: QC-R-102

THE BABCOCK & WILCOX-CO. QUALITY CONTROL SECTION

PAGE ___ OF ___ LYNCHBURG, VA.

C. N. F. P.

Approved By: We Date: 5.4.82

MISCELLANEOUS INSPECTION REPORT

DWG. NO. SPEC INSTA

(AGRINST EACH OTHER) LATERAL TEST

JOB NO. PROC. NO. SPEC INSTRA.

DADT NAME: CLIFCE CAN

				TABLE 3		
10AD (185)	DESLECTION					
	(ini)				7 No 7	
0	0					
100	10005					
200	.0065	•				
300	. 0075			1		
400	.0085					
500	.0095					
600	. 1105		,		142	
700	.012					
800	,013			*		
900	1010					
1000	.015					
1100	.0155					
1200	.0165					
1300	,0175					
1400	.019					
1500	.0185					

INSPECTED BY: CANADATE: 5.20-82 RELEASED BY: _____DATE: _____

FORM NO: QC-R-102 . THE BABCOCK & WILCOX-CO. QUALITY CONTROL SECTION

PAGE ___OF

C. N. F. P.
Approved By: WE

Date: 3-4-82

MISCELLANEOUS INSPECTION REPORT

LYNCHBURG, VA.

3th (OFFSET) LATERAL TEST

JOB NO. SC.1525 PROC. NO. SPICE ENSTR.

PART NAME: FILTER CANISTER ELEMENT

			TABLE 4		
LORD (285)	DEFLECTION (IN)	LOAD (185)	Octions (in)		
0	0	1800	MISSED		
100	.007	1900	.050		
200	.0095	2000	1054		
300	.0105	2100	,057	*	
400	.012	2200	,060		
500	10125	2300	.063		
600	, 0135	2000	.066		
700	.0145	2500	.077		
800	.016	2600	.108		
900	.018	2700	,112		
1000	. 0195	2800	.117		
1100	.021				
1200	.027				
1300	,029				
1400	.0315				
1500	.034				
1600	.037				
1700	.0415				

FORM NO.: QC-R-102

PAGE / OF /

THE BABCOCK & WILCOX COMPANY

COMMERCIAL NUCLEAR FUEL PLANT

LYNCEBURG, VIRGINIA

QUALITY ASSURANCE SECTION

APPROVED BY: 60. MISCELLANEOUS INSPECTION

REPORT

DWG. NO .: Special Instruct

DATE: 1/12/87 FILTER

SPEC. NO .: N/K JOB NO .: 56-1525

PART NAME: CANSTER ELEMENT

PROC. NO.: Special Instruct

	FREE H	EIGHT BE	CORE TE	ST			
5/,					TABLE	5	
5/1	A	В	C	Δ			
IA	11.2265	11.2346	11.2247	11.2178			A
2A	11.2128	11.2158	11.2082	11.2061			
					. D		
</td <td>FREE H</td> <td>EIGHT AF</td> <td>TEST </td> <td>• 24</td> <td></td> <td>1</td> <td>-</td>	FREE H	EIGHT AF	TEST	• 24		1	-
5/N	A	8		_ D		1	-/
IA	11.2019	11. 2097	11. 2034	11.1954:			c .
2A '	11.1871	11.1944	11.1864	11.1809			
				. 1		t	
100							
Plastic	Set					į,	7.
14	.0246	.0249	.0213	.0224	7 9 1 1		
		Dava	= .0233	11			
						X v	
2A	.0357	.0214	.0218	.0252			
		Dave	= .0235	11:			
			1 - 5 - 1 - 2	A STREET			
VC Iso V		10 11 2 11 2 E HY		E IV. La Septe		CENTE	

THE BABCOCK & WILCOX COMPANY

COMMERCIAL NUCLEAR FUEL PLANT LYNCHBURG, VIRGINIA
QUALITY ASSURANCE SECTION

APPROVED BY: 6... MISCELLANEOUS INSPECTION DWG. NO.: Special Instruct.

DATE: 1/12/87 REPORT SPEC. NO.: AIA

FILTER

PART NAME: CANISTER ELEMENT (BEFOLE)

PROC. NO.: Special Instruct.

			LATERA	L TEST	
5/1	ACLASS SCUBE LINE DIA.	OPPOSITE END	D/A. B	OPPOSITE END	TABLE 6
14	2.6320	2.6335	2.6340	2.6355	
24	2.6330	7.6350	2.6330	2.6350	
					•
5/1	ACROSS BOTH SCRIBE LINES DIA. A		OPASSITE END		
12 \$ ZL .	6. 2625		5.2605		1. ((())) 16
				5.2520 = -,	-5.2625
					5.2685)*
5/1	OFFSET DIA.		OPPOSITE		1
IL 车 ZL	5.1520		5.1460		
				<u></u>	
5.0460 - 5.	1520 =10	60"		5	1.0220 - 5.1460 =1240"
	<u> </u>	l Ü			
				STATE OF	
*	parenthe	416 is c	opposite en	nd	

INSPECTED BY: LE DATE: 5/20/87 RELEASED BY:

THE BABCOCK & WILCOX COMPANY

COMMERCIAL NUCLEAR FUEL PLANT LYNCHBURG, VIRGINIA QUALITY ASSURANCE SECTION

APPROVED BY: 6... MISCELLANEOUS INSPECTION
DATE: 1/12/87 REPORT SPEC. NO.: N/A

PART NAME: CANISTER ELEMENT (AFTER)

PROC. NO.: Special Instruct
PROC. NO.: Special Instruct

A STATE OF THE STA			LATERAL	TEST		.c. No.:	
5/1	ACESS SCRIBE LINE DIA.	OPPOSITE END	DIA.	OPPOSITE END	TA	BLE 7	
14	2.6230	2.6250	2.6345	2.6360			
24	2.6235	2.6300	2.6330	2.6360			
			-				-
5/1	OFF SET		OFFSET OAADSITE END				
1L 2L.	510460	* *	5.0220	:			
5/1	ACROSS BOTH SCRIBE UNES DIA. A		ALPOSS ASTN SCRIBE UNES DIA. B				###
14 26	5.2520		5.2540			i	
	B -	7/	- Scribe li	ne			-
+	1	4		•			
À		1	3 - 2.632 = - 25 - 2.6335 = -	/		0095	4
1	M	1		1		0095	<u>^) </u>
	4,000		+				
	+,000 +,000	5)			(+.001) - 2 L	<u> </u>	
+ Pa	renthesis	is opposi	te end		A La Company		




FIGURE 1 TYPICAL FILTER MODULE BEFORE TEST




FIGURE 2 CLOSEUP OF FILTER MODULE BEFORE TEST




FIGURE 3 FILTER MODULE 2A AFTER 4040 POUND AXIAL TEST




FIGURE 4 CLOSEUP OF FILTER MODULE 1A AFTER 4300 POUND AXIAL TEST




FIGURE 5 FILTER MODULES IN LATERAL CRUSH TEST




FIGURE 6 CLOSEUP OF FILTER MODULES AFTER
LATERAL CRUSH TEST OF 2800 POUNDS

11




FIGURE 7 CLOSEUP OF FILTER MODULE AFTER LATERAL CRUSH TEST OF 2800 POUNDS