

GPU Nuclear Corporation

Post Office Box 480 Route 441 South Middletown, Pennsylvania 17057 717 944-7621 TELEX 84-2386 Writer''s Direct Dial Number:

U.S. HUCLEAT

E

E.S

P

0

March 15, 1983 4410-83-L-0052

TMI Program Office Attn: Mr. L. H. Barrett, Deputy Program Director US Nuclear Regulatory Commission c/o Three Mile Island Nuclear Station Middletown, PA 17057-0191

Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2) Operating License No. DPR-73 Docket No. 50-320 Polar Crane SER - Additional Information

Attached for your information is additional information on the refurbished Polar Crane Safety Evaluation Report. This information is provided as a result of questions by your staff. NRC staff comments are listed by SER section number followed by GPUNC's response.

If you have further questions, please contact Mr. J. J. Byrne of my staff.

Sincerely, B. K. Kange

Director, TMI-2

D009

BKK/RBS/jep

Attachment

CC: Dr. B. J. Snyder, Program Director - TMI Program Office

8303190302 830315 PDR ADOCK 05000320

POLAR CRANE LOAD TEST SER

(NRC Comments and Responses Thereto) (Comments listed by SER section number)

Comment 2.4: Provide stress analysis of the D-ring wall at point of contact with stacked missile shields.

Response 2.4 A stress analysis is not specifically needed since the missile shields have previously been stacked on the D-rings safety using wood blocking to elevate them above interferences. The D-ring walls are designed for this function. The present plan substitutes steel for the wood blocks to avoid bringing combustibles into containment. For further information on design of the D-rings, see Section 3.8.3 of the FSAR.

Comment 3.1 Provide a list of any exception taken to ANSI Standards for the crane and lift rigging.

Fesponse 3.1 Exceptions taken to ANSI standards for the crane are described in the Polar Crane Functional Description, 2-M72-MH02, submitted as Revision 0 to the NRC via 4410-82-L-0021 dated October 8, 1982. Exceptions to ANSI standards for lift rigging were provided via GFUN letter 4410-83-L-0004 dated January 4, 1983.

Comment 3.2 Provide explanation of the statement, "Two individual though not redundant rope systems."

Response 3.2 The main hoist rope system includes two lengths of rope tied to two hoist drums and through a tandem reeved load block. The two ropes acting together are sized for the original 500 ton design rating of the crane.

Comment 3.2 Provide a clarification statement to the effect that the crane was originally designed to 500 tons.

Response 3.2 The original design capacity of the crane is stated in Section 9.1.4.3 of the FSAR.

Comment Figure 3.3-1

•

..

Provide an explanation of the load rating on the Dillon load cell, including the factor of safety to ultimate (breaking) strength. Clarify the "pull to 220 tons."

Response Figure 3.3-1

The factor of safety on the Dillon load cell is a 3 to yield and 5 to ultimate based upon a 200 ton load.

The 0-200 ton Dillon load cells have been recalibrated to measure the range 20-220 tons. The wording "pull to 220 tons" refers to the manner in which the calibration laboratory performed this task. Further detail of the calibration sequence would show that routine calibration techniques were used.

Comment Figures 3.3-1 and 3.3-2

-

•

Provide an analysis of load-bearing members in the lift rigging to be used. List design ratings and breaking strength. 10

Response Figures 3.3-1 and 3.3-2

Attachment 1 provides a comparison of design stress versus allowable stress or a factor of safety to yield and to failure of all the load-bearing members, excluding the head lift rig. The head lift rig was designed for a 170 ton load and tested to 255 tons. This lift rig has been used to remove the T!!I-2 head twice.

Attachment 2 provides an evaluation of design loads and stresses for the RV head and internals handling equipment.

- Comment 4.0 General comment. Do not use the word "probability" without quantification. 'Lither quantify the various probabilities mentioned or provide a clarification to the effect that the term 'probability" should be interpreted to mean likelihood.
- Fesponse 4.0 The interpretation stated above is correct. The word "probability" is not meant to be interpreted in the mathematical sense but rather is synonomous with "likelihood."

Comment 4.1.3.1 Last paragraph. Quantify any postulated release of radioactivity.

Response 4.1.3.1 An excerpt from the head removal safety evaluation which quantifies the postulated releases of radioactivity is repeated below:

> During head removal activities, there is a remote possibility that the krypton-85 which is assumed to be in the reactor core may be released. This remaining krypton-85 may be securely trapped in the grain boundaries of fuel pellets or in intact fuel rods. An analysis of the potential release was performed, based on the following assumptions.

- Krypton-85 inventory at shutdown (March 28, 1979) is
 9.6 x 10⁴ curies.
- Known releases of krypton-85 inventory are 44,600 curies (reference 2). This is the quantity released during the June-July 1980 reactor building purge. All other releases are negligible.

- The remaining krypton-85 is decayed to January 1, 1983.
- The offsite doses are based on an instantaneous release of the remaining krypton-85.
- An accident X/Q of 6.1 x 10⁻⁴ sec/m³ is used.

These assumptions yield a maximum release of 37,400 curies of krypton-85. Using Regulatory Guide 1.109 methodology and curies to dose conversion tables, the maximum site boundary total body dose is 12 mrem.

2

These calculations are considered conservative since accident X/Q is used, when in reality, the purge will be isolated. Therefore, release meteorology can be controlled reducing doses by as much as a factor of 100. Also, the assumption of Krypton remaining is conservative since RCS venting activities have not shown significant quantities of Krypton.

Comment 4.2.4 (B) State the quantity of unborated water that could be delivered to the sump as a result of load drops.

Response 4.2.4 (B) Attachment 3 provides the water volume by system of those systems that could be affected by load drop.

Comment (Table 4.2-1): Clarify the intent of using hazard elimination Category E.

- Response: Hazard elimination Category E was used with the intent to state that analyses of postulated damage to safety-related equipment have shown that the consequences of this damage are not significant with respect to maintaining required safety functions as stated in the SER.
- Comment 5.2 (2) Provide summary of or reference to recent decay heat analyses regarding losses to ambient at reduced RV water level. Response 5.2 (2) A summary of the referenced analysis is provided on Attachment 4.
- Comment 7.0 Include a description of the NDE Program on the main hock.

Response 7.0 The NDE of the main hook will be performed in accordance with GPUNC procedure MTIS-004 Revision 3 and work package M0043. These have been provided to the NRC.

ADDITIONAL COMMENTS:

- Comment A Clarify whether or not each indivual set of redundant main hoist brakes is capable of holding the test load.
- Response A Each individual set of redundant main hoist brakes is capable of handling the test load.

Comment B Will the purge be isolated during the actual lifting times of the load test?

Response B The purge system will be isolated during those times when a missile shield or the test load is actually being lifted by the polar crane.

- Content C Provide a summary of laboratory test report on wire rope sample.
- Response C A summary of the laboratory test is provided as Attachment 5. The complete laboratory test is available for inspection at your request.

-

- Comment D Clarify what loads are served by the out-of-containment power supply breaker that would be used to interrupt power to the polar crane.
- Response D MCC-2-32A, the 480V supply breaker in question supplies power only to the polar crane. No other loads are supplied by this breaker.
- Comment E Explain the selection basis for the chosen load path as shown on the figures in Section 2 for movement of the missile shields from the test load frame to their storage location on the "B" D-ring. Refer to figures 2.4-2 and 2.4-3. Specifically, state the reasoning by which clockwise rotation was selected over counter-clockwise rotation.
- Pesponse E Load path selection was based on maximizing the simplicity of movements and minimizing the number of manipulations required to transport the subject loads, as well as considering the load drop analysis as described in the SER.
- Comment F: Provide an analysis of load-bearing members of the load test frame. List design ratings and breaking strengths.
- Response F: Attachment 2 of the first response to verbal comments provides a comparison of computed stress versus allowable stresses for load-bearing members of the test frame.
- Comment G: Verify that rigging components associated with the load test have been certified to appropriate ANSI standards.
- Response G: Newly-designed and/or procured slings associated with the load test have been certified to meet appropriate AUSI standards. Other portions of the lifting assembly will be verified by a combination of testing and inspections as described in Section 3.3 of the SER.

POLAR CRANE LOAD TEST ASSEMBLY (Shown on Drawing 2-COP-1301)

• •

Component and - Drawing Detail	Type of Stess	Computed Stress (KSI) (See Note 1)	Allowable Stress (KSI) (See Note 2)	
Extension Bar (1),	' Tension	7.4	16.2	
DET. 6	Shear	7.4	14.5	
5%" \$ Pins (3),	Shear	6.8	14.5	
ELEV. A	Bending	14.9	27.0	
Lifting Plates (6),	Tension	7.3	16.2	
DET. 2	Shear	7.3	14.5	
Base Plates for Lifting	Bending	17.6	27.0	
Plates (3), DET. 2	Shear	3.5	14.5	
Lifting Plates (4),	Tension	6.4	16.2	
DET. 3	Shear	5.7	14.5	
Base Plates for Lifting	Bending	8.2	27.0	
Plates (4), DET. 3	Shear	2.3	14.5	
Load Spreading Frame, Partial Plan B				
- W27 x 146	Bending	11.9	22.0	
	Shear	8.9	14.5	
- W27 x 178	Bending	14.0	22.0	
	Shear	3.6	14.5	
- W30 x 173 (2)	Bending	14.1	22.0	
	Shear	5.5	14.5	
1 3/4" ϕ Wire Ropes (8) and Fittings, ELEV. A	Tension	(See Note 3)	(See Note 3)	
Lifting Plates (8),	Tension	7.1	16.2	
DET. 1	Shear	7.2	14.5	

Component and Type of Allowable Computed Stress (KSI) Drawing Detail Stress Stress (KSI) Load Frame, •• Partial Plan C . - W24 x 104 (4) 24.0 12.8 Bending Shear 4.6 14.5 - L'S 4 x 4 x 4 3.4 Compression 17.8 Bolted Connections Load Spreading Frame 7/8" 4 Bolts (20), SECT. L 12.2 Shear 30 Load Spreading Frame Shear 20.4 30 7/8" & Bolts (24), SECT. K Base Plate for Lifting Tension 19.9 44 Plates 14" \$ Bolts (18), DET. 2 Tension 22.8 44 Base Plate for Lifting Plates 14" ¢ Bolts (16), SECT. H 14.8 Load Frame ' Shear 30 3/4" ¢ Bolts (32), SECT. D Welded Connections 10.5 Shear 21 Load Spreading Frame 3/8" Fillet Weld, SECT. L Load Spreading Frame 14.1 Shear 21 7/16" Fillet Weld. SECT. K

• •

.

Lifting Plates Tension 4.7 21 3/4" Parial Pen. Weld, DET. 2

Page 2 of 3

Component and	Type of	Geograded	Allowable
Drawing Detail .	Stress	Stress (KSI)	Stress (KSI)
Lifting Plates -	Tension	6.5	21 .
3/4" Partial Pen. Weld,			

Page 3 of 3

Notes:

-

- 1. Computed stresses are based on a vertical design load of 220 tons.
- Allowable stresses are based on the latest edition of the AISC "Specification for the Design, Fabrication and Erection of Structural Steel for Buildings."
- Wire ropes and fittings have a factor of safety greater than 5 with respect to their ultimate strength.
- Any load test assembly components not listed in the above table are secondary members provided for lateral support only.
- 5. The existing head and internals handling fixture assembly and turnbuckle pendant assemblies shown on drawing 2-COP-1301 were furnished by B&W. These components were designed for a lifted load of 170 tons and were load-tested to 255 tons by B&W.

· · · · · · · · · · · · · · · · · · ·								
Component and - Drawing Detail	Yield Safety Factor (Design Load, See Note 1)	Ultimate Safety Factor (Design Load, See Note 1)	Yield Safety Factor (220 Tons)	Ultimate Safety Factor (220 Tons)				
10" ¢ Cylinders (2), DET. 1	3.8	5.1	3.5	4.6				
Attachment PL (2), DET. 2	4.1	6.6	3.7	6.0				
7" • Pin (2), DET. 3	4.0	5.4	3.6	4.9				
10½" ¢ Pin (1), B&W Mark 228	7.9	9.9	7.2	9.0				
Bore Plates (2), B&W Mark 223	4.1	6.6	3.7	6.0				

LOAD CELL RIGGING (Shown on Drawing 2-COP-1302)

Notes:

10

1. The design load for the load cell rigging components listed above is 200 tons.

2. The additional components shown in elevation with the load cell rigging but not listed in the table above are parts of the existing internals handling extension furnished by B&W. These components were designed for a lifted load of 176 tons and were loadtested to 264 tons by B&W.

ALESILE SHIELD RIGGING (Shown on Drawing 2-COP-1301)

Component and Drawing Detail	Yield Safety Factor (Design Load)	Ultimate Safety Factor (Design Load)
Attachment Plate (1) Shown in DET. 5	6.8	10.9
14" 4 Wire Ropes (4) Shown in Elev.) » »/A	5.2
75 Ton "Wide Body" Shackles (2) Shown in Elev.	N/A	15.8
1 3/4" Screw Pin Anchor Shackles (4) Shown in Elev.	N/A	12.7
Missile Shield Lifting Lugs (4/panel) shown on B&R Dwg. 4156	3.0	4.9

Notes:

.

٠.

1. Safety factors are based on a vertical design load of 41 tons.

Attachment 2

TMI-2 RECOVERY PROGRAM HEAD & INTERNALS HANDLING EQUIPMENT DESIGN LOADS & STRESS EVALUATION SUMMARY

Compiled By J. G. Sparks Mechanical Engineering

BABCOCK & WILCOX UTILITY POWER GENERATION DIVISION LYNCHBURG, VA 24505

.

FEBRUARY 1983



Atc-chment 2 Phor 2 of 6

HEAD & INTERNALS HANDLING FIXTURE THE MINDLING EXTENSION

1. The design load for the Fixture and Extension was as follows:

(360 KIPS) X (3G's - Allowance for shock or impact effect)

- The allowable stresses were as follows:
 - A. Yield strength (From no particular code) Where tensile, bending, bearing and shear stresses were concerned.
 - 5. AISC Manual Where compressive and weld stresses were concerned.
 - C. AISC Manual Where combined (Compressive and bending or tensile and bending) stresses were concerned except that in the equations the yield strength (Fy) was used for F_b and .6Fy.

TURNBUCKLE PENDANT

- The design loads were 120 KIPS for the turnbuckle and 360 KIPS for the remaining part numbers.
- The allowable stress for all part numbers except the turnbuckle was the yield strength (from no particular code).
- The proof (roughly, yield) and ultimate loads for the turnbuckle were 244.4 KIPS (S.F.2 x 122.2 KIP safe working load) and 611 KIPS (S.F.5 x 122.2 KIP safe working load) respectively.

HANDLING FIXTURE SLING

- 1. The design load was 360 KIPS
- The ultimate load for the wire rope was 818 KIPS.

Attachment 2 Page 3 of 6

HEAD AND INTERNALS HANDLING FIXTURE ACTUAL VS. ALLOWABLE STRESSES (KSI)

1

Part	Tens	Tensile		ling	Combined Stress	oined Compr		Compressive		Shear	Shear		d	Bearing		Yleld Strength	Ultimat Strengt
No.	ft	Ft	fb	Fb	Factor	fa	Fa	fv	Fv	Act.	A11.	fp	Fp	Sy	Su		
2478248	20.3	36	11.6	36	.89 < 1.0	-	-	-	-	•	-	-	-	36	58		
249	•	•	21.3	36	:98 < 1.0	11.6	34.8	•	•		-	•	•	36	58		
245	-	•	-	-	-	10.3	20.1	-	•	-	-	•	•	40	70		
241	9.6	36	6.6	36	•	•		6.6 (Tearout by P/N 32	36		•	11.4 (P/N 32 Against P/N 24	36 20 t 1)	36	58		
320	-	•	18.2	66	-	-		8.3	66	-	•	12.5	66	66	100		
241 to 247 and 249 weld	•	•	-		-	.•	•		•	11.4	18	•	•	36	58		
251	1.5	40	-	•		-	-	•	-	-	-	-	•	40	70		
242	-	-	8.4	36	-	-	-	•	•	-	-	•	•	36	58		
249 to 243 weld	-	-	-	•		•	•	•	-	13.2	18	•	1000 A	⁻ 36	58		
240	20.7	36	-		•	•		18.7 (Tearout)	36	-		28.7 (Pin Bearin	36	36	58		
247 or 248 to 240 weld	-	-	-	-	-	-		•	•	12	18	-	-	36	58		

Attachment 2 Page 4 of 6

INTERNALS HANDLING EXTENSION ACTUAL VS. ALLOWABLE STRESSES (KSI)

Part Tensile		sile	Shear		Bearing	Ben	ting	Yield Strength	Ultimate Strength	
No.	ft	Ft	fv	Fv	fp	Fp	fb	Fb	Sy	Su
223	24	36	21.1 (Tearout)	36	23.6 (P/N 229 Against P/N 223)	36	•	•	36	' 58
224	23.3	36	20.9 (Tearout)	36	28.7 (P/N 230 Against P/N 224)	36		-	36	58
222	34.4	50	30.5 (Tearout) *	50	38.2 (P/N 230 Against P/N 222)	50	•	•	50	70
228		-	6.2	40	15.7	40	12	40	40	80
229		-	14	66	23.7	66	41.1	56	66	100
230	-	-	17.6	66	28.8	66	33.8	66	66	100

*Effect of part numbers 225 and 226 and associated welding was neglected in the calculation of this stress.

Attachment 2 Page 5 of 6

ъ

Part	Tens	Tensile		Tensile Shear Tearout		Thread		Pin Bearing		Yield Strength	Ultimate Strength
No.	ft	Ft	fv	Fv	fv	Fv	fp	Fp	Sy	Su	
375	9.9	36	8.9	36	8	36	12.2	36	36	58 '	
376/377	43.2	5Ż	-	-	10.6	52	-	-	52	90	

.

TURNBUCKLE PENDANT ACTUAL VS. ALLOMABLE STRESSES (KSI)

Attachment 2 Page 6 of 6

Part	Shear		Tensile		Bearing		Bending		Yield Strength	Ultimate Strength
Name	fv	Fv	ft	Ft	fp	Fp	fb	Fb	Sy	Su
Open Socket	8.9 (Tearout)	50	16	50	13.7	50	•	-	50	80
Closed Socket	9.2 (Tearout)	50	15.9	50	12.5	50	•	•	50	. 80
5½" Dia Pin	8.3	40	•	•	13.7	40	18.2	40	40	80

*HANDLING FIXTURE SLING END FITTING ACTUAL VS. ALLOWABLE STRESSES (KSI)

.

*Assumptions concerning socket geometry and socket and pin materials were made; therefore, the actual stresses in this table are subject to verification.

.....

Water Volume for Unborated Water System Inside Containment

- Reactor Building Fire Protection: FS-V639-FS-V637, Penetration No. R-543, 1,800 gal.
- Reactor Building Demineralized Water: Penetration No. R-535, DW-V31-DW-V141, 100 gal.
- Reactor Building Nuclear Services Closed Cooling Water: Penetration No. R-557 and No. R-558, 900 gal.
- 4) Reactor Building Intermediate Closed Cooling Water Penetration No. R-563 and No. R-567, 500 gal.
- 5) Reactor Building Normal Cooling:
 - A. Inside the Reactor Building Penetration No. R-577, R-579, R-580, R-584, R-587, R-588, R-585, R-581, R-582 and R-578 (normal cooling coils), 6,400 gal.
 - B. Total Reactor Building Normal Cooling Volumes consisting of Part A plus the volume outside the Reactor Building, 12,200 gal.
- 6) Secondary Side of SG Including Steam and FW Piping, 41,000 gal/loop. B Generator drained and A Generator at head removal level and MS and FW lines drained, 12,488 gal.

Attachment 4

ADDENDUM TO THE THI-2 DECAY HEAT REMOVAL REPORT OF APRIL 1982

. • :

8303180313 830315 PDR ADDCK 05000320

PDR

•.....

> Prepared by G. A. Hipp L. L. Losh E. R. Miller

Prepared for

GPU Nuclear Corporation Under Master Services Contract 595-3174

by

BABCOCK & WILCOX Utility Power Generation Division P.O. Box 1260 Lynchburg, Virginia 24505

ADDENDEN

to the

THI-2 DECAY HEAT REMOVAL REPORT

of April 1982

Contents	Page
Abstract	3
Introduction	• •
Significance of Quick Look Data	5
Assessment of Existing Models	6
Conservative Analysis Draindown to Head Removal Level	8
Identification of Conservatism	10
Best Estimate Analysis Draindown to Head Removal Level	12
Conservative Analysis of Draindown to Bottom of Reactor Vessel Nozzles	13
Best Estimate Analysis of Draindown to Bottom of Reactor Vessel Nozzles	14
Summary and Conclusions	16

ABSTRACT

A conservative calculation of equilibrium temperatures and heatup rates for the reactor coolant system (RCS) draindown to head removal level (321.5 ft. elevation) has determined that the draindown with no supplemental heat removal can be accomplished after December 1, 1982 without exceeding the temperature criterion. A similar conservative analysis for RCS draindown to the bottom of the reactor vessel nozzles (314 ft. elevation) supports draindown after January 1, 1984 without exceeding the temperature criterion. The criterion is that fluid temperatures do not exceed 170°F.

These conservative calculations were made with models originally developed in the TMI-2 Decay Heat Removal Analysis of April 1982. In addition, best estimate models, benchmarked to temperatures measured following the partial draindown for the Quick Look inspection, were developed and used to predict the expected reactor coolant system heatup following the draindown to head removal level and draindown to the bottom of the reactor vessel nozzles. The best estimate models predict that draindown with no supplemental heat removal can be accomplished after December 1, 1982 for both draindown levels without exceeding the 170°F temperature criterion.

INTRODUCTION

The TMI-2 reactor has been in the decay heat natural circulation cooling mode for the past several years. In July 1982, the reactor coolant system (RCS) was partially drained to permit access for the Quick Look inspection. The next step in the recovery process called for draining down the RCS further to allow removal of the reactor vessel head. An analysis was performed to determine whether the TMI-2 decay heat loss to containment is sufficient to support the RCS draindown to head removal level (321.5 Ft. elevation) without exceeding the temperature criterion. It was concluded that the draindown to reactor head removal level can be accomplished after December 1, 1982 without exceeding the 170°F criterion.

An additional analysis was performed to determine whether the TMI-2 reactor decay heat loss to containment is sufficient to support the RCS draindown to the bottom of the reactor vessel nozzles (314 Ft. elevation) without exceeding the temperature criterion. The temperatures predicted with the April 1982 conservative models for December 1, 1982 and July 1, 1983 draindown dates exceed the 170°F criterion. This is the result of the large degree of conservatism in the decay heat generation, heat transfer, and heat capacity models.

Two best estimate models have been developed for draindown to the reactor vessel nozzle level; one including the hot legs' and steam generators' heat transfer areas and heat capacities and the other not including them. The reason for two best estimate models is uncertainty whether the steam generators would be in effective thermal communication with the core with the cold legs no longer full. Both best estimate models, however, yield temperature prediction well below the 170°F temperature limit.

SIGNIFICANCE OF QUICK LOOK DATA

During the month following the draindown for the Quick Look inspection, the RCS water temperature and reactor building ambient temperature were monitored daily. These data differ significantly from the data upon which the TMI-2 Decay Heat Removal Analysis Report of April 1982 was based in that the new data depict the dynamic temperature response of the RCS rather than "snapshots" of equilibrium temperatures. The advantage of the dynamic data is that it provides an indication of effective system heat capacity which steady-state data cannot. The system heat capacity in turn provides an indication of how much of the RCS is involved in the heat transfer process. Thus the new data provides an opportunity to further refine the existing analytical models and increases confidence in analytical predictions.

SESSMENT OF EXISTING MODELS

As a first step, the Quick Look draindown was simulated with the analytical models from the April 1982 analysis. The RCS heatup thus calculated was then compared to the measured RCS temperatures to assess the degree of conservatism in the existing analytical models. The comparison of the predicted and measured temperature trends is shown on Figure 1. As expected, the existing models predict higher RCS temperatures than actually measured. Thus it can be concluded that the models developed in the April 1982 analysis are conservative. Each model will be described briefly.

The existing models to be used in this assessment, decay heat generation, heat transfer, and heat capacity, were those developed in the April 1982 analysis to predict RCS temperatures after partial draindown. The decay heat model provides a conservative calculation of core power based on ANSI/ANS 5.1 - 1979 standard methodology. The decay heat power values for the time frame of interest are shown on Figure 2.

The heat transfer model assumes heat to be transferred only through the reactor vessel walls, lower dome, closure head, and hot legs. This model does not allow any heat transfer through the steam generators or cold legs to assure conservative results. Thus only the reactor building ambient air temperature is needed to predict RCS bulk water temperatures. The reactor building ambient temperatures used in both the previous and the current analyses are from the TMI-2 daily logsheets. Since only one reactor building temperature was recorded, it was necessarily assumed that the ambient air temperature is constant throughout the reactor building sump was $60^{\circ}F$ and that both RCS loops contribute to heat transfer, and also averaged temperatures for nodes between measured temperatures.) The conservative heat transfer model used in the current analysis is summarized in Table 1.

The heat capacity model includes only the success of the RCS consistent with the heat transfer model, i.e., only the success success and the water contained in it. This produces a conservatively sucle solute heat capacity which results in a fast RCS heatup. The heat capacity model is summarized in Table 2.

Having shown the existing models to be conservative, the drain down to reactor vessel head removal level can be simulated. The equilibrium temperatures and heatup rates thus calculated should be appropriate for licensing submittals.

2

CONSERVATIVE ANALYSIS OF DRAINDOWN TO HEAD REMOVAL LEVEL

Using the models as developed in the April 1982 analysis and as described in the preceding section with slight modification, the further RCS draindown to reactor vessel head removal level was simulated. The modifications to reflect the further draindown were a reduction in heat transfer area and a reduction in system heat capacity. It was assumed that no heat would be transferred through the reactor vessel head when drained down. This assumption reduces the reactor heat transfer area by 170 square feet. In addition, the lowering of the RCS water level reduces the system heat capacity. The resulting models are shown in Table 3.

The objective of this analysis was two-fold:

- To determine the equilibrium RCS bulk water temperature on several specific dates given the reactor building ambient temperature.
- To determine the RCS heatup rate starting at specified initial temperatures on specified dates.

The dates in question are December 1, 1982, July 1, 1983, and January 1, 1934. The reactor building ambient temperatures are 70° F in winter and 85° F in summer, and the initial RCS temperatures are 100 and 130° F.

The method used to calculate the equilibrium RCS temperatures is based upon the equation: $Q = IUA(t_{RCS}-t_{AMR})$

where: Q is decay heat

U is the air side film coefficient (since it is dominant)

A is the surface area

tprs is the reactor vessel bulk water temperature

^tAHB is the reactor building ambient temperature This equation can be solved for t_{RCS} since the values of all the other terms are known:

TRCS TAUE +Q/IUA.

The results of the equilibrium RCS techerature availysis with the RCS drained down to head removal level are as difficurs:

Date	Equilibrium	aus Hater	Temperature
December 1, 1982	i i	165.3 ⁰ F	
July T, 1983		158.0 ⁰ F	
January 1, 1984	••••••••••••••••••••••••••••••••••••••	130.3 ⁰ F	

It is significant to note that all of these equilibrium temperatures are less than the 170°F criterion adopted to maintain a positive margin to boiling.

The method used to calculate the RCS heatup rates following draindown is based upon the equation: $Q_{NET}(t)=Dmc_{D}(t_{NEXT}-t_{NOU})$

where: Q_{NET}(t) is the difference between decay heat generated and heat transformed out, discretized by time

Dmc, is the system heat capacity

twow is the RCS water temperature in the current timestep

tNEXT is the RCS water temperature for the next timestep

This equation can be rearranged and solved for sequential timesteps to calculate the RCS heatup rate starting at a given initial RCS temperature:

tNEXT=tNOW + QNET(t)/Emc

...

The results of this analysis of heatup rates are shown on Figure 3. The temperature traces are asymptotically approaching the equilibrium temperatures calculated above.

The results reported in this section support the conclusion that the RCS can be drained down to reactor vessel head removal level without exceeding the temperature criterion after December 1, 1982. These results, however, are conservative and are not expected to be observed during the actual RCS draindown. The next section identifies the sources of the conservatism in these results in preparation for a best-estimate calculation of temperatures that are expected to be observed during the RCS draindown.

IDENTIFICATION OF CONSERVATISM

In order to quantify the degree of conservatism in the results reported in the preceding section, best-estimate models for decay heat generation, system heat capacity, and heat transfer were generated. The Quick Look temperature data wis used for benchmarking best-estimate type models. Once these models were developed, temperatures resulting from the RCS draindown to reactor vessel head removal level were calculated.

I. Decay Heat

The ANSI decay heat prediction method is believed to be very conservative in its treatment of the neutron absorption factor (G factor) which causes high decay heat predictions during the time frame of interest. The TMI-2 decay heat analysis based upon the LOR-2 code (the B&W version of ORIGIN) is estimated to provide a more realistic prediction or best-estimate of the decay heat power levels. A comparison of the LOR-2 and ANSI based decay heat power levels is shown in Figure 4. The LOR-2 based decay heat power levels were used for best-estimate purposes.

II. System Heat Capacity

The system heat capacity was expanded significantly to reproduce the shape of the measured Quick Look temperatures. The physical description of the best-estimate system heat capacity is shown on Table 4. Minor core and reactor vessel internals contributions were added along with hot leg piping. The major new contributors, however, were the steam generators and the primary and secondary side water in them. Only 50% of the total available steam generator/water heat capacity, however, was needed to reproduce the measured temperature trace. This magnitude of effective contribution to system heat capacity appears credible and was thus assumed for best-estimate purposes.

III. Heat Transfer

The heat transfer model that expended to remain consistent with the system heat capacity model. In addition to the reactor vessel, the new heat transfer model included all of the hot legs and the steam generators. Since the hot leg to ambient and steam generator to ambient temperature difference is not known, a factor was determined which could be applied to the core to ambient temperature difference to estimate the effective hot leg or steam generator to ambient temperature difference. This factor, .27, balances the heat transfer to produce the measured terminal temperature at the end of the RCS heatup. One other refinement was made to the heat transfer coefficients. The constant value coefficients developed in the April 1982 analysis were replaced by temperature difference dependent air film correlations from the ASHRAE handbook. The best-estimate heat transfer model thus developed is summarized in Table 5.

The Quick Look draindown temperatures calculated with these best-estimate models are compared to the measured heatup temperatures in Figure 5. The agreement between measured and calculated temperatures is excellent. These best-estimate models were used to simulate the RCS draindown to reactor vessel head removal level.

:

BEST ESTIMATE ANALYSIS OF DRAINDOWN . TO HEAD REMOVAL LEVEL

Using the best-estimate models developed in the preceding section, the RCS draindown to head removal level can be simulated. Only a few modifications were needed to reflect the further draindown. The system heat capacity was decreased both by the lowered water level on the primary side and the assumed complete craining of the steam generator secondary side water. The total system heat capacity was reduced to $584,132 \text{ BTU/}^{\circ}\text{F}$. The only change to the heat transfer model was to assume that no heat is transferred through the closure head dome.

Using the same methods and reactor building ambient temperatures as before, but with the best-estimate models, the following equilibrium temperatures were determined:

Date		Equilibrium	RCS	Water	Temperature
·利尔省·利尔特的				-0-	
December	, 1982	•	m	.6~F	
July 1. 19	183		120	.1°F	

The July 1983 equilibrium temperature is higher than the December 1982 temperature (when more decay heat is being generated) because the ambient temperature assumed for July 1s 15° F higher (85° F versus 70° F). The heatup rates calculated with the best-estimate models assuming an initial RCS temperature of 100° F are shown on Figure 6. Again the temperature traces asymptotically approach the calculated equilibrium temperatures.

TO BOITOM OF REACTOR VESSEL NOZZLES

Several modifications to the existing conservative models developed for draindown to head removal level were made to reflect further draindown to the bottom of the reactor vessel nozzles. It was again assumed that no heat would be transferred through the reactor vessel head when drained down. In addition, because of the even lower water level, no heat was assumed transferred through the upper shell, head support and closure flange. This reduced the reactor heat transfer area an additional 390 square feet and also lowered the system heat capacity. (See Table 6)

The equilibrium RCS bulk water temperatures were determined for the previously specified dates and are as follows:

Date	Equilibrium	RCS Water	Temperature
December 1, 1982		198.0°F	
July 1, 1983		183.1°F	
January 1, 1984		151.1°F	

As the results above show, the existing conservative models do not predict RCS temperatures within the 170° F temperature criterion until January 1, 1984. The temperatures for earlier dates exceed the 170° F criterion. As noted on page 9, however, these conservative values are not expected to be observed during the actual RCS draindown.

The results of heatup rate calculations based on this conservative model are shown in Figure 7. The temperature traces asymptotically approach the above calculated equilibrium temperatures.

BEST ESTIMATE ANALYSIS OF DRAINDOWN TO BOTTOM OF REACTOR VESSEL NOZZLES

Modifications to the best-estimate models previously developed were made to reflect the further draindown. The system heat capacity was again decreased both by the lowered water level on the primary side and the assumed complete draining of the steam generator secondary side water. Uncertainty as to whether the steam generators would be in effective thermal communication with the core now that the cold legs were no longer full resulted in the development of two best estimate models: one including the heat transfer areas and heat capacities of the hot legs and steam generators and the other not including them. The uncertainty as to whether or not to include the hot legs and steam generators stems from uncertainty as to which of two possible heat transfer mechanisms accounted for the conbributions the hot legs and steam generators made to heat transfer and heat capacity that were deduced from heatup data following the draindown for Quick Look Inspection. One possible heat transfer mechanism is the convection of heated wapor up the hog legs to the steam generators. This mechanism would still function with the RCS water level at the bottom of the reactor vessel nozzles. The other possible mechanism is a stratified convective circulation through the cold legs to the steam generators. This mechanism would be interrupted by the reduced water level. Since the validity of each of the two possible heat transfer mechanisms is unknown. Two best estimate models are postulated. (See Table 7-10).

Using the same methods and reactor building ambient temperatures as before, but with the best-estimate models, the following equilibrium temperatures were determined:

Date	Equilibrium RCS Water Temperature		
	w/hot legs w/o hot leg		
	· & Steam Gen.	& Steam Gen.	
December 1, 1982	116.8°F	148.7°F	
July 1, 1983	124.6°F	151.5°F	
January 1, 1984	104.8°F	128.5°F	

Again, the July, 1983 equilibrium temperatures are higher than the December, 1982 temperatures because of the higher July ambient temperature (85°F versus 70°F). The heatup rates calculated with the best-estimate models are shown in Figures 8 and 9. These temperature traces also asymptotically approach the calculated equilibrium temperatures.

SUMMARY AND CONCLUSIONS

Both conservative and best-estimate equilibrium temperatures and heatup rates have been determined for draindown to the head removal level and to the bottom of the reactor vessel nozzles. The equilibrium temperatures and heatup rates calculated with the best-estimate models are predictably lower than those calculated with the models from the April 1982 analysis. For draindown to the head removal level (321.5 Ft. elevation), the conservative temperatures and heatup rates show that RCS temperatures do not exceed the 170°F criterion after December 1, 1982. The best-estimate temperatures and heatup rates are felt to be more representative of the expected RCS temperature response to the draindown to head removal level and are in the 110-120°F range. The conservative temperatures and heatup rates for draindown to the bottom of the reactor vessel nozzles (314 Ft. elevation) do exceed the 170°F criterion for December 1, 1982 and July 1, 1983. The best-estimate temperatures and heatup rates for this water level, however, are well below the criterion for all specified dates for the models both with and without hot leg/steam generator heat transfer areas.

It is the conclusion of these analyses that, based on the conservative models from the April, 1982 analysis, the RCS draindown to reactor vessel head removal level can be accomplished without exceeding the temperature criterion after December 1, 1982. Draindown to the bottom of the reactor vessel nozzles is supported by the conservative models from the April 1982 analysis after January 1, 1984. Based on the best-estimate models, however, RCS draindown to the bottom of the reactor vessel nozzles can be accomplished without exceeding the temperature criterion after December 1, 1982. The criterion is that RCS bulk water temperature does not exceed 170°F to insure adequate margin to boiling.

Original Heat Transfer Model

TABLE 1

1.

Sumponent	Heat Transfer Coefficient (BTU/hr-ft ² - ^o F)	Surface Area (Yt ²)
Bottom Head	.34	330
Lower & Intermediate Shells	.72	960
Upper Shells & Flanges	· .n	390
Closure Head Dome	89	170
Hot Leg Piping	.48	900

TABLE 2

Original Heat Capacity Model

Component	Mass (LBM)	Specific Heat (BTU/LBM-OF)	Heat Capacity (BTU/°F)
Reactor Vessel, Head & Studs	881,200	.115	101300
Water	248,500	1.00	248500
		Tota	349800

Conservative Bodel. Jos Draindown to Reactor Yessel Kend Removal Level

1. Heat Transfer Model

10.0

Component -	Heat Transfer Coefficient (BTU/HR-FT ² - ^U F)	Surface Area (FT ²)
Bottom Head	м.	330
Lower & Intermediate Si	hells .72	960
Upper Shells & Flanges	.71	390

2. Heat Capacity Model

Component	Mass (LBM)	Specific Heat (BTU/LBM-OF)	Heat Capacity (BTU/ ^O F)
Reactor Vessel, Head, & Studs	881,200	.115	101,300
Water	213,487	1.00	213,500
		Total	314,800

Page 18

1.47A.

2

Best Estimate Heat Capacity Model For Draindown To Reactor Vessel Head Removal Level

Component	•	Heat Capacity (BTU/OF)
Reactor Vessel, Head, & Studs		101,300
Core Support Assembly		27,600
Plenum Assembly		11,500
Core		19,100
Hot Leg Piping		18,900
Hater (Reactor vessel & hot legs)		270,500
Steam Generators		131,600*
Water (Primary side of stm. gen.)		82,700*
(Secondary side of stm. gen.)		123,700*
	Total	786.900

* - Only 50% of the available steam generator and water heat capacity assumed to contribute to system heat capacity to match Quick Look measured temperature trend.

. 7. 1

.

....

....

Con	iponent <u>ileat Yra.</u> (Ret	ference)	Surface Area (FT ²)
1)	Reactor Vessel		
	A. Bottom Head	1*	330
	B. Lower & Intermediate Shells	2	960
	C. Upper Shell & Flanges	2	390
	D. Closure Head Dome	3.	170
2)	Hot Legs		
	A. Reactor Vessel to Thermocouple	4	910
	B. Candy Cane	4	530
3)	Steam Generators	•	5050

TABL :

- 1 U=.10(At).33
- 2 U=.18(At).33
- 3 U=.22(At).33
- 4 U=.22(.274t).33

7:".

·

1

11.12.

1.200 200

T

.

Hot leg/ambient and stm. gen./ambient At estimated to be .27 of core/ambient At to match Quick Look measured temperatures.

Conservative Models' for Draindown

to Bottom of Reactor Vessel Nozzles

1. Heat Transfer Model

<u>Component</u> .	Heat Transfer Coefficient (BTU/HR-FT°- F)	<u>Surface Area</u> (FTº)
Bottom Head	.34	330
Lower & Intermediate Shells	.72	960
2. Heat Capacity Model		
Component. Mass	Specific Heat	Heat Capacity

Component	(LBM)	(BTU/LBM-°F)	(BTU/OF)
Reactor Vessel, Head, & Studs	881,200	.115	101,300
Water	162,300	• 1.00	162,300
		. Total	253 600

<u>Bast Estimate Heat Capacity Model for</u> <u>Draindown to Bottom of Reactor Veisel Nozzles</u> <u>With Hot Leg & Steam Generator Areas</u>

Component		Heat Capacity (BTU/°F)
Reactor Vessel, Head, & Studs		92,600
Core Support Assembly		27,600
Plenum Assembly		11,500
Core		19,100
Hot Leg Piping		18,900
Water (Reactor Vessel)		162,300
Steam Generators		131,600
Water (Steam Generators)		46,200
	Total	509,800

TABLE 8

Best Estimate Heat Capacity Model for Draindown to Bottom of Reactor Vessel Nozzles Without Hot Leg & Steam Generator Areas

Component	Heat Capacity (BTU/°F)
Reactor Vessel, Heal, & Studs	92,600
Core Support Assembly	27,600
Plenum Assembly	11,500
Core	19,100
Water (Reactor Vessel)	162,300
Tota	1 313,100

. 42

;

Best Estimate Heat Transfer Model for Draindown to Bottom of Reactor Vessel Nozzles With Hot Leg & Steam Generator Areas

Con	aponent	Heat Transfer Correlation* (Reference)	Surface Area (FT ²)
1)	Reactor Vessel		
	A. Bottom Head	1	330
	B. Lower & Intermediate Shells	2	960
2)	Hot Legs		
	A. Reactor Vessel to Thermocouple	3	910
	B. Candy Cane	3	530
3)	Steam Generators	3	5050

TABLE 10

Best Estimate Heat Transfer Model for Draindown to Bottom of Reactor Vessel Nozzles Without Hot Leg & Steam Generator Areas

Component				Heat Transfer Correlation* (Reference)	Surface Area (FT ²)
1)	Reactor Vessel				
	٨.	Bo	ttom Head	1	330
	B.	Lo	wer & Intermediate Sho	ells 2	960
	* - Heat Transfer Correlations: (BTU/HR-FT ² - ^o F)				
	1 U=.10(Δt) ^{.33} 2 U=.18(Δt) ^{.33} 3 U=.22(.27Δt) ^{.33} Hot leg/ambient and stm. gen./ambient Δt estimated to be .27 of core/ambient Δt to match Quick Look measured temperate			bient mbient temperatures.	
					Bass 22





. .,

٠.



••



....





•







-

. .

-

Summary

- The tensile test data of the subject wires tested compared very similarly to that of the new unused wire that was tested. The significance of this is that the tensile strength for these wires appears to have been unaffected by service conditions.
- SEM analysis shows that the new and used wires are similar except for the presence of surface residue (persumably from in-service and decontamination conditions).
- The EDAX analysis shows that the surface residue contains chlorine, potassium and silicon.
- 4. The microstructure examinations show no evidence of hydrogen damage. Both new and used wire show an identical microstructure cold worked high strength steel normal for the application. No evidence of corrosion was observed in any of the samples; hence, the presence of chlorine has not caused significant corrosion to date.
- 5. Microhardness data for the used and the control sample were similar. This indicates similar hardness, expected strength and lack of decarburized surface that would weaken the wire.

-

As a general assessment of the above data, the subject wires and the new control sample appear to have equivalent properties in terms of lift considerations.

.....

6

中にあ

İ

í

2

At >