Nuclear

GPU Nuclear Corporation

Post Office Box 480 Route 441 South Middletown, Pennsylvania 17057 717 944-7621 TELEX 84-2366 Writer's Direct Dial Number:

9

UT.

July 22, 1983 4410-83-L-0070

TMI Program Office Attn: Mr. L. H. Barrett Deputy Program Director US Nuclear Regulatory Commission c/o Three Mile Island Nuclear Station Middletown, PA 17057-0191

Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2) Operating License No. DPR-73 Docket No. 50-320 Containment Air Centrol Envelope

Attached for your review and approval are the Design Criteria and Technical Evaluation Report for the Containment Air Control Envelope (CACE) Building. These documents address the design and proposed use of the CACE. The CACE is intended to serve as a staging area for materials, equipment, and personnel being moved into and out of the containment. The CACE is not intended to serve as a storage area for radwaste being removed from containment. The CACE is designed not to hinder the removal of the equipment hatch. However, the Technical Evaluation Report does not support this activity.

Per the requirements of 10 CFR 170.22, the licensee has determined that a fee of \$4,000.00 is applicable for the Containment Air Control Envelope. This determination is based on the fact that the documents consist of a single safety issue. A check for \$4,000.00 is, therefore, enclosed.

If you have any questions or desire further information, please contact Mr. J. J. Byrne of my staff.

B. K. Kang

B. K. Kanga / Director, TMI-2

Doog Rec'd Chreek

8307260474 830722 PDR ADOCK 05000320 P PDR

BKK/RBS/jep

Attachments

CC: Dr. B. J. Snyder, Program Director - TMI Program Office

GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation

Containment Air Control Envelope (CACE)

Technical Evaluation Report



.

· ; ; ,

July, 1983 4410-83-L-0070

.1 . .

Containment Air Control Envelope Technical Evaluation Report Table of Contents

•

.

1.0	Intro	duction	Page 1	
	1.1	General	1	
	1.7	Organization of Report	1	
	1.3	Conclusions	1	
2.0	Facil	ity Description	1	
	2.1	Purpose of Facility	1	
	2.2	Summary Description	2	
		2.2.1 Location	2	
		2.2.2 Design Basis	2	
		2.2.3 Building Description	3	
	2.3	Major Systems	3	
		2.3.1 HVAC	3	
		2.3.2 Other Major Systems	5	
	2.4	Equipment Hatch Removal	5	
3.0	Technical Evaluations			
	3.1	Dose Assessment and Accident Analysis	6	
		3.1.1 On-site Dose Assessment	6	
		3.1.2 Offsite Dose Assessment	7	
	3.2	Occupational Exposure		
	3.3	Design Conditions		
		3.3.1 Normal Operation	9	
		3.3.2 Incidents of Moderate Frequency	10	
		3.3.3 Infrequent Incidents	10	
		3.3.3.1 Operating Basis Earthquake	11	
		3.3.3.2 Fire Protection	11	
4.0	Safe	ty Evaluation	11	
	4.1	Technical Specifications/Recovery Operations Pla	an 11	
	4.2	Safety Questions	12	

-i-

.

Revision 1

|1

INTRODUCTION

General

-

1

1

1.0

1.1

The Containment Air Control Envelope (CACE) provides space to mobilize equipment and materials needed to support the in-containment activities through defueling. Location of the CACE at the equipment hatch allows equipment and materials to be moved into and out of the containment building with a minimum of difficulty through the equipment hatch airlock doors. The CACE will serve as an aid in the control of the spread of contamination and airborne radioactivity during those times when the airlock doors are opened in accordance with procedures approved by the NRC.

This report does not apply to removal of the equipment hatch. A separate report will be prepared should it become desirable to remove the equipment hatch.

1.2 Organization of Report

This report is organized as follows:

After this introduction, a description of the design and operational considerations is presented. This is followed by a discussion of the safety issues associated with the facility. The report concludes with the safety evaluation required by 10 CFR 50, paragraph 50.59, "Changes, Tests and Experiments."

1.3 Conclusion

The evaluation of the safety concerns detailed in this report results in the following conclusions:

- The CACE fulfills the need for a facility which allows a large entryway into and out of the containment while acting as an aid in the control of the spread of contamination and airborne activity.
- The construction and operation of the facility is not an unreviewed safety question as defined in 10 CFR 50 paragraph 50.59.

2.0 FACILITY DESCRIPTION

2.1 Purpose of the Facility

The CACE is used as a staging/packing area for materials and equipment requiring transfer into or out of the reactor building, while helping to control airborne releases from the reactor building. Contaminated material may be wiped down, wrapped, or otherwise protected prior to being brought into the CACE.

Revision O

This building is temporary and is not designed to satisfy the criteria for a permanent TMI Unit 2 facility. The CACE is not designed to function as a storage area for radioactive waste, but will be used to temporarily stage radioactive material.

Summary Description

2.2

2.2.1 Location

As shown on Figure 1, the CACE is located southwest of the Unit 2 reactor building at the equipment hatch. The building is built on top of the existing control building area roof slab at the 305' elevation.

Access through the CACE personnel or equipment doors or through the M-20 area is controlled by Radiological Control Procedures.

2.2.2 Design Basis

The facility helps to control the releases of contamination and airborne radioactivity from the reactor building when both the equipment hatch airlock doors are open in accordance with procedures approved by the NRC. It also controls particulate releases from contaminated materials brought into the CACE from the reactor building. The CACE is a temporary facility which will be removed or upgraded to satisfy the criteria for a permanent TMI Unit 2 facility prior to plant restart.

The CACE structure is classified as Important to Safety for fire protection only. The HVAC equipment is classified as Not Important to Safety; however, the ventilation exhaust monitors are classified Important to Safety as the exhaust path is a release point. The reactor building purge system modifications are also classified as Important to Safety.

The CACE is designed for the probable natural phenomena as required by the local building codes. It does not have as part of its design basis the severe natural phenomena used for permanent nuclear power plant structures. Severe natural phenomena such as tornadoes, earthquakes, and probable maximum floods are not postulated to occur during the short-term design life of the CACE.

The CACE is designed to conform with 10 CFR Part 20.1 (c). This ensures that personal exposures associated with the CACE are ALARA. Transit and short-term staging of contaminated material in the CACE contributes to keeping exposures ALARA. In addition, access to the building will be controlled in accordance with the Radiological Control Procedures in effect at TMI Unit 2.

Revision 1

2.2.3 Building Description

The CACE, shown in Figures 2 and 3, is located adjacent to the reactor building. It is attached to the missile shield door -structure and the control building area roof slab which are seismically separated from the reactor building. The missile i shield door will be rolled back as shown in Figure 3 and the ; joints between the door structure and the adjacent structures will be sealed. The CACE structure will not prevent the rolling of the missile shield door back in front of the equipment hatch should it be required. The building has a structural steel frame with 2-hour fire rated metal siding for a fire from outside the CACC. The roof is non-fire rated galvanized metal decking. Access to the CACE is through a personnel door located on the north side of the building and a 27' roll-up truck door on the west side of the building. Personnel can also gain entry through the M-20 area and through the equipment hatch airlock from the reactor building. Interior surfaces are covered with sheet metal for ease of decontamination.

- 2.3 Major Systems
- 2.3.1 HVAC
- 2.3.1.1 Design Bases

The CACE HVAC design assures the following:

- a. Minimize the exfiltration of airborne contaminants to the outside environment
- b. Deleted
- c. Maintain the concentration of airborne particulate in the CACE below the limits defined in 10 CFR 20, Appendix B for 40 hour occupancy
- Direct air flow from the outside, through the CACE and into the reactor building
- e. Maintain a slight negative pressure inside the CACE with respect to the outside environment
- Limit differential pressure across the CACE walls to a saximum of 2 inches w.g.
- g. Operate in a manner not to reduce the reactor building average air temperature below 50°F
- h. Provide ventilation for the CACE
- 2.3.1.3 System Description
- 2.3.1.3.1 General Description

The CACE HVAC System consists of two filtered exhaust units, their associated ductwork, dampers, controls and three pressure relief intakes. The system interfaces with the

Revision 1

reactor building purge system on an operational basis when both equipment hatch airlock doors are open. The purge system maintains the reactor building atmosphere at a slightly higher negative pressure than the CACE to induce air flow from the outside, through the CACE and into the reactor building. There is no physical connection between the two ventilation (systems.

ⁱ The filtered exhaust system has three functions--to provide internal cleanup of the CACE atmosphere; to inhibit exfiltration by exhausting the building inleakage; and to reduce the amount of airborne particulate released to the environment. This system will be operated only when one or both equipment hatch airlock doors are closed. The exhaust units take inlet air from the CACE atmosphere, process the exhaust through a prefilter and HEPA filters, and discharge to the outside environment. The ventilation exhaust will be monitored for particulates in compliance with the Recovery Operations Plan. The HEPA filters will not be shop tested, but will be DOP tested in place.

Counterweighted pressure relief dampers are provided to limit differential pressure across the CACE walls to a maximum of 2 inches w.g. (negative pressure inside the CACE with respect to the outside environment). The dampers provide pressure relief to protect the structure.

Supplemental heating and cooling equipment will be provided for use, if required, to maintain a suitable environment for personnel and equipment.

2.3.1.3.2 System Operation

EXHAUST SYSTEM - The filtered exhaust system will be operated, as required, when one or both equipment hatch airlock doors are closed, to remove any airborne particulate contamination that may occasionally be present in the CACE. The system is started by a local handswitch. Normally one unit will be operated at a time, but both filter units may be operated simultaneously if required.

The exhaust system unit takes inlet air from the CACE atmosphere, processes the exhaust through a high efficiency prefilter and HEPA filters before discharging to the outside environment. An isolation damper is provided in each exhaust duct and each exhaust duct is isokinetically sampled for particulate activity. The radiation monitor is provided with local readout and alarm. Actuation of the alarm trips the filter unit and closes the isolation damper on high radiation. The handswitches provided on each filter unit may also be used to initiate building isolation.

-4-

Revision 1

PRESSURE RELIEF - Actuation of the relief mode is initiated by counterweighted pressure relief dampers set to open when differential pressure across the CACE walls exceeds 0.75 inches w.g. The dampers are provided for pressure relief only to protect the structure. The dampers will normally be closed.

SUPPLEMENTAL HEATING AND COOLING - Supplemental heating and cooling units will be operated, if required, to maintain a suitable environment for personnel and equipment. The heating and cooling units will be portable and will be operated independently of the CACE ventilation system. When operating, the units will also be used to circulate air in the CACE when one or both equipment hatch airlock doors are closed. Heating equipment can maintain a minimum temperature of 50°F in the CACE during winter. This equipment will be configured to ensure no release pathway is created from the CACE to the environment.

REACTOR BUILDING PURGE SYSTEM (Interaction with CACE) -Whenever both of the equipment hatch airlock doors are open, the reactor building purge system will be operated to induce airflow into the reactor building through the airlock doors. The purge system will be operated in two modes. In one mode the purge exhaust fan(s) operate and the purge supply fan(s) do not. Exhaust fan operation is controlled by a hand controller. In the other mode both purge supply and exahust fan(s) operate. Exhaust fan operation is controlled by an automatic differential pressure controller, maintaining a negative pressure in the reactor building.

2.3.2 Other Major Systems

1

Electrical service is provided to supply power for lighting, receptacles and electrically operated equipment. All electrical systems and the metal structure are grounded. Communications systems consist of surveillance cameras, a sound powered phone and dedicated P.A. system linked directly to the command center and/or the control room. A constant air monitor is provided with local readout and alarm. No permanent area radiation monitors are planned to be installed in the CACE since the radiation levels inside the CACE are expected to be low. Portable area radiation monitors will be added if required.

2.4 Equipment Hatch Removal

The CACE provides an area large enough to allow for removal and reinstallation of the equipment hatch. The roll-up truck door has been provided to allow removal of the equipment hatch from the CACE. The initial use of the CACE will only utilize opening of the airlock doors and will not utilize removal of the equipment hatch.

Revision 1

-5-

3.0 TECHNICAL EVALUATION

1

This section summarizes the licensing issues which were

considered in the design of the CACE. These issues deal with the expected performance of the facility during normal i operations and various design basis events.

The licensing issues associated with the operation of the CACE are:

- Demonstrating compliance with 10 CFR Part 20 with respect to on-site dose limits.
- Demonstrating compliance with 10 CFR Part 50, Appendix I, with respect to offsite radiation doses due to normal operations within the CACE.
- Assessing the consequences of potential accidents in the CACE that could lead to radioactive releases to the environment.
- o Demonstrating compliance with the principles of ALARA.
- Demonstrating that the design conditions specified in the TMI-2 General Project Design Criteria (GPDC) are satisfied.

Each of these issues is addressed in the following sections.

- 3.1 Dose Assessment and Accident Analysis
- 3.1.1 On-Site Dose Assessment

The CACE is designed for material handling activities that transfer material into and out of the reactor building. Measurements of the dose rate outside of the equipment hatch have been taken with the equipment hatch airlock doors closed and open. At a point approximately 6 ft. from the outer airlock door a dose rate of approximately .3 mrem/hr has been measured with the doors closed, while with both airlock doors open a dose rate of approximately .6 mrem/hr has been measured. Since .6 mrem/hr is the limit for an unrestricted area as defined by 10 CFR Part 20, paragraph 105(5)(2) and material handling may result in an increase in the general area dose rate in the CACE to a level above the unrestricted area limit, access to the CACE will be controlled by Radiological Control Procedures.

The staging of contaminated material in the CACE will temporarily increase the inside and possibly the outside area dose rates. Therefore, any staging of contaminated material

-6-

Revision 0

within the CACE will be controlled, monitored, and the operation reviewed prior to implementation in accordance with Radiological Control Procedures on a case-by-case basis. This does not preclude the establishment of procedures or limits for tasks which are generic in nature, such as staging of contaminated trash from the reactor building.

3.1.2 , Offsite Dose Assessment

3.1.2.1 Normal Operations

The handling of contaminated material in the CACE was evaluated to determine the resultant offsite doses. The only source for airborne radioactivity in the CACE will be the result of activities related to handling contaminated material from the containment. To assess this dose the following assumptions were made:

- a. The maximum exposed contaminated surface area that will be staged through the CACE annually is equivalent to the surface area of 10,000 drums (20,957 square meters).
- b. The surface contamination is 50,000 dpm/100 cm².
- c. 10⁻³ of the surface contamination is released due to material handling. This release fraction is conservatively based on the airborne release fraction due to a fire.
- d. No credit is taken for the CACE building or the CACE ventilation system.
- Isotopic distribution of contaminated surface is 84% Cs137, 12% Cs134, and 4% Sr90.

Table 3-1 lists the estimated annual airborne releases based on the above assumptions.

The dose to the public was calculated for these releases based on the following parameters:

a. The nearest garden and milk cow is located 1.1 miles east of the release point. The corresponding meteorological dispersion and deposition parameters at this location are 6.91 x 10^{-6} sec/m^3 and 2.05 x $10^{-8}/\text{m}^2$ for X/Q and D/Q, respectively, at this location.

b. The nearest residence is 0.5 mile east of the release point. The corresponding meteorological parameters are 7.83 x 10^{-6} sec/m³ and 1.71 x $10^{-8}/m^2$ for X/Q and D/Q, respectively, at this location.

The nearest milk goat is 1.2 miles north of the release point. The corresponding meteorological parameters are 7.83 x 10^{-6} sec/m³ and 1.71 x $10^{-8}/m^2$ for X/Q and D/Q, respectively, at this location.

-

1

1

c.

d.

The vegetable intake for the individual of interest is assumed to be from the location of the nearest milk cow and garden rather than from the nearest garden alone. This approach provides a higher calculated dose to the individual.

e. The does rate from the ground plane source was calculated based on the location of the nearest residence as described in b. above.

The resulting annual dose to the maximally exposed individual is summarized in Table 3-2.

3.1.2.2 Contaminated Material Fire

For the purpose of evaluating the consequences of a potential fire in the CACE the following assumptions were made:

- a. The maximum number of curies in the CACE at any one time is limited to 100 curies distributed as 84% Cs137, 12% Cs134, and 4% Sr90.
- b. A release fraction of 10⁻³ was used to estimate the airborne release based on the Atomic Energy Commission report, "Environmental Survey of Transportation of Radioactive Materials to and from Nuclear Power Plants," December 1972.
- c. No credit was taken for HEPA filtration or the CACE building.

The resulting inhalation dose was calculated at the exclusion area boundary distance of 610 meters. The 1-hour meteorological dispersion parameter (X/Q) of 6.1 x 10^{-4} sec/m³ for a ground level release was used as discussed in Appendix 2D of the Three Mile Island Unit 2 Final Safety Analysis Report (FSAR). The resulting doses are tabulated in Table 3-3.

3.1.2.3 High Velocity Winds

From the TMI-2 FSAR, the design wind velocity, based on the 100-year recurrence interval, is 80 miles per hour at 30 feet above grade. The CACE is designed to withstand this condition.

-8-

0073Y

An evaluation was conducted to assess the radiological consequences of a wind conditon at the design wind velocity. Assumptions used in this analysis include the following:

- a. The maximum number of curies in the CACE at any one time is limited to 100 curies distributed as 84% Cs137, 12% Cs134, and 4% Sr90.
- b. A conservative release fraction of 10^{-3} was used to estimate the airborne releases.
- c. No credit was taken for the ventilation or the CACE building.

The resulting inhalation dose was calculated at the exclusion area boundary distance of 610 meters. The meteorological dispersion parameter of $6.8 \times 10^{-6} \text{ sec/m}^3$ for an 80 mile per hour wind was used. The resulting doses are tabulated in Table 3-4.

3.2 Occupational Exposure

=

1

1

It is expected that the general arca dose rates that will be experienced in the CACE will be less than 1 mrem/hr. This dose rate will result in a small, but uncalculated, occupational exposure. However, use of the CACE reduces personnel exposure below that which would occur if the CACE were not used. Worker exposure is reduced because the CACE provides a lower background area to stage and assemble large pieces of equipment which would otherwise have to be transported into the containment and assembled there. This same area will allow contaminated material from the reactor building to be placed in drums or LSA boxes in a low radiation area. This will result in lower occupational exposure for activities associated with the reactor building. The minimum number of persons needed to perform activities are assigned to ensure that total exposure is ALARA. Access and operations within the CACE are controlled by Radiological Control procedures.

3.3 Design Conditions

The design conditions which must be satisfied are specified in the TMI-2 GPDC. These fall into three categories: normal operation, incidents of moderate frequency, and infrequent incidents. Each of these categories is addressed below.

3.3.1 Normal Operations

Normal operation conditions are discussed in the previous sections. These operations will be carried out without

Revision 0

-9-

0073Y

unplanned or uncontrolled releases of radioactive materials to the environment as a result of:

= °

1

 any radioactive material transferred into the CACE will be wiped down, wrapped, or otherwise protected such that the surface radioactivity is less than 50,000 dpm/100 cm² smearable.

- o When both equipment hatch airlock doors are open, the air flow will be from the CACE into the containment, and exhausted to the environment through the containment purge exhaust system.
- 3.3.2

۰,

Incidents of Moderate Frequency

The CACE and the equipment provided with the CACE serve no safety related functions and since there is no interface with any safety system, it will not interfere with the performance of any safety related feature. Therefore, loss of electrical power in the CACE, inadvertent actuation of a component provided with the CACE, single operator error associated with the operation of the CACE, or a single failure of an active component in the CACE will not endanger the health and safety of the public.

Failure of the reactor building purge system will not result in an uncontrolled release of radioactivity to the environment. Should the purge supply fail, pressure relief dampers are provided to protect the CACE from too great a negative pressure. Should the purge exhaust system fail, the purge supply system will be automatically shut down, preventing an overpressure in the CACE which could force radioactivity out of the CACE to the environment.

Normal operations in the CACE will involve the handling of contaminated radioactive material. During the course of handling the packages there is the possibility that a package could be broken open. This would not result in an uncontrolled release of radioactivity to the environment because of the design of the HVAC system, discussed in Section 2.3.1. Releases of radioactivity to the environment would be minimized by the filters in either the containment purge exhaust system or filtered exhaust system provided with the CACE. The result of a package breaking open is enveloped by the normal release calculation.

3.3.3 Infrequent Incidents

Rupture of tanks and pipe breaks are not considered because no tanks or liquid lines will be installed in the CACE. A fuel handling incident occurring in the CACE is not considered because fuel handling in the CACE is not planned. During fuel

11

11

1

handing in the containment, the airlock doors will be shut. This will ensure that releases of radioactivity to the environment will be within acceptable limits. The effect of fire and an operating basis earthquake are considered below.

3.3.3.1

Operating Basis Earthquake

In the event of an OBE, the CACE will not cause any damage to the reactor building because of the seismic expansion joint that separates the reactor building from the control building and the missile shield door structure to which the CACE is attached. The consequences of the collapse of the CACE on the control building roof slab are considered bounded by an aircraft impact, described in the TMI-2 FSAR.

3.3.3.2 Fire Protection

As noted in Section 2.2.2, opening both of the personnel airlock doors will be accomplished by procedures approved by the NRC. The existing procedure requires that when both airlock doors are open, someone is to be standing by to close the doors expeditiously in the event of an emergency. Should a fire occur in the containment when both of the airlock doors are open, one of the doors would be closed by the individual required by the procedure, and the control room notified, thereby reestablishing the containment boundary and preventing an uncontrolled release of radioactivity to the environment. The addition of the CACE will not change the reactor building fire boundary since the equipment hatch will remain installed.

4.0 SAFETY EVALUATION

10 CFR 50, paragraph 50.59, "Changes, Tests and Experiment," permits the holder of an operating license to make changes to the facility provided the change does not involve a modification of the plant technical specifications and the change is determined not to be an unreviewed safety question. As summarized below, the operation of the CACE neither requires a modification to the plant technical specification nor is it deemed to be an unreviewed safety question as defined in 10 CFR 50.

4.1

Technical Specifications/Recovery Operations Plan

The operation of the CACE will require no changes to the Technical Specifications.

Operation of the CACE with respect to staging contaminated material will require a change to the Recovery Operations Plan to specify the CACE ventilation as a possible release point. This change to the Recovery Operations Plan will be made prior

Revision 1

11

IF.

to operation of the CACE in this mode. A Recovery Operations Plan already exists (4.6.1.3, Rev. 17) which specifies the conditions under which both airlock doors can be

simultaneously opened. Since the opening of the airlock doors will continue in accordance with the existing procedures, the construction and operation of the CACE does not require (changes to the existing Recovery Operations Plan, except for the new release point.

Safety Question

4.2

The CACE does not increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluted in the safety analysis report. The containment integrity will be maintained with the CACE installed in accordance with existing technical specifications. As can be seen from Figures 2 and 3, the CACE is supported by the existing hatch shield area (i.e., missile shield support structure) and does not interfere with movement of the missile shield. The CACE is attached to the missile shield door structure and the control building area roof slab which are seismically separated from the reactor building itself. There is no interface between systems provided in the CACE and any safety related systems. Therefore, the CACE will not impact existing safety related structures or systems and there will be no increase in the probability of an accident or malfunction of equipment important to safety.

The possibility of an accident or malfunction of a different type than any previously evaluated in the safety analysis report is not created by the existence of the CACE. This is due primarily to the passive nature of the facility and the ability to quickly reestablish containment integrity in the event of an emergency. Also, the operation of the CACE does not result in a reduction in the margin of safety as defined in the technical specifications since the CACE does not impact any systems covered in the technical specifications and any release of radioactivity from the CACE will be monitored for compliance with environmental technical specifications.

Based on the above, the CACE is deemed not to be an unreviewed safety question as defined in 10 CFR 50.

Revision 1

÷.

TABLE 3-1

- CALCULATED ANNUAL AIRBORNE RELEASES FROM THE CACE

-

.

Radionuclide	Annual Release (curies)
св-137	4 x 10 ⁻⁵
Св-134	4.7×10^{-6}
Sr-90	1.9×10^{-6}

÷.

TABLE 3-2

ESTIMATED ANNUAL DOSE TO THE MAXIMALLY EXPOSED INDIVIDUAL FROM RELEASES FROM THE CACE

I.

-

1 1

12 .

\$. .

> Annual Dose from Inhalation, Vegetable Intake, Cow Milk, and Ground Plane

	Dose to Organ (mrem/yr))
Age Group	Bone	Total Body	Lung	Skin
Adult	.12E-2*	.71E-3	.70E-3	.22E-3
Teen	.16E-2	.72E-3	.13E-3	.22E-3
Child	.30E-2	.79E-3	.18E-3	.22E-3
Infant	.13E-2	.32E-3	.16E-3	.22E-3

II. Annual Dose from Inhalation, Vegetable Intake, Goat Milk, and Ground Plane

	Dose to Organ (mrem/yr)			
Age Group	Bone	Total Body	Lung	Skin
Adult	.15E-2	.95E-3	.11E-3	.22E-3
Teen	.21E-2	.95E-3	.21E-3	.22E-3
Child	.41E-2	.97E-3	.30E-3	.22E-3
Infant	.30E-2	.49E-3	.38E-3	.22E-3

* $.12E-2 = .12 \times 10^{-2}$

TABLE 3-3

102

٠,

1

= INHALATION DOSE ESTIMATE AT THE EXCLUSION AREA BOUNDARY FOR A FIRE IN THE CACE

Organ	Controlling Age Group	Dose (mrem)	
Bone	Teenager	13.0	
Total Body	Adult	1.9	
Lung	Teenager	2.1	

-

TABLE 3-4

•

-

1

INHALATION DOSE ESTIMATE AT THE EXCLUSION AREA BOUNDARY FOR A HIGH VELOCITY WIND

Organ	Controlling Age Group	Dose (mrem)	
Bone	Teenager	0.15	
Total Body	Adult	0.02	
Lung	Teenager	0.023	



4410-83-L-0070



....







Containment Air Control Envelope (CACE)

.

*

.

Design Criteria

July, 1983 4410-83-L-0070

DESIGN CRITERIA

1.10

FOR

CONTAINMENT AIR CONTROL ENVELOPE (CACE)

FOR

GPU NUCLEAR CORPORATION

THREE MILE ISLAND - UNIT 2

TABLE OF CONTENTS

Sect	<u>:fon</u>	Page
1.0	FUNCTION	1
2.0	SCOPE	1
3.0	FACILITY DEFINITION	1
4.0	FUNCTIONAL REQUIREMENTS	2
5.0	FACILITY DESIGN REQUIREMENTS	3
6.0	REFERENCES	6
7.0	GENERAL PROJECT DESIGN CRITERIA (GPDC) EXCEPTIONS	6

1.0 FUNCTION

12.9

The Containment Air Control Envelope (CACE) is to be used as a staging area for materials and equipment requiring transfer into or out of the reactor building, while preventing uncontrolled airborne releases from the reactor building. It will also be used for handling contaminated materials transferred out of the reactor building. Contaminated materials may be wiped down, packaged, and placed in drums or low specific activity (LSA) boxes in the CACE. The CACE is intended to support recovery activities through defueling only and will not be designed to satisfy the criteria for a permanent TMI Unit 2 facility. Furthermore, it is not intended to function as a storage area and will not be used to store the equipment hatch when removed.

2.0 SCOPE

The CACE will be designed and constructed in accordance with criteria established herein. These include constraints in the form of codes, regulations, and standards. This criteria document addresses essential design requirements. Additional criteria are delineated in the General Project Design Criteria.

- 3.0 FACILITY DEFINITION
- 3.1 FUNCTION

See Section 1.0.

3.2 INTERFACES

3.2.1 The following interfaces are associated with this facility:

- a. An interface with the control building area roof slab will be required to provide a foundation for the CACE.
- b. An interface with the reactor building purge system, to maintain airflow from outside through the CACE into the reactor building, will be required while both personnel air lock doors are opened or the equipment hatch is removed.
- c. An interface with the missile shield door will be required to allow for its closure.
- d. An interface with the existing plant electrical system will be required to provide power for lights and utility outlets.
- e. An interface will exist between the CACE and the command center for surveillance and communication.
- f. An interface with Plant Security will be required to maintain controlled access into the CACE whenever the personnel air lock door is open.

2

2

3.2.2 Provisions for future interfaces with the Containment Recovery Service Building (CRSB) will not be considered.

4.0 FUNCTIONAL REQUIREMENTS

4.1 FUNCTIONS

The CACE will perform no safety-related or important-to-safety function with the equipment hatch in place. The CACE will be classified as important-to-safety for fire protection only for future removal of the equipment hatch. The ventilation exhaust monitors will also be classified as important-to-safety since the exhaust path is a release point to the environment. The facility will support recovery activities through defueling; specifically, the material handling activities that will transfer material into and out of the reactor building through the equipment hatch. The CACE must also allow for the removal of the equipment hatch and reinstallation.

4.2 ACCESSIBILITY

Personnel access to the CACE will be by either direct entry from outside or through the M-20 area (El. 280'-6" of the control building area). A roll-up door will be provided for material and equipment access. Access will be controlled by Radiological Control Procedures.

4.3 MAINTAINABILITY

This facility shall require no preventive maintenance for at least 5 years.

4.4 PERSONNEL

Personnel activities within the CACE will be temporary in nature. Personnel will be needed in the CACE to perform material handling, including packaging of contaminated materials into drums and LSA boxes. The minimum number of persons needed to perform activities will be assigned to ensure that total exposure is "As Low As Is Reasonably Achievable" (ALARA).

4.5 SAFETY

4.5.1 Compliance with the codes, standards, and regulations of Section 5.2 will ensure that the facility will not have an unacceptable impact on public health and safety.

4.5.2 The site's Radiation Protection Plan, which implements the requirements of 10 CFR 20.1(c), will ensure that personnel exposures associated with the CACE are ALARA.

5.0 FACILITY DESIGN REQUIREMENTS

5.1 GENERAL REQUIREMENTS

.

5.1.1 The facility will serve as an aid in the control of the spread of contamination and airborne radioactivity during those times when the air lock doors are opened in accordance with procedures approved by the NRC. The CACE is a temporary facility which will be removed, or upgraded to satisfy the criteria for a permanent TMI Unit 2 facility, prior to plant restart. It will be designed for the probable natural phenomena as required by local building codes. It will not have as part of its design basis the severe natural phenomena used for permanent structures, such as: the safe shutdown earthquake (SSE), tornadoes and tornado missiles, and the probable maximum flood. These severe natural phenomena are not postulated to occur during the short-term design life of the CACE.

5.1.2 The reactor building average air temperature must be maintained at least 50 F. The CACE will be designed and operated in a manner that will not cause this requirement to be violated.

5.2 CODES, STANDARDS, AND REGULATORY REQUIREMENTS

5.2.1 Federal

5.2.1.1 10 CFR Part 20, "Standards for Protection Against Radiation"

5.2.1.2 10 CFR Part 50, Appendix I, "Numerical Guides for Design Objectives and Limiting Conditions for Operation to Meet the Criterion 'As Low As Is Reasonably Achievable' for Radioactive Material in Light-Water-Cooled Nuclear Power Reactor Effluents"

5.2.1.3 Appandix A to APCSB 9.5-1, "Guidelines for Fire Protection for Nuclear Power Plants Docketed Prior to July 1, 1976"

5.2.2 Industry

The facility will be designed in accordance with the applicable portions of the following industry and state codes:

5.2.2.1 American Institute of Steel Construction (AISC), "Specification for the Design, Fabrication, and Erection of Structural Steel for Buildings," November 1, 1978

5.2.2.2 American Concrete Institute (ACI), "Building Code Requirements for Reinforced Concrete," (ACI 318-77)

5.2.2.3 Building Officials and Code Administrators International, "The BOCA Basic Building Code," 1978

5.2.2.4 National Electrical Code (NEC)

5.2.2.5 Pennsylvania Code for Fire and Panic Regulations by the Department of Labor and Industry, 1978

Page 3 Rev. 2

5.2.2.6 American National Standards Institute (ANSI), "Building Code Requirements for Minimum Design Loads in Buildings and Other Structures," (ANSI A58.1-1972)

5.2.3 United States Nuclear Regulatory Commission (USNRC)

Regulatory Guide 8.8, "Information Relevant to Ensuring that Occupational Radiation Exposure at Nuclear Power Stations Will Be As Low As Is Reasonably Achievable," Rev. 3, June 1978

5.3 HVAC REQUIREMENTS

5.3.1 The reactor building purge system will be used to control leakage and to prevent uncontrolled releases of radioactivity from the reactor building/CACE by inducing airflow from outside through the CACE to the reactor building when both air lock doors are opened or the equipment hatch is removed. Provisions will be included to limit the differential pressure between the CACE and the outside to a maximum of 2 inches of water. If required, heating or cooling will be provided in the CACE to the extent necessary to ensure personnel comfort. This supplemental heating and cooling is to be designed to ensure no release pathway is created from the CACE to the environment.

5.3.2 The CACE filtered exhaust system will be operated, as required, when one or both air lock doors are closed, to remove any airborne particulate that may occasionally be present in the CACE. In addition, the exhaust system will provide the capability to maintain the CACE at negative pressure to ensure against uncontrolled exfiltration to the environment. The discharge path for the exhaust/ventilation system used to maintain the CACE at negative pressure will meet the present requirements for monitoring and filtration of airborne, potentially radioactive release points at TMI-2.

5.4 MATERIALS

The CACE building frame will be constructed of structural steel members. The roof will be galvanized, nonrated metal decking and the sides will be 2-hour fire-rated siding.

5.5 LAYOUT REQUIREMENTS

The CACE will be located on top of the existing control building area roof slab. The CACE layout will be limited to fall within the extent of the control building area roof slab adjacent to the reactor building equipment hatch. The CACE will be sized to accommodate materials currently identified as requiring transfer into or out of the reactor building to support recovery efforts through defueling. A roll-up door of sufficient size to permit equipment hatch removal will be provided.

5.6 DRAINAGE REQUIREMENTS

No floor drainage system is required. When water is used in the facility, it will be contained and manually removed.

5.7 STRUCTURAL REQUIREMENTS

. .

In addition to dead loads, the facility shall be designed to satisfy the following requirements:

5.7.1 The snow load shall be based upon a ground snow load of 30 psf and shall be proportioned using the appropriate snow load distribution and coefficients, as given in Section 711 of the BOCA Basic Building Code.

5.7.2 The wind load shall be determined in accordance with ANSI A58.1 for a design wind velocity of 80 mph at 30 feet above grade.

5.7.3 Seismic loads shall be determined in accordance with Section 716 of the BOCA Basic Building Code for seismic zone 1.

5.7.4 The differential pressure due to a malfunction of the facility ventilation system as described in Section 5.3 shall be considered in the design of the structure.

5.7.5 Floor loads for the CACE will be limited by the allowable load capacity of the existing control building area roof slab.

5.8 ARCHITECTURAL REQUIREMENTS

The exterior wall panels will have a 2-hour fire rating. Metal roof decking will be nonrated. Interior surfaces will be designed for ease of decontamination. The CACE will be equipped with both a personnel door and a roll-up door. Security devices will be provided at these doors.

5.9 FIRE PROTECTION REQUIREMENTS

Fire protection will consist of portable fire extinguishers and a dry fire hose run from an existing hydrant. Combustibles allowed within the CACE will be administratively controlled.

5.10 ELECTRICAL REQUIREMENTS

Electrical power will be provided to supply lighting, receptacles, heating, and ventilation (120/208 volt, single phase, 60 Hz, and 480 volt, 3 phase, 60 Hz). A lighting level of 40 footcandles will be provided. All electrical systems and the metal structure will be grounded.

5.11 COMMUNICATIONS

5.11.1 Surveillance cameras with pan/tilt, focus, and zoom capability shall be located in the CACE. Camera, pan/tilt, and zoom lens controls shall be located in the command center with the camera monitors.

5.11.2 A sound-powered phone in the CACE shall provide a direct communications link with the command center. 2

2

2

5.12 SUPPORT SERVICE REQUIREMENTS

5.12.1 Water

.

No permanent water supply is to be provided. Water, when needed, will be furnished by temporary/portable means.

5.12.2 Service Air

No permanent service air supply system is required. Service air, when required, will be furnished by a portable compressor or compressed air cylinder.

5.12.3 Material Handling

The existing overhead hoisting system will be used for equipment hatch removal. All other material handling equipment will be portable and self-contained (e.g., lifting rigs, electric forklifts, etc.).

5.13 RADIATION MONITORING

A constant air monitor will be provided with local readout and alarm capability. No area radiation monitors are required for this structure.

6.0 REFERENCES

General Project Design Criteria, 13587-2-G01-100

7.0 GENERAL PROJECT DESIGN CRITERIA (GPDC) EXCEPTIONS

Any exceptions between this facility criteria and the GPDC are noted below for each section of the GPDC.

7.1 GENERAL SECTION

There are no exceptions between this facility criteria and the General section of the GPDC.

7.2 ARCHITECTURAL SECTION

There are no exceptions between this facility criteria and the Architectural section of the GPDC.

7.3 CIVIL/STRUCTURAL SECTION

There are no exceptions between this facility criteria and the Civil/ Structural section of the GPDC.

7.4 CONTROL SYSTEMS SECTION

The following exceptions are taken. Paragraph numbers refer to the Control Systems section of the GPDC.

Page 6 Rev. 2

11.2.4 Effluent monitor has local readout only.

11.2.5 Effluent monitor is recorded locally only. Flow rate is not recorded - constant flow system.

11.4 Effluent monitor has local alarms only.

11.5 Effluent monitor is not provided with a check source.

7.5 ELECTRICAL SECTION

....

There are no exceptions between this facility criteria and the Electrical section of the GPDC.

7.6 PLANT DESIGN/MECHANICAL SECTION

There are no exceptions between this facility criteria and the Plant Design/Mechanical section of the GPDC.

7.7 NUCLEAR SECTION

There are no exceptions between this facility criteria and the Nuclear section of the GPDC.