



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number

August 1, 1983
4410-83-L-0162

TMI Program Office
Attn: Mr. L. H. Barrett
Deputy Program Director
US Nuclear Regulatory Commission
c/o Three Mile Island Nuclear Station
Middletown, PA 17057-0191


Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Reactor Vessel Head and Internals Handling Fixture

Attached for your review is the TMI-2 Reactor Vessel Head and Internals Handling Fixture Serviceability Evaluation which was prepared in response to your letter NRC/TMI 83-091 dated July 8, 1983. The conclusion of this evaluation is that the Head and Internals Handling Fixture is acceptable for use in performing the Polar Crane Load Test.

If you have any questions, please contact Mr. J. J. Byrne of my staff.

Sincerely,


B. K. Kanga
Director, TMI-2

BKK/JJB/jep

Attachment

CC: Dr. B. J. Snyder, Program Director - TMI Program Office

8308040262 830801
PDR ADOCK 05000320
P PDR

GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation

1983 AUG 1 PM 12 30

U.S. NUCLEAR
REGULATORY COMMISSION

0009
1/0