DISTRIBUTION:
DN 50-320
NRC PDR
Local PDR
DCS
TMI Site r/f
TMI HQ r/f
BJSnyder
TCPoindexter
MMasnik
RWeller
PGrant
AFasano
LChandler
I&E
ACRS
HDenton
M-Town Office

July 17, 1984
NRC/TMI 84-052

Docket No. 50-320

Mr. B. K. Kanga
Director, TMI-2
GPU Nuclear Corporation
P. O. Box 480
Middletown, PA 17057

Dear Mr. Kanga:

We have reviewed your request to delete the requirement to isolate Reactor Building Air Coolers during load handling operations in the reactor building (letter 4410-84-L-0098). Based upon the information provided in the letter and additional communication between you staff and the NRC staff we concur with your request.

We note that your supporting data and analysis limit you to a maximum content of 100,000 gallons and a minimum boron concentration of 1700 ppm in the reactor building sump and an inventory requirement of 175,000 gallons of BWST water at 4850 ppm boron. We anticipate your submittal of procedure controls implementing the above limits for our review and approval.

/s/

Philip J. Grant
Acting Deputy Program Director
TMI Program Office

cc: J. Barton
R. Rogan
R. Freemerman
A. Miller
J. Byrne
Service Distribution List

8408010105 840717
PDR ADOCK 05000320
P PDR

OFFICE	TMI:PO	TMI:PO					
SURNAME	LHThonus:wa	PJGrant					
DATE	7/17/84	7/17/84					