

GPU Nuclear Corporation

Post Office Box 480 Route 441 South Middletown, Pennsylvania 17057 717, 944-7621 TELEX 84-2386 Writer''s Direct Dial Number

(717) 948-8461

4410-87-L-0108 Document ID 0142P

July 21. 1987

US Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555

Dear Sirs:

Three Mile Island Nuclear Station, Unit 2 (TMI-2) Operating License No. DPR-73 Docket No. 50-320 Pressurized Defueling Safety Evaluation Report

Attached for your review and approval is Revision 3 of the Pressurizer Defueling Safety Evaluation Report (SER). This revision supercedes Revision 2 which was submitted to the NRC on March 11, 1987. This revision permits the process stream to bypass the Defueling Water Cleanup System (DWCS) filter canisters. The primary system flowpath will process the discharge from the pressurizer through a knockout canister and return it directly to the Reactor Vessel (RV) through the DWCS. This flowpath will enable pressurizer defueling to be performed without affecting ongoing water clarity operations. The capability to use the DWCS filter canister will be maintained. This evolution is currently scheduled to commence the second week of August 1987.

Sincerely,

F. R. Standerfer Director, IMI-2

FRS/CJD/sle

Attachment

CC: Regional Administrator, Region 1 - W. T. Russell Director. TMI-2 Cleanup Project Directorate - Dr. W. O. Travers 8707270400 870721 PDR ADUCK 05000320 PDR PDR

GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation



SAFETY ANALYSIS

SA #_____3255-86-0907 . Rev. #_____ Page _____ cf ____12

TITLE

SAFETY ANALYSIS REPORT

FOR THE

PRESSURIZER DEFUELING SYSTEM

Dete 7.9.87 CONCURRENCE 4000-61-7310.09-1 (9/86) Leed Engineer Dete Date 7/9/87 Rad Com unizant Er APPROVAL En section Placen For RE. CALLAGAE 7/10/917 Streeter Will and all for WEBRATE 20187 8707270405 870721 PDR ADOCK 05000320 PDR

Rev. <u>3</u> Page <u>2</u> of <u>12</u>

SAFETY ANALYSIS REPORT FOR THE

PRESSURIZER DEFUELING SYSTEM

PURPOSE AND SCOPE

The purpose of this safety analysis is to demonstrate that the addition of the Pressurizer Defueling System, for removing fuel debris, will not result in any harmful effects to the reactor coolant system inventory or undue risk to the nealth and safety of the public.

The scope of this safety analysis includes only those new components such as the submersible pump, flexible hose, nozzles, instrumentation, piping, and valves. It does not include existing components such as the Defueling Water Cleanup System (DWCS).

BACKGROUND

Due to the effects of the TMI-2 accident on March 28, 1979, fuel and/or core debris have been located throughout the Nuclear Steam Supply System (NSSS), which includes the pressurizer. Several investigations were performed to determine the quantity of fuel debris in the pressurizer. The first investigation was performed using spectrometry measurements taken under the lower head of the pressurizer adjacent to the surge line elbow. The results of this first investigation indicated that 100 to 200 grams of uranium were deposited in the eastward section of the pressurizer surge line

Rev. <u>3</u> Page <u>3</u> of <u>12</u>

(Reference 1). A second investigation was performed using a sodium iodide scintillation spectrometer assembled under the pressurizer to detect fuel related photon events. The results indicated that 11 to 25 KG of uranium were deposited on the bottom of the pressurizer (Reference 2). The third investigation was performed using a video camera and by collecting samples. Observations with the video camera concluded that a maximum of 12 liters of finely divided debris exists within the pressurizer. However, based on the sample of sediments taken from the inside of the pressurizer, the total fuel quantity was determined to be 910 grams (Reference 3). Reference 4 suggests that additional samples be taken to resolve the differences between estimates obtained from video observations and sample analysis.

SYSTEM DESCRIPTION

The recommended method of defueling the pressurizer is to vacuum the debris out of the pressurizer using a submersible pump. This method is preferred over a method using an external pump because of the long suction height of approximately 40 feet. Other methods of defueling the pressurizer were considered but were determined to be uneconomical or inefficient.

The Pressurizer Defueling System utilizes a portion of the DWC System to provide a flow path back to the reactor vessel. Inherent in the design of the DWC System, is the capability to use filter canisters and/or knockout canisters as part of the process stream to filter and remove fuel debris. Although this debris separation capability exists, and may be used if defueling conditions warrant, present baseline plans are to bypass the filter canisters and return the process stream directly to the reactor vessel.

Rev. <u>3</u> Page <u>4</u> of <u>12</u>

The Pressurizer Defueling System will remove fuel debris from the pressurizer by pumping water out of the pressurizer. This water is expected to contain mostly fuel fines with maximum particle size of 1/4" (this is limited by the pump). In order to ensure an adequate transport velocity for this debris, a flow rate of 100 GPM will be delivered by the pump into a discharge hose of 2 inch diameter. The flow will be directed to a knock-out canister where those particles exceeding 800 microns will be retained (Reference 8). The water is then directed to either the DWCS filters or directly to the reactor vessel where the remaining fuel fines are collected. The water is then routed from DWCS back into the pressurizer via an agitation supply line. This line is equipped with a nozzle which promotes agitation of the water inside the pressurizer, thus suspending fuel fines, which increases the efficiency of the vacuuming process. Appropriate valving and instrumentation will be used to monitor and control the flow. Attachment 1 serves as the basis for this system description.

SYSTEM COMPONENTS

PUMP

The pump is a submersible centrifugal type, capable of handling solids up to 1/4" in size. The junction chamber (where the electric cable interfaces with the terminal connections) has separate water sealing and strain relief functions. This junction chamber is sealed off from the motor, preventing burn out should moisture enter the junction chamber. Ferminal board connections can be changed to suit service voltage requirements. The motor windings are rated at 310°F and the motor is

09528 PC

Rev. <u>3</u> Page <u>5</u> of <u>12</u>

sealed and runs in air. The pump has an integral cooling system that allows the unit to pump continuously with the motor above liquid level. The impeller is constructed of abrasion-resistant steel.

AGI ATION NOZZLES

These nozzles are two-piece cast type with an internal removable vane and are made of 300 series stainless steel.

HOSE

This is a rubber hose of braided construction. The working pressure of the hose is 30G psi, which is well above the maximum working pressure the submersible pump can deliver (approximately 195 psi). Normal system operating pressure is 140 psig. The hose is supplied in 100 foot lengths, which will minimize the number of connections. The lose is capable of operating in a radiation environment of 1.8×10^6 rads, and is also capable of handling suspended solids. The hose is color coded to avoid misconnection or confusion with other hoses.

SUPPORTING ACCESSORIES

Piping, pipe fittings, pipe flanges, and valves are stainless steel. These components are also rated for the maximum system pressure and conform to the American National Standards Institute (ANSI) code.

Rev. <u>3</u> Page <u>6</u> of <u>12</u>

Instrumentation such as flow and pressure indicators will not be restricted due to suspended particles. Existing long handled tools will be used as required and are not covered by this report.

DEFUELING WATER CLEANUP SYSTEM (DWCS)

This is an existing system with its own safety analysis. The tie-in locations into DWCS will be addressed by the appropriate engineering change authorization.

BORON DILUTION

During operation of the Pressurizer Defueling System, water from the reactor vessel will mix with water contained in the pressurizer via the DWC system and agitation supply line. This will result in a more uniform boron concentration between the two vessels. Reference 7. Section 3.1.1.2 gives limiting conditions for boron concentration, that the Pressurizer Defueling System will not violate. In addition, since the Pressurizer Defueling System is a closed loop system, no other water sources are introduced as possible boron dilution paths.

RADIOLOGICAL CONTROLS

No direct radioactive release paths to the environment exist for this system. Any spillage of contaminated water from the Pressurizer Defueling System will result in a local contamination problem. To preclude any significant

Rev. <u>3</u> Page <u>7</u> of <u>12</u>

radioactive releases during pressurizer defueling, the operating procedures associated with processing reactor vessel water shall include requirements to ensure isolation of the system should a line break occur.

The following table provides an estimate of the man-hours and man-rem associated with the installation, operation and removal of the Pressurizer Defueling System. These estimates are based upon current man-hour projections:

LOCATION	ACTIVITY	MAN-HOURS	(mR/Hr) Y	MAN-REM
R.B. Floor at Elev. 348'-3"	Installation Operation Removal	49 9 4	50 mRem	2.45 .45 .2
"A" D-Ring at Elev. 367'-4"	Installation Operation Removal	10 0 1	50 mRem	.5 0 .05
Pressurizer Missile Shield at Elev. 370'-4"	Installation Operation Removal	22 133 4	50 mRem	1.1 6.65 .2
Pressurizer Platform at Elev. 349'-9"	Installation Operation Removal	15 35 1	1000 mRem	15.0 35.0 1.0

TOTAL 62.6

The total man-rem attributable to the installation, operation, and removal of the Pressurizer Defueling System, as a whole, is expected to be approximately 62.6 man-rem. The estimate includes coverage by Health Physics.

This man-rem estimate is considered the maximum dose for this job for the following reasons:

Rev. 3 Page 8 of 12

- 1.) For this man-rem estimate it is conservatively assumed that during system checkout and operation a worker is continuously positioned at the pressurizer manway. The Pressurizer Defueling System is controlled from a station on the pressurizer missile shield, but manipulation of the agitation nozzle is performed from the manway location. It is considered llkely that the agitation nozzle will not need to be continuously manned and that only a fraction of the estimated time for operations at the manway will be expected.
- 2.) The dose rate at the manway location is conservatively estimated to be 1 rem/hr. Worker position as well as portable shielding will be used when practical to reduce the operator's dose rate.

Personnel protection for airborne and other potential contamination generated by the installation, use, and/or removal of the Pressurizer Defueling System will be addressed in the appropriate plant procedures.

The routing of hoses and the location of valves for the Pressurizer Defueling System will be such that dose rates to personnel performing tasks unrelated to pressurizer defueling will be minimized.

LINE BREAK

Hose and piping will be hydrostatically pressure tested prior to use to ensure against any potential line break or failure. In the unlikely event of a hose rupture or line rupture upstream or downstream of the submersible pump, the system will trip the pump on IIF low level and alarm at the local control

Rev. <u>3</u> Page <u>9</u> of <u>12</u>

panel. The pump will trip on IIF low level because it will be electrically interlocked with the IIF water level monitoring instrumentation (Reference 5). This event could deliver approximately 500 to 1000 gallons of reactor vessel water to the area of the break.

Siphoning of reactor vessel water from the pressurizer through the agitation supply line is prevented by the placement of a check valve in close proximity to the pressurizer. This check valve will prevent water from flowing out of the pressurizer should a hose break occur inside the pressurizer. A hose break in the submersible pump discharge line is of no concern with respect to siphoning, since all unsubmerged piping and hose outside of the pressurizer is at or above the Reactor Vessel water level.

10CFR50.59 EVALUATION

The Pressurizer Defueling System does not increase the probability of occurrence or the consequences of an accident or malfunction of equipment important to safety previously evaluated in a safety analysis report. The system failures such as boron dilution, radiological impact, and line break have been addressed in previous sections of this document. In addition, operation of the Pressurizer Defueling System will be performed under strict administrative procedural control to further ensure safe operation. The procedures used for operation of the Pressurizer Defueling System will be reviewed and approved prior to use in accordance with Reference 7, Section 6.8.1.

Rev. <u>3</u> Page <u>10</u> of <u>12</u>

A

The Pressurizer Defueling System is essentially a liquid radwaste system utilized to transport radioactive material from the pressurizer into a knockout canister and into DWCS filter canisters or the reactor vessel. As such, the possibility of an accident or malfunction is of the same type as previously evaluated for other liquid radwaste systems.

Operation of the Pressurizer Defueling System does not result in a reduction in the margin of safety as defined in the bases for the technical specifications. Liquid effluents will not be released to the environment directly from the Pressurizer Defueling System operation.

Based on the above, the installation and operation of the Pressurizer Defualing System does not present an unreviewed safety question as defined in ICCFR50.59 (Reference 6).

CONCLUSION

Based on the foregoing discussion, it can be concluded that the addition of the Pressurizer Defueling System will not violate reactor coolant system technical specifications, or affect boron concentration. Additionally, it does not adversely affect the Defueling Water Cleanup System or increase the consequences of a hose or line break. Therefore, utilizing the Pressurizer Defueling System presents no undue risk to the health and safety of the public.

Rev. <u>3</u> Page <u>11</u> of <u>12</u>

REFERENCES

- TMI-2 Technical Planning Bulletin TPB-85-9 Rev. 0, Dated 03/27/85, "An Estimate of Fuel Debris in the Pressurizer Surge Line."
- 2. TMI-2 Technical Planning Bulletin TPB-85-10a Rev. O. Dated 03/28/85, "An Estimate of Fuel in the Pressurizer Bottom."
- 3. TMI-2 Technical Builetin TB-86-02 Rev. O. Dated 01/13/86, "Physical/ Radiological Inspection and Sampling of the Pressurizer."
- TMI-2 Technical Bulletin TB-86-13 Rev. O, Dated 02/27/86, "Gamma Analysis of Pressurizer Sample."
- 5. TER 3525-015-15737-2-GO3-106 Rev. 10, "TMI-2 Division Technical Evaluation Report for Defueling Water Cleanup System."
- Code of Federal Regulations Title 10 (Energy) Part 50 Paragraph 50.59, Revised as of January 1, 1985.
- Three Mile Island Nuclear Station Unit 2 Operating License Number DPR-73 with the Recovery Technical Specification.
- TER 3527-016-15737-2-GO3-114 Rev. 3, "TMI-2 Division Technical Evaluation A Report for Defueling Canisters."

A

ATTACHMENT

 DC 3255-86-0004 Rev. 1, "TMI-2 Design Criteria for Pressurizer Defueling System."

GPU Nuclear

ς,

FORM 4000-ENG-7310.01 (03/86)

ITS

DC	3255-86-0004 REV_	1
DAT	E _July 1987	
	SITE ENGINEERING	
	PLANT ENGINEERING	
X	DEFUELING ENGINEERING	

TMI-2

DESIGN CRITERIA

FOR

PRESSURIZER

DEFUELING

SYSTEM

	Signature	Concurring Organizational Element	Date
Originator	Loreno Alticomo 27.987	Defueling Engineering	6-8-87
Concurred by	Altration of 19	Responsible Technical Reviewer	618187
	2 Burlauper 27Bint	Manager, Safety Review Group	6/19/87
	OF March OFW 7/10/27	Manager of Quality Assurance	6/26/87
	(1) Marshell for WEPSts	Site Operations Director	7/10/87
			이 나는 것 같아?
Approved by	Blacks FOR R.E. GALLACARER	Manager, Defueling Engineering	7/10/87
	Γ		

8707270409 870721 PDR ADDCK 05000320 PDR

Fage Lof 17

DC 3255-86-0004 Rev. 1 Page <u>2</u> of <u>18</u>

TABLE OF CONTENTS

SECT	ION	SUBJECT	PAGE	NO.
1.0	PURPOS	SE AND SCOPE	3	
2.0	REFERE	INCES/CODES/STANDARDS	3	
3.0	FUNCTI	ONS AND DESIGN REQUIREMENTS	6	
	3.1 3.2 3.3 3.4 3.5 3.6 3.7 3.8 3.9 3.10	Functions Design Requirements Process Requirements Structural Requirements System Configuration and Essential Features Maintenance and In-Service Inspection Instrumentation and Control Interfacing Systems Testing Requirements Materials	6 10 14 15 15 16 16 16 16 17	
4.0	QUALIT	TY ASSURANCE	18	
5.0	HUMAN	FACTORS	18	

GURES

- FIGURE 1 PIPING & INSTRUMENT DIACRAM, PRESSURIZER DEFUELING SYSTEM, DRAWING NO. 2C-3255-1132
- FIGURE 2 PRESSURIZER GENERAL ARRANGEMENT

DC 3255-86-0004 Rev. 1 Page <u>3</u> of <u>18</u>

1.0 PURPOSE AND SCOPE

The purpose of the Pressurizer Defueling System is to remove fuel debris from inside the pressurizer in a systematic and safe manner. This system will agitate and pump out the estimated 11 kg of fuel debris existing within the pressurizer and any fuel debris which may be flushed into the pressurizer from other ex-vessel defueling operations, such as pressurizer spray line defueling.

This design criteria is applicable to the following items which comprise the Pressurizer Defueling System:

- Pressurizer Vacuuming Pump
- An agitation water supply line
- Supporting accessories which are needed to complete the system such as long handled tools, controls, piping, fittings, flexible hosing, etc.
- The existing Defueling Water Cleanup System (DWCS).

2.0 REFERENCES/CODES/STANDARDS

- 2.1 References
 - a. Bechtel P&ID 2-M74-DWCO1, Defueling Water Cleanup System

Burns & Roe Flow Diagram Drawing 2024, Reactor Coolant Make-Up
 & Purification

- c. Babcock & Wilcox Drawing, Pressurizer General Arrangement, GPU File #07-00-0110
- d. TMI-2 Technical Bulletin iB 85-10a Rev. 1, A Reevaluation of Fuel in the Pressurizer.
- TMI-2 Technical Bulletin TB 86-02 Rev. 0,
 Physical/Radiological Inspection and Sampling of the Pressurizer
- f. TMI-2 Technical Bulletin TB 86-13 Rev. O, Gamma Analysis of Pressurizer Sample
- g. Babcock & Wilcox Pressurizer Instruction Manual
- h. TER 15737-2-GO3-106 Rev. 10, "TMI-2 Division Technical Evaluation Report for Defueling Water Clean-up System"
- SD 15737-2-M72-DWCO1 Rev. O, "TMI-2 Division System Description for Defueling Water Clean-up Reactor Vessel Clean-up System"

DC 3255-86-0004 Rev. 1 Page <u>5</u> of <u>18</u>

2.2 CODES/STANDARDS

2.2.1 The following codes and standards are specifically referenced and shall be applied as required by this document.

ANSI N45.2 (1977)	Quality Assurance Program Requirements for Nuclear Facilities
ANSI B16.34 (1981)	American National Standards Institute, Valves - Flanged and Buttwelding Ends
ANSI B1.20.1 (1983)	American National Standards Institute, Pipe Threads - General Purpose
ANSI B31.1 (1983 with Winter 1984 addenda)	American National Standards Institute, Power Piping Code
ANSI 816.5 (1981)	American National Standards Institute, Pipe Flanges and Flanged Fittings
ANSI B16.11 (1980)	American National Standards Institute, Forged Steel Fittings, Socket Welding and Threaded
ANSI/ASME NQA-1 (1979) Supplement 17S-1 and Appendix 17A-1 (including Addenda NQA-1a-1981)	Quality Assurance Program Requirements for Nuclear Power Plants, Supplementary Requirements for Quality Assurance Records
ASTM A36-1981	American Society of Testing and Materials, Structural Steel
ASTM A312/A312M-1985	Seamless and Welded Austenitic Stainless Steel Pipe
ASTM A500-1984	American Society of Testing and Materials, Cold-Formed Welded and Seamless Carbon Steel Structural Tubing in Rounds and Shapes

1126B RP

DC 3255-86-0004 Rev. 1 Page <u>6</u> of <u>18</u>

10 CFR 50, Appendix B. 1982	General Design Criteria for Nuclear Power Plants
OSHA	Occupational Safety and Health Standards, Part 1910, Section 1910.179, 1977.
OSHA	Occupational Safety and Health Standards, Part 1926, Section 1926,550, July 1980.

2.2.2 Should any requirements of this document conflict with those of the Code or applicable standards, the more stringent requirement shall govern.

3.0 FUNCTIONS AND DESIGN REQUIREMENTS

Refer to Figure 1 for a schematic representation of this system.

- 3.1 Functions
 - 3.1.1 Pressurizer Vacuuming Pump

The pump will draw suction from the water inside the pressurizer. This water will contain suspended particles of fuel debris which the pump is capable of handling during suction. The pump, along with its discharge piping, will be located within the pressurizer. In order to ensure that the heavier debris is drawn into the pump, the pump unit will be lowered as close as possible to the lower head of the pressurizer.

DC 3255-86-0004 Rev. 1 Page 7 of 18

3.1.2 Agitation Water Supply Line

The agitation water supply line with a nozzle shall be used to suspend debris particles in the pressurizer by using water from the DWCS. The position of the nozzle can be maneuvered using long handled tools. Since this is a closed system, the volume of water entering the agitation supply line is the same volume as being discharged by the submersible pump. Therefore the volume of water in the pressurizer remains unchanged.

3.1.3 Supporting Accessories

Hose shall be used for the agitation water supply line and for the pump discharge. Valves and associated fittings shall be used to control the flow of water into and out of the pressurizer. Instrumentation such as pressure and flow indicators shall be used to monitor the flow of water in and out of the pressurizer. Long handled tools shall be used to maneuver the agitation nozzle as required and to position the pump where necessary for effective vacuuming. To the extent practical, valves, instrumentation and pump controls shall all be centrally located and within easy reach of the operator.

DC 3255-86-0004 Rev. 1 Page <u>8</u> of <u>18</u>

 \wedge

M

3.1.4 The existing Defueling Water Cleanup System (DWCS)

The Pressurizer Defueling System utilizes a portion of the DWC System to provide a flow path back to the reactor vessel. Inherent in the design of the DWC System, is the capability to use filter canisters and/or knockout canisters as part of the process stream to filter and remove fuel debris. Although this debris separation capability exists, and may be used if defueling conditions warrant, present baseline plans are to bypass the filter canisters and return the process stream directly to the reactor vessel.

The DWCS can also be configured as described below.

The existing DWCS train "B" shall be used to filter the water from the submersible pump discharge prior to returning it to the pressurizer via the agitation supply line. Water from the pressurizer will enter a knockout canister prior to returning to the reactor vessel or Internet being filtered. This knockout canister will retain those particles exceeding 800 microns in size. The water will then be routed to the reactor vessel or to a DWCS filter Internet canister. The filter canisters for DWCS are capable of removing debris down to 0.5 micron in size. This would ensure that water entering the pressurizer through the agitation supply line is sufficiently clean to prevent fuel debris from returning to the water inside the pressurizer.

During operation of the Pressurizer Defueling System, Train B of DWCS will not be in operation except for the Train B filter canisters (F3 & F4). The remaining DWCS can be isolated by closing valves VOO4B and VOO7B and opening VOO3B (if filter canister F-3 is to be used), or by closing valves VOO4B and VOO3B and opening VOO7B (if filter canister F-4 is to be used). This will ensure that DPIT-5B will monitor the differential pressure across the filters. Valve V356 will also be closed and V357 will be open. This will create a flowpath from the submersible pump back to the agitation supply line.

During operation of Train B the Pressurizer Defueling System will not be in operation. The Pressurizer Defueling System can be isolated from DWCS by closing valves DWC-V357 and V501.

Allowing the ability to operate either DWCS or the Pressurizer Defueling System by valve alignment will maintain body feed/precoat on the DWCS filters.

3.2 Design Requirements

3.2.1 Pressurizer Vacuuming Pump

The pump shall be a vertical submersible pump. The pump shall operate at 100 gpm which will ensure sufficient velocity to transport fuel debris solids. The pump shall operate at approximately 300 feet total head, with a shutoff head of approximately 450 feet. The pump shall be furnished and delivered completely assembled. The pump shall be powered by an electric motor rated for 460 volts, 3 phase, 60 Hz and have an integral cooling system. The pump shall be capable of handling particle sizes up to 1/4" in size. A minimum of 50 feet of power cable shall be supplied with the pump. The pump will be handling radioactive, borated, reactor vessel water with the chemistry described in Section 3.3. The pump shall be capable of being operated in air without damage. The overall dimensions of the pump shall be such that it can be placed down to the lower head of the pressurizer.

3.2.2 Agitation water supply line

Water will be introduced into the pressurizer using a hose with a nozzle at one end. The hose diameter will be sized to accommodate the flow of the submersible pump.

DC 3255-86-0004 Rev. 1 Page 11 of 18

The nozzle will have sufficient discharge velocity to promote agitation of debris in the pressurizer. The configuration of the nozzle shall be such that agitation occurs in all directions with a minimum of manual manipulation. The nozzle shall be stainless steel, shall have a full cone spray pattern with uniform distribution, and shall be of sufficient size to avoid clogging.

3.2.3 Supporting Accessories

Hose for the pump discharge and agitation supply line shall be rated for the maximum discharge pressure of the submersible pump. The hose shall be as continuous as practical to minimize connections. Hose fittings to adapt to steel pipe shall be provided. Valves used to control flow shall be stainless steel conforming to ANSI Standards. Valves shall be temporarily supported as required. Flow indicators shall be installed on the supply and discharge lines. A pressure indicator shall be used on the discharge line. Minimum tap sizes for flow and pressure indicators shall be 3/8" in order to prevent clogging by fuel debris. These same instruments shall be located on the top of horizontal pice to avoid being plugged from settlement of debris during no flow conditions. An On/Off switch for the submersible pump shall be provided. Existing long handled tools shall be utilized to the greatest extent possible. Design of special tools shall be minimized.

Hose and piping will be hydrostatically pressure tested prior to use to ensure against any potential line break or failure. In the unlikely event of a hose rupture or line rupture upstream or downstream of the submersible pump the system will trip the pump on IIF low level and alarm at the control panel located on the pressurizer missile shield. The pump will trip on IIF low level because it will be electrically interlocked with the reactor vessel cleanup pump which would trip on IIF low level (Reference h). This event could deliver approximately 500 to 1000 gallons of reactor vessel water to the area of the break.

Siphoning of reactor vessel water from the pressurizer through the agitation supply line is prevented by the placement of a check valve in close proximity to the pressurizer. This check valve will prevent water from flowing out of the pressurizer should a hose break occur inside the pressurizer. A hose break in the submersible pump discharge line is of no concern with respect to siphoning, since all unsubmerged piping and hose outside of the pressurizer is at or above the Reactor Vessel water level.

DC 3255-86-0004 Rev. 1 Page <u>13</u> of <u>18</u>

 \wedge

3.2.4 The Existing Defueling Water Cleanup System (DWCS)

The preferred flowpath would provide agitation supply water from either DWC-V357 (Train "B") or DWC-V363 (Train "A"). The discharge water from the submersible pump would be routed to a knockout canister and then directly to DWC-V358 (Train "B") which would then flow into the reactor vessel.

An optional flowpath would be as follows.

Water discharging from the vacuuming pump will first be routed to the knockout canister. The water will then be directed to filter canisters F-3 and F-4 downstream of valves DWC-V003B & V007B respectively. Two new valves DWC-V360 and V361 will be installed between V003B and V007B and filter canisters F-3 and F-4. These new valves will be used to control flow to the filter canisters and will be also be used to bypass the filter canisters if required. Valve DWC-V501 will be installed to be used as an isolation valve between DWCS and the Pressurizer Vacuuming Pump discharge line. Water to the agitation supply line will enter through valve DWC-V357.

3.3 Process Requirements

The complete Pressurizer Defueling System shall be used inside the reactor building and be capable of operating continuously as required.

The design temperature for components in air (hoses, valves, etc.) is 50°F to 130°F, relative humidity of 5 to 100% and pressure of 14.7 psia atmospheric pressure to not less than 12.2 psia.

Components in the pressurizer (submersible pump, nozzles, hose, etc.) shall be designed for external pressure ranging from 0-10 psig and the following maximum water chemistry conditions:

Boric Acid	4350-6000 ppm boror	1
рH	7.5 - 8.4	
Chloride	5 ppm	
Temperature	50-200°F	

Defueling performance shall be monitored as required. During the monitoring activity, the vacuuming pump shall be turned off and the water in the pressurizer shall be calm. A video camera will be used to determine the amount of debris remaining. Defueling is then resumed as necessary. Those particles which cannot be vacuumed will be removed using long handled tools as required. The flow of water from the pressurizer shall be monitored to ensure

DC 3255-86-0004 Rev. 1 Page 15 of 18

that the vacuuming pump has not clogged. The flow shall be monitored using the flow indicator on the Pressurizer Defueling System, the video camera in the pressurizer and the flow recorders on the DWC system. Since the pump is equipped with a screen it is unlikely that the pump will clog. However, should it be necessary to unclog the pump screen, a backflush can be performed.

3.4 Structural Requirements

Structural components shall be designed in accordance with the ANSI B31.1 code. Structural components shall be designed for equipment dead loads, operating loads, and containment environmental conditions given in Section 3.3. All structural welding shall be done in accordance with the ANSI B31.1 code. All piping shall be in accordance with ANSI B31.1.

3.5 System Configuration and Essential Features

The system will be handling radioactive water. The system shall be designed so that doses to personnel are limited to those which are as low as reasonably achievable (ALARA). The system will be located inside the reactor building. Figure 2 shows a general arrangement of the pressurizer.

3.6 Haintenance and In-service Inspection

Fluids and lubricants used for the vacuuming pump shall be acceptable for use in the RCS and their quantities shall be minimized. Where feasible, fluids should be miscible and/or less dense than the pressurizer vessel water to preclude boron dilution concerns.

3.7 Instrumentation and Control

The vacuuming pump shall have an On/Off switch accessible from the platform at the top of the pressurizer. Manually operated valves shall be provided on the agitation supply line and pump discharge line. These valves shall be located outside of the pressurizer. Flow indicators shall be installed on both supply and discharge lines along with a pressure indicator on the discharge line. Balancing the water flow for the Pressurizer Defueling System will be minimal since this is a closed loop system. However, valve alignment on DWCS must be performed to ensure that water leaving the pressurizer will not escape through unwanted flow paths.

3.8 Interfacing Systems

The electrical power supply that will be available is 460 volt, 25 amp, 3 phase, 60 Hertz AC for continuous service. The Defueling Water Cleanup System is used as a means of filtering the water being removed from the pressurizer.

3.9 Testing Requirements

A functional test of the pump shall be performed prior to installation into the pressurizer.

Hydrostatic pressure testing is required of all piping and hoses The test pressure shall be 225 psig and shall be performed in accordance with ANSI B31.1. The pressure shall be held for 10 minutes. This is compatible with the DWCS test pressure and provides enough margin to ensure that the maximum pressure delivered by the pressurizer vacuuming pump (195 psig) is within the test pressure. Testing of the hose will be performed after couplings have been attached. Pipe and hose may be tested cutside of the Reactor Building.

All connections will be initial service leak tested after the piping and hose are assembled.

3.10 Materials

Materials selected shall be suitable for the use intended and for plant environmental conditions such as radiation, temperature and wetting with borated water. Wherever practical, 300 series

DC 3255-86-0004 Rev. 1 Page <u>18</u> of <u>18</u>

stainless steel components shall be used. Hoses shall be made of rubber.

4.0 QUALITY ASSURANCE

This system is classified as important to safety.

5.0 HUMAN FACTORS

Hose shall be used to allow for quick installation and use of existing radiation shielding. Hoses and valves shall be properly identified by metal tags or banded to avoid misconnection or confusion. Quick disconnect couplings shall be used for ease of assembly and removal. "Design features" such as special fittings and color coding shall be used, if possible, to preclude any potential boron dilution or loss of Reactor Vessel inventory.

