Docket No. 50-320

Mr. M. B. Roche Vice President/Director, TMI-2 GPU Nuclear Corporation P. O. Box 480 Middletown, Pennsylvania 17057 DISTRIBUTION
Docket File
NRC & Local PDRs
Plant File
SVarga
BBoger
SNorris
LThonus
MMasnik

OGC EJordan BGrimes ACRS(10)

Dear Mr. Roche:

Subject: Three Mile Island Nuclear Station, Unit 2 - Use of Polar Crane Auxiliary Hook for Defueling (TAC 71131)

The Nuclear Regulatory Commission staff has reviewed your October 20, 1988, submittal pertaining to the use of the polar crane auxiliary hook for defueling-related activities. As stated in the enclosed Safety Evaluation issued by the staff, we conclude that the proposed activities can be accomplished without significant risk to the health and safety of the public provided that they are in accordance with the limitations stated in your submittals and in the staff's Safety Evaluation.

The use of the polar crane to aid in defueling falls within the scope of activities previously considered in the "Programmatic Environmental Impact Statement." We, therefore, approve the use of the polar crane auxiliary hook for defueling-related activities subject to the limitations discussed above.

Sincerely,

original signed by

John F. Stolz, Director Project Directorate I-4 Division of Reactor Projects I/II Office of Nuclear Reactor Regulation

Enclosure: As stated

cc w/enclosure: See next page

SHOTTIS

MITH PM:PDI-4 MMasnik 12 /20/88

15to1z 12/30/88

DFO!

Mr. M. B. Roche GPU-Nuclear Corporation

cc:

Regional Administrator, Region I U.S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Dr. Judith H. Johnsrud Environmental Coalition on Nuclear Power 433 Orlando Avenue State College, PA 16801

Ernest L. Blake, Jr., Esquire Shaw, Pittman, Potts, and Trowbridge 2300 N Street, N.W. Washington, DC 20037

Secretary U.S. Nuclear Regulatory Commission Washington, DC 20555

Sally S. Klein, Chairperson Dauphin County Board of Commissioners Dauphin County Courthouse Front and Market Streets Harrisburg, PA 17101

Thomas M. Gerusky, Director Bureau of Radiation Protection Department of Environmental Resources P. O. Box 2063 Harrisburg, PA 17120

Ad Crable Lancaster New Era 8 West King Street Lancaster, PA 17601

U.S. Department of Energy P. O. Box 88 Middletown, PA 17057

David J. McGoff
Office of LWR Safety and Technology
NE-23
U.S. Department of Energy
Washington, DC 20545

Three Mile Island Nuclear Station Unit No. 2

Frank Lynch, Editorial The Patriot 812 Market Street Harrisburg, PA 17105

Robert B. Borsum Babcock & Wilcox Nuclear Power Division Suite 525 1700 Rockville Pike Rockville, MD 20852

Marvin I. Lewis 7801 Roosevelt Blvd. #62 Philadelphia, PA 19152

Jane Lee 183 Valley Road Etters, PA 17319

Walter W. Cohen, Consumer Advocate Department of Justice Strawberry Square, 14th Floor Harrisburg, PA 17127

Hr. Edwin Kinter Executive Vice President GPU Nuclear Corporation 100 Interpace Parkway Parsippany, NJ 07054

U.S. Environmental Prot. Agency Region III Office Attn: EIS Coordinator Curtis Building (Sixth Floor) 6th and Walnut Streets Philadelphia, PA 19106

Richard Conte Senior Resident Inspector (TMI-1) U.S.N.R.C. Post Office Box 311 Middletown, Pennsylvania 17057 Mr. M. B. Roche GPU Nuclear Corporation

cc:

T. F. Demmitt GPU Nuclear Corporation

G. Kuehn GPU Nuclear Corporation

J. J. Byrne GPU Nuclear Corporation Three Hile Island Nuclear Station Unit No. 2

R. E. Rogan GPU Nuclear Corporation

S. Levin GPU Nuclear Corporation

W. J. Marshall GPU Nuclear Corporation



UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

SAFETY EVALUATION BY THE OFFICE OF NUCLEAR REACTOR REGULATION

USE OF POLAR CRANE AUXILIARY HOOK FOR DEFUELING

GPU NUCLEAR CORPORATION

THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 2

DOCKET NO. 50-320

INTRODUCTION

6PU Nuclear Corporation (GPUN, the licensee) submitted by letter dated October 20, 1988 (reference 1) a proposal expanding the use of the polar crane (PC) auxiliary hook in defueling activities. General use of the PC during the TMI-2 cleanup was approved in reference 2. Limited use of the PC auxiliary hook below the defueling work platform (DWP) was approved in reference 3. The limitations included using slow speed only (4 inches/minute) and having additional standby personnel at electrical disconnects. The current GPUN proposal would use redundant overload sensors to allow use of the auxiliary hook in all speeds while the hook or loads are below the DWP.

EVALUATION

GPUN's load handling program incorporates the elements referenced in Generic Letter No. 81-07 and NUREG 0612, "Control of Heavy Loads at Nuclear Power Plants." These elements include the following.

- 1. Definition of safe load paths.
- 2. Development of load handling procedures.
- 3. Periodic inspection and testing of cranes.
- 4. Qualifications, training and specified conduct of operators.
- Special lifting devices should satisfy the guidelines of American National Standards Institute (ANSI) N14.66.
- Lifting devices that are not specifically designed should be installed and used in accordance with the guidelines of ANSI B30.9.
- Design of cranes to ANSI B30.2 or Crane Manufacturers Association of America (CMAA) 70.

The specific safety concern with using the PC auxiliary hook under the DWP is the potential for a load or empty hook hang-up. The PC auxiliary hook has the capability to tilt or lift the DWP.

The licensee has proposed to place redundant load sensors on the PC auxiliary hook. They would limit a sensored load to 10,000 pounds. If this load were exceeded, the sensors would trip, defeating all motion by the PC auxiliary hook, except down motion. This would allow the load to be lowered to a safe position and the sensors would reset. The 10,000-pound limit on lifting force would preclude tilting or lifting the 50,000-pound shielded work platform with a safety margin greater than two.

The licensee will perform annual maintenance and surveillance testing on the overload sensors. In discussions with the NRC staff, the licensee has agreed to perform the first two surveillance and maintenance activities on a quarterly basis. The licensee will evaluate the quarterly data and data from the reactor building service crane and verify that setpoint drift will be within acceptable limits prior to switching to annual maintenance and surveillance.

CONCLUSION

The staff has reviewed and evaluated the proposed expanded use of the PC auxiliary hook. The staff concluded that the proposed activities can be accomplished without significant risk to the health and safety of the public, provided that they are in accordance with the limitations for this safety evaluation. This activity falls within the scope of activities previously considered in the "Programmatic Environmental Impact Statement."

REFERENCES

- GPUN letter, 4410-88-L-0165/0332P, dated October 20, 1988, B. Roche to NRC, Use of Polar Crane Auxiliary Hook for Defueling
- NRC letter, NRC/TMI 85-090, Revision 2, dated November 15, 1985, W. D. Travers to F. R. Standerfer, Heavy Load Handling Inside Containment
- NRC letter, NRC/TMI 87-082, dated November 16, 1987, W. D. Travers to F. R. Standerfer, Use of Polar Crane Auxiliary Hook for Defueling

Principal Contributor: Lee H. Thonus

Dated: December 30, 1988