

# CONTROLLED COPY CENTRAL FILE

2202-1.9  
Revision 4  
09/01/78

*5/1/78 123*

## THREE MILE ISLAND NUCLEAR STATION UNIT #2 EMERGENCY PROCEDURE 2202-1.9 LOSS OF INTERMEDIATE CLOSED COOLING WATER

Table of Effective Pages

| <u>Page</u> | <u>Date</u> | <u>Revision</u> | <u>Page</u> | <u>Date</u> | <u>Revision</u> | <u>Page</u> | <u>Date</u> | <u>Revision</u> |
|-------------|-------------|-----------------|-------------|-------------|-----------------|-------------|-------------|-----------------|
| 1.0         | 03/03/78    | 3               | 26.0        |             |                 | 51.0        |             |                 |
| 2.0         | 03/03/78    | 3               | 27.0        |             |                 | 52.0        |             |                 |
| 3.0         | 09/01/78    | 4               | 28.0        |             |                 | 53.0        |             |                 |
| 4.0         |             |                 | 29.0        |             |                 | 54.0        |             |                 |
| 5.0         |             |                 | 30.0        |             |                 | 55.0        |             |                 |
| 6.0         |             |                 | 31.0        |             |                 | 56.0        |             |                 |
| 7.0         |             |                 | 32.0        |             |                 | 57.0        |             |                 |
| 8.0         |             |                 | 33.0        |             |                 | 58.0        |             |                 |
| 9.0         |             |                 | 34.0        |             |                 | 59.0        |             |                 |
| 10.0        |             |                 | 35.0        |             |                 | 60.0        |             |                 |
| 11.0        |             |                 | 36.0        |             |                 | 61.0        |             |                 |
| 12.0        |             |                 | 37.0        |             |                 | 62.0        |             |                 |
| 13.0        |             |                 | 38.0        |             |                 | 63.0        |             |                 |
| 14.0        |             |                 | 39.0        |             |                 | 64.0        |             |                 |
| 15.0        |             |                 | 40.0        |             |                 | 65.0        |             |                 |
| 16.0        |             |                 | 41.0        |             |                 | 66.0        |             |                 |
| 17.0        |             |                 | 42.0        |             |                 | 67.0        |             |                 |
| 18.0        |             |                 | 43.0        |             |                 | 68.0        |             |                 |
| 19.0        |             |                 | 44.0        |             |                 | 69.0        |             |                 |
| 20.0        |             |                 | 45.0        |             |                 | 70.0        |             |                 |
| 21.0        |             |                 | 46.0        |             |                 | 71.0        |             |                 |
| 22.0        |             |                 | 47.0        |             |                 | 72.0        |             |                 |
| 23.0        |             |                 | 48.0        |             |                 | 73.0        |             |                 |
| 24.0        |             |                 | 49.0        |             |                 | 74.0        |             |                 |
| 25.0        |             |                 | 50.0        |             |                 | 75.0        |             |                 |

Unit 1 Staff Recommends Approval

Approval NA Date       
Cognizant Dept. Head

Unit 2 Staff Recommends Approval

Approval NA Date       
Cognizant Dept. Head

Unit 1 PORC Recommends Approval

NA Date       
Chairman of PORC

Unit 2 PORC Recommends Approval

RP Warren Date 3/30/78  
V - Chairman of PORC

Unit 1 Superintendent Approval

NA Date     

Unit 2 Superintendent Approval

J. I. Locking Date 9/1/78

Manager Generation Quality Assurance Approval NA Date

THREE MILE ISLAND NUCLEAR STATION  
UNIT #2 EMERGENCY PROCEDURE 2202-1.9  
LOSS OF INTERMEDIATE CLOSED COOLING WATER

1.0 SYMPTOMS

- 1.1 I.C. System Flow Low Alarm, 8.F14, 550 GPM.
- 1.2 I.C. System CRD Cooling Flow Low Alarm, 8.A15, 138 GPM.
- 1.3 I.C. Surge Tank Level Hi/Lo Alarm, 8.A14.
- 1.4 I.C. Cooler Outlet Temp. Hi Alarm, 8.E14.
- 1.5 CRD Stator Temp. Hi, Computer Points 625 through 693 Setpoint 160°F.
- 1.6 R.C. Pump Cooling Water Temp. Hi, Computer Point 451, 452, 453, & 454.
- 1.7 Any of the following valves closed due to E.S. testing, 4 pound E.S. Signal, or valve malfunction:
  - IC-V2, 3, 4, or 5.
- 1.8 Letdown isolation valve, MU-V376 closes on Hi Temperature of 135°F which secures letdown.

2.0 IMMEDIATE ACTIONS

2.1 Automatic Actions

- 2.1.1 Standby I.C. Pump starts on low flow (550 GPM) or breaker trip.

2.2 Manual Actions

- 2.2.1 Verify automatic start of Standby I.C. pump at a low flow of 550 g.p.m. or running pump breaker trip.
- 2.2.2 If standby I.C. pump has not started, verify an indicated level in the I.C. surge tank and attempt to start manually by turning control switch to "ON".

- 2.2.3 Check CRD pressure gages locally for CRD filter d/p. Change to standby filter if alarming at 10 psid. Note maximum d/p permitted is 12 psid. Utilize procedure 2104-1.6C for procedure to shift filters.
- 2.2.4 RCP operation may continue if normal seal injection is maintained.
- 2.2.5 Closely monitor RCP parameters to insure within the limits specified in 2103-1.4.

### 3.0 FOLLOW-UP ACTION

- 3.1 Try to isolate any leakage and/or while filling surge tank from DW-V-46 (Panel 8) isolate portions of system to keep flow in CRD's. Establish normal 18.5 inch surge tank level.
- 3.2 Verify on Panel 15 that IC-V-5 is open if CRD coolant flow is low. (Alarmed at 138 GPM).
- 3.3 Verify normal Nuclear Services River Water System Pressure of 17-21 psig on Panel #8, NR-PI 340 thru 343, NR pump discharge pressure gages.
- 3.4 At or before stator temperature 160°F assign one CRD stator temperature of the controlling CRD group to analog trend recorder.
- 3.5 If CRD Temp. is High (>170°F) on one rod, reduce power to 50%, drive rod in and de-energize.
- 3.6 If more than one CRD High Temp. exists (>180°F), reactor must be tripped.
- 3.7 Backwash IC cooler if High outlet temp. alarm (120°F) has actuated.
- 3.8 Check flow control and isolation valves for correct positions. (Should be secured in position and position logged on O.P. Checkoff List).



- 3.9 Re-establish at least the minimum 45 GPM letdown flow.
- 3.10 If letdown flow cannot be re-established, unit must be shutdown at 385 inches in pressurizer.
- 3.11 Place standby IC cooler in service for continued High outlet temp. or leakage.
- 3.12 If RC pump seal temperatures  $T_1$  or  $T_4$  are  $>180^{\circ}\text{F}$ , or  $T_3$  is  $>170^{\circ}\text{F}$ , shut down and inspect the RCP seals.