(CORRECTED COPY) IMMEDIATE <u>PRELIMINARY NOTIFICATION</u>

April 9, 1979

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-79-67P*

This preliminary notification constitutes summary information of an event of safety or public interest significance. The information presented is a summary of information as of 6:00 a.m. on 4/9/79.

Facility: Three Mile Island Unit 2 Middletown, Pennsylvania (DN 50-320)

Subject: NUCLEAR INCIDENT AT THREE MILE ISLAND

<u>Plant</u> Status

Bulk coolant inlet and outlet temperatures are about 280 degrees F. The average core thermocouple temperature is about 300 degrees F, and the highest thermocouple reading (8H) is about 425 degrees F.

At approximately 0430 hours, April 9, the reactor coolant system pressure reached the 400 psig endpoint established for the second degassing evolution. At lower pressures in the 400 to 1,000 psig range, noise monitoring indicated possible presence of some gas in Loop B of the reactor cooling system. Noise monitoring verified re-solution of gas with time. The operating reactor coolant pump vibration increased to 8.5-9 mils but the level of vibration was still significantly below the limit (30 mils). Pressure variation for degassing is continuing. Following reduction to 400 psig, the licensee plans to increase pressure to the 900-1,000 psig range and a phased cooldown is under consideration as the next step.

The licensee requested and received permission to temporarily change the minimum pressurizer level to 150" from 200" to prevent high pressurizer levels on pressure decreases.

At approximately 1320 hours, April 8, the reactor coolant system began to heat up. This was due to a decrease in steam generator level. Steam Generator A level was increased to decrease the primary temperature.

Hydrogen concentration in containment is about 1.85%.

At approximately 1942 hours EST, the last airplane involved in the filter airlift left Pasco, WA, for Harrisburg, PA.

CONTINUED (CORRECTED COPY)

(The letter "O" was not used, previous issuance was PNO-79-67N)

Continued		April 9, 1979
Page 2	CORRECTED COPY	· · · ·
ويسترك المتنب المستري فتشته بمشارك ومرفقتها تترك المتناقات	COARCOTLD COFT	PN0-79-67P

ENVIRONMENTAL STATUS

Offsite radiation levels identified by NRC survey teams continue to range between 0.01-0.1 mR/hr. The results were obtained from routine surveys performed on the east and west side of the Susquehanna River at distances of up to 4 miles north and south of the site.

The following ARMS surveys were conducted during April 8, 1979:

TIME	MAXIMUM RADIATION LEVELS	LOCATION	DISTANCE FROM SITE
00:00-00:30	l mR/hr	sector 180° (south)	½ - 1 mile
06:00-06:20	0.3 mR/hr	sector 200° (west-southwest)	l mile
09:00-09:50	0.03 mR/hr	sector 170° (south-southeast)	l mile
18:05-18:30	0.05 mR/hr	sector 275° (west-northwest)	3 miles

Eight offsite air samples collected near the NRC trailer during April 1-8 indicated iodine-131 concentrations between 0.9 - 3.3 picocuries per cubic meter (pCi/m³). The maximum permissible concentration per 10 CFR 20 is 100 pCi/m³.

No new data were reported for milk, water, and vegetation samples.

Offsite dose rates as determined by NRC thermoluminescent dosimeters (TLDs) indicate that present radiation levels are in close agreement with expected natural background levels. Minor fluctuations among individual TLDs are expected due to the limitations of the TLD system. Forty-seven TLDs are presently positioned at various locations around the site.

Dose rates (47 locations) as measured by NRC thermoluscent dosimeters have ranged from 0.01 to 0.02 milliroentgens per hour for the past 24-hour periods of April 7 and 8.

CONTINUED (CORRECTED COPY)

 Continued Page 3	CORRECTED COPY	April 9, 1979 PNO-79-67P
<u>Contact</u> : EJordan, IE x28180 <u>Distribution</u> : Transmitted Chairman Hendrie Commissioner Kennedy Commissioner Gilinsky	9:55 000	S. J. Chilk, SECY C. C. Kammerer, CA (For Distribution)
Transmitted: MNBB <u>10:00</u> Am L. V. Gossick, EDO H. L. Ornstein, EDO J. J. Fouchard, PA N. M. Haller, MPA R. G. Ryan, OSP H. K. Shapar, ELD	P. Bldg <u>10:02</u> AM H. R. Denton, NRR R. C. DeYoung, NRR R. J. Mattson, NRR V. Stello, NRR R. S. Boyd, NRR SS Bldg <u>10:04</u> AM W. J. Dircks, NMSS S. Levine, RES	J. G. Davis, IE Region I <u>ID/ID</u> AM Region II <u>ID/ID</u> AM Region IV <u>ID/ID</u> AM Region V <u>ID/D</u> AM (MAIL) J. J. Cummings, OIA R. Minogue, SD
IE (TMI) Site <u>10:07 Am</u> White House Situation Room <u>10</u> EPA <u>11:08 Am</u> FDA/BRH <u>11:30 Am</u> DOE/EOC <u>0:27 Am</u> FDDA/FEMA <u>11:30 Am</u> BRP (State of PA) <u>12:13 Am</u> DCPA <u>12:15 Am</u> HEW <u>Dickup</u> PEMA <u>1100</u> Handcarry (FAA)	Provide copy to STATE) D:35AM	

......

IMMEDIATE

.

PRELIMINARY NOTIFICATION CORRECTED COPY