
Investigation into Information Flow During the Accident at Three Mile Island

**U.S. Nuclear Regulatory
Commission**

Office of Inspection and Enforcement



Available from

GPO Sales Program
Division of Technical Information and Document Control
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Printed copy price: \$10.00

and

National Technical Information Service
Springfield, Virginia 22161

Investigation into Information Flow During the Accident at Three Mile Island

Manuscript Completed: January 1981
Date Published: January 1981

**Division of Program Development and Appraisal
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555**



INVESTIGATION INTO INFORMATION FLOW DURING THE ACCIDENT AT THREE MILE ISLAND

I. Introduction

On October 25, 1979, Victor Stello, Director of the Office of Inspection and Enforcement (IE), sent a Notice of Violation to Metropolitan Edison (Met Ed) resulting from the IE investigation into the accident at Three Mile Island (TMI) that occurred on March 28, 1979. In the transmittal letter, Mr. Stello said, "Among other things, additional enforcement action is under review with regard to the reportability of several items of information following the onset of the accident, including specifically the calculated dose rate of 10-40 R/hr in Goldsboro, the elevated incore thermocouple indications and the pressure spike in the containment vessel."

Subsequently, the Commission concluded that the area of information transfer should be examined by the NRC Special Inquiry Group. At the conclusion of its review, the Special Inquiry Group reported that it found no direct evidence suggesting intentional withholding of information, but it did not reach conclusions on the questions of enforcement.

On March 21, 1980, NRC Chairman Ahearne requested that the Executive Director for Operations direct IE to resume its investigation regarding information transfer on the day of the accident at TMI. Accordingly, the IE investigation effort was initiated on April 1, 1980. The investigation examined information that did not adequately flow from TMI to NRC and to the Pennsylvania Bureau of Radiological Protection (BRP) on March 28, 1979.

This investigation examined the transfer of information and knowledge related to specific events, parameters, and systems. The summary, conclusions and recommendations of this investigation are presented in Section II. Section III of this report contains a description of the information flow and a summary of the knowledge of specific plant personnel for each of the key indicators examined during this investigation. The review of the information flow associated with the key indicators allowed a description to be developed for the onsite information flow (Section IV), information flow to the NRC (Section V), and information flow to the State (Section VI). This investigation concluded with an evaluation of enforcement considerations related to the transfer of information (Section VII).

The investigation team was composed of Norman C. Moseley (IE), Team Leader; Terry L. Harpster (IE); John W. Craig (IE); and William L. Fisher (IE). David H. Gamble participated in this investigation as a representative of the Office of the Inspector and Auditor, whose function is to protect the interest of the Department of Justice in any criminal matters that may arise. Richard K. Hoefling (ELD) provided legal advice and assistance to the team and participated in most of the interviews.

Victor Stello, Director (IE), participated in some of the interviews. Although Ronald C. Haynes (IE) was initially a member of the team, he was released to resume other pressing duties.

An early premise of the investigation was to make maximum use of the extensive records that had been already accumulated. The records used included NUREG-0600, IE interviews, tape recordings, logs, depositions taken by the NRC Special Inquiry Group, testimony and depositions taken by the Kemeny Commission, testimony and depositions taken by the Senate investigation, and testimony before the Subcommittee for Energy and The Environment.

The investigation was delayed when some persons to be interviewed contested the validity of NRC administrative subpoenas. After the court enforced the subpoenas, all interviews were conducted under oath with a court reporter providing a verbatim transcript. During the investigation, employees of Met Ed/General Public Utilities (GPU), Babcock & Wilcox (B&W), Pennsylvania Bureau of Radiological Protection (BRP), and NRC were interviewed. Copies of transcripts of the interviews will be available for inspection in the Public Document Room.

The following summary of events that occurred on March 28, 1979 was developed from NUREG-0600. This summary is intended to familiarize the reader with some operational aspects of the accident. It is not intended to be all-inclusive. Detailed summaries are presented in NUREG-0600 and in the Special Inquiry Group's Report, NUREG/CR-1250. (The timing indicated is approximate.)

SUMMARY OF EVENTS

Time of Event,
March 28, 1979

Event Description

4:00 a.m.	The main feedwater pumps tripped resulting in an almost simultaneous trip of the turbine (actual time 04:00:37, March 28, 1979). Low feedwater pump suction pressure or loss of the condensate booster pumps, while in automatic, caused the feedwater pump turbines to trip. Tripping of both feedwater pumps caused the main turbine to trip.
+3-6 seconds	Reactor coolant system (RCS) pressure reached electromagnetic relief valve (EMOV) opening setpoint (2255 psig).
8 seconds =	Reactor tripped from reactor high pressure (setpoint 2255 psig). Indicated reactor pressure on the wide range RCS pressure strip chart from the control room showed an increase to approximately 2435 psig, which would normally suggest that one of the two safety valves may have lifted.

CONTENTS

	<u>Page</u>
Abstract.....	iii
I. Introduction.....	1
II. Summary, Conclusions, and Recommendations.....	10
III. Knowledge and Reporting to NRC of Key Indicators Related to the Accident.....	12
1. Primary Coolant System.....	13
a. HPI and Letdown Systems.....	13
b. Reactor Coolant Pumps.....	14
c. EMOV.....	16
d. Th/Superheat/Incore Thermocouples.....	18
e. Count Rate Behavior.....	20
2. Containment Pressure Spike.....	22
3. Goldsboro Radiation Dose Rate Projection.....	31
IV. Onsite Information Flow.....	33
V. NRC Information Flow.....	35
VI. Operating Information Supplied to the State.....	39
VII. Enforcement Considerations.....	45
1. Potential Material False Statement.....	45
2. License Modification Related to Gary Miller.....	46
3. Reporting.....	47
a. Regulatory Requirement to Report.....	47
b. Knowledge of Reportable Events.....	48
c. Failure to Report.....	48
d. What Constitutes Reporting.....	48
e. Assessment of this Case.....	49
Appendix A--Notification Citation Considered by the Investigation Team	
Appendix B--Report References	

ABSTRACT

This report was prepared in response to a request from NRC Chairman Ahearne that directed the Office of Inspection and Enforcement to resume its investigation of information flow during the accident at Three Mile Island (TMI) that occurred on March 28, 1979. This investigation was resumed on March 21, 1980. The transfer of information among individuals, agencies, and personnel from Metropolitan Edison was analyzed to ascertain what knowledge was held by various individuals of the specific events, parameters, and systems during the accident at TMI. Maximum use was made of existing records, and additional interviews were conducted to clarify areas that had not been pursued during earlier investigations. Although the passage of time between the accident and post-accident interviews hampered precise recollections of events and circumstances, the investigation revealed information was not intentionally withheld during the accident and that the systems for effective transfer of information were inadequate during the accident.

U.S. NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT

INVESTIGATION INTO INFORMATION FLOW DURING THE ACCIDENT AT THREE MILE ISLAND

Docket No. 50-320

License No. DPR-73

Category C

Licensee: Metropolitan Edison Company
P. O. Box 542
Reading, Pennsylvania 19640

Facility Name: Three Mile Island Nuclear Station Unit 2

Investigation conducted: March 1980 - January 1981

Investigators

Norman C. Moseley

Date

Terry L. Harpster

1/23/81
Date

William L. Fisher

1/23/81
Date

John W. Craig

1/23/81
Date

Time of Event,
March 28, 1979

Event Description

~13 seconds

RCS pressure reached setpoint for EMOV closure (2205 psig). However, later events showed that closure did not occur.

Plant Status--TMI Unit 2 had just experienced a turbine/reactor trip. RCS pressure and pressurizer level were decreasing rapidly after reaching their peaks. Unknown to the plant operators, the EMOV was not shut and was passing reactor coolant from the steam space at the top of the reactor coolant system pressurizer. Based on control room indications, the RCS pressure and pressurizer level were trending together and decreasing as was expected after a reactor trip. The once-through steam generator (OTSG) water levels were at about 90 inches and decreasing at about 4 inches/second. The OTSG steam pressures were about 1030 psig and decreasing at 4 psi per second. The turbine bypass valves were open to relieve steam. The OTSG water levels had not yet reached the setpoint of 30 inches for the programmed opening of the emergency feedwater valves that would admit feedwater to the OTSG.

14 minutes

The reactor coolant drain tank (RCDT) rupture disc blew at an RCDT indicated pressure of 192 psig, dropping RCDT pressure to approximately 10 psig in 36 seconds. Reactor building pressure appeared to jump one full psi. At this time, up to about 1.2 psig, pressure rise was evident in the reactor building.

74 minutes

The reactor coolant pumps (RCP) in B loop were chosen to be tripped to be able to maintain maximum pressurizer spray capability which comes from A loop. RCP 1B and 2B tripped.

Prior to
101 minutes

Approximately 5-10 minutes after the trip of the B loop RCP source range monitor (SRM), count rate instability increased again as well as continued to trend upward. Intermediate range monitor (IRM) current also began to show an upward trend. Operators reported that loop flow instability was increasing again, and the indicated loop flow continued to show a decrease. Operators asserted during interviews that they were concerned about a "seal failure loss of coolant accident (LOCA)" and decided to go on natural circulation. An operator stated that he started "emergency boration" during this period, based on SRM increases and fear of a restart accident.

Time of Event,
March 28, 1979

Event Description

101 minutes

The loop A RCPs tripped. SRM count rate spiked upward to peak at least one decade over count rate expected following a normal reactor trip. All radiation monitors exhibited substantial ramp increases. Operators stated they did not believe that natural circulation had been established due to the differential temperature across the steam generator and the low steam generator pressure with minimum heat removal, if any.

The reactor coolant system (RCS) had no forced-flow cooling. All reactor coolant pumps (RCPs) were stopped. The RCS average temperature and pressure were approximately 520°F and 750 psig. Makeup pump 1A was operating. The operators were attempting to establish natural circulation flow to cool the reactor core. OTSG B was isolated because of a suspected leak to the reactor building.

6 a.m.

Nuclear engineer called the site to gather information required for standard post-trip report. There was some question of whether the reactor had experienced a restart based on SRMs. The third boron sample indicated approximately 400 ppm.

6 a.m.

A conference call was established among Unit 2 technical support (Unit 2 control room) and Station Manager, Vice-President of Generation, and B&W site representatives (at their homes) lasting approximately 38 minutes. They all knew that the trip was abnormal since RCPs were off and they were unable to draw pressurizer bubble. Having a blown rupture disc and water on the floor were not surprising since this had happened before. The condition of the EMOV block valve was questioned and reported to be shut. The group decided that a need existed to restart an RCP and all should report to TMI. (A conference call had been initiated by station support following discussion with Unit 2 technical support (on-call Duty Officer) around 1 hour 15 minutes into event. The Unit 2 technical support had been on the site since 50 minutes into the event, following his call to the site shortly following the initial trip.)

6:18 a.m.

The operator requested computer printout of EMOV and code safety outlet temperatures (229°F, 190°F, and 194°F, respectively). The operator isolated the EMOV by closing the block valve. The operators had noted tail pipe temperature on relief valve 35°F higher than others and believed the valve to be leaking.

Time of Event,
March 28, 1979

Event Description

They noted a drop in reactor building pressure after closure of the block valve. The pressure change in the reactor building was more marked than when B OTSG was isolated. The plant operations group decided that the B OTSG did not have a leak from the shell into the reactor building. The B OTSG still had a water level.

6:40 a.m. An operator initiated emergency boration based on increasing nuclear instrument (NI) indicator, low boron sample results reported, and calculated shut-down margin of only 2.4% reactivity.

7:00 a.m. The RCS loop B hot leg temperature reached 800°F.

7:16 a.m. The answering service attempted to reach the Region I Duty Officer, but he had already left for the Region I Office.

7:18 a.m. Plant Status--After attempts to establish natural circulation had failed, the operator started RCP 2B. However, based on a no-flow indication, RCP 2B was stopped after 19 minutes. Superheated steam/gas was present in the reactor vessel head and RCS hot leg. Both reactor coolant system hot leg temperatures were offscale high (i.e., greater than 620°F). The RCS cold leg temperatures were about 375°F for loop A and 330°F for loop B. OTSG B was isolated due to a suspected RCS-to-OTSG leak. OTSG A pressure control was implemented by means of the power-operated emergency main steam dump valve A. An attempt was in progress to control pressurizer pressure and level with the EMOV.

7:20 a.m. The answering service signaled the Region I Duty Officer beeper, but the beeper reportedly did not alarm.

The RCS loop A hot leg temperature dropped from 800°F to 710°F. Makeup pump 1B had been off since engineered safety features initiation (referred to as ES initiation) at 2 minutes after the start of the incident. The RCS loop A hot leg temperature varied between 680°F to 760°F over the next 6 hours. Loop B followed loop A, but it was about 60°F hotter.

7:24 a.m. A General Emergency was declared by the Station Manager.

7:26 a.m. The pressurizer level and pressure were dropping. The pressurizer high-level alarm cleared indicating 254 inches

Time of Event,
March 28, 1979

Event Description

and pressurizer pressure had dropped to 1500 psig. The pressurizer surge line temperature had returned to normal at 581°F.

7:30 a.m.

The borated water storage tank low-level alarms were received at 53.03 and 53.06 feet.

7:56 a.m.

The ES and reactor building isolation were initiated by high reactor building pressure (approximately 4 psig). Makeup pump 1B started automatically, joining makeup pump 1A in injecting through the wide-open valves. Intermediate closed-cooling pumps 1A and 1B tripped.

8:00 a.m.

The ES and reactor building isolation was defeated by operator. The operator restarted the intermediate closed-cooling pumps to ensure RCP seal and letdown flow cooling.

By this time, the pressurizer level was approximately 380 inches with a reactor pressure of 1500 psig.

The detector, shielded with 2 inches of lead located in the containment dome, was reading 200 R/hr.

The Station Manager requested the B&W Site Operations Manager and other senior supervisors to caucus with him in the Shift Supervisor's office. It was decided to try another RCP start since pressure was high enough to satisfy net positive suction head (NPSH) requirements.

The nature of subsequent discussions was reported to consider the current situation and options available for return to normal conditions; discussions were not retrospective to determine what actions or conditions resulted in the plant reaching its current status.

The NRC Regional Director called the NRC IE Director to notify him of the activation of the Regional Emergency Center.

8:22 a.m.

Technicians lifted the leads on RCS loop A hot leg resistance temperature detector (RTD) to take a reading (729°F). Initially, temperature readings were not believed due to their magnitude and the fact that the readings were outside the calibrated range of the instruments.

8:00 a.m. to
9:00 a.m.

The Station Manager had requested verification of incore thermocouple (T/C) readings, which were

Time of Event,
March 28, 1979

Event Description

indicating off-scale temperatures. Technicians took incore T/C readings at terminal strips in the control building. The readings indicated temperatures from 80°F to 2620°F.

- 9:15 a.m. Convinced that steam was present in each loop, the licensee's staff decided to raise RCS pressure and collapse unwanted steam bubbles. They verified again that the EMOV was shut. (Recall that position "indication" shows valve position demand rather than actual position.) An increase in high-pressure injection flow was directed.
- 11:30 a.m. An operator opened both the EMOV and its block valve to depressurize the RCS. Reactor building pressure showed a rise from low point of 0.2 psig to 2.5 psig during this RCS depressurization.
- 1:50 p.m. ES was actuated on the reactor building isolation by high building pressure (4 psig). The building pressure experienced a spike to 28 psig (indicated), tripping the reactor building pressure switches (nominal 30 psig setpoint) some 6 seconds later. Building spray pumps started and the 30 psig actuation cleared within 4 seconds. The RCS pressure indication showed rapid 40 psi dip (probably due to increased pressure on RCS pressure detector reference leg) and recovery to 500 psig at the same time. Makeup pump 1C started (1B already operating and 1A in pull-to-lock). Decay heat pumps 1A and 1B started, intermediate closed-cooling pumps 1A and 1B tripped.
- Code safeties and RCP air temperatures alarmed high. Operator defeated building isolation and restarted intermediate closed-cooling pumps 1A and 1B to maintain RCP seal water and letdown cooling.
- 1:55 p.m. The Station Manager and Superintendent of Technical Support met with the Vice-President of Generation and proceeded to the Lt. Governor's office.
- 1:56 p.m. The reactor building spray pumps shut down and were placed in pull-to-lock position by operator to secure sodium hydroxide (NaOH) washdown of building when pressure drop indicated it was no longer needed. It appears these switches were returned to normal within minutes.
- 3:32 p.m. Operators indicated that method of cooldown at this time was using one high-pressure injection pump and the core flood tanks.

Time of Event,
March 28, 1979

Event Description

4:10 p.m.

The incore temperatures were reported to be unavailable. The Supervisor reported to NRC that the computers were all printing question marks, which indicated that either the computer point or the sensor was malfunctioning. The supervisor did not indicate that the same result occurred when the temperature exceeded the range of the software calibration for those points. These were the first thermocouple data or comments to the NRC. The first request had been made at approximately 8 hours 20 minutes into the accident. It was stated that core flood tanks were floating on the core, the Th was 590°F, and that the staff was convinced there was no boiling in the core.

4:56 p.m.

An NRC inspector reported the following:

1. Licensee was concerned that current cooldown process was too slow and believed that it would be faster to cool down by steaming the OTSG.
2. Licensee was working to get rid of bubbles in loops, to establish bubble in pressurizer, and to go on natural circulation.
3. Licensee was concerned about further use of EMOV since water was dumped to the floor, and, with sources of clean water being exhausted, was concerned that they would be forced to use dirty sump water for recirculation.
4. Licensee concluded core was covered. Discussed and rejected further blowdown because this would ultimately entail recirculation of sump water.

5:30 p.m.

Staff was repressurizing RCS to collapse voids and was prepared to start RC pump. Plant charges confirmed pressure increase.

7:50 p.m.

RCP 1A was started and was allowed to run. Flow and amps looked good. The reactor coolant pressure dropped to 1123 psig. OTSG B indicated level dropped below 79% and recovered to above 85% within 8-second span. OTSG A indicated level dropped below 81% and recovered to above 82% within a 9-second span, 40 seconds after OTSG B transient.

7:52 p.m.

Pressurizer level was still offscale high.

8:00 p.m.

The RCP 1A was running with both RCS loop cold legs temperature at about 290°F. The pressurizer level was still full scale with RCS pressure at about

Time of Event,
March 28, 1979

Event Description

1350 psig. OTSG B was operating with about 97% level and 99 psig, whereas OTSG A was steaming to the main condenser at about 93% level and 76 psig. Makeup pump 1B was operating and supplying RCP seals and normal makeup, the latter at 95 gpm. Makeup pumps 1A and 1C were secured, as were the decay heat removal pumps 1A and 1B. Pressurizer temperature was at 150°F and operators were letting down in attempt to draw a bubble.

II. Summary, Conclusions, and Recommendations

Summary

This investigation found that, although pertinent information was not intentionally withheld on March 28, 1979, information was not adequately transmitted to the Nuclear Regulatory Commission or the Bureau of Radiological Protection (BRP). The investigators concluded that two primary factors examined during this investigation caused the failure of station personnel to adequately inform the necessary organizations. The predominant factor was the absence of an effective onsite system to accumulate, evaluate and disseminate information. The second factor was the lack of comprehension by plant personnel of the behavior of the plant systems.

The investigators relied heavily on existing information, including data from the plant computer, reconstructions of recorded parameters, personal notes, and tapes to establish the time when information could have been known. Other information came from personal notes and transcripts of statements made to the various investigators during interviews were conducted to supplement the existing information. In some cases, the accumulated information contained apparent conflicts concerning the knowledge of individuals about specific information. The conflicts resulted from differences in an individual's testimony taken at different times, and differences in the testimony of different individuals with regard to the same subject.

To reconstruct what information was known, the investigators examined several of these apparent conflicts. This examination resulted in conclusions on the information known by various individuals. These conclusions are stated in the body of the report. One possible explanation for the apparent conflicts in knowledge of specific information is that one or more of the individuals involved has lied. Other possible explanations include poor recall, different statements by an individual on the same subject as a result of a slightly different question, the inability of an individual to differentiate between what was known on March 28, 1979 and knowledge gained later, and the effect of elapsed time. The investigators did not attempt to assign a specific cause for each of the apparent conflicts examined. They did, however, conclude that none of the conflicts examined were the result of lying.

Two potential items of noncompliance were examined related to the failure to report specific information (discussed in Section VI of the report). However, an additional citation of noncompliance is not recommended.

Conclusions

1. There was significant information that did not adequately flow either on the site or to the necessary offsite groups on the day of the accident.
2. On the day of the accident, an effective system did not exist to ensure adequate information flow; i.e., to provide significant information for dissemination and evaluation within the onsite

organization or offsite within the Met Ed and GPU organizations as well as the NRC, Commonwealth of Pennsylvania, and other agencies.

3. Those individuals on site failed to understand the extent and significance of the problems confronting them on the day of the accident; this contributed to the inadequate flow of information.
4. Met Ed was not fully forthcoming on March 28, 1979 in that they did not appraise the Commonwealth of Pennsylvania of either the uncertainty concerning the adequacy of core cooling or the potential for degradation of plant conditions.
5. Information was not intentionally withheld from the State on the day of the accident.
6. Information was not intentionally withheld from the NRC on the day of the accident.
7. The NRC did not have an effective system to ensure that information was properly accumulated, evaluated, and disseminated.
8. Reporting requirements, both to NRC and to the State, were not sufficiently specific on March 28, 1979.

Recommendations

1. The investigators recommend that no citation for failure to report be issued against Metropolitan Edison. Even though the investigators are unanimous in this recommendation, the underlying reasons vary. These reasons include the following:
 - a. The regulatory requirements in existence on March 28, 1979 with regard to reporting were not sufficiently specific to support such a citation;
 - b. Sufficient information was transmitted by Metropolitan Edison on March 28, 1979 to conclude that the reporting requirements existing at that time were satisfied; and
 - c. A belief that a citation of this type at this time for this licensee has no real meaning.
2. The investigators recommend that NRC require emergency plans and implementing procedures to specifically address, in detail, the following communications functions:
 - a. Assignment of specific responsibilities to ensure that all pertinent information is accumulated, recorded, and displayed.
 - b. Assignment of specific responsibilities to ensure that this information is disseminated to both those responsible for evaluation of the information and those responsible for communication of the information, including specification of how this information is to flow.

- c. Assignment of specific responsibilities to ensure that all pertinent information is communicated to all offsite groups and agencies which require this information, including specification of how this information is to flow. This recommendation includes the communication of plant management's evaluation of the significance of the information.
3. The investigators recommend that NRC reporting requirements and related regulatory guidance be modified or revised to ensure that all pertinent information is provided. Those requirements and guidance should:
 - a. Specify the nature of the subevent, occurrence, or indicator within an overall event that should be reportable in itself.
 - b. Specify that, the evaluation or assessment of each reported subevent, occurrence, or indicator is reportable.
 - c. Specify the responsibilities of the plant staff to promptly provide and continue to provide timely assessment of the plant conditions and the potential for deterioration.
 - d. Specify the responsibilities of the plant staff to provide information related to anomalous plant behavior; i.e., information related to plant behavior which is not understood.
4. The investigators recommend augmentation of the present system of verbal/telephonic information flow with a real-time data link in order to provide offsite organizations and agencies sufficient information to permit timely independent evaluation of plant conditions and the timely initiation of the resulting recommendations or actions.
5. The investigators recommend that NRC review and revise, as necessary, the communications channels to be implemented in response to an accident.
6. The investigators recommend that the roles of those NRC personnel involved in responding to an accident be clearly defined. This includes those personnel to be on site, in the Regional Office, and at headquarters. These roles should also be discussed with and understood by licensees.

III. Knowledge and Reporting to NRC of Key Indicators Related to the Accident

The investigators reviewed previous testimony, reports, and other source materials. Based on the results of this review, key indicators (events or key plant parameters) were identified as being particularly significant. Because these key indicators were significant, knowledge or lack of knowledge associated with them should have enabled the investigators to trace the flow of information among plant personnel on March 28, 1979. However, it was found that past testimony contained both incomplete

answers and unasked questions that prevented the investigators from establishing knowledge of the key indicators for some personnel. Therefore, a series of interviews was conducted in an attempt to get complete answers and to ask previously unasked questions. This process allowed the investigators to reach conclusions concerning the extent of knowledge possessed by particular Metropolitan Edison employees related to each of the key indicators. A summary concerning this knowledge of key indicators is discussed in the following.

1. Primary Coolant System

- a. HPI and Letdown Systems

A review of the status of the makeup pumps (MUPs) and the letdown system during the initial hours (prior to 8:00 a.m.) of the accident confirmed previous TMI operating staff testimony that the behavior of the plant was not understood. Approximately 2 minutes into the transient, reactor coolant system pressure decreased rapidly through the 1640 psig level, initiating both trains of the safety features actuation system (SFAS). During the next 6-8 minutes, pressure continued to decrease to saturation values for the corresponding hot leg temperatures. Contrary to the transient behavior of the plant for which they had been trained--that is, rapid pressure and level decrease during a loss-of-coolant accident (LOCA)--the pressurizer level increased rapidly to an offscale value and returned intermittently within the indicated range only when the operators throttled the high-pressure injection (HPI) flow and increased letdown to a value greater than 160 gpm. The plant appeared to stabilize in this anomalous condition, with the pressure essentially stable at saturation and pressurizer level offscale high, until the EMOV was closed after 2 hours and 19 minutes into the accident. At that point, pressure rapidly increased. In retrospect, it appears that, because the behavior of system pressure was essentially stable over much of this period, the operating staff became increasingly preoccupied with pressurizer level and a related concern over the possibility of operation with a solid primary coolant system (e.g., with the system completely filled with water). As a result, the operator actions of throttling the HPI and increasing letdown were directed toward restoring pressurizer level, thus contributing to the continual reduction of coolant inventory in the primary system.

This is significant because the incorrect analysis of the anomalous conditions not only resulted in detrimental operator actions but also delayed recognition of LOCA conditions and the potential severity of the accident. The resulting confusion was evidenced by the fact that some members of the key staff were aware of the prior status of these systems. However, post-accident testimony reveals that little discussion occurred early in the morning among key staff members regarding either the status of these systems (HPI and letdown) or the resulting implications with regard to the potential magnitude of the coolant inventory deficiency.

Knowledge of HPI and Letdown

George Kunder--Kunder was aware that HPI had been secured shortly after initiation of the transient and that letdown had been increased in an attempt to restore pressurizer level to a less-than-full indication (SIG, 9/18/79, pp. 32-35, 42-45). Kunder cannot remember if this information was discussed with any of the key staff (IE, 9/4/80, pp. 3-4).

Leland Rogers (B&W)--Rogers was unaware of the status of HPI and letdown prior to 8:00 a.m.; he did not recall any subsequent conversations with regard to its status prior to 8:00 a.m. (IE, 9/2/80, pp. 3-5).

William Zewe--On the morning of March 28, 1979, Zewe directed the reactor operators to throttle HPI and increase letdown in an attempt to restore pressurizer level. Zewe recalled briefing Kunder and Miller (separately) on what had happened prior to their arrivals and specifically recalled that the status of these systems was discussed (IE, 9/4/80, pp. 3-5).

Michael Ross--In testimony on September 18, 1979 to the SIG (pp. 11-12), Ross stated that he thought the fact that HPI had been off for some time or was throttled back was discussed prior to 11:00 a.m. When questioned on September 24, 1980 (IE, pp. 4-5), Ross stated that the discussion would have involved the "think tank" people.

Joseph Logan--Logan vaguely recalled (IE, 10/16/80, p. 5) that when he arrived in the control room he was told by Zewe that a safety injection had been automatically initiated and that it had been secured. Logan recalls no subsequent discussions of this subject.

Gary Miller--When asked, Miller did not recall knowing that HPI had been secured and/or throttled for some period of time prior to his arrival in the control room at approximately 7 a.m. (IE, 9/5/80, pp. 6-7 and IE, 11/10/80, pp. 140-146). Miller did not think Zewe's recollection of briefing him on the status of HPI and letdown was accurate.

The investigators conclude that Miller was briefed on the status of the HPI and letdown systems as they existed prior to his arrival. Zewe, who was present when the EMOV block valve was closed, probably did not recognize that a significant inventory loss had occurred. Thus, Zewe did not recognize the significance of the HPI system being secured and the letdown flow being increased for a period of time. Because of this, the investigators conclude that any information with regard to the status of the HPI and letdown systems was presented to Miller in the context of actions taken to restore an offscale high pressurizer level. Thus, Miller's attention was not directed to the length of time the HPI system had been secured.

b. Reactor Coolant Pumps

As reactor coolant system (RCS) inventory decreased due to the stuck open EMOV, the reactor coolant progressively changed to a circulating two-phase mixture with a continually increasing steam fraction. This condition was evidenced both by the increasing vibration of the RCPs and by the erratic and decreasing RCS flow rates. In response to these indications and the

minimum net positive suction head limits, operators secured the loop B RCPs at 5:14 a.m. The loop A RCPs were tripped at 5:41 a.m., thus terminating the forced coolant circulation through the reactor core. At 6:54 a.m., RCP 2B was restarted. At 7:12 a.m., the indicated flow was zero and the motor running current was 100 amps; therefore, RCP 2B was tripped. At 8:09 a.m., RCP 1A was restarted to confirm the pump running conditions. At that point, the indicated pump current rapidly decreased to less than 100 amps with no flow being indicated. RCP 1A was tripped 37 seconds later.

This sequence was significant for two reasons. First, termination of forced flow resulted in separation of the two-phase mixture, thereby vapor-binding the loops. This effectively terminated an already degraded two-phase heat transfer mechanism, resulting in coolant boiloff and initiation of core uncovering. Second, a qualitative indication of the severity of loss of coolant could have been inferred from the extent of voiding as evidenced by the steam environment in the RCP volute (suction).

The investigators conclude that the inability to run the RCPs on the morning of March 28, 1979 did not lead the plant personnel to infer the extent of voiding in relation to core water level.

Knowledge of RCPs

George Kunder--Subsequent to the attempt at 8:09 a.m. to run RCP 1A, Kunder concluded that the RCP was spinning in a steam environment. At that point, Kunder was concerned that they could be uncovering the core (Senate, 8/22/79, pp. 17-18). Kunder recalls no specific conversation on March 28, 1979 regarding this concern (IE, 9/4/80, pp. 6-7).

Leland Rogers (B&W)--Subsequent to the attempt at 8:09 a.m. to run RCP 1A, Rogers concluded that the loop was filled with steam at least to the suction of the RCP (IE, 9/2/80, pp. 14-16).

Joseph Logan--Logan was aware of the inability of the RCPs to provide forced circulation on the morning of March 28, 1979 (IE, 5/9/79, pp. 6-7, 33).

William Zewe--After Miller and Rogers arrived, Zewe informed them of the actions he had taken with regard to securing the RCPs and the bases for his taking these actions (IE, 9/4/80, p. 9).

Michael Ross--Ross was convinced that the RCP was pumping steam. When asked about checking plant elevation drawings subsequent to the attempts to start the pump, Ross recalls some discussion within the think tank about levels and the probable problem. However, he does not think they ever related it to a core water level (IE, 9/24/80, pp. 11-12).

Gary Miller--From the time the reactor coolant pumps were restarted and indicated 100 amps, Miller was aware that there was a coolant inventory deficiency in the plant (IE, 9/5/80, pp. 37, 48-50). Miller's concern was related to the level of water in the hot leg. The investigators conclude that Miller did not recognize the magnitude of the inventory

deficiency, and that he did not attempt to relate this inventory deficiency to core water level.

c. EMOV

Approximately 4 seconds after the turbine and generator trip, the EMOV opened as RCS pressure increased through the 2255 psig setpoint. When the pressurizer steam space was vented to the reactor coolant drain tank (RCDT), excess pressure, which was caused by the coolant expansion from the RCS into the pressurizer via the surge line reactor coolant was relieved. RCDT temperature and pressure began then to increase. At 2345 psig (approximately 8 seconds after turbine trip), the reactor tripped on high pressure and the coolant began to contract, thereby rapidly reducing system pressure and pressurizer level. Approximately 7 seconds after the reactor trip, pressure decreased through 2205 psig (the EMOV closure setpoint) and the EMOV did not close.

The EMOV solenoid deenergized and the EMOV control board position indicator (which was sensed from the electrical state of the solenoid) indicated closure of the EMOV. From this time (approximately 15 seconds from turbine trip) until the EMOV block valve was closed (2 hours and 19 minutes into the accident), an unrecognized loss of coolant continued to flow from the reactor coolant system.

The RCS pressure steadily decreased to the saturation pressure for the hot leg temperatures. The unavailability of feedwater to remove heat from the RCS and the low RCS pressure caused a rapid expansion of reactor coolant into the pressurizer. In fact, contrary to the expected transient behavior for loss-of-coolant accidents and contrary to the symptoms for which operators were trained to respond, pressurizer level was increasing rapidly within 1 minute of the reactor trip. A pressurizer high-level alarm (266 inches) was received at about 3 minutes and 28 seconds, and within 5 minutes and 30 seconds, the indicated pressurizer level was offscale high (maximum indicated range of 400 inches).

At 3 minutes and 15 seconds, the RCDT relief valve lifted (setpoint 122 psig), discharging coolant into the reactor building sump. The pressure and temperature in the reactor building began to increase as a result of the hot coolant expanding through the EMOV into the RCDT and out of the RCDT relief valve into the reactor building atmosphere (sump). At approximately 15 minutes into the accident, the RCDT rupture diaphragm burst (192 psig RCDT pressure) and released the contents of the RCDT into the reactor building atmosphere. This caused a rapid increase in reactor building pressure.

From this time until the EMOV was isolated, conditions remained essentially stable: RCS pressure remained at the saturation level for the corresponding hot leg temperatures, pressurizer level remained offscale high, and reactor coolant inventory continued to decrease as the coolant expanded through the EMOV into the RCDT and into the reactor building atmosphere.

The EMOV block valve was closed at 6:19 a.m. The reactor building pressure decreased rapidly, and the RCS pressure increased from 680 to 2120 psig during the next 41 minutes.

Knowledge of the EMOV

George Kunder--At some time on March 28, 1979 (he does not believe it was in the morning), Kunder became aware that the EMOV had been stuck open (IE, 9/4/80, p. 8-9). In earlier interviews (e.g., SIG 9/18/79, pp. 39-41), Kunder left the impression that it was earlier in the morning (perhaps shortly after the general emergency was declared) that he became aware that the EMOV had been stuck open.

Joseph Logan--Logan does not recall if he became aware on March 28, 1979 that the EMOV had stuck open (IE, 10/16/80, pp. 11-16).

Leland Rogers (B&W)--Rogers does not recall becoming aware that the EMOV had stuck open until March 29, 1979 when the reactimeter data was delogged (IE, 9/2/80, p. 7).

William Zewe--After the EMOV block valve was shut, Zewe recognized that the EMOV had been open for some period of time. Zewe was aware that some inventory had been lost and that, with closure of the block valve, the RCS pressure started increasing and the reactor building pressure started decreasing (SIG, 10/11/79, pp. 92, and Senate, 11/15/79, pp. 35-38). He recalled discussing this fact with several members of the plant staff, whom he believed included Kunder, Ross, and Logan. He also believed that it was discussed with Rogers and Miller some time on March 28, 1979 (IE, 9/4/80, pp. 11-12).

Michael Ross--Ross recalled arriving about the time the block valve was shut and Zewe saying that the reactor building pressure was decreasing with the EMOV closure (IE, 5/19/79, pp. 11-12). He also recalled discussion in the think tank regarding the EMOV having been open (IE, 9/24/80, pp. 17-20).

Gary Miller--Miller has stated that he was aware on March 28, 1979 that the EMOV had been open longer than it should have been because the RCDT rupture disc had blown. However, his perception of that time period was in terms of minutes rather than hours (IE, 11/10/80, pp. 61-78).

The investigators conclude that Miller was aware on March 28, 1979 that the EMOV had stuck open and that it was related to the abnormal indications in the early morning but that he did not perceive how much water had been lost from the RCS.

William Dornsife (BRP)--Dornsife recalled Miller briefing him at approximately 9:00 a.m. on March 28, 1979. He recalled Miller stating that the EMOV had been stuck open for a period of time and that the position indication had been faulty (IE, 10/1/80, p. 11).

James Higgins (NRC)--Higgins stated in an IE interview on October 7, 1980 (p. 31) that he was told by Marshall (on his arrival at about 10:15 a.m.) that the EMOV had been stuck open.

d. Th/Superheat/Incore Thermocouples

The loop B RCPs were secured at 5:14 a.m. Twenty-seven minutes later (5:41 a.m.), the loop A RCPs were secured. Loops A and B hot leg temperatures were approximately 535°F at that time. Within 9 minutes, the loop A hot leg temperature started to increase rapidly and within 30 minutes exceeded the wide-range console indication (maximum indicated 620°F). The loop B hot leg temperature did not increase immediately, but went off the scale 19 minutes after the loop A temperature indication. Both loops A and B hot leg temperatures increased to greater than 700°F and remained there for approximately 7 hours.

The significance of these temperatures is derived from the thermodynamic relationship of coolant temperature, pressure, and core water level. After the loop A RCPs were secured, coolant boiloff reduced the coolant level below the top of the fuel. Steam rising above the steam-water interface continued to be heated by the exposed fuel rods beyond the saturation temperature (i.e., the steam became superheated). The reduction in the heat transfer capacity of the superheated steam resulted in further degradation of heat removal from the exposed fuel. The overheating of the fuel rods resulted in a reaction of the zircalloy tubes with the steam, which produced free hydrogen.

Given the training of the plant personnel, it is questionable to believe that the extent of core damage during the accident should have been inferred from the indications present. However, recognition of the obvious superheated conditions should have led to a closer reexamination of some of the information present in the control room. In fact, when the loop A hot leg temperature exceeded the wide-range indication (620°F), RCS pressure was approximately 700 psig and decreasing, which was well below the saturation pressure for 620°F (1787 psig). The indicated temperatures were questioned by the plant staff, particularly with regard to the validity of the calibration of the hot leg temperature sensors in a steam environment. To verify the indicated temperatures, the plant staff checked these temperatures with other instrumentation. An attempt was made to read out the core exit thermocouples on the plant computer. Question marks were obtained from many locations, which indicated that these core exit thermocouples were damaged or off scale (700°F). The plant staff then tried to read the thermocouples with test equipment in the cable spreading room. The range of data presented to the Station Manager (five readings that varied from a high of >2000°F to a low of <100°F) was characterized as unreliable; however, they provided him with a gross indication that the core was hot and that this was why the computer read off the scale. It is important to note that these personnel had no experience, training, or procedures for the use of these core exit thermocouples. In retrospect, if all the readings had been available and had been examined in the light of other confirming temperature indications, it might have been recognized that the >2000°F temperature indicated that the core was within the range in which an autocatalytic exothermic zircalloy-steam reaction could occur. Confirmation of the magnitude of the hot leg temperatures was obtained (and believed) by connecting instrument bridges to the hot leg temperature sensors for the reactor protection system. These were read out in the control room and confirmed the hot leg temperatures in the range of 700-800°F (i.e., superheated).

The investigators conclude that the significance of superheated steam was not understood on March 28, 1979 by the people on site.

Knowledge of Th/Superheat/Incores

George Kunder--Kunder was aware that the hot leg temperatures were in the range of 700-800°F. Kunder inferred from these temperatures that there could be portions of the core that were being cooled by steam. Kunder believes that his concern was verbalized in the think tank meetings (SIG, 9/18/79, pp. 53-55, and IE, 9/4/80, pp. 11-17), but he does not recall any specific conversations relative to superheated steam.

Kunder, who was unfamiliar with the core exit T/Cs, briefly discussed these T/C readings with Porter. Kunder accepted Porter's analysis of unreliability. Kunder was not aware of any other discussions of these core exit T/Cs (IE, 7/11/79, pp. 12-14, and IE, 9/4/80, pp. 28-29).

James Seelinger--Seelinger concluded that the hot leg temperatures could have been hotter than indicated (maximum indication on meter was 620°F wide range).

Although Seelinger was aware that Porter went to get the core exit T/C readings, Seelinger did not know the results of those readings. Seelinger was aware of the question marks on the computer and concluded that they were probably out of range and that the hot leg temperatures were valid (IE, 10/14/80, pp. 77-78).

Leland Rogers (B&W)--When interviewed, Rogers stated (IE, 9/2/80, pp. 16-17) that, although he was aware of a temperature readout (hot leg temperature) greater than 700°F, he was never certain on March 28, 1979 that the correct hot leg temperatures were being indicated in the steam phase. Rogers was aware of the core exit thermocouple readings but he was not certain of their validity (IE, 9/2/80, pp. 26-27). Rogers recalled no discussions of superheated steam on March 28, 1979 (IE, 9/2/80, p. 18).

Joseph Logan--Logan did not recall knowing the magnitude of the hot leg temperatures on March 28, 1979. He recalled Porter's discussion of a range of core exit T/C readings with Miller and the remark that the readings were questionable. However, Logan was not aware of nor did he consider or discuss superheated steam conditions on March 28, 1979 (IE, 10/16/80, pp. 18-22).

William Zewe--Zewe was aware of the hot leg temperatures on the extended scale device connected by Porter. Zewe then became aware that the temperatures were in excess of the saturation values (IE, 9/4/80, p. 15).

Zewe has testified both that he was not aware of the core exit T/C readings taken by Porter (Senate, 10/18/79, p. 23) and that he does not recall whether he knew these readings were being taken (IE, 9/4/80, p. 30).

Michael Ross--Ross was aware of the hot leg temperatures; however, he related them to inadequate core cooling and did not connect them with an

inventory deficiency (IE, 9/24/80, p. 26). Ross stated in the same interview that, although the term "superheat" was never discussed, the plant staff's analysis was that the hot leg temperatures were too hot for the existing pressure (p. 28).

Ross recalled being aware of the core exit T/C readings and the discussion between Miller and Porter that took place in the control room. However, he only recalled the core exit thermocouples being discussed in passing in the think tank (IE, 9/24/80, pp. 41-45).

Ivan Porter--Porter and four instrument technicians were involved in reading out the incore thermocouples in the cable spreading room. Based on the magnitude of the readings observed, some of the instrument technicians concluded that the core could be uncovered. Porter returned to the control room to pass on the initial readings. Porter advised Miller that some readings were high ($>2000^{\circ}\text{F}$), some were low, and some did not read out. Porter felt that the thermocouples may have been damaged. Porter did not pass on the concerns of the instrument technicians. Although a complete set of readings were taken after Porter left, neither Miller nor other key staff members were aware of them on March 28, 1979.

Gary Miller--Miller was aware that hot leg temperatures were greater than 700°F . Even though there was a discussion of steam conditions and Miller was aware of the readings from the extended-scale hot leg readout, Miller said he made no connection between the existing steam conditions and core uncover. Miller did state, however, that they might have believed there was some steam environment near the top of the fuel rods (IE, 9/5/80, pp. 21-56).

The investigators conclude that Miller did not believe that the core had been uncovered on March 28, 1979 and that Miller's concern, resulting in reinitiation of HPI at a less-than-maximum flow rate, was based predominantly on ensuring adequate core cooling (i.e., removing decay heat). The investigators also conclude that, prior to receiving the incore thermocouple data, Miller already believed the core was hot. This belief (Miller's belief) was based on the hot leg temperatures obtained from the instrument bridges hooked up to the reactor protection system (RPS) cabinets, the offscale computer indications, etc. Thus, when Porter advised Miller that the thermocouples could have melted and formed new junctions, Miller was concerned that the core was hot but he saw no further use for the incore thermocouple data.

e. Count Rate Behavior

Following the turbine and reactor trip, source range nuclear instrumentation readings decreased at a normal decay rate of approximately one-third decade per minute for the first 20 minutes. At that point, the count rate leveled off at about 5000 cps and then increased slowly until 5:41 a.m. when the loop A RCPs were secured. The count rate then abruptly dropped. Shortly thereafter, it increased again and continued to behave erratically over the next 2 hours. This behavior has been postulated to represent both changes in core configuration and changes in neutron leakage due to moderator conditions in the reactor vessel annulus.

Although the complexity of neutron transport mechanics could prevent a simple analysis of the count rate with changing plant thermal-hydraulic conditions, it is significant that the operators were presented with an unexpected and unexplained increase in source range count rates following the shutdown condition.

Boron concentration prior to the trip was in excess of 1000 ppm. At approximately 5:15 a.m., the shift supervisor received a boron analysis indicating that the concentration was approximately 700 ppm. A second sample taken at 5:45 a.m. yielded approximately 400 ppm boron in the RCS. Based on the count rate behavior and the boron concentration, there was a concern about recriticality as a result of moderator dilution. Emergency boration was initiated at about 6:10 a.m. and continued until 7:22 a.m.

Count rate behavior essentially stabilized after about 7:45 a.m. Later in the morning, a B&W employee postulated that this count rate behavior could have resulted from increased neutron leakage due to voiding. This conjecture, when combined with other information, suggested that the core may have been uncovered.

Knowledge of Count Rate Behavior

George Kunder--Kunder was concerned about the count rate behavior and low boron concentration. His concern, along with that of Ross and Zewe, resulted in initiation of emergency boration. Kunder had nuclear engineers looking at the count rate behavior; however, he did not remember any further discussions with either of them or with the think tank members regarding the count rate behavior. Kunder did not become aware of the implications (i.e., voiding and partial core uncovering) until he heard Flint's explanation late in the morning (IE, 4/25/79, pp. 26-34, and IE, 9/4/80, pp. 24-26).

Joseph Logan--On the morning of March 28, 1979, Logan was aware of the low boron concentration and the count rate behavior (IE, 5/9/79, pp. 8, 9). Logan did not believe that the reactor was returning to criticality; however, he could not explain the count rate behavior. Logan recalled discussing these indications with Kunder and the reference to possible moderator dilution. However, he did not recall knowing of Flint's explanation as discussed below (IE, 10/16/80, pp. 33-39).

William Zewe--Zewe did not believe that the reactor was going critical. However, he also could not explain the increase in count rate. Zewe recalled discussing with Miller, Kunder, Flint, and Chwastyk the reason for an increase in flux in the detectors. Zewe did not recall these discussions being concerned with core voiding (IE, 9/4/80, pp. 29-30).

Michael Ross--Ross was aware of the increasing count rate and believed that the reactor was returning to criticality. Ross recalled no discussions with regard to Flint's explanation of core voiding and increased neutron leakage (IE, 9/24/80, p. 37).

Gary Miller--Miller knew that emergency boration had been initiated, based on count rate behavior and boron concentration (IE, 5/7/79, p. 76).

Miller did not recall being aware of Flint's explanation on March 28, 1979, nor did he recall any inferences related to inventory based on count rate behavior (IE, 9/5/79, pp. 57-59).

Leland Rogers (B&W)--Rogers recalled discussing with Zewe a concern about low boron concentration and recriticality. Rogers recalled no discussion, however, of count rate behavior. Rogers did not recall discussions with Flint regarding core voiding and neutron instrumentation behavior (IE, 9/2/80, pp. 22-24).

John Flint (B&W)--After reviewing plant instrumentation, Flint concluded that the increase in count rate had probably been caused by a change in the leakage flux from the core. Based on this and other instrumentation readings, Flint believed that the core had been uncovered earlier in the morning (Kemeny, 6/30/79, pp. 18-19 and IE, 4/23/79, pp. 4-5). Flint recalled discussing this information with Kunder, Zewe, and Rogers. Flint's recollection was that Rogers said he would discuss it with Met Ed management (IE, 9/2/80, pp. 18-19).

The investigators conclude that Miller, Logan, Seelinger and Ross were not aware of the implication of core uncovering based on the count rate behavior. They also conclude that Kunder did not learn of this explanation until late in the morning or early in the afternoon. By this time, the count rate had stabilized and Kunder dismissed this factor as not being priority information.

2. Containment Pressure Spike

Three aspects are pertinent to a discussion of the 28 psig containment pressure spike that occurred at 1:50 p.m. on March 28, 1979: (1) the containment and associated systems, (2) the hydrogen, and (3) the testimony of Chwastyk and Mehler.

The safety features actuation system (SFAS) is the instrumentation monitoring and actuation system for engineered safety features (ESF). SFAS receives input from reactor coolant pressure transmitters and containment pressure switches. On actuation, SFAS initiates emergency coolant injection, isolates the containment, starts the emergency containment cooling system, initiates the containment spray, and starts the emergency diesel generators.

Table 7.3-2 of the final safety analysis report (FSAR) for TMI-2 lists equipment associated with ESF actuation. Each of these components has component status indication in the control room (e.g., containment isolation, containment cooling equipment actuation, high-pressure injection valves position indication and high-pressure injection pump actuation, decay heat removal pump actuation, containment spray valve position indication, and diesel generator status).

The signals for the containment spray functions are provided by six containment pressure switches. These switches are arranged in two separate and independent actuation logic trains (three channels per train with two-out-of-three logic). Each pressure switch has a range of 0-100 psig and trips at a nominal 28 psig. There is control room panel status indication for each channel and train.

At 1:50 p.m. (9 hours and 50 minutes into the accident), the reactor building pressure rose abruptly from about 3 psig to about 28 psig and then decreased rapidly to less than 4 psig. Containment spray pumps automatically started. Coincident with these events, two 480 Vac busses were tripped, after which a "thump" or "thud" was heard by some personnel in the control room. Several members of the control room operations staff witnessed the reactor building pressure recorder respond to the pressure transient and the accompanying spray pump actuation. However, with the exception of two shift supervisors, it appears that the recorded pressure transient and spray pump actuation were generally attributed to electrical faults or instrument malfunctions.

It was not until late the next evening on Thursday, March 29, 1979, that the significance of the containment pressure spike was generally known, and it was not until early in the morning of Friday, March 30, 1979, that the Station Manager was aware that the pressure spike had been real. The investigators believe that, because the pressure spike was not generally recognized as being "real" on March 28, 1979, it was generally ignored. It is reasonable, however, to expect that, based on their licensing, training, and required knowledge of engineered safety feature (ESF) systems and associated instrumentation, personnel at TMI-2 should have deduced that the observed pressure spike did not result from instrument malfunction or an electrical fault. The recorded containment pressure transient was, in fact, a real pressure excursion and a potentially serious challenge to the containment integrity. The investigators conclude that licensed operators and operating supervisors in the Unit 2 control room should have recognized that the pressure spike was caused by a real pressure increase inside the containment. [Two shift supervisors (Chwastyk and Mehler) have testified that they thought the spike was real; however, the investigators conclude that they did not explain or discuss this belief with their supervisors on March 28, 1979. They appear to have diverted their attention away from the spike to other plant activities after a brief time period. See also the discussion of the third aspect in this section.]

The second aspect related to the pressure spike is the extent of knowledge of hydrogen as the cause of the spike. Two shift supervisors have stated beliefs concerning the symptoms of the pressure spike that are substantially different from the beliefs of other Met Ed personnel. In fact, they have testified that they were aware on March 28, 1979 that a real pressure transient had occurred and that a chemical reaction or hydrogen was the possible cause. Chwastyk also testified that an order not to restart electrical equipment was issued on March 28, 1979 (IE, 9/4/80, pp. 12-22).

The ESF systems at TMI-2 were designed to prevent core meltdown, to maintain the integrity of the reactor containment building, and to ensure that the exposure of the public to radiation would be below the limits of 10 CFR 100 during LOCA conditions. The principal document discussing the ESF systems and post-accident hydrogen production, and with which the TMI-2 personnel would have been familiar, is the final safety analysis report (FSAR). The FSAR analyses show that post-accident radiolytic hydrogen plus hydrogen contributed by metal-water and aluminum-corrosion

reactions does not approach the generally accepted lower flammability limit of 4 volume percent for several months (4 months) after the LOCA (refer to Figure 6A-10, TMI-2 FSAR). Therefore, it is probable that, prior to the TMI-2 accident, it was beyond the range of credible operator knowledge to infer that amounts of hydrogen sufficient to reach a flammable concentration in a 2×10^6 ft³ containment might exist 10 hours after the initiation of the accident.

The investigators conclude that hydrogen was not believed to be the cause of the pressure spike. The testimony reviewed leads the investigators to further conclude that hydrogen was not discussed on March 28, 1979. This conclusion concerning hydrogen not being identified as the cause of the pressure spike on March 28, 1979, is based on the testimony of operators and a review of the engineered safety systems.

The third aspect of the containment pressure spike was developed from the testimony of Chwastyk and Mehler. The investigators examined a possible discussion of the pressure spike in the presence of an NRC inspector in the Unit 2 control room at the time of the spike. At this time, two NRC inspectors were in the area of the TMI-2 control room. They were James Higgins, a reactor operations inspector, and Don Neely, a health physics inspector. Two Med Ed employees, Joseph Chwastyk and Brian Mehler, have testified that an NRC inspector was present in the TMI-2 control room at the time of the spike.

Joseph Chwastyk stated that he told an NRC inspector that he (Chwastyk) believed that an explosion had taken place in the containment (IE, 9/4/80, p. 104). In testimony to the Special Inquiry Group (10/30/79, p. 18), Chwastyk stated "...and I know specifically there was at least one NRC inspector there. And I don't know who it was, I don't remember his name or what he looks like." [Although Chwastyk was interviewed on May 21, 1979 and October 11, 1979, the NRC inspector was not mentioned until October 30, 1979, even though the pressure spike was discussed.] In testimony before these investigators, Chwastyk stated that he later learned the NRC inspector's name. When asked by another NRC investigator, he remembered that Neely was the NRC inspector to whom he explained that the pressure spike was real. Chwastyk further stated that Neely saw the containment pressure recorder (IE, 9/4/80, pp. 104-109).

Brian Mehler testified (Senate, 8/22/79, p. 9) that he discussed the spray pump actuation that occurred as a result of the pressure spike with an NRC inspector. He stated that, "There were NRC people in there wandering around, and he asked me a question, so I explained it to him." Mehler then stated that he could not identify this NRC inspector (Senate, 8/22/79, p. 10). When asked about the identity of the NRC inspector, Mehler said that it was not Neely because he became acquainted with Neely after March 28, 1979 (SIG, 10/30/79, pp. 19, 20). Mehler also states that Donald Haverkamp was the only NRC inspector in the TMI-2 control room whom he recognized on March 28, 1979 (SIG, 10/30/79, p. 19). Haverkamp did not go to the site until Thursday, March 29, 1980.

Donald Neely testified that he was not aware of the pressure spike on March 28, 1979 and that he did not discuss the spike with Chwastyk or Mehler on March 28, 1979 (IE, 10/7/80, p. 10). He also testified that

weeks after the accident (in April), a Met Ed employee told him that he (the Met Ed employee) had information relating to the spike. Neely turned this matter over to the IE investigation team, whose findings are contained in NUREG-0600 (IE, 10/7/80, pp. 10-13).

James Higgins also testified that he was not aware of the pressure spike on March 28, 1979 (IE, 10/7/80, p. 22). When asked how he could explain being in the control room during the time period of the spike and not be aware of the event, he stated: "I guess I can't really explain that. All I could say was that there was certainly a lot of activity going on at that time. I don't recall any thud of that type, and if it was a dull type of thud, similar to a main coolant pump check valve, when you start a main coolant pump on a submarine, which is what--when I discussed it with Gary Miller on Friday, the way he described it, and that is sort of a dull thud in the background. There are lots of noises at a plant that happen at various times, and if you are familiar with the plant, one that's a little bit different sticks out, if you're there all the time. If you're not, and you hear all these various noises, and there are lots of them at a plant--now if you're not familiar with the noises, what's common and what's not, they don't really register with you, and the odd ones that are not normal don't really stand out as they would to somebody that was very familiar with it and there on an every-day basis..." (IE, 10/7/80, p. 23).

Recognizing the apparent conflicts that exist between the testimony of Mehler and Chwastyk concerning the identity of the inspector, these investigators conclude that an NRC inspector was not informed that an actual pressure of about 28 psig had existed inside containment on the day of the accident. These investigators also conclude that the NRC inspectors in the control room at TMI-2 were aware of some of the symptoms associated with the rapid increase in containment pressure to 28 psig (indicated). The symptoms of the pressure spike included the SFAS actuation and containment spray actuation. However, the investigators conclude that they did not understand the symptoms or pursue an explanation of any symptoms they may have observed.

Knowledge of Containment Pressure Spike and Hydrogen

Gary Miller--Miller was in the Unit 2 control room at the time the pressure spike occurred when he heard a noise like a "thud." He did not observe the spike on the containment pressure recorder or recognize that the containment spray pumps had actuated (Kemeny, 5/31/79, p. 57; IE, 9/5/80, p. 112; Senate, 9/28/79, p. 25). Miller discussed the source of the noise with Ross and Marshall and requested an explanation. When the noise was attributed to the ventilation system changing modes, Miller did not question this explanation (Senate, 9/28/79, p. 25).

The investigators conclude that Miller was not aware of the 28 psig pressure spike on March 28, 1979, and also conclude that he did not believe or have discussions concerning the possibility that hydrogen was being generated and could become a problem on that date. Although the investigators conclude that it is possible that Miller was aware that the containment spray pumps actuated, they also conclude that he placed no

significance on this actuation and accepted the explanation of the ventilation system to be the cause of the "thud."

Michael Ross--Ross was in the Unit 2 control room at the time of the pressure spike. He was aware that the containment spray pumps started, and that the containment pressure recorders showed the 28 psig spike (IE, 5/19/79, p. 3). He believed that an instrument failure caused the spray pumps to be actuated. The event itself, however, was not believed to be possible (i.e., the rapid increase and rapid decrease in containment pressure). Ross did not believe on the day of the accident that hydrogen buildup would happen in such a short period of time (IE, 9/24/80, pp. 47-56). Therefore, on March 28, 1979, he did not conclude that hydrogen had been or was a problem.

William Zewe--Zewe was in the Unit 2 control room at the time of the pressure spike. He was aware that the containment spray pumps actuated and that the containment pressure recorders showed the 28 psig spike (IE, 7/2/79, pp. 34-41). Zewe told Ross that the spray pumps had actuated, but he did not believe that the pressure spike was real on March 28, 1979. He could "not conceive how the building of over 2 million cubic feet could pressurize that rapidly, and then be depressurized that rapidly" (IE, 9/4/80, p. 44). On March 28, 1979, he did not conclude that hydrogen was or could become a problem.

Joseph Chwastyk--Chwastyk was in the Unit 2 control room at the time of the pressure spike (IE, 5/21/79, pp. 8-18). He has stated that he was aware that containment spray pumps had started and that the recorders showed a spike. After a few minutes, he ordered that the spray pumps be secured. He knew that a real pressure spike had occurred on March 28, 1979, but he did not hear the "thud." During this same interview, he was asked "...at that time as far as the cause was strictly a channel or pressure spike in the containment but [did you] not have any feeling for what would cause that kind of problem?" He responded, "No, I did not." However, when he later learned of the noise, he assumed that some kind of explosion had taken place. Chwastyk also testified (IE, 9/4/80, p. 24) that he reached the conclusion on March 28, 1979 that a zirconium-water reaction had been caused by heat generated in the reactor core and that this reaction resulted in hydrogen generation that was sufficient to cause an explosion. He also stated that shortly after the pressure spike he "related" to Gary Miller that a hydrogen explosion had probably taken place.

In an IE interview (5/21/79, p. 9), Chwastyk stated that he was hesitant to secure equipment because he did not know what caused the pressure spike. In this same interview, he stated that he reset the equipment, but he had no idea of the time frame after the spike in which this equipment was reset: "Oh, I have no idea. It was...there were a lot of things happening. I remember it was just an oh-by-the-way type thing. . . How, exactly long after the spike I don't know" (p. 12). However, less than 1 minute after the spike, operators began to take actions to defeat the ESF actuation signals that were caused by the spike; at about 6 minutes after the spike, the containment spray pumps were secured.

Chwastyk has testified that not very long after the spike he "...suggested to Gary Miller we no longer cycle the electromagnetic relief valve because it had...the explosion...or rapid rising pressure in the reactor building corresponded to opening the electromagnetic relief valve" (IE, 5/21/79, p. 18). Chwastyk also testified that, "It was right after the hydrogen explosion and I mentioned that I correlated the opening of the valve with the detonation period that I again went to Gary Miller and explained what I thought had happened as far as the hydrogen detonation and the simultaneous opening of the valve, and it was shortly after that, Gary Miller got back to me and said go ahead and draw the bubble" (SIG, 10/11/79, p. 18).

In an SIG interview (10/30/79, p. 17), Chwastyk was not sure that he told Miller of a hydrogen explosion; he stated, "my best recollection of that is that I did relate to Gary that we had some sort of an explosion. Whether I said it was hydrogen or not, I'm not sure. But I remember distinctly putting together the operation of the valve and the spike, and I think I relayed those thoughts to Gary." In this same interview, Chwastyk stated that he did not remember specifically discussing the possibility of an explosion with other control room personnel other than Mehler on March 28, 1979 (pp. 17, 18). He also stated (pp. 19, 20) in this interview (in response to a question about Miller's lack of knowledge of an explosion on March 28, 1979), "Well, that could very well be true. Again, I can't absolutely--if Gary said--I may not have told him what I thought at the time, because I really wasn't certain." In testimony conducted as part of this investigation (IE, 9/4/80, p. 11), Chwastyk responded to the following:

"Q. What about Mr. Miller, was he already aware before you discussed it with him that there had been a pressure spike?

A. I don't know that. To the best of my recollection, I think I asked someone to tell him that we had just had something happen in the building that caused a pressure spike. I don't remember who that was, and what they did, if they actually told Gary."

In contrast to Chwastyk's testimony is the testimony of the other think tank members who have testified that the spike was not believed to be real on March 28, 1979.

Chwastyk also stated (IE, 9/4/80, pp. 33-36) that he directed someone to inspect the containment to determine if containment integrity had been lost. He did not know that he ever got a report of the status of actions that he directed be taken. He stated, "I don't know that I ever got the report back on that outside, you know, check of the containment. I guess I don't remember because I think by the time they could make any kind of inspection I had come up with the idea, and quote if you will, of the hydrogen explosion. And I think after that I just sort of forgot about the containment check" (IE, 9/4/80, p. 36).

The investigators conclude that Chwastyk may have directed operators to make checks to help identify the cause of the spike. However, the investigators conclude that Chwastyk did not direct that the integrity of a

containment (known to contain substantial amounts of radioactivity) be checked on March 28, 1979. It is also concluded that Miller did not give Chwastyk permission to establish a bubble in the pressurizer before he (Miller) returned from briefing the Lt. Governor. [Pressurizer heaters were turned off and on several times between 2:00 p.m. and 4:30 p.m. The actions being taken were attempts to maintain the plant status; i.e., continued efforts to collapse the bubble in the loops and cooldown by natural circulation using loop A and to make preparations to initiate the decay heat system.]

The investigators conclude that Chwastyk believed the pressure spike to be real (containment pressure reached 28 psig) and discussed it with Mehler on March 28, 1979. They conclude that Chwastyk's recollection of the cause of the spike is in error. The investigators conclude that hydrogen was not discussed as a cause for the pressure spike on March 28, 1979; there was no acknowledged cause for the spike on that date. It is concluded that the order not to restart electrical equipment was given on some day subsequent to March 28, 1979.

Brian Mehler--Mehler was in the Unit 2 shift supervisor's office at the time of the pressure spike. He was aware that the containment spray pumps had actuated and saw the spike on the containment pressure recorder (wide range) (IE, 5/17/79, pp. 29-33). Mehler discussed the symptoms associated with the pressure spike with Chwastyk. Part of this discussion concerned the cause of the spike as being "some kind of chemical reaction or something" (SIG, 10/11/79, pp. 14-15).

Mehler testified (SIG, 10/11/79, p. 15) that he did not connect the spike with the EMOV block valve operation.

"Q. Did you connect the spike with the fact that it [spike] just happened after the vent valve had been operated?

A. No, later on, yes. Two days later when everyone became concerned, yes."

Mehler also discussed an order not to start any pumps and "...not to do anything that could give an ignition" (SIG, 10/11/79, p. 15). When asked (SIG, 10/11/79, p. 16) about the time of the order or recommendations he may have made to Gary Miller in connection with the pressure spike, Mehler responded, "No. It's very hard. I would like to put the time together, but I can't. I can't. I do not know sometime after the pressure spike happened we were told not to start equipment because they assumed that it could happen again and they probably put it that there was hydrogen in there, but that was sometime after 1:50. Now how far past that, I don't know. And I do not, I said--well, to Gary Miller I said--he said don't start any more oil pumps and I said we don't have to, I already tested them all, because they were concerned--but how far into the afternoon at that time, I don't know whether it was 4:00, 2:00 or what, but it was sometime after."

The investigators conclude that Mehler recognized on March 28, 1979 that the pressure spike was real (containment pressure reached 28 psig), but

its cause was not known. It is concluded that Mehler's recollection of hydrogen being discussed on March 28, 1979 and his recollection that an order not to start electrical equipment which could cause a spark was given on March 28, 1979 are in error. It is concluded that an order not to restart electrical equipment was given on some day subsequent to March 28, 1979.

Charles Mell--Mell arrived in the Unit 2 control room after the pressure spike occurred. He learned of the spike on the evening of March 28, 1979. Subsequent to March 28, 1979, Mell learned that a hydrogen explosion had possibly caused the spike (Senate, 8/22/79, pp. 14-17).

Theodore Illjes--Illjes arrived in the Unit 2 control room after the pressure spike (3:45 p.m.) and was briefed by Chwastyk. Illjes and Mell were told of the pressure spike and resulting containment isolation. Illjes testified that in this briefing there was a discussion of hydrogen having been the cause of the pressure spike (IE, 5/23/79, pp. 5-10). The investigators conclude that discussions concerning hydrogen and an order not to restart electrical equipment were learned by Illjes subsequent to March 28, 1979.

In a separate but related effort, the NRC Office of Inspector and Auditor (OIA) interviewed several of the inspectors who went to TMI on the day of the accident. During these interviews, Karl Plumlee, an NRC inspector, expressed several concerns related to this investigation. Copies of OIA summaries of their two interviews with Plumlee are attached as is an OIA summary of a followup interview with James Seelinger who was employed by Met Ed at the time of the accident.

Plumlee's concerns, as evidenced by the OIA interview summaries, may be condensed into the following:

- (1) Knowledge by Region I personnel of elevated hydrogen concentration inside containment on the morning (~8:00 a.m.) of March 28, 1979;
- (2) Performance of hydrogen monitoring by Met Ed before the containment spike (1:50 p.m.) as evidenced by specific concentration numbers about which he was told; and
- (3) A perception that information may not have been freely supplied by NRC management to NRC inspectors or by Met Ed to its employees.

The investigators' review of these concerns included interviewing all of the inspectors who were sent to the TMI site with Plumlee as well as interviewing George Smith, reviewing notes and records of information received by Region I prior to the departure of the inspectors, and reviewing TMI records for evidence of containment air sample results. The results of the review are summarized in the following paragraphs.

Plumlee's belief that regional personnel had knowledge on the morning of March 28, 1979 of specific concentrations of hydrogen in the containment came from two sources. First, he believed that his Branch Chief, George Smith, said that there was 2.3% hydrogen in the containment when Smith

briefed inspectors at about 8:15 a.m. prior to their leaving for the TMI site. Second, his own analysis of the other information he was provided led Plumlee to conclude that hydrogen levels could be expected in the containment building. Plumlee asked Smith at the time of the briefing about the hydrogen and Smith said he believed that he had said pressure rather than hydrogen composition but, if he had said it differently, that what he meant to say was pressure.

The review leads these investigators to conclude that the containment hydrogen composition was not known by anyone until the morning of March 31, 1979 when the first sample was analyzed at about 6:00 a.m. The investigators also conclude that Plumlee was and continues to be mistaken in his perception that elevated hydrogen levels could be expected from the information that was available in Region I prior to 8:45 a.m., some of which he was told on the morning of March 28, 1979. He stated that his conclusion on this perception was based on the containment dome monitor reading and the primary coolant sample result. The containment dome monitor was reported to Region I to be 200 R/hr at the time. Although there was a question as to whether this number was the shielded or unshielded value, lack of certainty about the value precluded Plumlee's certainty. A radiation rate of 200 R/hr on the containment is not evidence of core damage involving a zirconium-water reaction. The initial report of primary coolant activity was reported to Region I after Plumlee left for the site. Even if he had learned of the activity level reported to the regional office shortly after he left, he could not have properly concluded that the reported value was indicative of core damage involving a zirconium-water reaction.

Plumlee concluded that Met Ed had been monitoring the containment atmosphere for hydrogen before the pressure spike based on his conversation with Seelinger, which was followed very shortly by a discussion of the hydrogen analyses with Gallina. Originally, he believed that this conversation took place on Wednesday, March 28, 1979. On a subsequent day, a followup discussion with Gallina caused him (Plumlee) to think the conversation may have occurred on Thursday, March 29, 1979. Plumlee was certain that his conversation with Gallina immediately followed the discussion with Seelinger and that three sample analysis results were mentioned by Seelinger. Plumlee was also certain that, when he told Gallina of his conversation with Seelinger, Gallina told him that there was already general speculation that hydrogen burn had occurred. The investigators' review of this matter showed that the specific concentrations of hydrogen in the containment were not obtained until Saturday, March 31, 1979, at about 6:00 a.m. Gallina and Plumlee were not on the site simultaneously on Thursday, March 29, 1979, but they were there simultaneously on the afternoon of March 30 and 31, 1979 between 2:00 p.m. and 5:00 or 6:00 p.m. The records show that these containment air samples were analyzed at about 6:00 a.m., 2:00 p.m., 9:00 p.m., and 10:00 p.m. on March 31, 1979. Plumlee distinctly remembered three sample analyses being mentioned by Seelinger, and this information was not available until at least 9:00 p.m. on Friday March 31, 1979 after Plumlee had left the site. The investigators conclude that the discussion by Plumlee with Seelinger and Gallina of these data occurred on Saturday, March 31, 1979.

The investigators' pursuit of Plumlee's feeling that NRC management was less than forthcoming with the inspectors who were being sent to the site was hampered by lack of specificity in the basis for Plumlee's feeling. It is concluded that Smith could not have known specific hydrogen concentrations in the containment, and that he could therefore not have been holding back this information. Likewise, even though Smith and others must have had some conclusions of the severity of the accident, these conclusions would have been based in large measure on speculation. There is not a factual basis to conclude that failure to discuss speculation of specific severity was motivated by fear that the inspectors would be reluctant to go to the site. Conversely, the cause for incomplete briefing seems to have resulted from lack of information and a desire to get inspectors on site as promptly as possible.

Plumlee's feelings about Met Ed's failure to inform those who were on site were also based on nonspecific feelings and inferences that are hard to address directly. These investigators differ with Plumlee, as discussed elsewhere in this report, that Met Ed management had a clear understanding of how bad the situation really was. However, the investigators conclude that Met Ed was not fully forthcoming on March 28, 1979 in that the State was not appraised of either the uncertainty concerning the adequacy of core cooling or the potential for degradation of plant conditions.

During the course of the investigators' review of Plumlee's concerns, they learned that inspector Neely had a notation on a sheet of paper referring to hydrogen and a concentration of 4%. There was on this same sheet a reference to the date of March 29, 1979 noting when a filter was changed. On the basis of other events mentioned on the same page, it was concluded that the notes were taken on Sunday, April 1, 1979 and the reference to March 29, 1979 concerned something that had happened earlier rather than it being a contemporaneous note.

3. Goldsboro Radiation Dose Rate Projection

Upon arriving at the plant at 6:55 a.m. in time to hear the announcement of a Site Emergency, Howard Crawford, a nuclear engineer, proceeded to the Unit 2 control room. There, he gathered materials for predicting offsite exposure rates on the basis of the reactor building dome monitor reading, a task he had performed during drills for two years. Crawford recalls that his first calculation, which was completed soon after 7:00 a.m., showed an exposure rate of 40 R/hr in Goldsboro. Neither the time of day nor the result of this calculation has been substantiated by records or the recollection of others. However, a similar documented calculation (10 R/hr at the low population zone (LPZ) boundary) was performed before about 7:50 a.m. This calculation (10 R/hr at the LPZ) appears to have been performed by Crawford after 7:13 a.m., during the beginning of the massive release of radioactive material to the reactor building atmosphere. Both the time and magnitude of Crawford's dome monitor (HP-R-214) reading (300 R/hr) are uncertain. Accurate or not, the 300 R/hr reading formed the basis for the LPZ calculation. The time of 7:44 a.m. shown on the calculation sheet probably indicates either when the monitor was read or when the calculation was performed. Therefore, Crawford's calculation of 10 R/hr at the LPZ seems to have occurred between 7:13 a.m. and 7:44 a.m.

This prediction was reported to the Supervisor of Radiation Protection and Chemistry, Richard Dubiel. Although the projected dose rate of 10 R/hr was doubted because of conservative assumptions in the calculation, TMI management appears to have realized the need for a quick measurement in Goldsboro to confirm or deny Crawford's prediction. The containment dome monitor readings were questioned, but as a precaution the Station Manager, Gary Miller, requested that a State Police helicopter transport a survey team to Goldsboro for radiation monitoring. The helicopter did not arrive until 8:35 a.m., by which time Charlie Team had reported in from Goldsboro and Bravo Team had left by truck for Goldsboro. The helicopter was not used to transport a survey team to Goldsboro.

There was a common concern for getting onsite and offsite radiation measurements to supplement the Crawford prediction. Upon declaration of a Site Emergency at 6:55 a.m., efforts to organize and dispatch onsite and offsite monitoring teams began. An onsite team (Alpha) was instructed at about 7:30 a.m. to measure the radiation level west of the Unit 2 reactor building. During that survey, the wind was westward and very light with minute-to-minute variations of about 10 to 30 degrees. At 7:46 a.m., Alpha Team reported less than 1 mR/hr at Station GE-8 west of the Unit 2 reactor building. This measurement became the basis for discounting Crawford's prediction(s) of high exposure rates off site. At about 8:00 a.m. and 8:30 a.m., respectively, Charlie and Bravo Teams were dispatched by vehicle to Goldsboro. At about 8:30 a.m., Charlie Team reported less than 1 mR/hr in Goldsboro; Bravo Team reported similar results at about 9:40 a.m.

The calculation that resulted in the 10 R/hr projection in Goldsboro could also be used to indicate a prediction of 220 times the reportable level of xenon-133 at the LPZ established in 10 CFR 20.403(a). The reportable level of xenon-133 is $1.5 \times 10^{-3} \mu\text{Ci/ml}$ ($5000 \times 3 \times 10^{-10} \mu\text{Ci/ml}$). The xenon-133 level calculated was 0.33 $\mu\text{Ci/ml}$ at the LPZ.

The licensee reported the 10 R/hr projected dose rate at Goldsboro to the BRP. The BRP notified the Pennsylvania Emergency Management Agency (PEMA) of this projection at 7:45 a.m. and suggested that it was advisable to make preparations for possible evacuations. However, Met Ed did not report the 10 R/hr projection to the NRC on the day of the accident. The licensee reported the accident to the NRC Region I office at 7:50 a.m. on March 28, 1979. The survey that was used to discount the 10 R/hr calculation was made at 7:46 a.m. Although this survey was not technically adequate to make a valid new calculation, it clearly demonstrated that the 10 R/hr calculation was predicting an excessively high radiation rate. It did not preclude the possibility that a lower but still significant offsite (LPZ) radiation release could occur.

Knowledge of 10 R/hr Dose Projection

Gary Miller--Miller was aware of the 10 R/hr dose rate projection for Goldsboro on the morning of March 28, 1979, prior to 7:50 a.m. Based on this prediction, action was initiated to get onsite readings that would be in the same direction of, if not actually in, the plume; in addition, he requested that a helicopter transport a monitoring team to Goldsboro. He was aware that onsite readings were less than 1 mR/hr.

Richard Dubiel--Dubiel was aware of the offsite dose projections because he reviewed the calculation results. However, he believed that the results were probably not accurate because the dome monitor had not responded properly and because the calculation was based on an assumed containment pressure of 55 psig. Containment pressure at that time was known to be less than 4 psig. He discussed the dose projection of 10 R/hr and the calculation assumptions with State officials. He believed that offsite readings were needed to back up and recalculate the dose projection; he did not believe that an immediate offsite hazard existed (IE, 4/24/79, pp. 7-8).

Howard Crawford--Crawford made the calculations associated with offsite dose projections on the morning of March 28, 1979. He was involved in discussions that questioned the validity of the dose projection (IE, 6/6/79, p. 18).

IV. Onsite Information Flow

The flow of information within the Unit 2 control room on March 28, 1979 has been examined in previously published reports; i.e., the "Rogovin" (SIG) and "Hart" (Senate) reports. The scope of the present investigation in this area was limited to trying to understand the flow of information with regard to certain key indicators or events that occurred on March 28, 1979. These key indicators are discussed in Section III of this report. An attempt was made to establish the recognition of key indicators and then to understand the subsequent flow of related information within the control room organization. The purpose of this attempt was to evaluate this information and identify the resulting conclusions and recommendations or actions taken to mitigate the accident.

The flow of information was directly influenced by the organizational structure that existed at various times throughout the day. Key staff members, who were important to understanding the information flow, arrived at (or left) the Unit 2 control room at various times during the accident; e.g., Kunder (Unit 2 Superintendent Technical Support) arrived at approximately 4:50 a.m.; Logan (Unit 2 Superintendent) arrived at approximately 5:45 a.m.; Mehler (oncoming Shift Supervisor) arrived at approximately 6 a.m.; Seelinger (Unit 1 Superintendent) arrived at approximately 6:50 a.m.; Ross (Unit 1 Operations Supervisor) arrived at approximately 7 a.m.; Rogers (B&W Site Operations Manager) arrived at approximately 7 a.m.; Miller (Station Manager) arrived at approximately 7:05 a.m.; Flint (B&W Startup Engineer) arrived at approximately 9 a.m.; and Chwastyk (Unit 2 Shift Supervisor) arrived around noon. Because there was not an effective system for accumulating and passing on information, many of the key staff members did not become aware of important information related to events that occurred prior to their arrival. The best example of this is the EMOV (refer to Section III.1.c.).

At 6:19 a.m., the EMOV block valve was closed. Reactor building pressure decreased rapidly and RCS pressure increased from 680 to 2120 psig during the next 41 minutes. The recovery of plant conditions with block valve closure was known to three shift supervisors (Zewe, Mehler and Bryan), a shift foreman (Scheimann), and two control room operators. However, the

investigators were unable to establish that Miller, Logan, Seelinger, or Rogers (the four principal members of the "think tank" or "command team") connected the closure of the EMOV block valve with the subsequent RCS pressure increase and reactor containment pressure decrease. Subsequent actions taken that morning are indicative of a lack of understanding that a significant inventory loss had occurred through the stuck-open EMOV. It was concluded that Miller's order at around 8:00 a.m. to keep the HPI on unless he personally approved a change was motivated by the need for decay heat removal rather than making up for primary coolant inventory losses. If the order was based on a concern for primary coolant inventory, then the investigators conclude that Miller would have given more specific instructions on maximizing net input of water into the system.

A second example of inadequate information flow was that associated with the apparent recriticality (refer to Section III.1.e.). Because of the concern of Kunder, Ross, and Zewe over what appeared to be an uncontrolled approach to criticality (they concluded that a moderator dilution was in progress), the primary system was emergency borated from 6:10 a.m. until 7:25 a.m. The count rate behavior stabilized after 7:45 a.m. and attention was directed to other problems. Three engineers (Wilkerson, Benson, and Crawford), who were attempting to resolve the unexplained behavior, discussed the indications with Flint, B&W startup engineer, after his arrival in the control room around 9:00 a.m. Flint postulated that these indications, along with others he checked shortly after his arrival, were results of voids forming in the core. Flint believed the core may have been uncovered. Both Kunder and Zewe, as well as other control room operators, were aware of Flint's explanation. Flint has testified that he also discussed these conclusions with Rogers. In spite of the number of people who were aware of Flint's explanation (Crawford, Wilkerson, Benson, and Rogers), the investigators conclude that Miller, Logan, Seelinger, and Ross did not become aware of Flint's explanation of core uncovering on March 28, 1979.

In each of the preceding two examples, at least one think tank member was aware of information that was not discussed in the think tank. An additional example is that Seelinger, Unit 1 Superintendent, testified that on the morning of March 28, 1979 he believed (based solely on radiation levels) that the core was uncovered. Seelinger further testified that he discussed this important belief with no one else. The investigators conclude that the think tank did not exist as a group that held periodic formal meetings. This is supported not only by the testimony of Miller but also by the record, or lack thereof, of discussions/evaluations, conclusions, or resulting actions relating to significant knowledge of key indicators. The investigators' perception of how the think tank actually functioned is this: Miller would converse with different staff members at different times depending on the subject, but usually with only one or two individuals at a time. Further support for this perception is provided by the testimony of the think tank members themselves; e.g., Seelinger has testified that his primary involvement was overseeing the implementation of the emergency plan and Logan's role was ensuring that individual steps were performed (as in a quality control check). For almost every key

indicator, the record contains recognition by at least one key staff member. However, the same record demonstrates a lack of discussion/evaluation of these indicators within the think tank itself. Finally, there is no record of actions taken that would indicate an understanding of the implications of these indicators.

A final example of inadequate information flow is that of the pressure spike on the afternoon of March 28, 1979 (refer to Section III.2). Two shift supervisors (Chwastyk and Mehler) believed the pressure spike to be real. Numerous others in the control room (e.g., Ross and Zewe) were aware of one or more of the indications. The investigators conclude that this knowledge was not passed on to other members of the organization who would have been responsible for evaluating this information on March 28, 1979. It is therefore concluded that on March 28, 1979 Miller, Logan, Kunder, Seelinger, Ross, Rogers and Zewe did not have knowledge that the pressure spike was real on March 28, 1979.

V. NRC Information Flow

At 7:10 a.m. on March 28, 1979, a TMI-2 engineer left a message with the NRC Region I office that a Site Emergency had been declared. The answering service was unable to contact the Duty Officer. At 7:37 a.m. a second message was left and at 7:40 a.m. a final message was left. A General Emergency had been declared at 7:20 a.m. at TMI-2, there was a primary to secondary leak in steam generator B, and there had been an offsite release. At 7:45 a.m., the Region I Reactor Operations and Nuclear Support Branch Chief received the messages and returned the calls to the site.

The following gives a limited reconstruction of the information flow to the NRC during certain periods on March 28, 1979. This reconstruction is based on the (1) IRACT tapes; (2) transcriptions of the Region I tapes; (3) Region I incident center message forms; (4) interviews with NRC and Met Ed employees; and (5) reports by the Senate, Special Inquiry Group, and IE investigation group. Only information important to characterize the severity of the accident has been identified. It is important to note that this is only part of the information that flowed to NRC on March 28, 1979.

In the first 10 minutes following the notification of the General Emergency (prior to 7:55 a.m.), the following information was passed on to Region I:

- Reactor trip and safety features actuation had occurred
- Fuel had failed
- Bubble was located in reactor vessel
- Measurements of 1500 psi and 571°F recorded
- All containment radiation monitors were in high alarm
- Measurement of 1 to 2 psi in containment recorded
- EMOV had lifted and blown the RCDT rupture disc
- Site and General Emergencies declared

Based on these early communications, Region I declared a level 1 severity incident and assembled a 5-member team to send to the site. George

Smith, the Region I Fuel Facilities and Materials Safety Branch Chief, when interviewed by the investigators, said that it was his impression of the first calls that it was an extremely serious accident and that it could get significantly worse. He further stated that, based on the information Region I was receiving, he felt that the potential for further deterioration existed throughout the afternoon.

The Regional Director notified NRC headquarters and at 8:05 a.m. the headquarters Incident Response Center was manned. At 8:23 a.m., headquarters returned the call to the Region I Incident Response Center and, from this time on, most of the information transferred to headquarters from Region I was taped. The first call (8:23 a.m.) was a discussion of the initial information received in the regional office. At 8:34 a.m., the first containment dome monitor reading of 200 R/hr was reported to headquarters. The reported temperature of 571°F was an average of the hot and cold leg temperatures that were already out of the indicated range. [Regional personnel were not aware that this was an erroneous temperature when they received this information from the site and passed it on to headquarters.]

Shortly after 8:30 a.m., based on the initial information, John Davis, the Acting Director, Office of Inspection and Enforcement, informed Lee Gossick, the NRC Executive Director for Operations, and Edson Case, the Deputy Director, Office of Nuclear Reactor Regulation, of the accident. He stated, "It looks like there's some loss of coolant." At 8:59 a.m., Kunder informed Region I that he was concerned the core was not being cooled. Kunder thought they were not getting proper flow to the core. Kunder thought the loops were vapor locked.

At about this time, headquarters asked how the core was being cooled. Region I reports the following:

- Core was not being cooled
- RCPs were off
- Primary system was vapor bound
- There was no indication of primary temperature (no flow)
- Containment pressure had been to at least 4 psi

Between 8:30 a.m. and 9:15 a.m., NRC headquarters perception of the accident was that an earlier inventory deficiency probably resulted in partial core uncover, and had caused damage to the fuel. However, in this time frame, the core was thought to be covered even though an inventory problem still existed, as evidenced by the voids in the primary system.

By 9:15 a.m., the NRC had notified the U.S. Senate and House of Representatives as well as the White House of the problems at TMI.

At 9:21 a.m., Region I reported that the core was being cooled by natural circulation only minutes after Region I had reported that the core was not being cooled. At 10:04 a.m., Region I told headquarters that there was no natural circulation. Headquarters was now thoroughly confused and could not establish either how the reactor was being cooled or where the water was going. Finally, at 10:06 a.m., headquarters was told that they

[site] were pumping in 500 gpm and using the EMOV to control pressure. This was also the only means of cooling.

At about 9:25 a.m., Region I was preparing a press release and a preliminary notification (PN). They requested to speak to Kunder to establish the information and times accurately. In the following exchange, Kunder was attempting to explain the steam conditions in the core and loops, and why it appeared that the HPI system was not adequately cooling the core. Region I, however, moved on to get additional information for the PN. Kunder then attempted to explain the anomalous plant conditions (level, pressure, and temperatures) and why they were not understood. Region I again interrupted Kunder and asked him to get Dubiel so that they could get the health physics (HP) information.

Region I: "This is Don Haverkamp. I would like to go through the scenario with George Kunder--is he available. Or with someone familiar with it because I am going to try and get some times...."

Kunder: "Once the operators recovered from that, and pressurizer level went up and the thing I have not gotten from the operators yet--still debriefing on--because they are all pretty much tied up with the plant activities--but it looks like the pressurizer level went up and went virtually solid and that apparently through the letdown activity and so forth--you lost your bubble--apparently pushed it right through the relief valves into the drain tank which subsequently ruptured the ruptured disc--when the level came down then you don't have that steam bubble--you put too much cold water into the pressurizer and now the heaters are on but you are not really drawing a bubble--the pressure came down at that point, all the way down to about 10 hundred pounds and that was over roughly a 15-minute span. I think it was during that condition that we possibly lost the--we got a bubble--steam bubbles or some such--through apparently the heating in the core up in the loops and the--it apparently had an effect of vapor-locking--you know--the coolant system such that we were not getting good flow--we did not have any RC pumps running for awhile--but once the pressure got down below their NPSH for the temperature we were at and then the flow dropped off. We secured the pumps--the indications were very confusing but now that we are looking at the thing now--it looks to me like we had that vapor locking effect being fed by the heat in the core--and we reinitiated HP injection, of course, to get the coolant flow in but it didn't appear to have the effect that we wanted--okay--and we did try to run another coolant pump to turn it on again but it didn't give you any flow--so it was still apparently vapor locked. The problem is trying to get the pressure down low enough so we are sure that the flow is going into the--is going down--in the reactor vessel annulus and up into the core. The vapor-lock apparently is preventing that from occurring--and that is apparently what led to failed fuel."

Region I: "Okay...Let me go on, George, with a couple of things--to get your confirmation...."

KUNDER: "That's right, the pressurizer level being pegged, then the pressure was drifting down, temperature staying about where it was, around [545°] or so, in that range--plus or minus 5 degrees. That's the

thing I think that baffled people the most, and it was--we did have RC flow at the time--I think it was close to full flow."

Region I: "Just a minute, George, we have a couple of questions I think you can answer for us...."

Region I: "The HP related questions, if Dick Dubiel is handy, you might have him answer them...."

At 9:39 a.m., Boyce Grier, Regional Director, and Karl Abraham, Region I Public Affairs Officer, discussed a draft press release with John Davis, Acting Director, Office of Inspection and Enforcement, and with Joe Fouchard, NRC Director of Public Affairs. The following statement was read: "They apparently have a vapor lock in the primary system so that they're not able to circulate coolant and get as cool as they would like to...."

Kunder's concerns were not passed on to headquarters. Headquarters was not aware of the concerns over steaming in the core and the inability to get adequate HPI flow into the core. The following exchange between headquarters and Region I took place at 10:21 a.m.

Headquarters: "We still don't know the status of the core."

Region I: "They are still injecting."

Headquarters: "Where is it going?"

Region I: "I don't know."

Accurate temperature information had still not flowed either to Region I or headquarters at that time. Region I requested the primary system temperature and pressure at about 9:55 a.m. Kunder reported a pressure of 2000 psi and temperature of 571°F ^{ave}. He cautioned the region that this was not a representative temperature. Kunder told Region I that Ross (Operations Supervisor) was sure the core was covered, but the hot leg temperatures were still high and that these were bothering them.

Shortly after 10:00 a.m., the 5-member team arrived on the site. They started reporting to Region I from the Unit 1 control room at 10:23 a.m. Bubba Marshall, a Met Ed Operations engineer, had just been evacuated to the Unit 1 control room from the Unit 2 control room. Marshall briefed Higgins (Region I reactor operations inspector) on the status of Unit 2 prior to his departure (Unit 2 conditions up to approximately 9:30 a.m.).

Higgins testified that, as a result of this briefing, it was his understanding that the EMOV had stuck open causing a loss-of-coolant accident. Marshall did not know how long the valve had been stuck open or how much inventory had been lost. Higgins testified that he was sure that he passed on this information to Region I prior to proceeding to the Unit 2 control room. This information, however, was not recorded on the Region I incident message forms with other information transmitted to the region by Higgins in his first update at 10:55 a.m. The following information was reported to headquarters as a result of these exchanges: 142,800

gallons were injected from the borated water storage tank (BWST), containment sump level was pegged high (6 ft max.), containment pressure was 2 psi and decreasing, pressurizer level was pegged high, they were trying to draw a bubble with heaters, they were using atmospheric dumps and steam generator A, cold leg temperature was 220°F, pressure was 1950 psi, and reactor coolant pumps were off. Region I inspectors Higgins and Neely proceeded to the Unit 2 control room. They arrived in the Unit 2 control room around 11:15 a.m. From that time throughout the afternoon, Higgins and/or Neely participated in most of the caucuses in the shift supervisor's office.

At 11:41 a.m., Region I reported that the hot leg temperature was believed to be 620°F, cold leg temperature was 220°F, and pressurizer temperature was 359°F; they were maintaining 2000 psi by cycling the EMOV. In fact, Miller had just instructed that the EMOV block valve be opened to rapidly depressurize the plant and allow core flood tank injection. This decision was the result of discussions that were primarily concerned with the assessment of core coverage and core cooling. Although the NRC inspectors were present for these discussions, the considerations that led to this action were not passed on to either Region I or headquarters.

At 12:17 p.m., headquarters requested the core exit thermocouple readings. This request went unanswered. (The readings were requested again at 4:00 p.m. This investigation did not attempt to determine why this data was not provided). At 12:33 p.m., headquarters was informed by Region I that pressure was 1100 psi, the hot leg temperature was 565°F, and that there were bubbles some place in the system, maybe in the core. At 12:49 p.m., three-way communications were established between the Unit 1 control room, Region I, and headquarters.

Throughout the early afternoon, the information flow was mainly through the Unit 1 control room to Region I and headquarters. Some of the information received by both Region I and headquarters was erroneous. Region I had a direct line into Unit 2; however, it received only a minimum of operating information. An example of this is an accurate hot leg temperature that was not reported to headquarters until 2:20 p.m. Headquarters repeatedly requested operational information until headquarters finally requested a three-way telephone call into Unit 2 at 3:56 p.m. At 4:35 p.m., headquarters established three-way communications with both the Unit 2 control room and Region I, at which time operational information began to flow directly to headquarters.

The NRC inspectors located on the site and at Region I had a better understanding of the accident than headquarters. The role of each of the NRC components was vague. This resulted in a degree of confusion concerning the flow of information within the NRC. The investigators conclude that, on the day of the accident, an effective system did not exist within NRC to ensure that information was properly accumulated, evaluated, and disseminated.

VI. Operating Information Supplied to the State

Scope

This portion of the investigation addressed the reporting of certain key operating events by Metropolitan Edison to the Pennsylvania Bureau of

Radiological Protection (BRP) during the day of the accident. The key events were the same ones discussed in Section III of this report. The three principal members of the BRP were interviewed to evaluate the operating information that was provided to BRP in contrast to information that was supplied to NRC. The operating information supplied to the BRP was also reviewed with the objective of identifying improvements that could be made.

TMI Emergency Plan

Several of the TMI Emergency Plan implementing procedures make reference to an Emergency Status Board and contain as an enclosure a format for the information that is contained on the Board. A list of the questions contained in the enclosure under the title "Penna. Bureau of Rad. Health Questions" is excerpted below:

1. What type accident has occurred:
2. Has the reactor tripped?
3. Did the Emergency Safeguards Systems actuate? If so, which ones?

a. High Pressure Injection	Yes _____	No _____
b. Low Pressure Injection	Yes _____	No _____
c. Core Flood	Yes _____	No _____
d. Reactor Building Isolation	Yes _____	No _____
e. Reactor Building Cooling	Yes _____	No _____
4. What is the status of the Plant?

a. At Power
b. Hot Standby
c. Hot Shutdown
d. Cooling Down
e. Cold Shutdown
5. Is offsite power available?
6. Are diesels operable?"

The above operating information questions are followed by questions pertaining to radiology and other areas.

Emergency Plan Implementing Procedure 1670.2 (Rev. 1), "Site Emergency Plan Procedure," specifies that the plant nuclear engineer is to relay data of plant status as defined in the enclosure to the procedure, the Plant Status Board format. (Note that the procedure actually refers to Enclosure 2, whereas the Status Board format is labeled Figure 2, but the format sheet pagination is correct for an Enclosure 2). The procedure does not specify to whom the nuclear engineer is to relay the status information. However, the format identifies the particular questions as "Penna. Bureau of Rad. Health Questions," leaving little doubt that the information is to be passed on to the BRP.

Emergency Plan Implementation Procedure 1670.3 (Rev. 1), "General Emergency Procedure," states in Note (1), page 4, that "It shall be the responsibility of all of the above to provide maximum assistance and information possible to the various offsite groups; i.e., AEC, State of Pa., Bureau of Radiological Health..." This note is the first of three that conclude the procedure section entitled "General Emergency Immediate Action." It immediately follows a statement that says the duties of listed personnel during a General Emergency are outlined in a specified procedure. The personnel listed are shift supervisor, control room operator, supervisor of operations, station engineer, supervisor of maintenance, nuclear engineer, radiation protection supervisor, chemical supervisor, radiation monitoring teams, emergency repair party, and security guards.

Operating Information Supplied

Based on the investigators' interviews and other interviews, the three principal BRP staff members (Gerusky, Dornsife and Riley) say that on March 28, 1979 the following operating information related to the key events previously identified was passed on or reported to the State:

- (1) Dornsife knew of the low boron sample analysis (IE, 10/1/80, pp. 2-3).
- (2) All of them knew that the reactor coolant pumps were not running (Dornsife, IE, 10/1/80, pp. 9-10; Gerusky, IE, 10/1/80, pp. 9-10; Riley, IE, 10/1/80, pp. 5-7).
- (3) Only Dornsife recalled knowledge that the EMOV had been open for a period of time that was longer than normal (IE, 10/1/80, pp. 11-14).
- (4) Both Dornsife and Gerusky knew that there was some voiding in the primary coolant system (Dornsife, IE, 10/1/80, pp. 13, 11, 28; Gerusky, IE, 10/1/80, pp. 5, 29, 41-43).
- (5) Gerusky and Riley knew of the early-morning calculated projected dose rate of 10 R/hr at Goldsboro and that this projection was believed to be high (Gerusky, IE, 10/1/80, p. 33; Riley, IE, 10/1/80, pp. 19).
- (6) Dornsife believed that, although the plant was not in the desired mode, the plant was stable and that the core was being cooled through a feed-and-bleed process using HPI for feed and bleed through the electromagnetic relief valve/block valve (IE, 10/1/80, pp. 10, 14-15).
- (7) The pertinent data from the Status Board "Penna. Bureau of Rad. Health Questions" was passed on during a telephone conversation between Miller and Dornsife at about 9 a.m. (Dornsife's "Recollections").
- (8) It could not be established that Gerusky, Dornsife, or Riley received specific knowledge on March 28, 1979 of hot leg or core exit thermocouple temperatures.

BRP Perception of Adequacy of Operating Information Supplied

In general, the BRP expressed satisfaction with the information supplied to them by Met Ed on the day of the accident. Dornsife and Gerusky described previous drills as not having detailed operational information relayed and, in cases where information was relayed, the State relied on Met Ed to assess it. Gerusky said that they were not expecting much more information from the site than that received. He and Dornsife said that personnel at BRP were not thinking about the hardware as much as their major responsibility, offsite consequences. The key BRP personnel believed that the questions they asked of Met Ed were adequately answered. Both Gerusky and Riley said that the BRP personnel did not pursue sufficient additional questions with Met Ed. (Note that some specific questions, which are keyed to an identification of the specific accident under way, are contained in the State Annex to the TMI Emergency Plan. Although the Annex is not specific, the implication is that the State will initiate the questions.)

Notwithstanding BRP's apparent satisfaction with the communication of operational information described above, when the investigators asked BRP staff if a number of specific operational data or parameters should have been passed on by Met Ed on the day of the accident, each of the key BRP personnel were of the opinion (September 1980) that many of these parameters should have been passed on.

The loss of confidence in Met Ed, which Pennsylvania officials developed as a result of the mid-afternoon briefing of the Lt. Governor, has been covered by other investigators and was not pursued in this investigation. The effect of the meeting on Gerusky was opposite to that which he had as a result of direct telephone contacts. During the interview with Gerusky, he attributed his loss of confidence to Met Ed's failure during the briefing to admit offsite releases of which the BRP was aware. This was reinforced by Gerusky's perception of an attitude conveying that the accident was over and all that remained was cleanup.

NRC Assessment of Operating Information Supplied by Met Ed to the State

The BRP staff with whom the IE investigators talked seemed to have concluded in hindsight that there was a need for the specific operational data that was not received. Although the BRP Emergency Plan Annex indicates that they have an interest in more specific operating data, BRP staff believed that they should have pursued these data through further questioning. Operating information was provided by Miller in the telephone conversation (about 9:00 A.M.) he had with Dornsife in preparation for Dornsife's briefing of the Lt. Governor. There is a correlation between the operating information supplied to Dornsife and that supplied to Floyd. Although the correlation is not exact, the operating information supplied to Dornsife is similar to that supplied to Floyd in his conversation with Bryan in the Unit 1 control room at about 9:00 a.m. (Floyd was the Unit 2 Operations Supervisor who was in Lynchburg, Virginia, on the day of the accident.) The similarity in the information supplied is substantiated by comparing Dornsife's notes and his written recollections with what Floyd said he received, which was verified by the March 28, 1979 B&W log (Wandling notes). (Floyd was told among other things that there

was a natural circulation cooldown, the RCDT rupture disc had blown, the EMOV block valve had been closed, there was high radiation in the reactor building, and the reactor coolant pumps were not running.) Although the information supplied to both Dornsife and Floyd was not indicative of the concern the investigators now believe should have been conveyed, it is believed to be representative of the assessment of the conditions prevailing in the Unit 2 control room at that time.

Shortly after Miller's telephone conversation with Dornsife, Miller had a telephone conversation with several people in Reading, Pennsylvania, in which he talked about the Dornsife conversation. A tape recording of this conversation was made at the Reading office. This recording has become known as the "Troffer tape" because the principal person talking from Reading was George Troffer, a QA Manager. If the Troffer tape transcript is read without relating it with what the investigators believe to be Miller's lack of understanding and, without relating it to what Floyd has been told, it can be inferred that Miller is describing a better situation than he believed existed. Contrary to this inference, the investigators conclude that Miller was describing how the accident was assessed at that time in the morning. A complication to this conclusion is the information that Kunder was providing to the Region about one-half hour later. The investigators conclude that, although Kunder had a more accurate perception of the accident, Miller and others did not share Kunder's concerns at that time.

Near the end of the Troffer transcript, there is a specific passage that could be interpreted to mean that Miller believed the situation to be more severe than he had told Dornsife. It says, "We've been assessing* the plant, we don't know where the plant is going. See, the situation we're in is a delicate one because we actually have plant integrity. If we had a leak we'd be all right--as far as we'd have a lot more economic consequences. We've been trying to figure out how to cool down in the most expeditious fashion without releasing and without damage too much." The investigators conclude that this passage means that the situation was not understood at that time, but it does not mean that Miller believed that the situation was continuing to deteriorate. The phrase, "If we had a leak we'd be all right," seems to reinforce the conclusion of a lack of understanding because procedures for handling a leak existed. However, the conditions being experienced were not anticipated and were not covered by procedures. Conversely, the phrase "we'd have a lot more economic consequences" if there was a leak seems to indicate that further deterioration was not expected. Another complication comes from Miller's statement to IE investigators on April 11, 1979 when he said, "I didn't feel I got...could get any help from anybody because I felt I didn't think anybody believed where I was...." Miller stated in an interview with the investigators that he did not intend in this statement to convey hesitancy to pass on information. The investigators conclude that Miller was not withholding information from the State (BRP) in his telephone conversations with them. Although it is not concluded that Miller believed

*The transcript says "testing" but the tape itself says "assessing."

that conditions were going to deteriorate, he could not preclude this possibility.

The afternoon briefing of the Lt. Governor left a number of the State people with a belief that Met Ed (Herbein was the principal spokesman) was downplaying the accident, and that "everybody was making a big deal out of nothing" (Gerusky, IE, 10/1/80, p. 23). The investigators' review of the Lt. Governor's briefing from the perspective of the State people was limited to their interview with Gerusky. Based on the information received, the investigators accepted the fact that some of the State people believed they had been misled and attempted to assess whether this happened deliberately on the part of Met Ed. On the one hand, there could be motives for Met Ed to describe conditions as being better than they believed them to be. On the other hand, although Met Ed knew the plant was outside known operating parameters, they also believed that conditions were improving. It was concluded that Miller and Herbein were encouraged by indications showing that the hot leg temperatures were decreasing and that the cold leg temperatures were increasing. The notes of IE Inspector Higgins show that those located on site believed that the situation was improving. Miller and Herbein would not have wanted to unduly alarm the State people. Not knowing exactly how much detail or background information the people present for this briefing wanted or needed, Miller and Herbein could have expected to be guided by questioning as to how much information was wanted. Nevertheless, based on a belief that information was omitted about their concerns earlier in the day and their lack of assurance that the situation would not deteriorate, the investigators conclude that the Met Ed representatives were not completely forthcoming during the briefing.

Miller was asked by Congressman Cheney during hearings by the House Subcommittee on Energy and the Environment (Transcript 5/11/79, pp. 203-204) about criteria for recommendations to the State for evacuation. In response, Miller referred to EPA Protective Action Guides (PAG) that recommend threshold radiation exposures for which protective action should be taken. He pointed out that the measured offsite dose rates on the day of the accident did not indicate exposures near the PAG values. Miller said that he had to use judgment about plant status to give the State input as to whether he thought "the consequences in the plant is going to get severely worse quickly."

The judgment that a plant may get "severely worse quickly" is purely subjective. Nevertheless, the effectiveness of offsite protective actions is enhanced by as much notice and preparation as possible. A lack of certainty about the assessment of plant conditions and the adequacy of core cooling should be communicated promptly and clearly to offsite agencies to enable contingency planning. As discussed in the following paragraph, this lack of certainty was not communicated by Met Ed to the State on the day of the accident.

For much of the day on March 28, 1979 prior to the Governor's briefing, TMI management personnel were primarily concerned with a continuing assessment of core cooling. They were unable to obtain a previously analyzed or known configuration of system components for which they could

be confident that the core was being adequately cooled (Ross, IE, 9/24/80, p. 34; Miller, IE, 9/5/80, pp. 31, 43). Because of the extensive voiding, both natural circulation and forced circulation were precluded. This left a feed-and-bleed method for which there were no direct indicators of the adequacy of cooling. Without a procedure to specify an adequate flow rate or a means for direct verification of the adequacy of cooling, those located on site were left with uncertainty (Miller, IE, 9/5/80, pp. 41, 43). This lack of certainty led to depressurization of the plant before the noon hour in an attempt to assure core coverage with the core flood tanks and to go into the decay heat removal mode, a known cooling configuration.

In this section, aspects of the lack of full communications with the State have been discussed. These aspects involved a failure of Met Ed to be fully forthcoming in that information was not volunteered concerning the potential for degradation of plant conditions or concerning the uncertainty of the method being used to cool the core. The investigators conclude that the responsible Met Ed personnel did not perceive the situation to be as bad as it really was. However, it is concluded that their concern was sufficient to have made the receipt of this information important to the State. Finally, the investigators conclude that failure to pass on the information was not willful withholding, but rather it resulted from a lack of perception of the severity of the accident coupled with a perception that, unless PAG guidelines were approached, it was not necessary to discuss plant operational uncertainties with the State. In the time frame of the accident, the investigators believe that it would not have been uncommon for other utilities to have been similarly influenced by offsite releases so far below PAG levels.

VII. Enforcement Considerations

The reportability of three specific items of information was a central issue that led to this investigation. Consideration of these three items plus other possible noncompliance with reporting requirements is discussed in this section of the report following a discussion of two other enforcement issues that are related to the investigation.

1. Potential Material False Statement

On May 9, 1979, Herman Dieckamp, President of General Public Utilities (GPU), forwarded to NRC Commissioner Victor Gilinsky a copy of a mailgram which he had sent to Congressman Udall. The mailgram contained the statement, "There is no evidence that anyone interpreted the 'Pressure Spike' and the spray initiation in terms of reactor core damage at the time of the spike nor that anyone withheld any information." In view of the testimony of Chwastyk and Mehler about their knowledge and conclusions on the pressure spike, the investigators reviewed the record to determine if a material false statement had been made in the mailgram.

The investigators have concluded that, for a statement to be considered a false statement under Section 186 of the Atomic Energy Act of 1954 as amended, the statement must be made in a license application or it must be a statement of fact required under Section 182 of the Act. The Dieckamp

mailgram was neither of the above. Therefore, it does not constitute a potential material false statement under the Act.

2. License Modification Related to Gary Miller

Gary Miller--In the course of assessing the flow of information on March 28, 1979, the investigators identified common or focal points for the flow of information. The Emergency Director, Gary Miller, was identified as a key focal point through which critical onsite information flowed. It is from the Emergency Director, as the manager of the think tank, that decisions flowed based on the assessment of information. The final phase of this investigation was a consideration of enforcement action to be taken with respect to Gary Miller. This involved an evaluation of Miller's performance on March 28, 1979.

This evaluation was complicated by the absence of specific criteria on which an objective assessment could be based. Another factor complicating the evaluation was the brevity of the record concerning Miller's individual actions. However, the investigators attempted to evaluate Miller's performance based on the record established during this and previous investigations. This led to two conclusions:

- Miller's decision to leave the site to brief the Lt. Governor (regardless of Met Ed management influences) was not in the best interest of plant safety.
- Miller could have more effectively utilized offsite technical resources known to be available on March 28, 1979 (i.e., GPU and B&W).

The investigators reviewed the need for enforcement action with respect to Gary Miller. These investigators reviewed the existing record, including the conclusions of this report. Based on this review, three investigators conclude that enforcement action directed to Miller is not warranted. One of these investigators based his conclusion on his review of the 10 R/hr projected dose rate as this was the sole area examined by this investigator.

The fourth investigator recommended that, although the record does not strongly support such a conclusion, Met Ed be required to show cause why Gary Miller should be allowed to continue to be involved in the licensee's nuclear activities in a supervisory capacity. This investigator's recommendation was based on Miller's performance on the day of the accident as summarized below:

- Miller's decision to leave the site to brief the Lt. Governor (regardless of Met Ed management influences) was not in the best interest of plant safety.
- Miller could have more effectively utilized offsite technical resources known to be available on March 28, 1979 (i.e., GPU and B&W).

- Miller failed to effectively utilize onsite resources in that he assumed the detailed decisionmaking role for a broad spectrum of activities. This diluted his own ability to overview these activities.
- The failure of knowledgeable plant personnel to put together symptoms, to review previous assessments in the light of later information, and to more thoroughly understand the accident is considered to be a supervisory or management deficiency in Miller's performance on the day of the accident. His role should have been to cause those under his direction to be more thorough and complete in their analyses. He should have questioned explanations that were given to him (for example, the explanation about the core exit thermocouples and the containment pressure spike indications).

3. Reporting

a. Regulatory Requirement to Report

The potentially applicable requirements to report information to the NRC on the day of the accident are contained in the following:

- (1) Code of Federal Regulations,
- (2) Facility Technical Specifications, and
- (3) Procedures implementing the Emergency Plan.

The specific requirements of each are discussed in the following paragraphs.

Paragraph 403(a) of 10 CFR 20 requires immediate notification by telephone and telegraph, mailgram, or facsimile to the Director of the appropriate NRC Regional Office of any incident involving byproduct, source, or special nuclear material that may have caused or threatens to cause a whole-body exposure of 25 rems or more, release of radioactive materials in concentrations exceeding 5000 times the specified limits, loss of one working week or more in facility operations, or damage to property in excess of \$200,000. Paragraph 403(b) of 10 CFR 20 requires notification within 24 hours of incidents of less severity.

Section 6.8 of the technical specifications states that written procedures shall be established, implemented, and maintained for stated activities, including emergency plan implementation. Emergency Plan Implementing Procedure 1670.3, page 4, Note (1), following a list of key people for General Emergency, says, "It shall be the responsibility of all the above to provide maximum assistance and information possible to the various offsite groups; i.e., AEC, State of Pa., Bureau of Radiological Health...."

Section 6.9 of the facility technical specifications requires reporting within 24 hours by telephone and confirmed by telegraph, mailgram, or facsimile to the Regional Director, or his designee, certain events, including "abnormal degradation discovered in fuel cladding, reactor

coolant pressure boundary or primary containment;...personnel error or procedural inadequacy which prevents or could prevent, by itself, the fulfillment of the functional requirements of systems required to cope with accidents analyzed in the SAR."

A broad concept of an "implicit reporting requirement" has been suggested. Although it is clear that both NRC and the State need pertinent information in order to discharge their responsibility to protect public health and safety, expanding this need to include an "implicit reporting requirement" implies that failure to report such information is a violation of a requirement, and, as such, can be the basis for specific enforcement action. Although NRC is justified in criticizing Met Ed for failure to provide pertinent information, enforcement action based directly on an implied requirement does not appear to be valid. This conclusion is supported by the Statement of Considerations associated with promulgation of 10 CFR 50.72. Since the TMI accident, NRC issued 10 CFR 50.72 requiring nuclear power plant licensees to report listed events as soon as possible and in all cases within one hour. As a part of the same action, 10 CFR 20.403 was modified to make incidents included therein also reportable pursuant to 10 CFR 50.72. The Statement of Considerations for these regulation modifications says, "most of these events are not required presently to be reported immediately to NRC." If the "implicit reporting requirement" concept is applied, such a statement could not have been used as one of the justifications for waiving the normal public comment period prior to making the rule change effective.

b. Knowledge of Reportable Events

The knowledge of key members of the TMI staff on March 28, 1979 about a number of operating parameters and data is contained in the knowledge of key indicators section (Section III) of this report. Even though the Emergency Director/Station Superintendent Gary Miller says he does not recall knowing of some of these key indicators, knowledge by any responsible licensee personnel on duty is all that is required to establish knowledge by the licensee.

c. Failure to Report

The facts concerning reporting or passing on of specific important individual events or pieces of data to the NRC by Met Ed on March 28, 1979 are contained elsewhere in this report. Although some key indicators were reported, a question exists on the timeliness of the reporting. For those cases where timeliness is a factor, this aspect is discussed later as a part of the consideration of whether or not to cite Met Ed for noncompliance.

d. What Constitutes Reporting

On the day of the accident, the licensee communicated various times by telephone directly with NRC Region I, with NRC Region I and headquarters on a conference telephone line, and with NRC inspectors located on site. In the circumstances of these various communications, the question is raised as to what constitutes reporting.

One of the items of potential noncompliance considered refers to 10 CFR 20.403. This regulation states that the "...licensee shall immediately notify by telephone and telegraph, mailgram, or facsimile, the Director of the appropriate Regional Office...." As a matter of informal practice in the past, NRC has accepted telephone notification of the regionally based principal inspector, or his supervisor, as meeting the requirement to notify the Regional Director. From the time Region I returned the initial Met Ed telephone notification on the day of the accident, either the principal inspector or his supervisor was a party to the conversation. Therefore, any report made over this telephone is considered to be adequate in this instance.

It is less clear whether information passed on to an onsite inspector is acceptable. On the one hand, the onsite inspector may be considered a responsible NRC representative. Otherwise he would not be sent to the site. On the other hand, many inspectors are specialists in one particular discipline and cannot be expected to understand the significance of each item of information they receive if it is outside their area of specialty. Licensee representatives cannot be expected to know the limits of each inspector's expertise. A further complication is the danger of miscommunications if simple mention of a subject by a licensee representative to an onsite inspector is taken to satisfy reporting requirements. This could put an unduly large burden on the inspector and could thwart the purpose of reporting. An acceptable resolution of this dilemma is that licensees should be expected to notify the regional office by telephone unless it is assured that the onsite inspector understands the significance of what he is told. Telephone notification to the regional office minimizes concern that information will not be understood because this communication automatically alerts the recipient that the licensee considers the information to be important.

The other area of potential noncompliance relates to failure to inform NRC and the State based on the emergency plan implementing procedure. The procedure contains no guidance on which to base a conclusion as to how the passing on of the information is to be accomplished. For the purposes of this report, the investigators will use the same criteria as previously described for 10 CFR 20.403.

e. Assessment of this Case

Appendix A is a citation containing two specific items of noncompliance that were considered by these investigators. The citation includes the three items that were put aside last year plus an additional item related to the EMOV. The other key indicators were dropped from consideration because they were reported in a timely manner or they were not events.

The requirements and facts in this situation can be argued to a conclusion that further enforcement is either justified or that it is not justified. In this section of the report, a rationale for both sides is presented.

Basis for Citations

In the assessment of potential citations, the use of Section 6.9 of the technical specifications for failure to report information on March 28,

1979 was found to be inappropriate. The requirement was not applicable to the projected dose rate calculation. In relation to core temperatures, it was potentially applicable to the fuel degradation reporting requirement; however, a belief that fuel damage had occurred was reported early in the morning. Lack of knowledge by those on site of the extent of core damage precluded this meeting the requirements for a citation for failure to report. It was not applicable to the pressure spike because, even though the containment was challenged, it was not degraded. It was potentially applicable to the EMOV both as a degradation of the primary coolant boundary and as a personnel error (failure to recognize the open EMOV). It was, however, reported to the onsite inspector within the time specified by the requirement. It was concluded, therefore, that a case could not be made for citation against Section 6.9 of the technical specifications.

The use of 10 CFR 20.403(a) as a basis for a citation must rest on there having been an incident in addition to the incident reported by Met Ed (once communications were established with NRC Region I early in the morning). The containment pressure spike is the only potential item of noncompliance for which a clear argument can be made that a separate incident occurred. This event represents a unique challenge to the containment that was known to have a large inventory of radioactive material, the release of which could have caused consequences of the magnitude of those contained in 10 CFR 20.403(a). Such an argument is not believed to be sustainable for the other items cited.

A calculation (the radiation prediction in Goldsboro) cannot be successfully argued to be an incident. The other items in the citation are believed to be sufficiently related to the information that was reported to preclude classifying them as individual incidents. Two members of the TMI crew on duty at the time the containment pressure spike occurred stated that they talked about the event with an NRC inspector who was also in the control room at the time. One of the Met Ed employees identified the inspector by name. Neither of the two NRC inspectors who were in the Unit 2 control room area at the time have any recollection that they had knowledge of the event on March 28, 1979. Conversely, considerable evidence points to a general knowledge in the control room and shift supervisor's office that something significant happened at that time. Alarms sounded, equipment changed operational state, and operators took actions in resetting and shutting down equipment. Notwithstanding their belief now that they were not aware of the pressure spike on the day of the accident, these investigators believe that it is likely that one or both of the inspectors were aware of some of the symptoms of this event. If this be the case, it is believed that either they did not understand the symptoms to be indicative of the problem or they accepted an incorrect explanation of the symptoms. One of the Met Ed crew who stated he talked about the spike with an NRC inspector said that the inspector did not appear to understand what he was told.

Knowledge and understanding of information by onsite NRC inspectors can be accepted as a substitute for a required immediate verbal report to the regional office. However, some knowledge without an understanding cannot be accepted as a substitute for a verbal report. Even though there is conflicting information on what the NRC inspectors on site were or were

not told about the pressure spike, the necessary elements to satisfy reporting requirements were not met.

The emergency plan implementing procedure was used as a basis for the other item of noncompliance. As was discussed earlier, because of the wording of the requirement, it was concluded that 10 CFR 20.403(a) was not applicable for these examples, but the broad language in the implementing procedure does not present such constraint. It can be argued that the information contained in the examples was not supplied in a timely manner, so this constitutes failure to comply with Technical Specification Section 6.8. In the context of the statement in the implementing procedure, to be timely the information is to be provided promptly or at the first available opportunity. In the examples contained in Enclosure 1, it can be argued that the information either was not provided or that it was not provided at the first available opportunity.

Discussion of Whether or Not to Cite

At this juncture, it can be asked, "Why should further citations be considered in response to the TMI accident?" There are two apparent principal reasons that can serve as motivations for citation: (1) a citation can deter a licensee from future failure to follow regulatory requirements, and (2) a citation can "send a message" to other licensees as well.

With regard to deterrence for this licensee in this case, no further civil penalty may be assessed because the legal limit has already been imposed. The licensee is already facing a hearing to justify restarting Unit 1 (much less Unit 2) so that license suspension is not a main deterrent. Licensee revocation would subject the licensee to a different sanction; however, it is not believed that the factual basis surrounding the events on the day of the accident would support license revocation. Use of a "failure to report" citation as a mechanism for deterrence for this licensee could then be viewed as unrealistic. The motive to "send a message" may be characterized as "tough but not fair." The changes already made in reporting requirements through the issuance of 10 CFR 50.72 and the revision of 10 CFR 20.403 have improved the specificity of NRC reporting requirements. This report recommends further modification to the regulations. This action is needed regardless of whether or not Met Ed is cited in this case. It is not clear that what is in effect a "pro forma" citation against Met Ed will provide any meaningful remedial action for other licensees. Ample opportunity for any needed remedial action against Met Ed is already open before either unit is allowed to start up.

The applicability of 10 CFR 20.403 may be challenged on the basis of the historical development of the regulation. The precedent of prior citations against 10 CFR 20.403 is that in the past it has only been used to cite power reactor licensees for overexposure of people to radiation. The existence in reactor technical specifications of explicit reporting requirements that are related to operational events adds weight to a conclusion that it is inappropriate to use 10 CFR 20.403 for operating events.

The failure to specifically report the calculation of a projected dose rate in Goldsboro and the related implications of the technically

inaccurate early discounting of the calculation may be questioned on the basis of information that was supplied. Met Ed did report to NRC that the dome monitor was reading 200 R/hr and that the containment pressure was 1 psig. Although this information alone does not enable a direct inference of potential offsite dose rates, it is a clear indication that significant releases could occur. It is true that, if the calculation had been accurate, minutes were important. Nevertheless, the Pennsylvania BRP was notified and it was the logical agency to have initiated action if the need to do so had been confirmed.

The citation against the Emergency Plan Implementing Procedure rests on a very general statement that can be characterized as more of a philosophy statement than a procedural step. This is exemplified by the fact that the statement admonishes all of the listed people to supply information. Taken literally, this would have each of these individuals personally calling the agencies to assure that they received the information. Furthermore, responsibility that is assigned to everyone may be responsibility that is assigned to no one. The lack of specific assignment of responsibility to one person with a systematic flow of information to that person was concluded elsewhere in this report to be the principal deterrent to full reporting. Citation against such a general statement as that referenced in the potential citation could have the effect of drawing attention to the wrong problem. In conclusion, it is recommended that citations not be made against Met Ed for failure to report.

APPENDIX A

NONCOMPLIANCE CITATION CONSIDERED BY THE INVESTIGATION TEAM

- A. 10 CFR 20.403(a) requires that each licensee immediately notify by telephone and telegraph, mailgram, or facsimile, the Director of the appropriate NRC Regional Office of any incident involving byproduct, source, or special nuclear material possessed by him and which may have caused or threatens to cause the release of radioactive material in concentrations that, if averaged over a period of 24 hours, would exceed 5,000 times the limits specified for such materials in Appendix B, Table II.

Contrary to the above, on the afternoon of March 28, 1979, at about 1:50 p.m., two on-duty shift supervisors of the licensee recognized that a pressure spike (approximately 30 psig) had occurred inside the containment building of Three Mile Island Unit 2. Because the containment building contained radioactive material which, if released and averaged over a period of 24 hours, would exceed 5,000 times the limits specified for such material in Appendix B, Table II, this incident threatened to cause a release of such material. The incident was not immediately reported to the NRC by telephone and telegraph, mailgram or facsimile.

- B. Section 6.8 of Three Mile Island Unit 2 Technical Specifications states that written procedures shall be established, implemented and maintained covering Emergency Plan Implementation. Radiation Emergency Procedure 1670.3, which implements the Three Mile Island Unit 2 Emergency Plan, states that, in a General Emergency, it shall be the responsibility of licensee personnel "...to provide maximum assistance and information possible..." to the NRC (among others).

Contrary to the above, following the declaration of a General Emergency at Unit 2 at 7:25 a.m., on March 28, 1979:

- (1) The licensee failed to provide maximum information possible to the NRC in that a projected dose rate of 10 R/hr in Goldsboro, Pa., calculated at approximately 7:44 a.m., was not reported to the NRC.
- (2) The licensee failed to provide maximum information possible to the NRC in that the core exit thermocouple readings, taken at approximately 9:00 a.m., were not reported to the NRC.
- (3) The licensee failed to provide maximum information possible to the NRC in that the conclusion by an on-duty shift supervisor at approximately 6:30 a.m. that the open EMOV was the cause of abnormal plant conditions was not reported to the NRC.

APPENDIX B
Report References

List of Attachments

<u>Attachment Page No.</u>	<u>Name</u>	<u>Source</u>	<u>Date</u>	<u>Page(s) Referenced</u>
1-1	Kunder	SIG	9/18/79	32-35, 42-45
2-1	Kunder	IE	9/4/80	3-4
3-1	Rogers	IE	9/2/80	3-5
4-1	Zewe	IE	9/4/80	3-5
5-1	Ross	SIG	9/18/79	11-12
6-1	Ross	IE	9/24/80	4-5
7-1	Logan	IE	10/16/80	5
8-1	Miller	IE	9/5/80	6-7
9-1	Miller	IE	11/10/80	140-146
10-1	Kunder	Senate	8/22/79	17-18
11-1	Kunder	IE	9/4/80	6-7
12-1	Rogers	IE	9/2/80	14-16
13-1	Logan	IE	5/9/79	6-7, 33
14-1	Zewe	IE	9/4/80	9
15-1	Ross	IE	9/24/80	11-12
16-1	Miller	IE	9/5/80	37, 48-50
17-1	Kunder	IE	9/4/80	8-9
18-1	Kunder	SIG	9/18/79	39-49
19-1	Logan	IE	10/16/80	11-16
20-1	Rogers	IE	9/2/80	7
21-1	Zewe	SIG	10/11/79	92
22-1	Zewe	Senate	11/15/79	35-38
23-1	Zewe	IE	9/4/80	11-12
24-1	Ross	IE	5/19/79	11-12
25-1	Ross	IE	9/24/80	17-20

List of Attachments

<u>Attachment Page No.</u>	<u>Name</u>	<u>Source</u>	<u>Date</u>	<u>Page(s) Referenced</u>
26-1	Miller	IE	11/10/80	61-78
27-1	Dornsife	IE	10/1/80	11
28-1	Higgins	IE	10/7/80	31
29-1	Kunder	SIG	9/18/79	53-55
30-1	Kunder	IE	9/4/80	11-17
31-1	Kunder	IE	7/11/79	12-14
32-1	Kunder	IE	9/4/80	28-29
33-1	Seelinger	IE	10/14/80	77-78
34-1	Rogers	IE	9/2/80	16-17
35-1	Rogers	IE	9/2/80	26-27
36-1	Rogers	IE	9/2/80	18
37-1	Logan	IE	10/16/80	18-22
38-1	Zewe	IE	9/4/80	15
39-1	Zewe	Senate	10/18/79	23
40-1	Zewe	IE	9/4/80	30
41-1	Ross	IE	9/24/80	26
42-1	Ross	IE	9/24/80	28
43-1	Ross	IE	9/24/80	41-45
44-1	Miller	IE	9/5/80	21-56
45-1	Kunder	IE	4/25/79	26-34
46-1	Kunder	IE	9/4/80	24-26
47-1	Logan	IE	5/9/79	8-9
48-1	Logan	IE	10/16/80	33-39
49 -1	Zewe	IE	9/4/80	29-30
50 -1	Ross	IE	9/24/80	37

List of Attachments

<u>Attachment Page No.</u>	<u>Name</u>	<u>Source</u>	<u>Date</u>	<u>Page(s) Referenced</u>
51-1	Miller	IE	5/7/79	76
52-1	Miller	IE	9/5/79	57-59
53-1	Rogers	IE	9/2/80	22-24
54-1	Flint	Kemeny	6/30/79	18-19
55-1	Flint	IE	4/23/79	4-5
56-1	Flint	IE	9/2/80	18-19
57-1	Chwastyk	IE	9/4/80	12-22
58-1	Fig GA-10	TMI-2 FSAR		
59-1	Chwastyk	IE	9/4/80	104
60-1	Chwastyk	SIG	10/30/79	18
61-1	Chwastyk	IE	9/4/80	104-109
62-1	Mehler	Senate	8/22/79	9
63-1	Mehler	Senate	8/22/79	10
64-1	Mehler	SIG	10/30/79	19-20
65-1	Mehler	SIG	10/30/79	19
66-1	Neely	IE	10/7/80	10
67-1	Neely	IE	10/7/80	10-13
68-1	Higgins	IE	10/7/80	22
69-1	Higgins	IE	10/7/80	23
70-1	Miller	Kemeny	5/31/79	57
71-1	Miller	IE	9/5/80	112
72-1	Miller	Senate	9/28/79	25
73-1	Ross	IE	5/19/79	3
74 -1	Ross	IE	9/24/80	47-56
75 -1	Zewe	IE	4/23/79	34-41

List of Attachments

<u>Attachment Page No.</u>	<u>Name</u>	<u>Source</u>	<u>Date</u>	<u>Page(s) Referenced</u>
76-1	Zewe	IE	9/4/80	44
77-1	Chwastyk	IE	5/21/79	8-18
78-1	Chwastyk	IE	9/4/80	24
79-1	Chwastyk	IE	5/21/79	9
80-1	Chwastyk	IE	5/21/79	12
81-1	Chwastyk	IE	5/21/79	18
82-1	Chwastyk	SIG	10/11/79	18
83-1	Chwastyk	SIG	10/30/79	17
84-1	Chwastyk	SIG	10/30/79	18, 19, 20
85-1	Chwastyk	IE	9/4/80	11
86-1	Chwastyk	IE	9/4/80	33-36
87-1	Mehler	IE	5/17/79	29-33
88-1	Mehler	SIG	10/11/79	14-15
89-1	Mehler	SIG	10/11/79	15, 16
90-1	Mell	Senate	8/22/79	14-17
91-1	Illjes	IE	5/23/79	5-10
92-1	OIA Interview	Plumlee	12/2/80	
93-1	OIA Interview	Plumlee	12/3/80	
94-1	OIA Interview	Seelinger	12/23/80	
95-1	Dubiel	IE	4/24/79	7-8
96-1	Crawford	IE	6/6/79	18
97-1	Draft PN	Region I	3/28/79	
98-1	TMI Radiation Emergency Procedure 1670.3			
99-1	Dornsife	IE	10/1/80	2-3
100-1	Dornsife	IE	10/1/80	9-10

List of Attachments

<u>Attachment Page No.</u>	<u>Name</u>	<u>Source</u>	<u>Date</u>	<u>Page(s) Referenced</u>
101-1	Gerusky	IE	10/1/80	9-10
102-1	Riley	IE	10/1/80	5-7
103-1	Dornsife	IE	10/1/80	11-14
104-1	Dornsife	IE	10/1/80	11, 13, 28
105-1	Gerusky	IE	10/1/80	5, 29, 41-43
106-1	Gerusky	IE	10/1/80	33
107-1	Riley	IE	10/1/80	19
108-1	Dornsife	IE	10/1/80	10, 14-15
109-1	Dornsife	"Recollections"		
110-1	Dornsife	Notes	3/28/79	
111-1	"Wandling Notes" B&W		3/28/79	Vol 1, 1-8
	General Communications Record TMI-2 Transient			
112-1	"Troffer" Transcript			
113-1	Gerusky	IE	10/1/80	23
114-1	Energy and the Environment Subcommittee Hearings			202, 203, 204, 205
115-1	Miller	IE	9/5/80	31, 41, 42, 43
116-1	Ross	IE	9/24/80	34
117-1	Dieckamp Mailgram			

1 conversation with Gary. That would have been some time
2 after 6:00 o'clock. I think in previous testimony the times
3 are a little bit more accurate.

4 Q You arranged the conference call?

5 A No, Gary Miller did.

6 Q You testified that you had no basis to disbelieve
7 what you were seeing in the control room?

8 A Right.

9 Q Did there come a time when you began to disbelieve?

10 A No. The whole time I questioned it and I don't
11 think that there was any one time when I disbelieved it.

12 BY MR. FRAMPTON:

13 Q Mr. Kunder, I believe you said at some point
14 shortly after you came in you asked the operator how long
15 high pressure injection had been on and they said, "Not
16 very long"?

17 A Right.

18 Q What did you understand that to mean? That the
19 actuation had been recent and not at the beginning of the
20 transient?

21 A No. I perceive that as meaning when the reactor
22 cooling system pressure decreased to the actuation point
23 the high pressure injection came on and that the reactor
24 cooling system level -- they had pressurized level
25 recovery and they secured it within a brief period of time.

1 It would not be consistent with a high level.

2 In other words, if you were to leave the high
3 pressure injection, in effect, for the full flow, that it
4 develops for a long enough time, I would expect to see the
5 pressurized level increase and in fact, the reactor cooling
6 system would go solid.

7 Q So they were telling you that the HPI had only
8 been on for a short period of time at the beginning of the
9 transient before it was throttled or turned off, is that
10 right?

11 A That is my perception.

12 Q Was high pressure injection secured when you came
13 in at about 5:15?

14 A I did not look. Again, it is more a matter of
15 nonfamiliarity with the controls. In Unit 1 I am used to
16 going in and I can look at everything and I know exactly
17 what the status is and I can get that quicker than by
18 asking people. Unit 2 was not merely as obvious to me.

19 Q Just to jump to two other points on the same issue,
20 when you then had a conference call beginning at about
21 6:00 or 6:15 a.m., was there any discussion during the
22 conference call, that you remember, about whether high
23 pressure injection was on?

24 A I really don't remember anymore. I don't think
25 I would have thought it was on based on that question I

1 asked the operators.

2 Q Was there any decision at that time that you
3 better turn it on, manually?

4 A No.

5 Q I think you testified before that at some point
6 after you began to get radiation alarms you and Mike Ross
7 made a decision that you should attempt to -- that you
8 should start high pressure injection?

9 A I remember becoming real concerned over another
10 issue but I think that occurred before we got the radiation
11 alarms.

12 Q What was that other issue? Was that hot leg
13 temperature?

14 A No. I was misled into believing that we may have
15 a deboration event occurring. The indications of the
16 boron concentration and the indication of the intermediate
17 range, how to core detectors, were beginning to combine
18 to suggest that we had a moderated delusion accident
19 occurring.

20 We had just initiated boration into the makeup
21 tank, the emergency boration system. Bill Zewe initiated
22 that when I received the phone call from Dick Dubiel saying
23 that the concentration of boron in the system is 400 pp,
24 and so as a precaution he initiated that right away.

25 I was extremely concerned that that was not going

1 to be enough. At that point in time I was worried that
2 inaction was leading to a greater problem than if we were
3 to take a safe action of initiating high pressure injection.
4 At least we could be getting water from the boron water
5 storage tank, which I was hoping it was borated the way it
6 is supposed to be and get that into the reactor cooling
7 system to turn this, in effect, around.

8 I think it was largely on that basis and whatever
9 else I may have been responsive to at that point, that I
10 yelled to get the high pressure injection back on.

11 BY MR. DIENELT:

12 Q Did you order a state police helicopter?

13 A Yes.

14 Q When did you do that?

15 A That was after we had made contact with virtually
16 all the agencies required to be contacted per the emergency
17 plan. It would have been roughly 8:00 o'clock or something
18 like that, quarter of 8:00. It wasn't too long after the
19 general emergency was declared.

20 Q Were you directed to order the helicopter?

21 A The direction to order the helicopter was made by
22 someone, either Gary or probably Dick Dubiel in the control
23 room.

24 A few minutes later we got a call back from the
25 state police asking what services we wanted from them. I

1 the pressurizer be full or to have overfilled the system
2 and yet to have the pressure continue to be low?

3 A Yes. I can't remember how I perceived it
4 precisely in my own mind at the time.

5 Q Did you perceive how that could happen? Is there
6 any explanation of why the pressure --

7 A At that time I couldn't put it all together. It
8 is perfectly obvious now but at that time, as I recall my
9 perceptions at that time, somehow we had overfilled the
10 system and we lost the steam bubble, the bubble that was
11 giving us the pressure.

12 It just did not occur to me and I did not go
13 through the thought process that would have allowed me to
14 conclude at that point in time that we had voiding in the
15 other portion of the system and that the core itself or
16 the fluid in the region of the core actually took over
17 pressure control of the reactor cooling system.

18 Q As you understood it from the period of 5:00 a.m.
19 to let's say 7:00 a.m. or 7:30 when Mr. Miller arrived and
20 the emergencies were declared, what was the strategy for
21 trying to bring the plant to a more stable or more under-
22 standable status? What was it primarily that you under-
23 stood that the operators and Mr. Logan and yourself were
24 trying to do with the plant during that time?

25 A It is a variety of things. Relative to the

1 reactor cooling system per se, the operators were letting
2 down some water. I understand from subsequent testimony,
3 I guess, that they did have some high pressure injection
4 water going into the reactor cooling system. We were trying
5 to let down in order to bring the pressurizer level back
6 into range.

7 Q So you were basically trying to reduce inventory
8 in the system in order to get the pressurizer bubble back?

9 A In effect that was what was happening.

10 There were a lot of other activities that were
11 ongoing at the time. The fact that the containment pressure
12 was up around 2 PSI was at one point thought to have been a steam
13 leak from the 1 steam generator and that was believed to
14 be so because of the disparity in the pressure which is
15 classically something that would indicate a potential steam
16 leak out of the lower pressure steam generator.

17 The steam generator, I believe, at one point was
18 secured, isolated, on both the feed water and the steam
19 side in order to bottle up that generator and ultimately
20 stop the suspected steam leak into the building.

21 Later on when the reactor building pressure did
22 not decrease as expected, the operators felt that that
23 wasn't the problem and they reestablished normal feed water
24 and steam removal from the steam generator.

25 Q Didn't emergency boration using the high pressure

1 injection system go counter to the strategy of trying to
2 get the bubble back? That was putting more water into the
3 system, was it not?

4 A Yes. At the time I was not aware that they had
5 a high pressure injection continuing in the reactor
6 cooling system.

7 At that time, I am pretty certain I perceived
8 that they were just letting down.

9 Q But you said you and Mike Ross wanted to get some
10 high pressure injection --

11 A That was later.

12 Again, you have to realize that we were traveling
13 along at like 90 miles an hour and things were whizzing
14 by and you are making decisions. I don't think I could
15 ever reconstruct the feedback that I was getting and using
16 to make decisions upon at this point in time.

17 By the time that we made that decision to initiate
18 high pressure injection a lot of things had transpired by
19 the time I got in the control room. There were phone calls,
20 a lot of developments, minor things that didn't make sense
21 or that caused me to believe that something other than what
22 was really occurring was transpiring.

23 By the time we made that decision to initiate high
24 pressure injection it was apparent that we were dealing with
25 something an awful lot bigger or more consequential than I

1 had recognized when I first arrived at the plant. It had
2 developed a lot further by that time.

3 Q You still believe that the cooling system was
4 solid, the primary system was solid, when you were ready
5 for emergency boration, I take it?

6 A I guess that would be true to say that.

7 Q But you made a choice that the most important
8 thing was to prevent renew criticality at that point?

9 A That I think was the overriding idea that I had.

10 Q Let me ask you a question about the conference
11 call with Gary Miller and Mr. Herbein and yourself.

12 During that call there was some conversation
13 about whether the EMOV was closed or the block valve was
14 closed. Do you recall the substance of that conversation
15 about that subject?

16 A The thing that I recall and is pretty much what
17 I said in the past, in past interviews, and that is, I think
18 I was asked whether or not the electromatic release valve
19 was opened. I think that was true because I seem to recall
20 having gone out to the control room for a moment and asking
21 someone out there if the valve was opened or if it was
22 closed.

23 The response that I think I recall getting -- the
24 response that I would have gotten is that it was closed.

25 I just remember going out and asking that question.

1 Whereupon,

2 GEORGE A. KUNDER

3 was called for interview and, having first been duly sworn, was
4 examined and testified as follows:

5 EXAMINATION:

6 BY MR. HARPSTER:

7 Q George, a review of your testimony before the Special
8 Inquiry Group has indicated that shortly after your arrival in
9 the control room on the morning of March 28, 1979, it was your
10 perception that following the reactor and turbine trip high
11 pressure injection had been secured, and let down had been
12 increased in an attempt to restore the pressurizer level to
13 normal.

14 Was the status of these systems discussed in the
15 telephone conference call with Messrs. Miller, Rogers and Herbein
16 at approximately 6:00 a.m.

17 A I don't recall specifically what parameters I discussed
18 with them, other than I am pretty sure I discussed the fact that
19 the pressurizer level indication was high, that stands out in
20 my mind, and that the pressure was low. Beyond that, I cannot
21 recollect for sure any more.

22 Q Did you at any time on March 28, 1979, discuss the
23 status of these system as they existed prior to approximately
24 8:30 a.m., that is the high pressure injection secured, and the
25 let down increased?

1 A Would you repeat that again?

2 Q Did you at any time on the day of the accident discuss
3 the status of the high pressure injection system, and the let
4 down system as they existed prior to 8:30 a.m., that morning with
5 Messrs Miller, Rogers, Zewe, Herbein, Mehler, Chwastyk?

6 A It is possible, but I cannot remember.

7 Q To the best of your knowledge, was this information
8 pass on to the NRC on March 28, 1979?

9 A Do you mean specifically that the high pressure
10 injection was secure, and that the let down was increased?

11 Q Yes.

12 A I don't recall, nor do I recall in the communication
13 I had with the NRC from reviewing the taped conversations with
14 Region I, that that was in there either. That communication is
15 certain one where the record could be reviewed to see if I said
16 anything relative to those two parameters.

17 Q In your opinion, should this information have been
18 passed to the NRC on that morning, that is, the high pressure
19 injection was secured, and the let down flow increased?

20 A Do you mean, what was my opinion at that time?

21 Q What is your opinion today.

22 A Obviously, all that information should have been given
23 to the NRC

24 BY MR. MOSELEY:

25 Q What would you have said then?

P R O C E E D I N G S

MR. GAMBLE: Could we go on the record.

This interview is being conducted as a portion of the NRC's investigation into the exchange of information between the Metropolitan Edison Company and the NRC on March 28th, 1979.

Mr. Roger, we have counsel for B&W present here. Do you have any objections to their being present during the interview of you?

MR. ROGERS: No.

Whereupon,

LELAND C. ROGERS

having been first duly sworn by Mr. Gamble, was examined and testified as follows:

EXAMINATION

BY MR. CRAIG:

Q Lee, on the morning of 3/28/79 were you aware that high pressure injection flow had been throttled and the let-down flow had been increased to a high value, higher than normal value?

A No, not directly. I didn't follow that.

Q Were you aware that operators were taking actions to try and restore pressurizer level?

A That is a little strange question really. Pressurizer level was one of the things that we had and we were trying to restore it.

Q It was pegged high, and were you aware of the actions

1 that they were taking to try to get it back down to the indicating
2 range?

3 A Oh, yes, yes.

4 Q What were they trying to do?

5 A Well, what was being done that I observed at least was
6 that we were trying to get the heaters operable and with the
7 normal plant systems type operations to get that level back down
8 in the operating range.

9 Q Aside from the heaters, what plant systems?

10 A Well, I couldn't really tell you what they were doing
11 because I wasn't observing them in that way. I was just observing
12 the indication as I saw it from further back in the control room.
13 I knew that they were having apparent trouble with the heaters
14 and ~~it~~^I was following in that particular vein because it was easier
15 to follow in conversations, but as far as other actions, no, I
16 wasn't directly following those.

17 Q Besides the information concerning pressurizer level
18 being pegged were any other actions, the heaters, discussed on the
19 confernce call at approximately 6 a.m. that morning?

20 A I don't recall. At this time I don't recall much of
21 that conversation at all.

22 Q Did you at any time that day discuss the status of
23 high pressure injection and let-down as it existed prior to 8 a.m.
24 with Messrs. Miller, Kunder, Zewe, ~~Urbine~~^{Urbine} or Chwastyk?

25 A Not that I recall, no.

1 Q Our review of your testimony to IE investigators
2 indicates that during the 8 o'clock thinktank meeting in order
3 to restart a reactor coolant pump that system pressure was raised
4 by increasing HPI flow. However, in testimony before the Special
5 Inquiry Group in response to a question about HPI discussions
6 during the a.m. thinktank meeting you state that you didn't recall
7 the discussion of HPI occurring.

8 In your statement of 6/12/79, the statement that you
9 prepared you state that "The group impression was that HPI must
10 be keeping the core cool." Would you clarify your knowledge of the
11 status of the high pressure injection system before the 8 a.m.
12 meeting?

13 A I have no recollection of ever inquiring on my own part
14 of what the flow was or what they were doing to it. I just don't
15 ever recall that I was in a conversation about that. I know we
16 had the conversation as you stated there in your reading to get
17 the pressure up. We increased the HPI, but that makes an assump-
18 tion that you have some at that point to me. So I guess I wouldn't
19 try to speculate on anything else because I don't remember any
20 discussions of what the flow may have been.

21 Q After the primary system pressure was increased to
22 approximately 2,000 pounds in the 10 o'clock to 11:30 time frame,
23 would you clarify your knowledge about the high pressure injection
24 system from that point on?

25 A Well, I think I have already stated at other times that

2 2 0 0 E E D E N G S

MR. GAMBLE: We will go on the record.

This interview is being conducted as a portion of the Nuclear Regulatory Commission's investigation into the exchange of information between the Metropolitan-Edison Company and the NRC on March 26th, 1979.

Mr. Leve, will you please state your full name for the record?

MR. LEVE: William H. Leve.

MR. GAMBLE: Counsel present, would you please identify yourselves for the record.

MR. MOSBRIDGE: My name is Michael F. Mosbridge of the law firm of LeBoeuf, Lamb, Leiby & MacRae, counsel for Mr. Leve.

MS. BOAST: Molly S. Boast.

MR. GERRARD: Smith E. Gerrard, William & Gerrard.

MR. GAMBLE: Mr. Fiddell will be joining us later?

MR. MOSBRIDGE: That is correct.

MR. GAMBLE: Norman Leslie is also out of the room and will be joining us later.

Whereupon,

WILLIAM H. LEVE

having been first duly sworn by Mr. Gamble, was examined and testified as follows:

MR. GAMBLE: Thank you.

EXAMINATION

BY MR. CRAIG:

Q Still, our review of your testimony indicates that on the morning of 3/26/79 you instructed the shift foreman to reduce and maintain pressurizer level, and these actions were that high pressure injection would be reduced and let-down flow would be increased to recover pressurizer level. Did you at any time that day discuss the status of the high pressure injection and let-down systems with Mr. Miller?

A Yes.

Q Would you tell us what the substance of those conversations were?

A Well, throughout the day we had discussed the status of the high pressure injection system and the status of the let-down system throughout the whole day at various intervals.

Q Did you discuss the status of these two systems as they existed prior to 8:30 a.m. in that let-down had been increased and high pressure injection had been stopped for a while and then throttled?

A Yes, we did discuss that.

Q Would you tell us the context of those discussions?

A When Mr. Miller arrived I was briefing him on what had taken place to that point until he arrived. As I recall, I described the actions that we took up to that point which include increasing the let-down at various times and also verifying high

1 pressure injection flow and then further reducing it.

2 Q Did you have a similar conversation with Lee Rogers
3 concerning the status of the system as it existed prior to
4 approximately 8:30 in the morning?

5 A I really can't remember because Mr. Rogers was there
6 for a period of time and I am not certain when he arrived. He
7 was involved in most of the conversations that I had with
8 Mr. Miller after he arrived. So I don't recall exactly if I
9 addressed them to him and Mr. Miller together along with
10 Mr. Ross and so forth, whoever was with Mr. Miller at that
11 particular time.

12 Q Did you have any kind of a discussion concerning the
13 fact that HPI had been reduced and let-down increased prior to
14 8:30 a.m., the status and not the conversation with George
15 Sanders?

16 A Yes, I did discuss that with George after he had
17 arrived. We had talked about that.

18 Q What about with Jack ~~Miller~~ ^{Ward}?

19 A I do not recall any direct conversations with Mr. ~~Ward~~ ^{Ward}
20 concerning those two items on that particular day.

21 MR. FIDELL: Before we go on, may I ask for the record
22 please, to which of the three subjects listed on the subpoena
23 these questions relate?

24 MR. CRAIG: They relate both to the radiation levels
25 and to the pressure spike and to the core temperature.

ALDERSON REPORTING COMPANY, INC.

1 concerned you?

2 A Nothing right that minute. Later on we started
3 receiving radiation alarms and at that time we became very
4 concerned.

5 Q When you said you asked Bill Zewe if he was
6 injecting and he assured you that he was, did you ask him
7 that because you would have to be using high pressure
8 injection to get the maximum amount of borated water into
9 the system or was that a question that related to core
10 cooling?

11 A It was both. It was a question relating to both.

12 Q Was there any discussion between you and anyone
13 else the first hour or so after you had come into the Unit 2
14 control room as to whether high pressure injection had in
15 fact been on for a very long period after 4:00 a.m.?

16 A I did not ask that question. I didn't have time
17 to go back and look at what happened between 4:00 and 6:00
18 or whatever time it was that I got there.

19 Q Was there subsequently any conversation about that
20 whether you asked the question or not? What I am getting at
21 is whether, at some point in the time period before 11:00
22 o'clock in the morning, it was generally discussed that a
23 combination of the EMOV being opened and high pressure
24 injection being off could have resulted in a substantial loss
25 of inventory?

1 A I think we discussed the fact that high pressure
2 injection had been off for some time or throttled back.
3 I don't think we ever related it to fully uncovering the
4 core that early.

5 We were concerned that the possibility existed.
6 In our own minds we had a concern that we had to do something.
7 We knew we had some problem. We had radiation monitor alarms.
8 We knew we had fail fuel of some sort, and the seriousness
9 of it was not known, of course.

10 Q In your own mind, did you entertain the possibility
11 that the core had been partially uncovered for a period of
12 time?

13 A No, I guess I really didn't. I was kind of
14 concerned about it particularly as the day went on but I
15 don't think I ever said, "Hey, that thing could have been
16 uncovered," definitely.

17 Q What were the things that kept you from considering
18 that as a realistic possibility? Was it anything other than
19 the pressurizer level continuing to be high, if you can
20 recall?

21 A Being honest, we just never had full time to
22 sit back and analyze the whole situation very closely and
23 very methodically. I think that is the only thing that
24 prevented us from making that look-see effort.

25 Q I want to ask you a question about that but maybe

his presence during the interview?

THE WITNESS: I do not.

MR. GAMBLE: Thank you.

EXAMINATION

BY MR. MOSELEY:

Q Mr. Ross, during your questions I will make reference to prior interviews and statements that you have made. I have those available for reference, and if at any time you would like to view the statement, just say so and I will be happy to show it to you; but I had not planned to show you each of them as we go along. But if at any time you want to see them, just say so and I will be happy to let you see them.

A Okay.

Q In testimony to the Special Inquiry Group in September, in response to a question relating to the time period prior to 11:00 a.m., you responded -- and this is a quote: "I think we discussed the fact that high pressure injection had been off for some time, or throttled back. I don't think we ever related it to fully uncovering the core that early."

Now in the first sentence of this quote, who do you specifically mean when you use the pronoun "we"?

A As I recall, "we" would be the people in the back of the room in the think tank. That would be our group. That

1 would be Miller, Rogers, people like that participated in that
2 that morning.

3 Q It would be specifically the think tank people?

4 A It would be the think tank people.

5 Q Now let me ask you some specific names, because
6 they may or may not have been part of the think tank at that
7 period in time.

8 Did it include Kunder?

9 A I can't definitely say he was there, but he was
10 in there, in the room and part of that most of the time. I
11 can't say he was there for that particular conversation.

12 Q Okay, but let's relate it back to the sentence that
13 said, "I think we discussed the fact that high pressure
14 injection had been off for some time, or throttled back."

15 Now let me ask you: Do you think Kunder partici-
16 pated in that discussion?

17 A My recollection is "yes," but that's just what it
18 is, "my recollection."

19 Q Okay. Fine. Do you recall Zewe participating in
20 this?

21 A Yes.

22 Q Chwastyk?

23 (Pause.)

24 A You gave me the timetable, and --

25 Q Let me interrupt you there. I was making reference

1 there where -- HPCI was not the first thing that was of
2 concern, then; rather the fact that we were having radiation
3 alarms. And to me that was more -- would have been more
4 important, I believe, rather than discussing whether they had
5 secured or started the high pressure injection. That's what
6 I am saying now.

7 Of course, trying to remember what actually went on,
8 I have no recollection.

9 BY MR. CRAIG:

10 Q. On page 21 of the same interview, May 9, 1979, in
11 response to a question about high pressure injection you
12 state, and I quote, "I don't recall being informed. I don't
13 think -- let me rephrase that. At the time I got there, they
14 were not injecting. I recall vaguely that Zewe told me that
15 we had had an injection and that they had secured it."

16 During the course of any of the think tank meetings,
17 was the fact that high pressure injection had been secured in
18 the morning discussed?

19 A. Would you define think tank?

20 Q. This group of supervisors that Gary Miller was
21 calling into the shift supervisor's office periodically.

22 A. Okay. Are you asking did they discuss the fact that
23 it had previously been secured?

24 Q. Yes.

25 A. I don't know. I remember Gary ordering high

1 mind. He was discussing the release, the ventilation
2 systems, that type of technical type conversation because of
3 his awareness of the plant. That occurred throughout the
4 day and I can't begin to place times and subject matter any
5 more.

6 Q Moving on to another subject, we were told
7 yesterday in an interview by Mr. Zewe that he had briefed
8 you when you arrived on March 28th in the morning that the
9 HPI had been throttled and the let-down had been increased
10 in an effort to control the level in the pressurizer. In a
11 May 7th interview with the II investigators you said that
12 you perceived the operators were still tending to use the
13 pressurizer level as their indicator of a full system and
14 they were still tending to throttle HPI injection and trying
15 to recover pressurizer level.

16 From this can we conclude that you were aware in
17 the morning of the fact that the HPI had been throttled
18 and the let-down had been increased in an effort to regain
19 or to control the pressurizer level?

20 A I can recall discussions on HPI throttling but not
21 specific flow rates. In our procedures HPI throttling was a
22 recognized item that you had to do. I think in the May
23 thing I was trying to conclude in my mind what they were
24 thinking more than being sure of what they were thinking.
25 That was my perception. The only thing that stands out

1 strong in my mind is that somewhere in the early morning,
2 and I got there at 7 or 7:05, somewhere in the first hour to
3 hour and a half it was throttled beyond the point where I
4 wanted it to be and I very strongly told Zewe and Ross
5 personally that it wouldn't be secured without me
6 personally. That is the one strong conversation that I can
7 remember.

8 Q Yes.

9 A The let-down, I can't recall today as specifically
10 I can the HPI securing, say, at 8:15 or 8:20 in the morning.

11 Q Okay. Was the status of HPI in the let-down
12 system discussed in the telephone conference call that you
13 Rogers, Kunder and Herbein participated in at about 5
14 o'clock?

15 A I can't recall any better today than what I have
16 said previously to questions that were asked like was the
17 block valve shut. Those kinds of things I have said before
18 and I can't remember.

19 Q I don't believe this is mentioned in that. That
20 is why we were interested in whether or not this was.

21 A I can't recall. The status of the plant was the
22 discussion, and I can't recall all the questions that came
23 up. The result of the conversation was that, you know, my
24 day was changed from another activity to go to the plant,
25 the reasoning being that the status of the plant wasn't

1 THE WITNESS: Is that question relative to the period
2 of time of quarter to seven in the morning? That is an encom-
3 passing question when you ask it about the day.

4 MR. MOSELEY: Would you like to respond to it in
5 terms of quarter to seven? We will start with that.

6 THE WITNESS: I don't remember being told about throttling
7 of the HPI in the period of time at quarter to seven in the
8 morning.

9 MR. MOSELEY: I am asking in terms of water flow into
10 the system whether it is the pumps in the HPCI mode or in the make-
11 up mode?

12 THE WITNESS: I don't remember being told of a reduction
13 in flow. Is that what you are asking me?

14 MR. MOSELEY: Yes.

15 THE WITNESS: I don't remember being told about that.

16 MR. MOSELEY: Mr. Miller, I am going to read to you
17 from Sewe's testimony to us on September 1908.

18 MR. MAUPIN: What page?

19 MR. MOSELEY: Page 4.

20 "Question. Bill, our review of your testimony indicates
21 on the morning of 3-28-79 you instructed the shift foreman to
22 reduce and maintain pressurizer level, and these actions were
23 that high pressure injection would be reduced and let-down flow
24 would be increased to recover pressurizer level. Did you at any
25 time that day discuss the status of the high pressure injection

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 and let-down systems with Mr. Miller?

2 "Answer. Yes.

3 "Question. Would you tell us what the substance of
4 those conversations were?

5 "Answer, Well, throughout the day we had discussed the
6 status of the high pressure injection system and status of the
7 let-down system through the whole day at various intervals.

8 "Question. Did you discuss the status of these two systems
9 as they existed prior to 8:30 a.m. if that let-down had been
10 increased and high pressure injection had stopped for a while and
11 then throttled?

12 "Answer. Yes, we did discuss that.

13 "Question. Will you tell us the context of those
14 discussions?

15 "Answer. When Mr. Miller arrived I was briefing him on
16 what had taken place to that point until he arrived. As I recall
17 I described the actions we took up to that point which included
18 increasing the let-down at various times and also verifying high
19 pressure injection flow and then further reducing it."

20 Mr. Miller, do you have any recollection of these con-
21 versations which Mr. Zewe is describing?

22 THE WITNESS: I don't today have a recollection of
23 those conversations.

24 MR. MOSELEY: Given Zewe's clear recollection which
25 I have just read to you, isn't it likely you knew on March 29

1 that water flow on the coolant system had been throttled more
2 than the ordinary amount?

3 THE WITNESS: In earlier testimony and earlier dis-
4 cussion where I had been involved we discussed in detail the
5 status of the HPI system four in the morning on, analyzed it,
6 looked at it. We thought HPI was on a lot more gallons per min-
7 ute than you guys calculate it was on. It is as simple as that.
8 You look at the flow rate in your 0800 report at seven in the
9 morning and it comes like 60 gallongs a minute.

10 MR. MOSELEY: That is the net.

11 THE WITNESS: That is the net but that says there wasn't
12 much HPI. Bill does not remember it that way. I have been
13 involved in conversations. On the May 25th tape you will find
14 that. I don't remember that discussion and Bill's recollection
15 being vivid in September of 1980 is hard because we have gone
16 through an awful lot of discussion on HPI for this whole process
17 within the last year, year and a half.

18 MR. MOSELEY: I don't believe Mr. Zewe's recollection is
19 all that new. I believe his recollection has been very similar
20 to that from the very beginning. That is my recollection of his
21 testimony throughout.

22 THE WITNESS: I am aware that when you initiate HPI
23 and pressurizer level goes up, the procedure says to throttle
24 it. I have been aware of that ever since we have been in Unit 1,
25 to get on the discharge valve and get ready to throttle then

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2355

1 to prevent damage to the pumps and that sort of thing. I don't
2 have a recollection of Bill's exact conversation that is referen
3 here. That would have been very soon after the transient
4 started.

5 MR. MOSELEY: What I am talking about is something in
6 excess of what would be normal. In the quote that I have just
7 read Mr. Zewe is clearly talking about throttling in excess of
8 what would be normally expected by your procedures and by your
9 previous experience.

10 THE WITNESS: You know, if you go back to what my tes-
11 timony has been earlier, you will see that at five in the mornin
12 when I was on the phone with Kunder and he told me the pressuriz
13 was low, I didn't understand it. I am not sure that Bill Zewe
14 and I talked about this item at seven a.m. in the morning.

15 MR. MOSELEY: What I am trying to get at is the same
16 thing you were referring to earlier. Given Mr. Zewe's clear
17 recollection and your recollection or lack of recollection that
18 that you were aware of that, shouldn't we conclude that Mr. Zewe
19 indeed was right, that there is something you were aware of that
20 morning?

21 THE WITNESS: I am having trouble with what you are
22 trying to get me to conclude and concluding that HPI had been out
23 back for three hours?

24 MR. MOSELEY: My question is related to the total input
25 to the system.

1 THE WITNESS: And I had no recollection to that. I
2 had no recollection or conclusion of what he had done with HPI
3 from four to seven in the morning at that time.

4 MR. MOSELEY: Given your lack of recollection, is there
5 a reason that we should not conclude that given Mr. Zewe's clear
6 recollection, that you probably were aware of it?

7 THE WITNESS: I don't conclude the same thing you
8 do from that. I don't think that was discussed with me.

9 MR. MOSELEY: Moving on to another subject, in your
10 interview with the I.E. investigators in May 1979 relative to the
11 core ---

12 MR. STELLO: Wait a minute. I want to get back to something
13 that is not resting easy with me.

14 Gary, I am trying to understand whether or not you
15 are saying you were not briefed throughout the day on the status
16 of the total amount of flow going into the reactor. Is that what
17 I am to understand?

18 THE WITNESS: At periods throughout the day I would
19 have had that status. I was asking the question how much do
20 we need in the early part of the morning. I depended on Ross to
21 have HPI on and my interpretation would have been that it would
22 have been both pumps. I didn't give him a flow rate. I have
23 been asked that before.

24 MR. STELLO: The fact that you were searching for what
25 ought the flow rate be, you have said a number of times a concern

1 over running out of water and having to go piggyback to supply
2 water, I have just got to believe that throughout the day th is
3 was a popular discussion. Are you telling me that I shouldn't?
4 I mean you personally since you were the decisionmaker?

5 THE WITNESS: No, I am not telling you that. I am
6 interpreting the things that Zewe is talking about to being his-
7 torical before seven in the morning. There was a lot of talk
8 about HPI after seven in the morning. The questions asked today
9 relate to me being told what was done at seven in the morning with
10 HPI. I am saying I have no recollection of that fact being given
11 to me that HPI had been this way for this many hours. I don't
12 think Bill Zewe remembers exactly because he was not in the control
13 room most of that time.

14 MR. STELLO: The issue of how much water was going in the
15 primary system is one that I would think had considerable discussion
16 throughout the day.

17 THE WITNESS: Yes.

18 MR. STELLO: With you?

19 THE WITNESS: Yes.

20 MR. STELLO: Whom did you discuss it with?

21 THE WITNESS: Discussed it with the think tank.

22 MR. STELLO: Ross?

23 THE WITNESS: Yes.

24 MR. STELLO: Kunder?

25 THE WITNESS: Yes.

1 MR. STELLO: Rogers?

2 THE WITNESS: Yes.

3 MR. STELLO: Did you ever talk to Zewe about it?

4 THE WITNESS: He was not in most of the ---

5 MR. STELLO: Outside of the think tank, Zewe?

6 THE WITNESS: I don't believe so. I recall one instance
7 clearly and that is when he came in the office around 8:15 and
8 he said they were going to secure it. I said no. That is the
9 one instance I can recall. I can recall one instance when we were
10 going on core flood. I said we would not terminate it while we
11 were on core flood, because people in the room had discussed ter-
12 minating it.

13 MR. STELLO: The first was with Zewe?

14 THE WITNESS: The first was with Zewe. He walked out
15 of the room before I said anything. He told Ross it wouldn't
16 be secure without me personally knowing it, my direction being
17 that I had to know that.

18 MR. STELLO: So, you now have a recollection of a dis-
19 cussion of throttling HPCI and how much water was going in the
20 primary system throughout the day?

21 THE WITNESS: Throughout the day.

22 MR. STELLO: You have specific recollection in the think
23 tank it came up?

24 THE WITNESS: Yes.

25 MR. STELLO: With Zewe there is no doubt in your mind,

17
1 radiation level in the sample lines rose very sharply. Dick
2 came back on the phone and called for myself on line 1 and
3 indicated this, that we had big problems. Just knowing the fact
4 we were upset, I knew it had to be coming from the core, and it
5 was within either seconds, or just a few minutes at the most, that
6 we received the alarms --

7 Mr. Blush. Radiation alarms?

8 Mr. Kunder. The radiation alarms on the back panel. It
9 progressed too rapidly to really discern values on the meters.
10 We got alert alarms. They went into the full alarm status very
11 quickly and a large majority of the alarms were coming in almost
12 simultaneously. I know I turned to Joe Logan and told him, we've
13 got big problems.

14 Mr. Blush. Did you say we have failed fuel?

15 Mr. Kunder. I said it in terms I don't want to repeat here,
16 we're failing fuel.

17 Mr. Arena. What did you attribute that fuel failure to?

18 Mr. Kunder. I don't know that I conceptualized the precise
19 nature of the failed fuel in any other way than we are leaking
20 radiation out of the core. We are apparently damaging some clad-
21 ding to some extent, pleats or thermally, something is happening
22 that is releasing some of the activity.

23 Mr. Arena. When, can you recall, did you first start
24 worrying about the core being uncovered?

25 Mr. Kunder. I guess it was within maybe the next 15 minutes.

1 of the high pressure injection and the let down systems?

2 A No, not to my knowledge.

3 Q A review of your testimony, and this is Office of
4 Inspection report of July 1979, has indicated that on the morning
5 of March 28, 1979, it was your perception that the reactor
6 coolant pumps were pumping steam. Was this discussed in the
7 telephone conference call with Messrs. Miller, Rogers, and
8 Herbein at approximately 6:00 a.m.

9 A To the best of my recollection, that would not have
10 been discussed with Miller and Herbein, and Rogers, i- the
11 telephone conversation because I believe that I reached that
12 perception later on, after that phone call was terminated.

13 Q What would you have discussed or what do you recall
14 discussing with regard to the reactor coolant pumps that morning
15 and their inability to pump water?

16 A Do you mean during the phone conversation?

17 Q Yes.

18 A I don't really recall.

19 Q What discussions were subsequently held on March 28,
20 1979, regarding the inability of the reactor coolant pumps to
21 pump water with anyone that you were involved with?

22 A Do you mean days and weeks after the accident?

23 Q No, just on March 28 in trying to analyze why the
24 reactor coolant pumps could not pump water?

25 A I would estimate that within about an hour or two after

1 the phone conversation, it was evident to myself as well as
2 generally to the management team, I will call it, that the
3 coolant pumps were unsuccessful in establishing any kind of
4 coolant flow. We reached the conclusion that we were steam-bound.
5 I think that that is the terminology that I used. The behavior
6 of the coolant pumps when we attempted to start them was consistent
7 with that perception.

8 I cannot remember any specific conversation with any-
9 one, but I do remember that general perception that I had.

10 Q Let me ask you if you can expand on that just a little
11 for us. When you say that the reactor coolant pumps were steam-
12 bound, are you saying that you envisioned them as the hot loops
13 being void down to the pump section itself?

14 Can you explain what you mean by steam-bound?

15 A Yes. I had the perception that we had steam in the
16 system. I don't think -- I don't remember quantifying, or being
17 able to quantify how much steam and just where, but that the pumps
18 were sitting there rotating in a steam void.

19 So by implication, I guess you could say that that was
20 my perception.

21 Q In testimony before the special inquiry group on
22 September 18, 1979, you participated in the following exchange
23 with regard to the status of the electromagnetic relief valve.
24 Let me quote to you.

25 The question was, "I have been focusing those questions

1 A Well, a generalization is probably the best way I can
2 put it, and that would be just to what actions can we now suggest
3 to be taken towards getting this plant in a stable condition.

4 Q The sequence of events surrounding the accident up until
5 that time, were they discussed at all?

6 A No.

7 MR. HARPSTER: Before we go on let me ask Lee another
8 question.

9 Before you had the first thinktank session I believe
10 the operators had attempted to restart the coolant pumps. What
11 did you attribute to the fact that the reactor coolant pumps
12 just sat there and ran at a low current, at essentially a low
13 current? Not necessarily you personally, but what was the
14 discussion about with regard to that? You were running I think
15 if I recall at a hundred amps or something on a reactor coolant
16 pump.

17 THE WITNESS: Yes.

18 MR. HARPSTER: What was that attributed to?

19 THE WITNESS: I don't know that the operators or
20 Zewe or anyone else gave me their feelings about that sort of
21 thing and I wouldn't guess that they would. In soliciting some
22 information from Zewe about the fact had you attempted to run the
23 pump, and he gives me the facts, yes, we did. I tried to run all
24 four of them and only got one of them to start. Then he says they
25 had little or ^{no} ~~not~~ current on it and they weren't getting any flow

1 indication.

2 I have trouble trying to even put together things here
3 that really took ^{that} that day. It would seem reasonable that that was
4 another piece of information that I needed or was trying to digest.
5 I didn't reach a conclusion then. When we had our first meeting
6 together as a group, one of the things I wanted to do was try to
7 start it again so I could see what was going on. I know that was
8 the kind of thought I had, that I would like to see that myself.
9 The result of that conference was that we attempted to run the
10 pump. Then I saw that and concluded myself at that point that
11 there was no sense in running the reactor coolant pumps now and
12 the loops had ^{filled with steam} ~~oversteamed~~. That was quite obvious to me. With
13 all the things I had been told before and now I had seen it myself,
14 that was my conclusion. I don't believe I attempted to reach a
15 conclusion until after I had seen that next attempt at 8:15 or
16 something.

17 MR. HARPSTER: Once you get to the point where the loops
18 are steam bound were you able to draw any inferences then as to
19 what the extent of voiding was?

20 THE WITNESS: Yes. I think one of my testimonies makes
21 a statement to the effect that I told Miller you have got steam
22 as far down in the loop as the reactor coolant pump itself which
23 would given an indication in my mind at least of how much voiding
24 there was I am sure. The whole hot leg was steam bound down
25 through the steam generators and down to the suction ^{of --} pump.

1 MR. HARPSTER: Down over the pump lift?

2 THE WITNESS: Yes, which would to me just give an
3 amount of voiding conclusion I guess at that point.

4 MR. HARPSTER: Did anyone go to the isometrics to try
5 and equate this with where you might be at in the core?

6 THE WITNESS: No.

7 BY MR. CRAIG:

8 Q Our review of your testimony indicates that you were
9 aware that hot-leg temperatures were above 700 degrees and that
10 instrumentation bridges had been hooked up so that resistance
11 readings could be used to determine the approximate hot-leg
12 temperatures on 3/23.

13 Was a record kept of the data indicated by this
14 extended scale read-out for the hot-leg temperatures?

15 A A recorded record, a log-keeping book?

16 Q Any kind of a record.

17 A None that I know of, no. I would like to rephrase your
18 statement of my earlier testimony. I was aware of a read-out of
19 over 700 degrees. I wasn't aware that that was a correct
20 temperature. I never agreed that that was a correct temperature
21 at that time.

22 Q You didn't agree with the hot-leg temperature?

23 A I didn't agree that we knew that that was what the
24 temperature was.

25 MR. MOSELEY: With any of the instrumentation even after

Hunter: At that time were there any radiation alarms that you recall seeing or were there any brought to your attention?

Logan: Not at that time as I recall. I know I didn't at that time I didn't anticipate that we had a leak I mean that we had a problem other than perhaps a primary to secondary leak in the steam generator but as I recall Bill Zewe didn't indicate that he had picked up an alarm it was a pressure differential in the steam generators that I believe gave him the indication that we had a leak in the steam generator.

Hunter: Okay, Joe. The pressurizer level being full and the pressure being down can you give us a little information what that meant to you at that time?

Logan: Well, it was somewhat it's not a normal situation when we have a plant that is hot. To have that high a level and not have a high pressure also because you would anticipate with a bubble up there that the pressure would be high. At the time something you know didn't ring a bell. There was something that was wrong there at the time and I didn't, I couldn't identify what it was. The fact that the pumps were off certainly was you know abnormal. The shift supervisor was busy trying to get the plant squared away that's why I went to ask George Kunder you know what had happened, what was his assessment of this problem because he had been there for sometime and perhaps he could fill me in on some of the information. As I recall the information he gave me concerning the pumps was that they had fluctuation in the discharge flow

or flow indication on the discharge of the pump and I believe he also said that the amperage had dropped on the pumps indicating that they were not pumping water.

Hunter: You at this time had personally were talking with George Kunder in the shift supervisor's office?

Logan: Yes.

Hunter: And you had discussed the pumps. Did you discuss the pressurizer pressure and level problem?

Logan: I don't, I can't recall that I did. I think the thing that really hit me was the fact that the pumps were off and we were still hot you know and that to me you want to maintain flow and that's the thing that stuck in my mind. There's a tremendous problem I am real serious

Hunter: You are saying Joe that the pumps were off. Ah, two pumps or all four pumps?

Logan: I don't recall right now how many were off.

Hunter: Okay.

Logan: We were doing something, I'm trying to remember just what.

Hunter: Was there any discussion continuing and trying to put in core flood tanks or was at that time your understanding that you were stable on the core flood tanks and that that's, that was as far as you, as far as you, as far as you end up, was there any discussion of going down to the decay heat at that time?

Martin: Something like opening an automatic relief at that point.

Logan: It was further down here I believe, down here wasn't it.

Hunter: This is the, that spike is concurrent with the, yeah 8 hours, 9 hours, 10 hours, this is the spike almost, well it turned out right at 13, 50 whatever, this spike occurred but the power operated relief valve in fact, in the pressurize heaters which has very little probably, it could of been that but the power fail operated valve appears to it open at that moment.

Logan: Your right it was, something that could of caused the you know a spark in there and I think it was the pump, now refreshing my memory I believe we did operate that, I'm trying to, I don't recall right now why.

Hunter: Ok, you don't have any reason, you don't remember why it was being operated at that time?

1 THE WITNESS: I do not know that information.

2 BY MR. CRAIG:

3 Q To your knowledge, was the information withheld from the
4 NRC?

5 A To my knowledge, no information was withheld.

6 Q Our review of your testimony indicates that two reactor
7 coolant pumps were secured based on net positive suction head
8 limits and about 20 minutes later the remaining two coolant
9 pumps were secured due to deteriorated flow. With whom did you
10 discuss the inability of the reactor coolant pumps to pump water
11 other than George Kunder?

12 A The other members of my shift that were present there,
13 the shift foreman and control room operators Ken ^{Bryan}~~Brian~~, the
14 other shift supervisor who I had called from Unit I to Unit II.

15 Q Later on after Gary Miller and Lee Rogers arrived, did
16 you have a conversation with them about the inability of the
17 coolant pumps to provide forced flow through the core?

18 A I informed them of the actions that I had taken and
19 why I had taken them.

20 Q What was their reaction to that?

21 A As I remember, their reaction was that we should proceed
22 and try to start one of the reactor coolant pumps as soon as we
23 could.

24 Q During the conference call early in the morning, was it
25 your understanding that there was a direction during that phone

1 Q In your interview with the IE investigators back
2 in May, you stated in part, and again I quote: "Some people
3 stated the pump didn't run, and we were pretty well convinced
4 that it pumped steam, I think." And "the pump" here refers
5 to the primary coolant pump.

6 Again, to whom specifically does the "we" apply?

7 A Again I think the "we" applies to the people that
8 were in the think tank and the people in the control room.

9 Q Both the think tank and the control room?

10 A Oh, yes.

11 Q Does this statement mean that you believe that
12 each member of the think tank was convinced that the pump was
13 pumping steam?

14 A I think at least I could say that they had indica-
15 tion that it wasn't pumping water. Whether or not it was
16 pumping steam, everybody could draw their own conclusions.

17 Q Someone has testified -- and I don't recall who
18 right off the top of my head -- that isometric drawings were
19 checked in relation to this. Were you involved -- were you
20 personally involved -- in the checks of isometric drawings?

21 A I recall something about that, okay; but I don't
22 think I was personally involved. It's been a long time. I've
23 never been asked that particular question before.

24 MR. HARPSTER: Gary Miller told us that after you
25 ran the pump and saw the steam down around the valve

1 that it would either be yourself or Seelinger that he would
2 rely on to check those drawings to try and relate that to the
3 level of water.

4 THE WITNESS: I did not do that specifically myself.
5 I do remember some discussion within the tank about levels,
6 possible levels, what the problem was. I don't think we
7 ever related it yet to a core level, or I think our actions
8 would have been slightly different at the time; slightly
9 different.

10 BY MR. HARPSTER:

11 Q Let me ask you -- excuse me -- why would you get out
12 the isometrics if you weren't trying to relate it to the inlet
13 nozzle levels and the core level?

14 A Why we did a lot of things that day, quite honestly,
15 is something that's hard for us to defend right now. It's
16 easy for me to sit in this room and say I'd do things
17 differently now --

18 Q No, I think it's a very reasonable thing to do,
19 don't misunderstand me. I would have gotten out the drawings
20 in a hurry, too.

21 A I don't specifically remember relating it to the
22 core level; but I do remember a discussion about isometric
23 drawings.

24 (Pause.)
25

1 are many methods of determining primary system inventory.

2 Q I am asking you what did you do on that day? What
3 was done, to your knowledge.

4 A But you stated there were many methods. I am
5 saying that I don't agree with that.

6 Q The question that I asked you was what efforts did
7 you exert on that day to determine this?

8 A From the time we got there and started the reactor
9 coolant pumps and saw them pump a hundred amps we were
10 convinced we didn't have a water level fully in that whole
11 plant. The efforts we had were to assure that the inventory
12 which we couldn't see didn't degrade. I can't remember
13 efforts in the research over how low it had gotten or how
14 deficiency the inventory had been. Today I can't recall
15 discussions along those lines.

16 Q I understand that there were isometric drawings
17 taken out on the basis of the pump performance.

18 A To look at elevations of the plant, where the
19 hot-legs are, where the top of the nozzles are and where the
20 RPI comes in.

21 Q Wouldn't the core exit thermocouples be an
22 indication of core level? Wouldn't the water level be
23 indicated by the nuclear instrumentation and other factors?

24 A Core exit thermocouples weren't even wired out
25 except by a quirk of design. I called for a set of those

1 A Yes.

2 Q Okay. The only thing you could think you could
3 think of is turn on the pumps and put more water in, right,
4 as an engineer?

5 A As an engineer with some knowledge of the plant
6 that was the only method I knew available.

7 Q As an engineering then wouldn't the next question
8 be how do I find out if that was effective? Did that
9 thought enter your mind?

10 A The thought that entered my mind is how do we
11 determine how much heat removal we need versus much we are
12 putting in, yes.

13 Q What did you consider to be indicators of whether
14 you were being successful or not?

15 A I think we have gone through that. We looked at
16 temperatures in the RCS, we looked at the steam generator
17 pressure and we put an indicator or an a test instrument on
18 the RPS on the hot legs if I remember right. We put that on
19 there because the on-scale meter was off.

20 Q Slow down.

21 A Okay.

22 Q You wanted to look at that temperature. What were
23 you expected it to do?

24 A At the initial stages of looking at it, Vic, there
25 was no high temperature on scale available, so the initial

1 idea was to get some reading in addition to the other
2 information.

3 Q You had a reading then. What were you expecting
4 that reading to do as you added more and more water?

5 A As we added more and more water throughout the day
6 we were expecting that reading to come down.

7 Q So if it stayed superheat it was clear then, was
8 it not, that it wasn't covered with water? Those RTDs took
9 the drawings out and you looked at them, should you not have
10 concluded they weren't covered with water?

11 A Hot-leg RTDs I think are located up above the
12 coolant.

13 Q Yes, the are in that straight run area.

14 A I think that even early in the morning when the
15 pumps started and we looked at the level we knew there was
16 water missing out of the hot legs, yes.

17 Q But my point being that as you kept adding water
18 you knew you never got those thermocouples covered?

19 A I think we knew that those were in a steam
20 condition of some type because I think there was some
21 discussion at some point during the day about how accurate
22 were they in a steam environment versus their qualification
23 which was in a water environment, that type of thing. I
24 mean, I think there was that kind of recognition.

25 A That means you had that part of the system empty

1 of water. So you should add more water. What is another
2 thing that ought to come in your mind? Is there any other
3 indicator? You had this Navy training with the in-core
4 thermocouples. Were you thinking they might tell you if you
5 covered the core back up?

6 A Either me or Lee asked for those initially because
7 that was a part of the initial getting of some indication.

8 Q Indication of what, Gary?

9 A Of temperature. You know, when you go in and you
10 look at the panel on TH which is off scale high we began to
11 look for an instrument on the high end. That is my memory
12 of their initial, you know, why we started looking for, you
13 know, some indicator. And once we had at least an
14 indicator, I don't believe the in-cores were really a point
15 of our discussion any more.

16 Q You never thought of the in-cores as an indicator
17 of water level, that they weren't covered with water?

18 A I don't believe I did, no. I asked for them, and
19 then by the time I got information on them they seemed
20 useless to me because the conversation indicated they
21 weren't reliable. At the same time we got the RTD hooked up
22 to a bridge and that was giving some information.

23 Q On the hot leg?

24 A That is right. But you are asking about heat
25 removal, and I am saying that that was one. There was steam

1 on the period between 5:00 and 6:00 in establishing a time frame,
2 and your answer is, yes. The question, when subsequent to that
3 time, if at all, did you become involved in any discussions of
4 the release valve." I believe what was meant there was a relief
5 valve."

6 Your answer was: "That would be after the general
7 emergency was declared, and it was recognized that voiding had
8 occurred. At that time, I presumed someone had determined that
9 the relief valve had, in fact, opened, and that is how we lost
10 the inventory of water. It pretty much became common knowledge
11 what had happened."

12 How did you find out that the relief valve had been
13 stuck open?

14 A I don't really remember if anyone specifically told me.
15 Obviously, someone obviously told me. I cannot remember when.

16 Could I read that?

17 Q Sure. If you don't mind my notebook, I have put
18 everything in a notebook. They are indexed, and if you will go
19 to IE, but maybe I can find it much faster for you.

20 A All right.

21 (Document was handed to the witness.)

22 A That testimony, I did not have any specific time frame.
23 It was sometime after the general emergency, and I can't tell
24 whether it was minutes, hours, or just when that I gained the
25 perception or the knowledge that the relief valve had been stuck

1 open. I cannot remember any specific conversations, or how I
2 became aware that specifically we had a problem with the valve.

3 Q Can you recall exactly what it is that became common
4 knowledge, is it the fact that it became common knowledge in the
5 control room that the relief valve had been stuck open for some
6 period of time?

7 A When I say that it became common knowledge, I think I
8 was referring to the fact that when bits and pieces of the
9 accident scenario became known, as part of the general development
10 of information and disseminating that to the staff, it just became
11 known by the rest of the staff, and that was just my perception
12 at the time. But I cannot tell you for sure if that was in the
13 morning, in the afternoon, or later.

14 Q Do you recall that you at any time that day discussed
15 the fact that the electromagnetic relief valve had been stuck
16 open with Messrs. Miller, Rogers, Herbein, Zewe, Mehler, or
17 Chwastyk?

18 A I don't recall any specific conversations, but it is
19 certainly possible that later in the morning, or later that day,
20 whenever I became aware of the fact that the relief valve was
21 stuck open, or was believed to have been stuck open, we
22 certainly could have had conversations.

23 I do know that I was not really aware of that in the
24 morning, and it was a piece of information that I would have learned
25 from someone else.

1 patterns for radiological releases. In that sense I was
2 responsible to make sure all those things happened if any
3 area was not being taken care of.

4 Once those functions were carried out by individuals
5 I was available to assist in other matters. Most of the
6 time, just due to the involvement in the control room, I
7 wasn't in a very good position to relay information or
8 perceiving certain needs, I would go ahead and take care of
9 requesting those needs.

10 For instance, trying to get in touch with someone
11 at the observation center and letting them know that we
12 have a problem and directing those kinds of activities.
13 Talking to security and trying to find out where the Muster
14 Sheets are so we can account for everyone and then I would
15 report to Joe Logan or Gary Miller, whoever the emergency
16 director was, I would directly report to that individual.

17 Q Prior to the time that Mr. Logan arrived on the
18 morning of the 28th, had you been involved with or were you
19 aware of any consideration of whether the EMOV was opened?

20 A No, except from the standpoint of when I first
21 arrived, Ken Brian, who was the Unit 1 shift supervisor at
22 the time, had indicated to me that the relief valve
23 temperatures had looked like they were coming down. As a
24 result, qualitatively, I dismissed that we had a problem in
25 that area. I don't think, at that time, I was thinking in

1 terms of a stuck open valve. It was just another piece of
2 information that made sense to me and I don't think I ever
3 questioned it in my mind. The fact that we had a problem
4 with the release valve stuck open or a misoperation of the
5 release valve. It sounded to me like somehow they had the
6 release lift and the amount of steam that was discharging
7 into the drain tank was more than it was able to handle for
8 that particular discharge.

9 The fact that the release monitoring temperatures
10 were high made sense. The fact that they were coming down
11 made sense and I didn't question it any further.

12 Q Were you aware of any additional readings of the
13 temperatures that were made?

14 A I don't believe I was -- not after my conversation
15 with Ken Brian.

16 Q Were you involved in any discussions of any
17 possible leaks?

18 A I don't believe I was.

19 Q I have been focusing those questions on the
20 period between 5:00 and 6:00.

21 A Yes.

22 Q When, subsequent to that time, if at all, did you
23 become involved in any discussions of the release valve?

24 A That would have been after the general emergency
25 was declared and it was recognized that voiding had occurred.

1 At that time I presumed someone else had determined
2 that the release valve had in fact stuck open and that is
3 how we lost the inventory of water. It pretty much became
4 common knowledge of what had happened.

5 Q Would it be fair to say that the next time you
6 gave any thought to the stuck open release valve it was
7 after you had learned from some other source that it was
8 assumed to have been stuck open?

9 A That is correct.

10 BY MR. FRAMPTON:

11 Q Mr. Kunder, can you recall what kind of a
12 situation you perceived that you were facing the first hour
13 or two in the control room, if there were inflicting
14 indications of what was happening in the plant, what were
15 they and what was, in your mind, or what did you discuss
16 with others about what might be happening?

17 A The thing that was foremost in my mind at that
18 time was that somehow we had overfilled the reactor cooling
19 system. In doing so we lost the pressurizer steam bubble,
20 which allowed the pressure to be low.

21 I guess most of the activities that I tried to --
22 most of the indications that I tried to look at and assess
23 was relative to that concern. It was an anomaly that I had
24 never seen before and it did not make sense.

25 Q When you say it was an anomaly, you mean to have

1 the pressurizer be full or to have overfilled the system
2 and yet to have the pressure continue to be low?

3 A Yes. I can't remember how I perceived it
4 precisely in my own mind at the time.

5 Q Did you perceive how that could happen? Is there
6 any explanation of why the pressure --

7 A At that time I couldn't put it all together. It
8 is perfectly obvious now but at that time, as I recall my
9 perceptions at that time, somehow we had overfilled the
10 system and we lost the steam bubble, the bubble that was
11 giving us the pressure.

12 It just did not occur to me and I did not go
13 through the thought process that would have allowed me to
14 conclude at that point in time that we had voiding in the
15 other portion of the system and that the core itself or
16 the fluid in the region of the core actually took over
17 pressure control of the reactor cooling system.

18 Q As you understood it from the period of 5:00 a.m.
19 to let's say 7:00 a.m. or 7:30 when Mr. Miller arrived and
20 the emergencies were declared, what was the strategy for
21 trying to bring the plant to a more stable or more under-
22 standable status? What was it primarily that you under-
23 stood that the operators and Mr. Logan and yourself were
24 trying to do with the plant during that time?

25 A It is a variety of things. Relative to the

1 reactor cooling system per se, the operators were letting
2 down some water. I understand from subsequent testimony,
3 I guess, that they did have some high pressure injection
4 water going into the reactor cooling system. We were trying
5 to let down in order to bring the pressurizer level back
6 into range.

7 Q So you were basically trying to reduce inventory
8 in the system in order to get the pressurizer bubble back?

9 A In effect that was what was happening.

10 There were a lot of other activities that were
11 ongoing at the time. The fact that the containment pressure
12 was up around 2 PSI was at one point thought to have been a steam
13 leak from the 1 steam generator and that was believed to
14 be so because of the disparity in the pressure which is
15 classically something that would indicate a potential steam
16 leak out of the lower pressure steam generator.

17 The steam generator, I believe, at one point was
18 secured, isolated, on both the feed water and the steam
19 side in order to bottle up that generator and ultimately
20 stop the suspected steam leak into the building.

21 Later on when the reactor building pressure did
22 not decrease as expected, the operators felt that that
23 wasn't the problem and they reestablished normal feed water
24 and steam removal from the steam generator.

25 Q Didn't emergency boration using the high pressure

1 injection system go counter to the strategy of trying to
2 get the bubble back? That was putting more water into the
3 system, was it not?

4 A Yes. At the time I was not aware that they had
5 a high pressure injection continuing in the reactor
6 cooling system.

7 At that time, I am pretty certain I perceived
8 that they were just letting down.

9 Q But you said you and Mike Ross wanted to get some
10 high pressure injection --

11 A That was later.

12 Again, you have to realize that we were traveling
13 along at like 90 miles an hour and things were whizzing
14 by and you are making decisions. I don't think I could
15 ever reconstruct the feedback that I was getting and using
16 to make decisions upon at this point in time.

17 By the time that we made that decision to initiate
18 high pressure injection a lot of things had transpired by
19 the time I got in the control room. There were phone calls,
20 a lot of developments, minor things that didn't make sense
21 or that caused me to believe that something other than what
22 was really occurring was transpiring.

23 By the time we made that decision to initiate high
24 pressure injection it was apparent that we were dealing with
25 something an awful lot bigger or more consequential than I

1 had recognized when I first arrived at the plant. It had
2 developed a lot further by that time.

3 Q You still believe that the cooling system was
4 solid, the primary system was solid, when you were ready
5 for emergency boration, I take it?

6 A I guess that would be true to say that.

7 Q But you made a choice that the most important
8 thing was to prevent renew criticality at that point?

9 A That I think was the overriding idea that I had.

10 Q Let me ask you a question about the conference
11 call with Gary Miller and Mr. Herbein and yourself.

12 During that call there was some conversation
13 about whether the EMOV was closed or the block valve was
14 closed. Do you recall the substance of that conversation
15 about that subject?

16 A The thing that I recall and is pretty much what
17 I said in the past, in past interviews, and that is, I think
18 I was asked whether or not the electromatic release valve
19 was opened. I think that was true because I seem to recall
20 having gone out to the control room for a moment and asking
21 someone out there if the valve was opened or if it was
22 closed.

23 The response that I think I recall getting -- the
24 response that I would have gotten is that it was closed.

25 I just remember going out and asking that question.

1 That is what I seem to recall.

2 Q Subsequently, it turns out that the block valve
3 was apparently closed during that conversation --

4 A I am not sure of that.

5 Q -- whether as a result of your asking about
6 whether the release valve was opened or perhaps as a result
7 of somebody else coming in and suggesting that. Do you
8 recall that happening?

9 A No.

10 Q Do you recall learning shortly after the conversa-
11 tion that the block valve had been closed and some indica-
12 tion that this was having an impact on the system that the
13 pressure was going back up?

14 A I believe that I wasn't there.

15 Again, after we had declared the general
16 emergency and I had been told that we were trying to figure
17 out what happened to the water and I think it became
18 apparent to the group after that time that that is what had
19 transpired.

20 Whoever closed the block valve relayed that
21 information and it eventually filtered back to myself. I
22 am certain that I didn't know that until after we declared
23 a general emergency and we had pieced together, very quickly,
24 what we believe had occurred.

25 Q And that might have been an hour later or more?

1 A It might have been.

2 MR. FRAMPTON: I believe this would be a good
3 time for a short recess.

4 (Short recess.)

5 BY MR. FRAMPTON:

6 Q Mr. Kunder, do you recall when you learned that
7 the ruptured disk on the reactor cooling draining tank had
8 burst?

9 A That I had assumed occurred when I first got into
10 the plant and the pressure in the reactor building was up.

11 Q You learned that right away?

12 A Yes. It was based on a presumption. It made
13 sense that that had occurred. There is no indication that
14 the upper disk blew other than by looking at other parameters
15 in making that indication.

16 It was based upon previous experience in Unit 1
17 that that information made sense. I have seen Unit 1's
18 ruptured disk blow during -- it was a transient, I think,
19 involving some instrumentation problems during the start of
20 programming Unit 1, during the hot functional test program
21 of Unit 1.

22 Q Had you ever seen a ruptured disk blow in either
23 unit simply as a result of the pressurizer release valves
24 opening and then shutting again?

25 A The one in Unit 1 was the one I was familiar with.

1 That was due to an electronic problem.

2 Q Do you know whether Unit 1 has a much smaller
3 reactor cooling draining tank?

4 A My understanding is that it is smaller in terms
5 of cooling capacity. The tank size itself, I don't believe
6 is all that much different.

7 Q But the pressure would build up faster because
8 the cooling capacity of the tanks cooling system was
9 much smaller, is that correct?

10 A No. The statement I am trying to make is that
11 the tank and its quenching capability are probably the same
12 order of magnitude, they are about the same size.

13 However, the Unit 2 system has the ability of
14 cooling down that water after the relief has occurred and
15 the quenching function has occurred. It has the capability
16 of cooling it down much faster than the Unit 1 situation.

17 Q How would that affect the speed with which the
18 ruptured disk might blow?

19 A The only way that would have an effect is if you
20 had significant leakage into the drain tanks prior to that
21 event which allowed the contents to remain at an elevated
22 temperature in Unit 1 vs. Unit 2. Unit 2 could keep that
23 temperature down where the full quenching capability is
24 maintained.

25 Q Was there any discussion about whether the

1 ruptured disk might suggest that there was continuing
2 leakage through the relief valve? Do you remember that
3 being considered or discussed in the time period before
4 7:00 a.m.?

5 A No. I think the fact that it was recognized by
6 Ken Brian that the relief temperatures were coming down
7 allowed me, in my own mind, to say that made sense and
8 pretty much dismissed, you know, what had occurred there as
9 relating to our current problem in the pressurizer.

10 Q I think you testified before that after the
11 emergencies were declared and notifications made and Mr.
12 Miller had taken over command of the unit that basic
13 strategy was put into effect to try to repressurize the
14 reactor cooling system. What was the purpose of that
15 strategy? Was that because you perceived that you had
16 Voids and you were trying to collapse them?

17 A I think that would have been the basic strategy,
18 although I can't remember any more what our discussions
19 centered around at that time.

20 For instance, I can't remember any more whether
21 we deliberately closed the block valve in order to
22 pressurize or whether it had been closed by the operator who
23 first recognized that it may be the cause of our basic
24 problem and then left closed. Do you see what I mean?

25 Q Yes.

1 just don't recall them shutting the PORV block valve.

2 BY MR. MOSELEY:

3 Q. This is the time when Zewe made some comment to the
4 effect, gee, this was the cause of the thing, the valve was
5 open. And some other comment which I don't recall offhand.

6 And here we have the principal problems that were
7 concerning people are going away. The low pressure, high
8 pressurizer indications, which were analogous, were going
9 away. And what we are trying to get at is were you involved
10 in discussions of this ~~having~~ been the problem?

11 A. No, not at that particular time.

12 As I say, there were several other things going on,
13 as you will recall. We had a steam generator that was
14 isolated with a leak, evidence of a leak in there. We had
15 the coolant pumps off also, which was an abnormal situation,
16 certainly. And, as I say, I tend to think that I was, at
17 this particular instant, probably in with Kunder trying to
18 find out -- because he had arrived before -- from him the
19 sequence of events that had caused the trip, and also I
20 suppose trying to help him in answering questions that Miller
21 and Herbein --

22 Q. Were you in the room during the telephone
23 conversation?

24 A. In and out, yes.

25 Q. It just seems strange that this is, you know, the

1 thing that apparently has turned around the problem, and we
2 are trying to get at what discussions you had concerning this.
3 Do you recall any?

4 A. No, I don't recall -- in fact, I'm almost positive
5 that I didn't really find out that that PORV had been the
6 culprit until quite sometime later, and I don't even remember
7 if it was the same day, with everything else that was going
8 on.

9 You have to put yourself in the atmosphere that
10 existed in that control room at this particular time, with
11 all the other problems that were attendant with the accident,
12 to appreciate that.

13 Q. Because this was before the radiation alarms were
14 coming on?

15 A. Yeah, but the radiation alarms, as I recall, came on
16 about 6:30.

17 MR. CRAIG: Closer to 6:50.

18 THE WITNESS: Okay. Sometime in that time frame.
19 It's surprising how fast time goes when you are in those
20 situations.

21 BY MR. CRAIG:

22 Q. This is also about the time Zewe realized that the
23 steam generator was probably not leaking, and they were
24 watching the reactor building pressure, and he showed a
25 decrease at this point in time.

1 A. Not leaking into containment.

2 Q. Right.

3 A. But there was still -- we knew that there was a
4 primary -- secondary leak in the steam generator.

5 Q. You state in your IE testimony of May 9, page 31,
6 you were aware the reactor building sump pumps had been
7 secured and that you wouldn't have expected the reactor
8 coolant drain tank disk to rupture.

9 And you state, "Well, it" -- referring to the fact
10 that the disk had ruptured -- "was unusual, to me, for it to
11 occur. I would not have anticipated that it would rupture.
12 It's designed, of course, to protect the tank, but under
13 normal circumstances I wouldn't expect it to rupture."

14 And Hunter asks you a question, "How did -- what did
15 you get the impression -- what kind of impression did you get
16 from Bill when he's telling you about it and that it did
17 rupture?"

18 Your response was, "He was very vague. I'll have to
19 summarize that it was when we were probably discussing the
20 electromagnetic relief valve operation. If it sticks open,
21 you know, and you can't get the steam into it, it's not
22 designed for that, I don't believe."

23 BY MR. MOSELEY:

24 Q. Does that quote refresh your memory of any
25 discussion you had with Zewe on this?

1 A. When I first arrived, Zewe give me a quick run-down
2 on the status at that particular time, and as I recall in
3 that conversation, he had mentioned the water in the
4 containment and the fact that he had secured the pumps, sump
5 pumps.

6 Now, the discussion of the rupture of the tank, the
7 rupture disk going on the tank, I don't really remember
8 whether that occurred at that particular time or whether
9 during the day or even days after that that that discussion
10 took place.

11 BY MR. CRAIG:

12 Q. Can you remember any more specifics concerning this
13 discussion between Mr. Zewe and yourself about the EMOV
14 having been stuck open?

15 A. No. As I say, I don't recall any conversation with
16 him, at least on that day, about the EMOV being, you know,
17 stuck open.

18 When I got there, there was no mention of the EMOV
19 being stuck open, because we didn't realize it, of course, at
20 that time. And when that information became apparent to me,
21 as I say, I just honestly can't remember.

22 BY MR. MOSELEY:

23 Q. It just seems to us this would have been discussed
24 with people coming in, Rodgers, Miller, as sort of bringing
25 them up to what we know about where we are.

1 A. I agree. That's why I say I didn't know about it,
2 at least when Miller got there. I had no -- I still, when he
3 arrived, could not have explained the situation, why it
4 existed, because I wasn't aware of it. And, as I say, I do
5 not remember now when I became aware that the EMOV had been
6 found to be stuck.

7 BY MR. CRAIG:

8 Q. Was the possibility that the EMOV had been stuck
9 open discussed in the think tank meeting on the day of the
10 accident?

11 A. I do not recall any conversation concerning the EMOV,
12 but I would assume that it was discussed. Certainly if Zewe
13 was aware of it, I'm sure it would have come out on some of
14 those think tank meetings.

15 Q. Well --

16 A. Let me clarify one thing. When you say think tank
17 meetings, this isn't what you might assume to be a group of
18 people that are remote from the problem that get together in
19 a little corner and talk about things. This is Miller
20 sitting in there and calling individuals in at times, or a
21 couple of people in, or as many as he can get in there, and
22 people going out and doing things.

23 You have to appreciate the atmosphere that existed
24 of trying to control that accident, rather than trying to
25 rehash what caused it. What caused it was not material to

1 the problem at this particular time. That's what I'm trying
2 to get across.

3 BY MR. MOSELEY:

4 Q. You don't really believe that, do you?

5 A. Yes, I do.

6 Q. You've got to know how you got into a situation in
7 order to know how to get out.

8 A. Let me give a similar situation. You're aboard a
9 ship and you have a fire. Your object is to put the fire
10 out, not to find out what caused it.

11 Q. But I don't think this situation is quite analogous
12 to that. You had a situation that no one understood with the
13 low pressure and high pressurizer level, and this was when
14 the valve was finally closed, things begin to come back, and
15 it seems to me if you are in a position where you don't know
16 what caused it, that it is quite relevant and important to
17 say, well, how did we get here?

18 A. I don't disagree with that. I'm saying you have to
19 get the priority of what's important. At the time that all
20 of this was taking place, the main thing was to stop any
21 releases of radiation, right?

22 Q. Well, certainly.

23 A. Just like putting out the fire is what you want to
24 do first; then you look at what caused it.

25 Q. Well, go ahead.

1 and what were the plans and what we were going to decide to
2 recommend what the further actions were. I don't believe there
3 were any explanations or statements of surprise or any other
4 reaction, if you will, to the fact that the pumps were off. It
5 were merely stated as a plant condition.

6 Q Was there a discussion about what it meant?

7 A No, not that I recall.

8 Q On March 28th of 1979 when did you become aware of the
9 continuous relief path through the EMOV and block valve which we
10 have learned existed for approximately two hours?

11 A You mean prior relief path, prior to the time that I was
12 in there and prior to the knowledge of what time it was shut. I
13 did not know until the next day or the day after, I think it was
14 the next day, when we delogged the data from the reactimeter what
15 time it was shut. My only knowledge of it being opened at the
16 time that I was there was when we were using it as a pressure
17 control device, a mechanical pressure control device by operating
18 the block valve. I didn't know until some time later. I am sure,
19 as I recall now, it was the next day when the data was reduced that
20 it had been open for that period of time.

21 MR. MOSELEY: If the EMOV was operating properly, why
22 was the block valve used do you suppose?

23 THE WITNESS: I think we are digressing here a little
24 bit because in the conference call when I asked was the block
25 valve shut and got the answer that the block value was shut, then

LWRros 1

2 WITNESS ZEWE: Up until the site emergency and
3 everything else, I didn't thing of a problem reaching people
4 at all with any information I requested of them or I gave
5 them. I didn't have any problem in that respect.

6 MR. FRAMPTON: What about after the EMOV block
7 valve was closed off? Did you then realize very shortly
8 that that had been the main leak?

9 WITNESS ZEWE: Yes.

10 WITNESS SHEIMANN: Yes.

11 MR. FRAMPTON: Then you realized that in essence
12 you had a small break LOCA; right?

13 WITNESS ZEWE: True.

14 MR. FRAMPTON: Thereafter, didn't you continue to
15 face a situation in terms of the plant parameters that it
16 was very difficult to understand why the plant was behaving
17 that way?

18 WITNESS ZEWE: No. As soon as we closed the
19 electromatic valve the pressure in the reactor building
20 started to go down. The pressure in the coolant stem
21 started to come up. So we knew then that we once again had
22 a tight stem, which we didn't have before but didn't
23 preceive we didn't have a tight stem. So from then on we
24 knew that that was the leak and we were already on our
25 maximum capability of high pressure injection and just
continued on that path to pressurize up.

1 Mr. Zewe. Yes.

2 Mr. Recktenwald. And why wasn't that done prior to the
3 March 28th accident?

4 Mr. Zewe. Well, the temperatures that we monitored every
5 day on the discharge pipes of all three of the relief valves
6 were inconclusive where, which one was the leaky valve, and it
7 was accepted generally, I think, that we really did not have
8 any reason to believe that it was more one valve than another
9 valve. That the one code valve had been consistently, at least
10 a few degrees higher than the other valves.

11 So, I don't know why we didn't isolate it, and just count
12 it from that point. I really can't say that the logic wasn't
13 there to do that, just to eliminate it.

14 Mr. Recktenwald. Could you have done this on a shift
15 yourself?

16 Mr. Zewe. Yes, very easily.

17 Mr. Recktenwald. Was there any concern that if you did
18 that, the isolation valve might stick?

19 Mr. Zewe. Yes, there was, but that wouldn't have prohibited
20 us from doing it if we thought that it was a problem, but the
21 concern always is in a high-temperature fluid system, in a high-
22 temperature atmosphere that the valve could remain shut and we
23 would lose the inability of having that relief valve.

24 We have had other valves on the pressurizer that were
25 motor operated isolation valves similar to that one that have

1 had failure modes in that direction.

2 Mr. Recktenwald. During the first two hours of the March
3 28 accident, do you recall explicitly considering the possibility
4 that the PORV could fail?

5 Mr. Zewe. No, I did not.

6 Ms. Giannelli. I've got sort of a follow-up question.
7 ID a previous interview with our staff, you stated that you
8 realized the existence of superheated steam on Wednesday, the
9 28th. What time did you first realize that?

10 Mr. Zewe. Sometime later that morning and I'm not sure of
11 the time frame, 8, 9 o'clock, I'm not sure, certainly not within
12 the first one or two hours.

13 Ms. Giannelli. So, 8, 9 o'clock is your recollection?

14 Mr. Zewe. It's probably as close as I could remember now.
15 I really couldn't say. It may have been later than that, I
16 really couldn't recall, but that would probably be the earliest.

17 Mr. Recktenwald. Going back again to the first two hours,
18 do you recall what you thought was going on; what kind of
19 accident you thought you had prior to the time that the block
20 valve was closed on the PORV?

21 Mr. Zewe. Well, all kinds of items went through my mind.
22 we had, of course, the low pressure coolant system and the high
23 pressurizer level, and I could not conclusively come up with one
24 single failure that would cause all the indications that we had.
25 We had thought that we had a secondary steam generator leak that

1 was contributing to the pressure increase in the building, and
2 also --

3 Mr. Recktenwald. A steam line rupture?

4 Mr. Zewe. Some secondary side leak from the steam generator.
5 Either being feedwater or steam. We suspect it's steam, and
6 that contributed to the higher temperature and the increasing
7 pressure. And I felt that we did have a hole of some type
8 in the RC drain tank because of the low pressure, low level in
9 the elevated temperature.

10 I felt that the loss of feedwater transient, as rapidly as
11 it was initiated, in that the pressure spike was high enough to
12 possibly lift the code safety valves. And I thought that while
13 maybe that the valves blew and it ruptured something in the tank,
14 not thinking that it was the rupture disc or the relief valve,
15 but it could have been something else in the tank.

16 So, that would account for the high temperature and the low
17 pressure, but I felt that the relief valves had lifted and that
18 they had receded, I did not realize that it was an ongoing --

19 Mr. Recktenwald. Can I ask. What prior to the accident
20 would you have said, how would the reactor coolant drain tank
21 look after a normal reactor trip and turbine trip?

22 Mr. Zewe. It would have an elevated temperature, elevated
23 pressure, and an elevated level.

24 Mr. Recktenwald. And when you went back to look at it this
25 time -- and how would you have expected it to look? Had the PORV

1 stuck open?

2 Mr. Zewe. As it did.

3 Mr. Recktenwald. Did you think during the accident that you
4 might have had a LOCA, were you considering the possibility?

5 Mr. Zewe. I never really considered that we had a LOCA.
6 The automatic actuation of the engineering safety feature system
7 I felt at the time was because of feedwater initiation. And I
8 really didn't realize that we actually had a hole in the reactor
9 coolant system until we shut the block valve for the electro-
10 matic relief valve.

11 Mr. Recktenwald. Do you recall what radiation alarms you
12 got in during the first two hours of the accident?

13 Mr. Zewe. During the first two hours, the only alarms that
14 I recall are the intermediate monitors that monitor each of
15 the letdown coolers. Those were the only two that I can recall
16 that were in alarm.

17 Mr. Recktenwald. And if you had gotten an alarm on the
18 HPR 227, alarm, what would that have told you about the accident?

19 Mr. Zewe. That would have told me that we had activity in
20 the atmosphere of the building.

21 Mr. Recktenwald. In terms of diagnosing the accident?

22 Mr. Zewe. Yes, because one of the things that you look
23 for if you do have a LOCA is that you have activity indicated
24 on the atmospheric monitor in the building, so that certainly
25 would have been a key. And I know that Ed Frederick and I

1 for some period of time longer than the period that you would have
2 expected?

3 A Would you restate the beginning, please there? Are you
4 saying that containment pressure was going down?

5 Q You were aware that containment pressure decreased
6 after the block valve was shut.

7 MR. FIDELL: That is a question?

8 MR. CRAIG: No, a statement.

9 BY MR. CRAIG:

10 Q And that the [^]NOV valve being opened as caused the plant
11 status, high pressurizer level and low primary system pressure.
12 Did you conclude that the EMV had been opened for a period of
13 time?

14 A At that point, yes.

15 Q With whom did you discuss this conclusion?

16 A At that time there were several people present in the
17 control room and it was more of a collective type conclusion
18 once we had shut the block valve ~~from~~^{for} the automatic and the
19 pressure changed dramatically. We just concluded that it had been
20 opened, but I really didn't have a feel for exactly how long.

21 Q Would you identify those people for us?

22 A My control room operators were still present, the shift
23 foreman was still present, Brian Mehler was present, George Wunder
24 was present, I believe Mike Ross was present at that point and
25 Ken ~~Brian~~ and I am not sure of all of the others involved. I

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 believe that Mr. Logan was also present at that point in time.

2 Q Concerning the shutting of the block valve, decreasing
3 containment pressure and increasing primary system pressure, did
4 you discuss that with Gary Miller on 3/28/79?

5 A I am certain that we talked about it, but I am not sure
6 exactly what time frame it actually took place. Like I have
7 stated before, I tried to cover everything that we had done and
8 what had happened whenever he came and took charge and that should
9 have been among them.

10
11 Q What about Lee Rogers, did you discuss that with him?

12 A Here again I can only reiterate that I believe that I
13 did, but I can't recall the exact conversation.

14 Q How about Brian Mehler or Jack ~~Urbine~~ ^{Urbine}?

15 A Brian was present when we shut the block valve so he
16 was aware of the change in the pressure whenever we shut the
17 block valve and the repressurization of the reactor coolant itself.
18 ~~Urbine~~ ^{repressurization} Mr. ~~Urbine~~, I would say no, I did not have direct communication
19 with him on that subject.

20 Q Do you remember any of the conversation that you had
21 with Brian Mehler about the response to shutting the block valve?

22 A I don't recall exactly, but something to the effect that
23 that was it, that that was the reason for the low pressure.

24 Q Did you discuss this with George Kunder?

25 A In the same light, yes.

1 HUNTER: Okay.

2
3 ROSS: At that time we I kind of decided that we kind of left Unit 1 hanging
4 with a problem going so we ought to have someone go back up. So we sent
5 Brian back up in that he had the shift up there prior to this starting and
6 he was most current on information.

7
8 HUNTER: Did the readings... does readings on the power operated relief
9 valve and the safety valve discharges in the range of 200 to 230 even as
10 high as maybe 250? Was that unusual if you have a leaking valve?

11
12 ROSS: No, I don't think they're unusual if you have a leaking valve. I
13 think readings on the order of 2200 would indicate a leaking valve.

14
15 HUNTER: But not a valve that was discharging for instance.?

16
17 ROSS: That is correct.

18
19 HUNTER: The valve was apparently looked at that temperature and even
20 though they were above 200 in some cases. By looking at the computer data,
21 they finally ended up with, well Brian Mehler ended up, picking the tempera-
22 tures off at a specific time. I don't have any reason why it changed right
23 now, but it was like 260 above the relief valve so he... somebody said,
24 close the power failure relief valve, block valve and it was closed and it
25 turned out that was in fact the problem. In the previous tape and I want

1 to clarify something. At the time the power operated relief valve, block
2 valve was closed, okay, which occurs at 2.2 hours in that range, do you
3 recall the pressure transient or the events that occurred or the things
4 that you do recall seeing when the valve was closed?

5
6 ROSS: Yeah I basically just got there when that particular thing happened.
7 I was still trying to digest what was going on around me. A pretty frigh-
8 tening sight walking into something like this. I am sure you can understand.
9 Right after it was closed, Zewe turned around and said, "Geeze, that was
10 it, the reactor building pressure is going down." So he figured he had
11 found where it was going at that time.

12
13 HUNTER: Okay, do you recall looking at the reactor coolant pressure at
14 that time yourself or was...?

15
16 ROSS: Yeah, it was when I first got there it was like oh, well, I don't
17 know 1,300 or 1,400 pounds maybe in that area. It was not high. It was
18 not extremely low. It was lower than we would like to see it, of course.

19
20 HUNTER: Okay. And in your previous statement we had gone through you did
21 not note the steam generator primaries you were actually concentrating to
22 the left side of the control board and you had discussions concerning
23 getting a reactor coolant pump started. Can you characterize those discus-
24 sions, the reason for getting the pump back on?
25

1 the oncoming people at that time in the morning. I think right
2 after I got there, about the time I got there the PORV was
3 shut, and that is information I kind of picked up from there.

4 Q Let's see if we can identify people related to
5 this particular thing. Is the time now about 6:00, 6:30 a.m.?
6 What time are we talking about?

7 A Yes, to the best of my recollection it is some-
8 where around 6:30 in the morning.

9 Q And this would include yourself, Kunder, Zewe,
10 who else?

11 A Oh, there were a lot of people there by that time,
12 a lot of staff engineers. Logan was there. Maylor. In fact,
13 I think he's the guy who shut it, or had it shut. Ken Bryant.
14 There were a lot of people there, an awful lot of people there
15 at that time in the morning.

16 Q Rogers?

17 A That, I don't remember. I don't remember him
18 distinctly at 6:30 in the morning, but I do remember him
19 around right after 7:00 or so, in that area. I don't remember
20 him distinctly at 6:30.

21 Q Do you recall discussing this -- that is, the fact
22 that it was recognized that the valve had been open for some
23 period of time and that this had contributed to the problem
24 that you were then in -- was this discussed with Miller when
25 he arrived?

300 7TH STREET, N.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 664-2346

1 A I didn't take part in what he got turned over from
2 Zewe when he arrived. I don't know what Zewe told him about it.
3 In the think tank, it was brushed across that the PORV was a
4 part of the problem and it's now shut; but at that time they
5 were looking at so many other problems that had kind of
6 mushroomed secondarily and they had a lot of confusing informa-
7 tion by then.

8 Q But didn't that information indeed contribute to a
9 belief that this was the cause of the problem? This is why
10 you were where you were? The pressurized level was high, your
11 pressure in the system is low?

12 A Well, I don't think anybody ever jumped up and
13 said: We got here because the PORV is open. I don't think
14 anybody ever pounded on the table and said that. I'm sure it
15 was discussed.

16 Q Didn't this statement that I just read in effect
17 say: This is why we are where we are? Would you like to
18 refer to it?

19 A Would you reread it?

20 (Handing document to the witness.)

21 Q It starts about line 12 on page 9, and I am
22 referring to the Special Inquiry Deposition on September 18.

23 (Pause.)

24 A I think that particular statement refers to the
25 information we heard as we came into the control room I think

1 is what that particular statement refers to.

2 Q Is the interpretation that I just gave you the one
3 that is correct? Is my interpretation correct, that this says
4 that this is how we got here?

5 A I don't think that says that. I think it's a
6 statement of the fact of what happened at the time. The
7 conclusion we draw from that is sometimes hard to defend
8 later on.

9 Q I'll refer you to another quote from testimony of
10 yours to IE in May, and this quote says: "Right after it was
11 closed, Zewe came around and said, geez, that was it. The
12 reactor building pressure was going down, so we figured he'd
13 found out what was going on at the time."

14 Isn't that saying that there was a realization by
15 Zewe, and he's making this statement to others, that: Hey,
16 this is why we got here.

17 A I think you'd have to ask Bill that, but that's what
18 that would mean to me, yes.

19 Q And was this discussed with Miller when he arrived,
20 or at sometime later? I believe I asked you whether it was
21 discussed.

22 A Again, I didn't take part in what he was briefed
23 on when he came in. In the think tank, I'm sure it was known
24 knowledge that the PORV was open and had been shut.

25 Q And that it was open for some period of time, not

1 just for a couple of minutes?

2 A Yes, it was open for some period of time; but I don't
3 know what the conclusion we at the time drew from that. I
4 think that information was known. The conclusion was not.

and 5

JWB

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 664-2346

3

11:5

5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 a significant item from the other end of the phone at that
2 time.

3 MR. MOSELEY: What about later?

4 THE WITNESS: Eight thirty in the morning I am
5 saying; I have said that I don't recall. He is asking me, I
6 believe, could that have occurred in there, and you don't
7 recall it, and that could have occurred in there. I am
8 saying at 7:15 I wouldn't have had any discussions. I would
9 not allow any because of what I was supposed to do. At 8:30
10 that could have occurred, in that session and I don't recall
11 it.

12 None of the other people recall it either, because
13 the April 14th tape that I made with that same group --
14 Ross, Seelinger, Kunder, Zewe, Logan -- did not, that I
15 remember, have that in it. If it did, it would have been in
16 my testimony which was derived from that. I am trying to go
17 back to where we were and not get contaminated with the
18 knowledge that we all have since.

19 MR. STELLO: It would be easier if we moved a
20 little further down and pick this up sometime later, because
21 there are a couple of other related issues.

22 MR. MAUPIN: Let us take a break for a minute.

23 (Brief recess.)

24 MR. HARPSTER: Judge Higgins said in the October,
25 1980, interview -- our inspector referred to notes he made

1 while on site, TMI, on March 28th -- said that at 10:30 a.m.
2 he was briefed by Pubba Marshall on Unit II status as of
3 9:30 a.m., when Marshall left the Unit II control room.
4 Higgins said that Marshall and he understood that EXOV had
5 been stuck open longer than it should have been.

6 Higgins also said to us that while he was in Unit
7 II there was concern about cycling the block valve and there
8 was a general recognition that the EXOV had failed open.

9 Ross has testified to us on September 24 -- and I
10 will repeat what Ross said:

11 "Question: Then it was open for some period of
12 time, not just a couple of minutes?

13 "Answer: It was open for some period of time, but
14 I don't know what conclusion we at the time drew from that.
15 I think that information was known. The conclusion was
16 not. When you agreed with me, with my assessment, that this
17 is what was said, is that in agreement today and in
18 agreement that that is what was being said on March 28th?

19 "Answer: It is an agreement. That is my
20 testimony to the best of my recollection. I don't have a
21 distinct knowledge of that right now, that particular scene
22 at this time. I do remember that EXOV scene.

23 "Question: Let me make sure I understand what you
24 said. Have you said that the fact that the EXOV was open
25 for a period of time much in excess of what you would expect

1 it to have been open, and that this was discussed by members
2 of the think tank and members of the supervision on watch,
3 or in the control room in the early morning of March 28th,
4 is that what you have said?

5 "Answer: I am saying to my recollection we did
6 have knowledge that it was open for a period, a long period
7 of time. I can't testify that is the conclusion we drew
8 from that at this time."

9 Zewe testified to us on September 4th, 1980:

10 "Question: And that the EMCV valve being open has
11 caused the plant status, high pressurizer level and low
12 primary system pressure. Did you conclude that the EMCV had
13 been open for a period of time?

14 "Answer: At that point, yes.

15 "Question: With whom did you discuss this
16 conclusion?

17 "Answer: At that time there were several people
18 present in the control room, and it was more of a
19 collective-type conclusion. Once we had shut the block
20 valve to the electromatic and the pressure changed
21 dramatically, we just concluded it had been opened; but I
22 really didn't have a feel for exactly how long.

23 "Question: Would you identify those people for us?

24 "Answer: My control room operators were still

25

1 present, the shift foreman was still present, Brian Mehler,
2 was present; George Kunder was present; I believe Mike Ross
3 was present at that point; and Ken Brian; and I am not sure
4 of all of the others involved. I believe that Mr. Logan was
5 also present at that point in time.

6 "Question: Concerning the shutting of the block
7 valve, decreasing containment pressure and increasing
8 primary system pressure, did you discuss that with Gary
9 Miller on March 28, 1979?

10 "Answer: I am certain that we talked about it,
11 but I am not sure exactly what time-frame it actually took
12 place. Like I have stated before, I tried to cover
13 everything that we had done and what had happened whenever
14 he came and took charge, and that should have been among
15 them."

16 After all that, let me ask you the question: Were
17 you aware that the EMOV had been stuck open for a period of
18 time longer than it should have been?

19 THE WITNESS: Was I aware in the time period of
20 what, Terry, at 8:30 in the morning, 8:00 in the morning?
21 Is he talking 7:00 o'clock in the morning? Can you tell?

22 MR. HARPSTER: He is talking of the initial
23 briefing when you came in. He testified that he briefed you
24 for about ten minutes after you arrived in the control room.

25 THE WITNESS: I can't recall, but I don't believe

1 the significance of that valve being open was discussed at
2 that time.

3 MR. HARPSTER: Given the testimony --

4 MR. MOSELEY: Let us not restrict it to the time
5 when he arrived.

6 THE WITNESS: I am saying at 8:15 in the morning,
7 if everybody had attached the significance to it, I don't
8 understand why I had to provide the direction to keep HPI
9 on. I am trying to go back and pin myself on things I know
10 happened on the 28th. I know that happened and nobody
11 disputes that. HPI was directed to be secured and I said no
12 one, without me, personally. If that had that significance,
13 why would that have occurred?

14 MR. STELLIO: You recall it was said each of them
15 had a reservation on conclusions drawn therefrom. We are
16 trying to deal with only the issue of the stuck-open valve,
17 not the conclusions drawn therefrom. Don't bring the two
18 together, if that is what is causing your reservation.

19 Let us see if we can strictly deal with the issue
20 of the EMOV stuck open for a period of time longer than it
21 should have been.

22 MR. MOSELEY: I guess he is waiting for the
23 question.

24 Were you aware that EMOV had been stuck open for a
25 period of time longer than it should have been on March 28th?

1 THE WITNESS: I cannot recall that piece of
2 information exactly today.

3 MR. MOSELEY: Is the problem the use of the word
4 "stuck"? Because you seem to be willing to agree that you
5 were aware that it had ben opened for a period longer than
6 it should have earlier. Is the word "stuck" sticking in
7 your mind and is that a problem, and why we are not somehow
8 able to nail this down?

9 THE WITNESS: You are asking me specifically if I
10 was aware the valve was open longer than normal on the 28th,
11 period, the whole day, anytime during the day; is that right?

12 MR. MOSELEY: Yes.

13 THE WITNESS: Not restricting it at all?

14 MR. MOSELEY: Yes.

15 THE WITNESS: I cannot today remember exactly. I
16 can't remember today any discussion of that.

17 MR. STELLO: You are confusing me. You and I had
18 a discussion just a few moments ago, when I was trying to
19 use your exact words, and I thought that you agreed that the
20 valve was opened longer than it should have been?

21 THE WITNESS: That is true.

22 MR. STELLO: If I don't use the word "stuck" you
23 agree with the statement?

24 THE WITNESS: I agree with the statereent.

25 MR. STELLO: So it is the word "stuck" that is

1 stopping you from answering this question?

2 THE WITNESS: The word "stuck" is -- eliminating
3 the word "stuck" does make the question different to me, I
4 guess.

5 MR. STELLO: Can you tell me why?

6 THE WITNESS: Because the valve opened longer than
7 normal would rupture that disk and close, that is, has
8 opened before as opposed to sticking open for a very long
9 period of time.

10 MR. STELLO: What would be the reason that the
11 valve would be open for a longer period of time, in your
12 mind, longer than normal?

13 THE WITNESS: It would have to be electro or
14 mechanical, in my mind; either the valve didn't get the
15 signal to shut or it didn't shut; but it could have been
16 open for a period of time longer than normal and then shut.
17 During that period of time it would have been open either
18 due to being stuck or due to an electrical problem.

19 MR. STELLO: That is the distinction? "Stuck" to
20 you means mechanical, not electrical? If it did not close
21 because of an electrical problem, you would not describe
22 that as stuck?

23 THE WITNESS: I would not describe that as stuck,
24 right. When you say "stuck", to me it means the valve
25 electrically has been told to move and it stuck, as opposed

1 to an electrical problem or loss of power, which would have
2 occurred and that valve would have failed open, as opposed
3 to being stuck open.

4 I realize that the fail open part had been
5 corrected earlier in this plant. That is the difference
6 between your distinction and mine.

7 MR. STELLO: I guess maybe what we ought to do is
8 talk about is being open for a longer period of time. If we
9 don't use the word "stuck", it might be easier to
10 communicate. Why don't you try that for a while?

11 MR. MOSELEY: You testified that on March 28th you
12 were aware that EXOV was open for a period of time longer
13 than it should have been; is that correct?

14 THE WITNESS: Today's testimony?

15 MR. MOSELEY: Yes.

16 THE WITNESS: Yes, I have said that.

17 MR. HARPSTER: In fairness to him, it is
18 characterized as having been opened for a short period of
19 time, as opposed to longer.

20 MR. STELLO: He agreed it was open for a longer
21 period of time than normal

22 If you can try to relate some of the things that
23 have been said to decide on what that means --

24 MR. HARPSTER: Gary, when you say "longer than it
25 should have been," are you talking of seconds, minutes,

1 hours? Would you characterize for us what you mean?

2 THE WITNESS: As opposed to hours--not hours;
3 seconds or minutes, but not hours.

4 MR. HARPSTER: A relatively short period of time?

5 THE WITNESS: Yes.

6 MR. HARPSTER: Opposed to a longer period?

7 THE WITNESS: Yes.

8 MR. STELLO: What was your basis for making the
9 statement that it was irrelevant, a shorter period of time?
10 What information do you recall on the 28th that made you
11 answer that way?

12 THE WITNESS: I am saying that during the six
13 o'clock phone call, Vic, when I knew the tank disk was
14 ruptured, I would have know the valve would have been opened
15 longer than I would have expected on plant trip, period; and
16 that longer than expected is a short period of time.

17 I am saying I would have had knowledge of that in
18 the back of my mind from experience.

19 MR. STELLO: What did you glean from the plant
20 condition that made you conclude it was relatively short, a
21 few minutes, rather than hours?

22 THE WITNESS: Probably because the answer came
23 back the block valve was shut. When we asked the next
24 logical question -- you can't see that valve's position; we
25 all know that -- so you don't have an actual position

1 availability for that valve. You don't have a position
2 indicator. So the question that Lee Rogers asked on that
3 call was, "Is the valve behind it shut?" Which you do have
4 a position indicator for. The answer was, "We will check."
5 The answer came back "It is shut," and that stopped me from
6 thinking about the EXOV for a while.

7 MR. STELLO: The fact that they told you the block
8 valve was shut is when you concluded in your mind that it
9 doesn't matter about the PROV, that path is isolated?

10 THE WITNESS: That is right.

11 MR. STELLO: So you identified in your mind block
12 valve shut, path isolated, right?

13 THE WITNESS: And identified we didn't understand
14 what we had based on it.

15 MR. STELLO: That is how you decided that the path
16 was isolated?

17 THE WITNESS: That is right, didn't think about
18 the EXOV; that is the thought process.

19 MR. STELLO: You asked that at 6:15. Would it
20 have been reasonable to conclude it was open until the block
21 valve was closed?

22 THE WITNESS: It would have been reasonable to
23 conclude that now?

24 MR. STELLO: No, then.

25 THE WITNESS: I don't think so. We didn't know

1 that they had just shut it.

2 MR. STELLO: Excuse me. I didn't ask you when
3 they shut it, because you did not know the position on the
4 PROV. You did know the position on the block valve, that
5 when the block valve was shut at that time that is when the
6 path was isolated?

7 THE WITNESS: Right. I think that we in the phone
8 call made the assumption from the answer we got that the
9 valve had been shut previously, and here we are; we didn't
10 know that at that instant the valve had been shut. There
11 had not been any time lapse. If you look at the times that
12 are documented, right at that period it must have been right
13 after, they must have looked right after we acted.

14 The answer came back, "It is shut." We didn't go
15 back and say anything about that. We said, "Oh, that is not
16 the cause of the problem." We said, "What the hell is it?"
17 That is when we went in and tried to figure it out. George
18 had gone through the discussion on the phone about the
19 ruptured disk and all that. He knew that. That question
20 that came out was the one that should have been asked: We
21 didn't pursue the answer and say, you know, "how long has it
22 been shut?" The answer that came back gave no indication of
23 its not being shut, and you would have expected possibly
24 that it was shut earlier in the transient.

25 MR. STELLO: At what time did you have your first

1 briefing?

2 THE WITNESS: 7:05.

3 MR. STELLO: What did they discuss then at that
4 first briefing?

5 THE WITNESS: I didn't have a briefing. Bill Zewe
6 talked to me over the cabinets about what he had. He was at
7 that time, he ended up as the emergency director, because he
8 had sighted the emergency at ten to 7:00. I don't remember
9 the plant conversation.

10 MR. STELLO: He remembers telling you about the
11 valve being stuck open for a long time.

12 THE WITNESS: I am not agreeing or disagreeing.

13 MR. MOSELEY: That is not correct. He does not
14 recall what he said to Gary.

15 Going back to our discussion earlier, you don't
16 recall being told of this dramatic rise in pressure, what
17 caused that; the problem you had been concerned with when
18 you left home no longer existed in terms of pressure, that
19 wasn't discussed?

20 THE WITNESS: I don't recall that being
21 discussed. I was also trying to get across to you that if
22 everybody realized what you are saying, then I don't
23 understand why at 8:15 I had to be the one to say, "Turn the
24 water on." I am not trying to dispute anybody's testimony,
25 but I am trying to say if that was transmitted to me in the

1 context you are saying, then why did that occur? It should
2 not have; and that did occur and it is on that chart.

3 MR. MOSLEY: Were you aware that the block valve
4 was being opened and closed to both control pressure and to
5 let water out of the system during the morning?

6 THE WITNESS: During the morning, yes.

7 MR. MOSLEY: Unless the EXOV was opened, the
8 block valve would not have let the water out, would it?

9 THE WITNESS: No; I did not know which valve Mike
10 was using. He would have had to use both to get water out
11 of that path.

12 MR. MOSLEY: Unless the EXOV was stuck open?

13 THE WITNESS: But he would not have known that; he
14 would have given the valve a command signal. If the valve
15 was stuck open, he would never have known that the valve was
16 not cycling. The valve does not have anything but a command
17 signal.

18 MR. STELLIO: Zev didn't say he told you that. I
19 am going to read the question and answer:

20 "Question: Concerning the shutting of the block
21 valve, decreasing containment pressure and increasing
22 primary system pressure, did you discuss that with Gary
23 Miller on 3-26-79?"

24 "Answer: I am certain that we talked about it, but
25 I am not sure exactly what time-frame it actually took

1 place."

2 What I was trying to get at is, when did he talk
3 to you about it? He is certain that he did. There are many
4 times an answer starts out in discussing Three Mile Island
5 where nobodys says anything about being certain. The reason
6 it stuck so plainly in my memory is because it is one of the
7 few times he said he is certain he talked to you about it;
8 but he does not remember exactly when.

9 MR. MAUPIN: Aren't you first asking if he recalls
10 Zewe talking to him?

11 MR. STELLO: That was not my question.

12 MR. MAUPIN: The most recent one was when?

13 MR. STELLO: I am aying Zewe said he is certain
14 about talking to him about it, but he is not --

15 MR. MAUPIN: You are asking him when?

16 MR. STELLO: Starting at 7:00 o'clock, when he got
17 there, did he mention it then?

18 THE WITNESS: I don't recall.

19 MR. STELLO: Can you recall any time on the 28th
20 Zewe speaking about the block valve, decreasing containment
21 pressure and increasing primary system pressure, any time at
22 all on the 28th?

23 THE WITNESS: Vic, I can't recall. I have said in
24 respose to Terry that in that first think tank meeting that
25 could havbe been disucssed and I don't recall it.

1 MR. MOSLEY: Does the computer pick up command
2 signals to the EVOY?

3 MR. MAUPIN: Before you go on, I know that the
4 testimony does speak for itself. I take it you are trying to
5 get something from which you can draw some inference among
6 other things about the extent to which Zeve might have
7 talked about the length of time when the valve was open.

8 We have been addressing two questions: whether he
9 knew it was open at all, and if he did, whether he had any
10 reason to form some conclusion as to how long it had been
11 open. Zeve said that he had no feel for exactly how long it
12 had been open based on the same information Zeve seems to
13 think he told Miller.

14 MR. MOSLEY: Do you recall the outstanding
15 question?

16 MR. STEILCO: What is the thrust of what you have
17 just said?

18 MR. MAUPIN: The impression I have, for better or
19 for worse, is that for the last two hours you have been
20 exploring fundamentally two questions: (a) to what extent
21 Mr. Miller believed that sometime on the morning of March
22 28th that the EVOY had been open for longer than normal.

23 MR. STEILCO: We have clarified that.

24 MR. MAUPIN: The second is, what basis he had for
25 forming a judgment, if any, as to how long the valve had

1 been open.

2 I was simply afraid that in using the Zewe
3 testimony you were trying to provide the basis for drawing
4 an inference about whether Zewe might have told Miller about
5 how long the EMCV had been open.

6 I simply want to point out that on the previous
7 page of his testimony, Zewe said he did not have a feel for
8 exactly how long the EMCV had been open.

9 MR. STELLER: You ought to read the whole thing.
10 He said, "At that time there were several people present in
11 the control room and it was more of a collective type of
12 conclusion once we had shut the block valve from the
13 electromatic and pressure changed dramatically, we just
14 concluded it had been opened."

15 Then he added, "But I really don't have a feel for
16 exactly how long."

17 Knowing, I think reasonably from that statement,
18 that the valve had been open when they closed the block
19 valve because it was the system changes they saw that
20 allowed them to conclude at that time the valve was open,
21 that is what we are trying to establish. This is very
22 important information and whether or not that was known and
23 by whom is important.

24 What I am trying to understand for myself is when
25 someone starts a question with he is confident of something

1 that is unusual, very rarely do we get anybody saying he is
2 confident of anything. In this case, he did. .

3 THE WITNESS: Did you ask me if the command signal
4 was on the computer?

5 MR. MOSELEY: Yes.

6 THE WITNESS: I think it is. I believe it is. I
7 believe the computer gets an input where it can tell. I
8 don't know that it is a command signal. It could be the
9 pressure sensing signal. I think it is probably a command
10 signal.

11 MR. MOSELEY: Our review of the computer data does
12 not indicate that this valve was being operated, that the
13 only valve that was being operated was the block valve. Is
14 it your statement that you weren't aware whether or not both
15 valves were being operated?

16 THE WITNESS: That is right; that is my
17 statement. I am also saying if you look at the NSAC
18 printout, doesn't that say the valve had an open command
19 signal starting at 7:30, the valve being the ZNOCV?

20 MR. MOSELEY: This is entitled, "ZNOCV Block Valve".

21 THE WITNESS: I am saying Mike Ross would have
22 done that, and I would not have needed to know that. The
23 operation of those two valves plus the other one which goes
24 to the drain tank, I would not have necessarily known which
25 valves they were doing specific manipulations with.

1 MR. MOSELEY: Let me go on to something else for a
2 moment: We may come back to this.

3 Your testimony to us in September related to the
4 EMCV or rather the block valve. You said, "Certainly I
5 would have been concerned about the other valve, but my
6 history of failure of the block valve, it was a gate valve,
7 I believe, and it tends to stick sometimes open or shut."

8 What was the failure history you had experienced
9 with the block valve?

10 THE WITNESS: The valve was a gate valve and the
11 history I had experienced was in Unit I, because my response
12 in the testimony was that the block valve had a tendency to
13 stick open and shut.

14 MR. MOSELEY: Do you recall how many? Was it less
15 than a half dozen or more than a half dozen?

16 THE WITNESS: I vividly recall Unit I being five
17 or six times. I don't have as good a recall on Unit I
18 because I wasn't as close to the test program.

19 MR. MOSELEY: Your statement refers to some
20 performance related to Unit I's block valve; is that correct?

21 THE WITNESS: My statement refers to the fact that
22 the valves on top of the pressurizer in either unit in an
23 odd environment is inside the building and it has the
24 potential to stick, and that has happened.

25 That was only one of a couple of concerns that I

1 this is something he should have told you?

2 A Yes.

3 Q Okay. Or they should have told you.

4 A Yes.

5 Q Again I would like to ask you why you feel this
6 information was not passed on to you.

7 A Again probably the same reasons I gave for the other.

8 Q Okay. And then I will ask you -- I won't go through
9 the list of questions again, but could I ask you whether you
10 feel that other organizations within the state may have been
11 given this information?

12 A I don't believe so, not to my knowledge.

13 Q Another fact, the electromatic relief valve had been
14 stuck open for a period in excess of two hours. To your knowledge
15 on March 28th, was this information passed on?

16 A Yes, it was, in conversation with Gary Miller, he
17 told me the valve had been stuck open. The indication was faulty,
18 and it wasn't indicating the proper position on the indicator,
19 and the valve was now closed. But this was again at 9:00 a.m.

20 Q Did he tell you how long the valve had been open?
21 Maybe not two hours, but a long time? Or do you recall a period
22 of time?

23 A I think he indicated it was open for a fairly long
24 period of time, I believe.

25 Q Okay. Before we started the interview, you gave us

1 9:30, the conditions in Unit 2 were, and I have a readout of
2 the plant status.

3 Q Is that the --

4 A Actually this is not really the plant status. Well,
5 it's a plant status, plus it's a rundown of what had happened
6 in the initial accident.

7 BY MR. ROEFLING:

8 Q Jim, I think you just referred to the time of your
9 arrival as 10:20. Did you want to say that?

10 A In Unit 1, not Unit 2. It took about an hour to get
11 over to Unit 2.

12 Q Okay.

13 BY MR. MOSELEY:

14 Q Now is this time -- I guess I'm confused on that.

15 A This is the status I got in Unit 1 at around 10 --
16 probably by the time I got this from Bubba Marshall, I had
17 been in Unit 1 for maybe a half hour, so it may have been 10:45
18 by the time I got this particular status. Bubba Marshall had
19 been in Unit 2, had evacuated over to Unit 1 control room, and
20 the last time he had been in Unit 2 was about 9:30, so he told
21 me as of 9:30, this was his understanding of what had happened.

22 Q Okay. So you got this at around 10:30, but it was
23 his reporting to you of his knowledge at about 9:30 when he left?

24 A Right.

25 Q Now is that the place where you have the notation of

1 in the system. I know one of my pet concerns, which I
2 think was a more serious concern on my part than any of the
3 other concerns that were being considered, was the fact
4 that we could be concentrating boric acid in the core,
5 because any water that is getting in, if it is getting in,
6 it is flashing to steam and that is a cooling mode at that
7 point in time.

8 Of course, we didn't have any level indication so
9 you couldn't be certain what the level of coolant would be
10 in the core. I assumed that there is a significant
11 possibility that this boiling action that could be occurring
12 would be concentrating the boric acid in the core. I was
13 becoming worried that after some period of time, which
14 quantitatively I couldn't define, we could actually form a
15 slurry boric acid which possibly could impede per the
16 cooling.

17 I guess in the morning that was -- that issue
18 along with the issue of how do I assure that I am indeed
19 cooling the core were the major ones in my mind.

20 Q Was there ever anxiety about the core actually
21 being uncovered during this period of time?

22 A I believe it would be safe to say that there was
23 some anxiety along that line, but intuitively I believe I
24 always felt the core was covered or at least being cooled
25 sufficiently to stop any increase in core temperatures or

1 increase in the voiding that we may have experienced. We
2 couldn't prove it. There were no indications to prove that
3 we were cooling the core effectively.

4 In that regard there was anxiety about guaranteeing
5 that if we had the core cooled and verifying something that
6 we intuitively felt was occurring, either through direct
7 cooling with water or by some steaming that was, of course,
8 removing heat.

9 Q How did the high hot leg temperatures figure in
10 this evaluation?

11 A We were looking desperately for those temperatures
12 to show a decrease and that would point towards an improve-
13 ment in our condition.

14 Throughout a good portion of the morning and I
15 guess into the afternoon, those temperatures were not
16 responding as we were hoping them to respond in order to
17 use those as a basis for suggesting core cooling was
18 improving.

19 Q Were the hot leg temperatures disbelieved?

20 A No, I never disbelieved the hot leg temperatures.
21 I thought they were about 800 degrees, in that range.

22 I think that we had believed in those because we
23 had more than one RTD telling us the same information.

24 Q So what you are saying is the hot leg temperatures
25 showed you that you might not be getting out of the core

1 CRESWELL: What did the information mean to you?

2
3 KUNDER: Well, since I wasn't that familiar with the Unit 2 instrumentation
4 particularly in the area of the thermocouples, he said he wasn't sure if
5 there's anything that could be derived from it or anything reliable that we
6 could get from it at that point I guess I just dismissed it.

7
8 CRESWELL: Discounted the information.

9
10 KUNDER: Well, yeah I guess discounted might be one word. I didn't place
11 any concrete faith in that information you know I wasn't sure what it was
12 telling me and I think we were all looking for something that we could
13 identify with really pretty clearly in terms of meaningful instrumentation
14 to tell us what the conditions were in the core and since that was...you
15 know you can only speculate on what it was telling you at least that's what
16 we thought it was telling us at that point I didn't put a whole lot of
17 meaningful restored at that point.

18
19 SHACKLETON: Jim we are almost ready to run off our cassette and we'll
20 change the tape at this time. The time is 2:03 p.m. and we'll discontinue
21 until we come back on tape again.

22
23 SHACKLETON: The time is now 2:06 p.m. eastern daylight and this is a
24 continuation of the interview of Mr. George A. Kunder. Please continue Mr.
25 Creswell.

1 cooling with this particular mode of cooling?

2 A At the time I viewed the hot leg temperatures of
3 being representative of voiding steam in the core, I visualized
4 the reactor cooling system as being steam bound in the
5 upper section of the core and hot legs themselves. Since
6 we were relieving steam through the electromatic relief
7 valve at various portions of time in the morning and after-
8 noon, that we were removing some heat. We could not
9 confirm from those indications whether that removal of heat
10 was adequate to keep the core safely cooled or improve the
11 cooling of the core. We did not have indications that would
12 conclusively confirm that the core was covered in its
13 entirety.

14 I believe that there was some possibility that
15 we were having steaming in the core which was contributing
16 to some voiding and I guess in a technical sense you could
17 say the core was not fully covered but it was being cooled
18 to some extent. That is the way I think I perceived things
19 at that time.

20 Q Late in the morning a decision was made to depressur-
21 ize the system and to blow down to try to go on decayed
22 heat and to try to get the core flood tanks into the core.
23 Why was that decision made? Was that made simply because
24 you couldn't satisfy yourself that the strategy you had
25 employed during the morning was definitely working?

1 situation.

2 I think that it is unfair to task anybody with this
3 sort of Monday morning quarterbacking with the perfect vision that
4 we all have after an event.

5 MR. HARPSTER: I think one thing you should understand,
6 and one of the reason that we repeat this question and asks these
7 gentlemen for their opinion, is that we are tasked with the
8 problem of trying to write better reporting requirements, and
9 determine how better to get this information. So it is necessary
10 to have these gentlemen's opinion. We find it necessary to ask
11 it.

12 BY MR. HARPSTER:

13 Q George, you have previously testified that on the
14 morning of March 28, 1979, after the reactor coolant pumps were
15 shut off, the hot-leg temperatures screamed up. You were impressed
16 by the magnitude of 700 to 800 degrees of the hot-leg temperatures.
17 You perceived the core as being cooled by over-heated steam.
18 That is, you were considerably in excess of the saturation
19 temperature.

20 And, you never disbelieved the hot-leg temperatures
21 because you had more than one RTD telling you the same
22 information.

23 Did you at any time on March 28, 1979, discuss this
24 information or its implications with Messrs. Miller, Rogers, Flint,
25 Herbein, Zewe, Mehler, or Chwastyk?

1 A I would have been engaged in various strategy discus-
2 sions with Mr. Miller, and Mr. Rogers, throughout the morning, and
3 that information was a parameter that was a factor in those
4 discussions. But I don't remember any specific discussions. I
5 just remember that at various times we assembled in the shift
6 supervisor's office, and perhaps out in the control room, and
7 discussed what we were going to do next because we recognized that
8 we did have a need to establish cooling that we could identify
9 with, and conclusively say was a situation that was under control.

10 I really cannot remember any specifics, though.

11 Q Was a record kept of the data indicated by the extended
12 scale read-out device connected to the hot-leg RTD?

13 A I can't remember any specific records, but there could
14 be records of that information. If it is available, it would have
15 been retained by the data reduction group, and it would certainly
16 be available today.

17 Q On March 28, 1979, what was your evaluation of the
18 hot-leg temperatures when they sharply increased after the reactor
19 coolant pumps were shut down?

20 A My general recollection is that they indicated that we
21 had an abnormal situation in the plant. I think that those
22 conditions were beyond the bounds of plant conditions that I was
23 used to dealing with.

24 My general perception of the reactor coolant system
25 was that it was indicative of the voiding that we had. I cannot

1 recall specifically when I reached that general feeling, or that
2 conclusion. It was sometime, of course, after the temperatures
3 went up, and after many discussions with different people. You
4 gradually reached that perception.

5 I cannot remember any specific time frame for me to
6 draw that conclusion.

7 Q John Flint of B&W testified that he advised several
8 people, including Lee Rogers and Gary Miller, that the magnitude
9 of the temperature of the super-heated steam would preclude the
10 ability to collapse the bubble.

11 Were you aware, on March 28, 1979, or did you take part
12 in, or overhear any discussions of these concerns?

13 A I can't remember specific discussions, but John was
14 part of the management team, so to speak. He certainly had input.
15 I had specific discussions with him that I recall relative to the
16 indications of the source and intermediate range detectors, but I
17 don't remember any specific discussions that we had relative to the
18 high temperatures and the process you discussed.

19 Q Do you recall a concern of your inability to pressurize
20 the plant because of the release set points to a point where you
21 could collapse the bubbles?

22 A We had a lot of concerns that day, but looking at it
23 from the point of view you have expressed, I really can't remember.
24 I will have to say that I just don't recall reviewing it specifically
25 the way you have mentioned it.

1 Q You previously testified that on March 28, 1979, your
2 interpretation of the super-heated temperatures indicates that
3 the core had been uncovered and that it was being cooled by the
4 super-heated steam. Was this information discussed at any time
5 on March 28, 1979, with Messrs. Miller, Rogers, Flint, Herbein,
6 Zewe, Mahler, or Chwastyk?

7 A Again, I think the perception I had was similar or the
8 same as the general perception of the rest of the management team.
9 A large part of our discussions was directed toward what strategy
10 we would take to try and assure that the core was covered. It
11 meant what strategy we would take to get enough water into the
12 system and achieve plant status that we could guarantee that we
13 had the core covered.

14 I think intuitively we all hoped, or believed that we
15 had the core covered, at least I did. But there was not enough
16 positive information to say without a doubt that that was the
17 condition, and to relax, so to speak. Thus, we continued to
18 define our goals, and I am speaking of general goals, and come up
19 with a strategy that got ourselves in a condition where we could
20 say for sure that the plant was back under total control.

21 Q George, let me ask you a question which is similar.
22 As I have reviewed your previous testimony, and your conversations
23 with Don Haverkamp on that morning, I had the impression that you
24 were very seriously concerned that the core was uncovered at some
25 time, and in fact that it was being cooled through this super-

1 heated steam mechanism.

2 Did you express these concerns in this think tank
3 meeting, or meetings, as they were held throughout the morning?

4 A I remember one specific feeling that I had relative
5 to cooling of the core, and that relates to the fact that if we
6 were getting water into the core and it was evaporating, and that
7 is the mechanism I was thinking of, removing heat through the
8 evaporation of the water. Then, of course, as that steam would
9 contact other hot material, it would become super-heated, that
10 would achieve some cooling.

11 But I remember being concerned about the precipitation
12 of boron, and by this time, by the way, it would have been sometime
13 around the middle of the morning, and I believe that it was after
14 my conversation with Don Haverkamp. I don't recall any more as
15 to what terminated that conversation, but that thought and concern
16 was in the back of my mind.

17 Basically, I think my feeling was that I was hoping that
18 that was not going to be a real problem, and I had no way of
19 knowing whether that was going to be an eventual problem or not,
20 but the only way of avoiding that problem was to keep water
21 chugging into the core, and keep it there.

22 We did have high pressure injection established at that
23 point, and it seemed to me to be about the only thing that we could
24 do. There were no other alternatives that were obvious to us, or
25 I am sure that we would have perhaps taken a different course of

1 action, a different strategy.

2 Q Let me ask you, did you discuss these concerns on how
3 you perceived the core as being cold with the other members of
4 the management team?

5 A We had discussions throughout the morning. I am fairly
6 certain I verbalized that specific concern, and everybody else
7 verbalized the concerns they had. We all came to reach an
8 agreement on the course of action which seemed to be the best
9 course of action to take at that point.

10 Q Do you feel that people were in agreement with your
11 understanding of the way the core was being cooled that morning?

12 A My perception was that we all shared the same general
13 understanding, although I would have to say that it was more of a
14 qualitative feel for what was going on, rather than a quantitative
15 understanding because we did not have knowledge of actual level
16 in the core. We did not know how much water we had in the system.
17 We believed we had enough, but at least, I think on my part, it
18 was more of an intuitive feel for the conditions in the system.

19 Q Did you discuss or did you overhear or learn of any
20 conversations with regard to the implications of this super-
21 heated temperatures that morning?

22 A I don't recall any specific conversations relative to
23 that. Most of the time we were focusing on how to get to the
24 basic plant in a control mode of cooling, one that we understood
25 and one that we had experience in through our training, and so

1 forth, and that was either to try and achieve decay heat removal
2 operation, using the decay heat removal pumps. Ultimately it was,
3 as I recall, our goal, and we tried a number of strategies toward
4 achieving that goal, and we did try to keep in mind what we would
5 do if those individual strategies would fail, and have some back
6 up plan.

7 But I don't recall either taking the opportunity, or
8 being able to really sit back and think, and focus on some of the
9 academic aspects, shall we say, of parameters that we were
10 seeing. I think what pretty much motivated me personally was my
11 desire to see the plant in a controlled mode that I could identify
12 with as being safe, and my background in operations which I think
13 tended to make me react in that way.

14 Q How did you account, or what was your feeling toward
15 the continued extremely hot temperatures over the duration of the
16 day?

17 Did this generate a concern about whether or not you
18 were achieving your objectives, as the temperatures stayed up over
19 the course of the day?

20 A Certainly, it was a very frustrating experience to not
21 be able to restore the plant to a status that I was comfortable
22 with. To the best of my recollection, my belief was that there
23 was a lot more water loss than could be made up in a very short
24 period of time by the high pressure injection system. So that it
25 would take some period of time to regain control.

1 know it was sometime in the middle of the morning when we were meeting with
2 Gary and Lee Rodgers and so forth. The thing that was scaring me was the
3 thought that we were putting water in the core from high pressure injection
4 and it was boiling off and concentrating boric acid and I was really scared
5 that we would end up blocking flow lanes and stuff you know with the boric
6 acid unless we'd get enough cooling water near to really get some sort of
7 circulation and the only circulation that we could conceive of getting was
8 to blow fluid out the electromatic relief valve which was the only place
9 that we could find any kind of venting path and hopefully carry over whatever
10 other mechanism would exist would at least minimize any kind of buildup of
11 boric acid and... but...I know the feeling that I had was that we were
12 cooling the core but at a elevated temperature in through the steaming
13 process because we I don't think I thought in terms of the supercritical
14 steam point I don't think that thought went through my mind but at that
15 point I'm not sure I was prepared to think of that sort of thing but I knew
16 that we probably had a bubble in there, a steam bubble, so to avoid and I
17 couldn't define it in my own mind or really get a feel for what it was like
18 but as long as we were pumping in the high pressure injection that was the
19 only thing we could do other than try and start a pump and that had been
20 tried by others and it was apparently unsuccessful at that point.

21 CRESWELL: George the implementation you had some technicians hook up a
22 thermocouple reader and digital volt meters to the thermocouples. Were you
23 aware of the evolution?
24
25

1 KUNDER: I was aware of that evolution, the extent of that evolution I
2 believe, that's quite a few weeks after the incident, but I was aware that
3 he had gotten thermocouple data that morning and he had reported his findings
4 to Gary and I also discussed it with him briefly that the data was erratic
5 and he didn't know what kind of reliability to place on it cause he had
6 numbers that ranged all over the place. You see up to that time I was
7 unaware that Unit 2 had their thermocouples tied into the computer. Unit 1
8 doesn't they don't use them so I didn't even...I wasn't even aware of the
9 ability to get that kind of information and the data since it was so scattered
10 there was some questions marks there was temperature...I think he had
11 converted...I learned this after the fact...he had converted the DVM data
12 from all 52 thermocouples he took four of those or five of them, something
13 like that it was a very small number, and he converted the data to tempera-
14 tures just to see what kind of a range he was getting there was some I
15 guess a couple of points that weren't giving him any information at all.
16 One temperature was down around...either under 100 or just over 100⁰,
17 another one 20... around 2300 or somewhere in that range, another one high
18 question, another question mark they get four data points that I had learned
19 when I was down at the presidential hearings that he had actually converted
20 at that time and given to Gary and mentioned to me and they you know kind
21 of going along here at 90 miles an hour and that just... he wasn't sure
22 what kind of reliability to derive from the information so that was pretty
23 much the extent of you know any kind of involvement analysis that I can
24 recall.
25

1 to me. It was a voltage reading, and Ivan just indicated ---

2 Q Would it help to change your testimony from IE on 7-11?

3 Let me find that page for you.

4 A I think that it will refresh my memory.

5 Q Did your evaluation of this information, that is the
6 information you have just read in the IE transcript, change after
7 your discussions with John Flint regarding the explanation of the
8 re-criticality?

9 A I cannot remember which came first. I tend to think
10 that my conversation with John Flint came first, but to the best
11 of my recollection, I am just not sure.

12 Q Okay.

13 MR. MOSELEY: The question remains the same, did you
14 tie the two together?

15 THE WITNESS: I don't think that I tied the two together
16 no matter in which order it came.

17 BY MR. HARPSTER:

18 Q To the best of your knowledge, was the core exit
19 thermocouple information reported to the NRC on March 28, 1979?

20 A To the best of my recollection, it was not.

21 Q Can you recall why?

22 A Well, I am fairly certain that I was not aware of that
23 when I was talking to Don Haverkamp. Again, I am not sure in my
24 own mind if I ever really knew that information in terms of
25 temperature, or if I knew it in terms of DVN values. There was a

1 number of them that just raced all over the place, and therefore
2 you could not put any specific reliability into what they are
3 telling you.

4 My recollection is that it was something that did not
5 give you a whole lot to work with, and I don't recall really
6 thinking about it, or dealing with that information much further
7 for the rest of the day.

8 Q At any time on March 28, 1979, did you monitor, or
9 were you aware of anyone else monitoring the south power neutron
10 detectors?

11 A I don't remember anyone taking a look at that.

12 MR. FISHER: Would this be an appropriate place to take
13 a five minute break?

14 MR. HARPSTER: Sure.

15 (Whereupon, a short recess was taken.)

17

18

19

20

21

22

23

24

25

BY MR. HARPSTER:

Q I quote page 73, line 6: "One of the early conversations was to try to get a readout from the incore thermocouples to determine the temperature conditions inside the core" -- end of quote.

In your I. E. interview on May 3th, 1979, -- and I refer you to page 101 -- you state in reference to your participation in the first Think Tank session after arriving in the Unit 2 control room -- and, I quote: "I do remember, in the first discussion we had, bringing up the incore thermocouples to look at for temperature, and we immediately went up to take a look at those and got them back with question marks on them out of the computer, which really didn't give us any information other than it was perhaps outside the program, so we probably really did have the hot condition in the core.

"In other words, the fact that T hot" -- and, I believe the transcript reflects: Th -- "was offscale was probably valid from the basis of what we saw on the computer" -- end of quote.

On page 153 of this same interview, you state -- and, I quote: "Because of the incore thermocouples had question marks, and that T hot was in excess of six twenty, and we knew what our pressure was,

1 and we knew that we had temperature in excess of the
2 saturation temperature for that pressure" -- end of
3 quote.

4 Given that information that you have
5 testified to in these quotes, what then was your
6 evaluation of the thermocouple data taken by Ivan Porter
7 in the cable spreading room, which included a reading
8 greater than two thousand degrees Fahrenheit?

9 A Sir, I, on that day, did not hear the
10 reading, any of the readings, to the best of my
11 recollection, from Ivan Porter, taken in the cable
12 spreading room.

13 Q Were you aware on March 28th, 1979, that they
14 were taking readings locally in the cable spreading
15 room?

16 A I knew on March 28th, 1979, that Ivan Porter
17 had been sent out of the room to try to get readings
18 somehow.

19 I do not believe that I ever heard the results
20 of any of those readings.

21 Mike Ross, in his Special Inquiry Group
22 deposition, has testified that the incore thermocouples
23 were discussed in the Think Tank at least twice, and
24 maybe four times.

25 Others have testified that there was

1 MR. HARPSTER: Down over the pump lift?

2 THE WITNESS: Yes, which would to me just give an
3 amount of voiding conclusion I guess at that point.

4 MR. HARPSTER: Did anyone go to the isometrics to try
5 and equate this with where you might be at in the core?

6 THE WITNESS: No.

7 BY MR. CRAIG:

8 Q Our review of your testimony indicates that you were
9 aware that hot-leg temperatures were above 700 degrees and that
10 instrumentation bridges had been hooked up so that resistance
11 readings could be used to determine the approximate hot-leg
12 temperatures on 3/26.

13 Was a record kept of the data indicated by this
14 extended scale read-out for the hot-leg temperatures?

15 A A recorded record, a log-keeping book?

16 Q Any kind of a record.

17 A None that I know of, no. I would like to rephrase your
18 statement of my earlier testimony. I was aware of a read-out of
19 over 700 degrees. I wasn't aware that that was a correct
20 temperature. I never agreed that that was a correct temperature
21 at that time.

22 Q You didn't agree with the hot-leg temperature?

23 A I didn't agree that we knew that that was what the
24 temperature was.

25 MR. MOSELEY: With any of the instrumentation even after

ALDERSON REPORTING COMPANY, INC.

1 this bridge was hooked up?

2 THE WITNESS: That is correct. There was speculation
3 and discussions to the effect do we know that those are really
4 going to indicate the correct temperature in the steam ~~line~~. If
5 we had all sat down and remembered everything maybe that we had
6 known earlier maybe we wouldn't have arrived at that speculation,
7 but the question was put forth and that made me as an individual
8 not sure that those were the real temperatures at that point in
9 time.

10 MR. HARPSTER: At what point did you believe them?

11 THE WITNESS: After we had gone up in pressure. That
12 was a fairly obvious conclusion that those temperatures were too
13 high for the 2,000 pounds there.

14 MR. MOSLEY: At this time here (Indicating)?

15 THE WITNESS: Yes.

16 MR. MOSLEY: That is approximately ---

17 THE WITNESS: Nine or ten o'clock.

18 MR. MOSLEY: --- at the 9:30 time.

19 BY MR. CRAIG:

20 Q On 3/23/79 what was your evaluation of the hot-leg
21 temperatures when they sharply increased after the reactor coolant
22 pumps had been shut down?

23 A We didn't know that. We didn't have that piece of
24 information.

25

1 Q Our review of your testimony before the inspection --
2 the Office of Inspection and Enforcement, indicates that you were
3 aware that the core exit thermocouples were being monitored,
4 and that some were reading, and I quote, "pretty high and some
5 were reading 600 and some degrees. A lot of them are not
6 reading or indicating."

7 You also testified that you were aware that millivolt
8 readings of the core exit thermocouples were being taken, and that
9 these readings were as high as approximately 2400 on some thermo-
10 couples.

11 What was your evaluation and meaning of the core
12 exit thermocouple temperatures?

13 A I don't believe I would try to correlate it at all at
14 that point, merely as a piece of information that we were getting
15 as a group or individual, depending on the -- if it were part of
16 the conversation at the time, and that is probably because they
17 didn't tie into the safety system, or part of the normal
18 operating condition. It was just an auxiliary piece of informa-
19 tion for use of anyone.

20 I know very well that the discussion of the temperatures
21 that we were getting again, just like we did on the RTDs, how
22 do we know that these are good, is the conversational pieces
23 that came out, are these really reading correctly? Are they
24 the real temperatures, or do we know that? Do we know we can
25 rely on them?

1 And I know that in that kind of an atmosphere, once
2 you're not sure that the people that are telling you they are
3 right, they are not sure that the information is really correct,
4 you discount it as being information that you don't want to use.

5 Q Did you discuss these temperature readings with John
6 Flint?

7 A I'm not sure that I recall any conversation with John
8 on the temperatures. I'm not sure I can recall that.

9 Q The core exit or the hotleg temperatures either?

10 A Well, John and I, during the course of the day, were
11 discussing hotleg temperatures because we were both reading them
12 trying to see that the actions being taken in the plant would
13 result in getting an indication back in a normal range, and I'm
14 sure we had discussions on the RTDs.

15 Q Did you discuss any time that day the core exit
16 thermocouple readings with the exception of can we really believe
17 them, with Miller, Kunder, Flint, Herbein or Chwastyk?

18 A That's hard to recall at all. The answer to that has
19 to be I don't recall those kind of conversations, no.

20 Q Did you have a conversation with John Flint with
21 respect to the hotleg temperatures that he felt that the
22 temperature indication, both the core exit thermocouples and
23 the hotleg temperatures, sort of backed each other up?

24 A Not that I remember, no.

25 Q Based on your discussions with John Flint, did you

1 Q On the morning of 3/28, were you aware that hotleg
2 temperatures were in excess of the saturation pressures to the
3 corresponding coolant system pressures?

4 A As I stated, not until we got up to pressure.

5 Q And that's again approximately 9:30?

6 A Uh-huh.

7 Q At that point, did you recognize the temperatures in
8 excess of 705 degrees were above the critical temperature for
9 steam and, in fact, meant that the system had contained super-
10 heated steam?

11 A I don't believe I put it all together like that, no.
12 I really didn't arrive at any conclusions from an analysis point
13 of view, no.

14 Q Was superheated steam discussed with you or in your
15 presence on 3/28?

16 A Not that I recall, no.

17 BY MR. MOSELEY:

18 Q Excuse me. Did Rogers -- I mean Flint, talk to you
19 about his conclusions on superheated steam on the morning of
20 March 28th?

21 A I don't remember anybody talking about superheated
22 steam at all during that whole day.

23 BY MR. CRAIG:

24 Q You testified on 3/28 that you were aware that the
25 reactor coolant pumps had been shut off because they were not

1 which I just don't.

2 MR. MOSELEY: I can appreciate that problem.

3 BY MR. CRAIG:

4 Q. Was the fact that the RC drain tank disk had
5 ruptured discussed with Gary Miller? Did you discuss that
6 with him?

7 A. I can't recall whether I discussed it with him or
8 not. If I was aware that it had ruptured at that time, yes,
9 I did tell him, I'm sure.

10 By this I mean if he had told me he was aware that
11 it had ruptured, and again I can't remember when he told me
12 this, whether it was after Miller was there or before, but
13 I'm sure I would have told him.

14 Q. Was information passed on to the NRC, to the best of
15 your knowledge, concerning the fact that the EMOV had been
16 stuck open or that the RC drain tank rupture disk had, in
17 fact, ruptured on the day of the accident?

18 A. Again, I did not have a conversation with them
19 concerning this, and I wouldn't participate in that
20 conversation with him on it, so I don't really remember.

21 Q. To your knowledge, was this information withheld
22 from the NRC on 3-28-79?

23 A. Not to my knowledge.

24 Q. Were you aware that the hot leg temperature was 2700
25 and 800 degrees as measured by Ivan Porter on the digital

1 volt meters and on the multi-point recorder in the control
2 room on 3-28-79?

3 A. I don't remember the readings that Ivan had
4 mentioned. Ivan came through the control room at some point
5 in the accident or in the --

6 BY MR. MOSELEY:

7 Q. I believe you are talking about the core exit
8 thermocouple. He's asking about hot leg temperatures.

9 A. I don't remember any readings on the hot leg
10 temperature that he had hooked up. At the time that Ivan was
11 making his measurements and things, both thermocouples -- I
12 was running the emergency plan for Miller, and as far as the
13 operation of the plant and particularly the parameters
14 affecting the plant, I wasn't really involved in those. Those
15 are things that I heard from being in there.

16 Yes, I can recall those, but some of the things that
17 went on I did not get involved in just because I was doing
18 other things.

19 BY MR. CRAIG:

20 Q. Well, were you aware on the morning of 3-28 that the
21 temperatures were above 620 degrees Fahrenheit, which I
22 believe is the maximum indicated on the front panel?

23 A. At sometime during the day I was, and that was when
24 I mentioned that Ivan came up, because he went down to
25 measure thermocouple temperatures.

1 MR. MOSELEY: Core exit.

2 THE WITNESS: Yes. Because obviously we didn't have
3 any pumps running or stuff like that. It would have been
4 more accurate to get them off the thermocouples core exit.

5 I remember him coming through the control room and
6 mentioning to Miller -- I think it was Miller. Yeah, I'm
7 sure it was -- that he had some awfully high readings and
8 very low readings, the inference being that they were
9 questionable, the readings were questionable. Some of them
10 were very low, some very high, so what did you believe.

11 In that context, I feel I knew that the hot leg
12 temperatures were unreliable up there. They were probably
13 off scale or he wouldn't have taken those.

14 BY MR. MOSELEY:

15 Q. You don't recall either personally seeing or being
16 told that the meter indications of hot leg temperature, which
17 pegged at 620 degrees, were either 620 degrees or the meters
18 were pegged?

19 A. No, I don't. I can't recall that.

20 Q. Do you recall having any knowledge of the hot leg
21 temperatures, the fact they were high, or some indication
22 other than the reference that you made to the core exit
23 thermocouples?

24 A. I don't recall that right now. Now, at the time I
25 may have. I just don't recall right now of seeing that.

1 My big concern at that particular time — now, when
2 I first got there, and the period shortly thereafterwards, I
3 was interested in trying to re-establish flow. That was my
4 main concern, was to re-establish flow. Now, whether I
5 looked at the hot leg/cold leg temperatures or not, I don't
6 remember.

7 Walking across that board, you remember the number
8 of gauges and dials that you have on there. And I was
9 concerned with trying to get the flow back.

10 Also, I must say there were some people that were in
11 front of it. I was trying to stay out of their way, so I was
12 actually behind them.

13 Q. Why were you concerned about getting flow back if
14 you had no feel for temperature?

15 A. Decay heat is there. We have been operating, and a
16 philosophy that had been bred into me, if you try to sustain
17 flow -- I have never been -- natural circulations was a new
18 concept to me, as far as actually coserving it or having a
19 lot of confidence in it. To me, the more desirable
20 situations have forced circulation.

21 BY MR. CRAIG:

22 Q. What was your evaluation of the meaning of super
23 heated steam in the system on 3-28-79?

24 A. My evaluation of it? I never discussed that with
25 anybody. I didn't evaluate it, is what I'm saying. I never

1 considered it, at the time.

2 Q. Did you believe that the loops were steam-bound?

3 A. I don't recall even considering that. I must have.
4 When they said that the pumps weren't pumping water,
5 something was preventing them from pumping it. I would have
6 assumed that I felt there was something in there that was
7 preventing them from pumping. Naturally, something would be
8 steam.

9 But I don't recall -- certainly I didn't discuss
10 that with anybody, nor do I recall it going through my mind,
11 as far as super heating.

12 BY MR. MOSELEY:

13 Q. But there is a difference, I think, between pump
14 cavitation limits that one sees on pumps and a pump that is
15 operating in a steam environment. Did you have the
16 impression that this pump was operating in a steam
17 environment?

18 A. I didn't have any impression because, of course,
19 when I got there the pumps had been secured, or were secured
20 shortly after I got there. And I did not observe their
21 operation.

22 There are different things that can cause a pump to
23 cavitate, as you say. Pressure, low pressure, or steam
24 environment, or whatever. And I did not witness the
25 fluctuation of the current or the flow on the generator, so I

1 BY MR. CRAIG:

2 Q Our review of your testimony indicates that you were
3 aware of hot-leg temperatures in the neighborhood of 740 to 800
4 degrees and that you verified these temperature readings in
5 the 740 to 800 degree range by the instrument, the bridge, by
6 comparing it to a graph. Was a record kept of the data indicated
7 by this extended scale readout device which was connected to the
8 hot-leg RTD?

9 A I don't remember whether there was a record kept of that
10 or not. We have an ISC engineer that was involved in that, and I
11 am not sure whether he did, but I certainly did not.

12 Q On 3/28/79 what was your evaluation of the hot-leg
13 temperatures when they increased sharply after the reactor coolant
14 pumps were shut down?

15 A What time was that again? I am sorry.

16 Q In the morning when you secured the reactor coolant
17 pumps, and I am looking at a graph that was part of the Rogovin
18 Report, and I will show you a copy of it.

19 MR. FIDELL: Let the record show that the witness is
20 looking at a copy of a graph or a series of graphs from the
21 Rogovin Special Inquiry Group Color Plate III.

22 THE WITNESS: I believe that if memory serves me the
23 final pair of reactor coolant pumps were secured at approximately
24 8:41 in the morning.

25 MR. CRAIG: It is four or five down.

ALDERSON REPORTING COMPANY, INC.

1 situation and tried to get ideas as to what to do next as far
2 as the core being cooled for sure was concerned, what certainty
3 we had, et cetera. But I don't recall any direct correlation
4 between that and something to require this action level.
5 We didn't feel we were anywhere near the situation that we would
6 affect the off-site population.

7 Mr. Carlson. In the morning there were actual measurements
8 taken of the incore thermocouple readings besides the question
9 marks that were being printed out by the computer. Were you
10 aware of these measurements?

11 Mr. Zewe. No. I was unaware of those measurements until
12 I believe sometime the next day. Certainly not that day.

13 Mr. Carlson. Were you aware of the containment pressure
14 spike when it occurred that afternoon?

15 Mr. Zewe. Yes. I was. Because I was directly in front
16 of the reactor building core, and I directed the operator at
17 that point to operate the electromatic block valve to open up
18 to further vent down the reactor coolant system because we
19 were into the depressurization point at that time, and we wanted
20 to try and limit the reactor building isolation four point
21 signal, so I was losing a point in time in the pressure where
22 we should open up the vents, and I was directing him to do so,
23 looking at the recorder, and I directed him to open it up and
24 as soon as we did that, we had a pressure spike.

25 Mr. Carlson. Did you hear a thump when that happened?

1 system for core uncover, which would give you the increase in
2 flux at the outer detectors?

3 A Not that I can remember, no.

4 Q In your opinion today, should this increase in count
5 rate and potential for recriticality have been passed on to the
6 NRC on the day of the accident?

7 A Yes.

8 Q To the best of your knowledge, what were the core exit
9 thermocouples used for during normal operation?

10 A Prior to the accident, we did not really use them.
11 They were unavailable in Unit 1, and they were available in Unit
12 and to my knowledge, there were not any existing procedures that
13 really had you use them at all.

14 Q To the best of your knowledge, who would have used
15 the core exit thermocouples?

16 MR. MC BRIDE: On the day of the accident?

17 MR. CRAIG: Previous to the day of the accident.

18 MR. MC BRIDE: Well, that question strikes me as a
19 little odd, because he's just testified that they weren't used.

20 MR. CRAIG: No, he testified that he wasn't aware
21 that they were used. I'll be a little more specific.

22 MR. MC BRIDE: Okay.

23 BY MR. CRAIG:

24 Q I interpreted the response that you didn't believe
25 that they were used, is that Metropolitan Edison personnel didn't

1 temperatures which were measured by the digital voltmeter set
2 up by Mr. Porter were known by Think Tank members and discussed
3 in the meetings.

4 Were you aware that this instruments indicated
5 temperatures of 700 to 800 degrees Fahrenheit?

6 A I was aware they indicated temperatures around 700
7 degrees.

8 Q What was your assessment of these temperatures?
9 What did they mean to you?

10 A They meant to me that I didn't have a cooling method
11 for the core, is what it meant at the time. Today it means
12 something different to me, as it does to any operator. But
13 at the time it meant to me that I didn't have an adequate
14 cooling method in the core.

15 Q And you related it to method rather than coolant
16 available?

17 A I don't think I ever said, oh, I've got a low level.
18 I think I said, hey, I'm not removing the heat.

19 Q Did you at any time on March 28th discuss the
20 implications that you drew of these temperatures with Mr. Miller?

21 A I think we did discuss them in the Think Tank. One
22 of the things we discussed was to establish the cooling method.
23 As you gentlemen know, no place in any procedure in any B&W
24 plant was there an alternate cooling method thought of, like the
25 PORV. That's why we started pushing water through the PORV.

1-6-6

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 Q Okay. You have told us what your assessment of these
2 temperatures were, in the range of 700 to 800. Was the
3 assessment of any of the members of the Think Tank different
4 from your own?

5 A That I can't really say. I can say in our discus-
6 sions, no one jumped up and down and said the core is uncovered.
7 A couple of times the question was raised, are we sure it's
8 covered. But no one related the temperature at that time to
9 either superheat or anything, any of the things we would do
10 today.

11 Q Zewe stated to us a couple of weeks ago that after
12 the DVM was set up, that -- I'm quoting him now -- "We were
13 aware that we were in excess of saturation temperature for
14 the existing pressure."

15 He also goes on to say that he believes that super-
16 heated steam conditions were discussed by the Think Tank.

17 Did you participate in or overhear any discussions
18 about superheating conditions on the morning of 3/28?

19 A I don't recall that we got superheated steam ever
20 being passed. We did discuss and we did look, or have B&W look
21 at some steam tables, and what their analysis was, I don't know.
22 Our analysis was we were too darn hot for where we were for
23 existing pressure.

24 Q Does the term superheat -- maybe that term wasn't
25 used, but the implications that the temperature is beyond what

-2 JWB

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 A Somewhat, yes, sir.

2 Q Did you have reason to recall this prior experience
3 and the use of these on March 28th?

4 A No, I did not.

5 Q Do you know why these thermocouples or alarms are
6 in the computer?

7 A No, I do not.

8 Q To the best of your knowledge, is there any
9 procedure -- Met Ed procedure -- for these thermocouples?

10 A Prior to March 28th, on Unit 1, there definitely
11 is none; on Unit 2, to my knowledge, none.

12 Q Were you aware of anyone monitoring the computer
13 printout of in-core thermocouples during the day of March 28th?

14 A No, sir.

15 Q You were not aware that Flint, for instance, was
16 doing this?

17 A (Nodding in the negative.)

18 Q Your response is "no"?

19 A "No."

20 Q You stated to the Special Inquiry Group that you
21 were in the vicinity when Porter reported to Miller the core
22 exit thermocouple readings which had been taken down below
23 the terminal. Later in the same interview, you say: "They
24 were discussed a couple of times" -- and I'm quoting you.
25 "They were discussed a couple of times, and I can't remember

JWB

1 whether it was just the two times that I remember, or four
2 times, but they were discussed. And each time in the discus-
3 sion, they were discounted."

4 Did the existence of the high temperatures at least
5 imply to you that the core was or had been uncovered?

6 A At the time, they did not.

7 Q Did you discuss or overhear discussions with other
8 think tank members the possibility that these readings could
9 indicate that the core was uncovered?

10 A As I stated before, I was aware of the readings,
11 sir. The span of the readings. I don't remember anybody
12 drawing any analogy to the core coverage based on the
13 thermocouples.

14 Q Do you recall the reasons discussed on March 28th
15 for discounting these thermocouple readings?

16 A Yes. The span was very wide. There were some
17 anywhere from 200 degrees up. It was just a fan. Basically
18 they were discounted because of their span. There were some
19 that were 0, 200°, 40°, it was -- what I got out of what I
20 heard was it was just a real wide area, and no conclusion
21 could be drawn from it.

22 Q Do you recall a discussion that new junctions may
23 have been formed? Do you recall that statement on March 28th?

24 A No, sir. No new junctions. I've heard since
25 March 28th, but not that day; I don't recall.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 654-2345

1 Q You stated to the Special Inquiry Group that you
2 think, or you recall hearing additional thermocouple readings
3 which I, in reading your statement, take that to mean reference
4 to additional readings taken down below at the terminals. And
5 you go on to say that the additional numbers were pretty much
6 the same.

7 A Yes. I don't remember that today, but I remember
8 something vaguely with another set of readings coming in, and
9 they discounted them the same way, and we just went on.

10 Q Can you give me some -- Can you relate that in any
11 way, those additional discussions, to something else that
12 was going on at the time? Or can you enlarge on the state-
13 ment that you have already made?

14 A No, sir; you've got to remember the time span we're
15 involved in here. I cannot.

16 BY MR. GAMBLE:

17 Q Do you recall if it was a large quantity of
18 readings?

19 A I recall it was not a large quantity of readings --
20 and this is a feel for how the thing flowed. I recall a
21 small sampling of readings, is how I put it.

22 BY MR. MOSELEY:

23 Q Do you believe the other discussions were somehow
24 referring to the same set of readings? Or did you have the
25 impression they were additional readings?

1 A My impression was they were additional readings,
2 but I can't say. I know now some things I didn't know then
3 and that's the problem, as you guys know. My impression at
4 the time is that they were additional readings; but where they
5 were taken, I can't nail down because I have some other
6 knowledge now.

7 Q Do you at that time have knowledge that the
8 instrument was left hooked up down below such that it could be
9 read at various times during the day?

10 A No, sir, not down below. We had an instrument
11 hooked up upstairs, but not on the thermocouple.

12 Q And you don't have any knowledge of who may have
13 discussed these readings, or any recollection whatsoever as
14 to who was discussing it and in what context they were
15 discussing it?

16 A The first discussion, Ivan made the discussion and
17 I heard a part of that. Subsequent discussions are kind of
18 like a flowing blur, and I am sure Ivan was part of it.

19 BY MR. GAMBLE:

20 Q In the context of a think tank meeting?

21 A All I remember about the first one, it was out
22 in the control room. That's my best recollection, but you've
23 got to remember that it's 18 months old.

24 Q Right. The first one you believe might have been
25 out in the control room?

1 out in the control room?

2 A That's my first belief. I don't know why I say that;
3 I just say that from something I remember and I don't know what
4 it is. It seems to me it was right out in the control room.

5 Q How about the second one? Do you have any feel
6 for that?

7 A I think they were mentioned just in passing, perhaps,
8 in the think tank.

9 BY MR. MOSELEY:

10 Q You indicated that you have knowledge now, improved
11 knowledge, of what may have gone on in terms of the thermo-
12 couple readings, the ones that were taken down below. What
13 is that? Do you have knowledge that additional readings were
14 taken?

15 A I hear rumors that a lot of things went on down-
16 stairs. I've heard people say that -- I've heard a lot of
17 information that thermocouples were applied, and I've heard a
18 lot of things. I had heard that a complete set was taken, but
19 that's all hearsay information.

20 Q Have you seen the record that was made of a complete
21 set on March 28th, which was subsequently I believe placed on
22 the console and its whereabouts was unknown for some period
23 of time?

24 A I did not.

25 Q You are now aware of this?

1 status of the EMOV?

2 A The discussions I recall in the think-tank
3 involved the use of the block valve and the EMOV for vending
4 off for the plant conditions we were in then and not the
5 plant conditions that had progressed us to that point.

6 Q Your 30-page prepared statement stated that you
7 knew that the hot-leg temperatures were greater than 700
8 degrees after about 6:30 a.m., and that you knew even
9 earlier that the console TH instruments were pegged high.

10 Did you observe or were you told that the expanded
11 scale multipoint recorder printout showed a sharp increase
12 beginning shortly after the pumps were shut down?

13 A Which scale is that?

14 Q That is depicted here (Indicating on chart) during
15 the time period again from 6 to 7 a.m.

16 A Is that the black recorder on the back panel?

17 MR. HARPSTER: It is the one on the back panel,
18 Gary.

19 THE WITNESS: The one that is not necessarily the
20 qualified grade instrument. It is not normally used that
21 much. It has got a lot of points on it. It is hard to read

22 MR. HARPSTER: On the left-side of the console.

23 THE WITNESS: My recollection that I have of that
24 time frame was that we were hooked up on TH with the test
25 instrument. We were using that. There may have been a

1 discussion with me that I don't recall on that black panel
2 recorder. I always thought that the operators had a problem
3 reading that black panel recorder. I knew it was there, but
4 I don't think the RTDs are hooked to the RPSs where we were
5 taking voltage readings that I remember and getting similar
6 data, you know, in the range.

7 BY MR. MOSELEY:

8 Q Did you inquire, or were you told as to what had
9 happened or how the sharp divergence between TH and TC had
10 developed and when it had developed?

11 A I don't recall a discussion of that. I did recall
12 in my testimony I think in that earlier time frame, 7 to 8
13 or 8 to 9 in the morning, a discussion of an evaluation of
14 some heat removal. The TC we would have thought was low
15 because HPI physically comes into the systems, I remember
16 being told, and we would have expected that to respond to
17 that colder water. TH would be on scale. That is one of
18 the reasons we were looking for a temperature device. Plus
19 I think we were using a steam generator pressure or
20 temperature recording instrument. That kind of discussion
21 I remember in the early time frame as far as trying to
22 determine some heat removal capability while we were pumpin
23 the HPI in.

24 Q Early on you asked for a instrument to be set up
25 to expand the scale of the TH indications on the console.

1 Was a record kept of the data from these instruments?

2 A I had a requested that a record be kept. I can't
3 tell you where that is at or whether that was fully
4 implemented, but I had requested that, yes.

5 Q Were you aware on March 28th that it was being
6 kept? Let me go on to say that what I am getting at is was
7 this record looked at or trends or movements or changes in
8 these temperature indications?

9 A There were points during the day when I recall
10 discussions with Ross I believe and some of the group about
11 trending on temperatures, the differences in temperatures
12 and differences in the loops in the temperatures. I can't
13 recall specifics of the discussions, but I think that was a
14 part of some of our think-tank meetings.

15 Q Was Ross or someone else assigned the
16 responsibility for trending these data?

17 A I can't recall who would have been assigned.

18 Q Do you recall that someone was assigned?

19 A I can't recall a specific assignment other than
20 that was a part of the discussions. I can't recall a
21 specific set of words saying you do that trending. I guess
22 I am saying it was implied in the kind of meetings I was
23 having every hour or every two hours to discuss that, to
24 trend it. The assignment could have come from some other
25 level than mine.

1 Q Just to clarify, did you direct or request Mr.
2 Boss to have someone do this?

3 A I can't recall giving a specific direction today.

4 Q In your statement during the Met-Ed group
5 interview, and this was a recording that was made on April
6 12th, you said, and I quote:

7 "Our major concern was that the fuel didn't
8 degrade any more than it had degraded from there on and to
9 somehow figure out how to prevent that and how to stop
10 this. I didn't really feel that we were stopping at the
11 initial stages. I was scared of running out of water. The
12 outside pressure that I was getting indicated that you could
13 just pump this thing solid and I couldn't get it solid. You
14 could have pumped all day, but I am convinced that without
15 pumping water into the hot leg because you had to collapse
16 those bubbles we didn't have a 4,000 pound system."

17 You also stated in your testimony to the Senate
18 investigators on September 28th:

19 "We were pumping at that time or close to that
20 time as high a pressure as we had decided to go, and the
21 water level not changing or not charging the system solid.
22 In fact, we were losing water to the reactor building floor,
23 in other words, very hot superheated conditions."

24 Further in your statement to the Senate
25 investigators on October 29th you stated, and I quote:

1 "Somewhere in the morning, maybe because of Lee
2 Rogers' thrust, there must have been discussion of a
3 superheated condition, but as of today I can't remember
4 that."

5 Later in the same interview you said in another
6 quote:

7 "I think sometime later in the morning we may have
8 discussed steam conditions when we got into the core flood
9 type discussion because we were aware we weren't getting
10 anywhere by charging the plant."

11 You were then asked if you think that perhaps
12 later in the morning the steam conditions were discussed and
13 you responded, and I quote:

14 "I think that is true, and I base that on the fact
15 that I think Lee Rogers and his people may have brought that
16 up. I don't think that that made much difference from an
17 action standpoint. I think we talked about going against
18 the code release, but that is very hard to remember."

19 Now, a final reference. Zewe has stated to us
20 that everyone was aware of superheat after the bridge was
21 set up in on the RPS.

22 Now, my question is, weren't you aware on the
23 morning of March 28th that hot-leg temperatures were in
24 excess of saturation temperature for the corresponding
25 reactor system pressure?

1 A I don't think I can add any more to the quotes
2 that you have given me from what I have said previously.
3 The essence of that was it is hard to remember at which time
4 the steam conditions were exactly discussed, and from an
5 action standpoint the concern was to keep putting water in.

6 Q Does that mean that in the morning of March 18th
7 you were aware that the temperature was in excess of
8 saturation; in other words, there was superheat conditions
9 existing?

10 A I don't understand the question relative to
11 everything you have read back to me. I don't know what I
12 can answer to amplify it any better.

13 Q Would you like to refer to the records?

14 MR. BLAKE: Could we have the question repeated or
15 have him read through it again.

16 THE WITNESS: Please do that.

17 MR. MOSELEY: I apologize for the length of it,
18 but I was trying to capture the essence of several different
19 things.

20 In your statement during the Met-Ed interview on
21 April 12th you stated and I quote:

22 "Our major concern was that the fuel didn't
23 degrade any more than it had degraded from there on, and to
24 somehow figure how to prevent that and how to stop this. I
25 didn't really feel that we were stopping at the initial

stage. I was scared of running out of water. The outside pressure that I was getting indicated that you could just pump this thing solid and I couldn't get it solid. You could have pumped all day, but I am convinced without pumping water in the hot legs because you had to collapse those bubbles we didn't have a 4,000 pound systems."

You also stated in your testimony to the Senate investigators in September, and I quote:

"We were pumping at that time or close to that time as high a pressure as we had decided to go and the water level not changing or not charging the system solid, and in fact we were losing water to the reactor building floor; in other words, very hot superheated conditions."

In your statement to the Senate investigators on October 29 you stated:

"Somewhere in the morning maybe based on Lee Rogers thrust there must have been a discussion of a superheated condition, but as of today I can't remember that."

Later in the same interview you said:

"I think sometime later in the morning we may have discussed steam conditions when we got into the core flood type discussion because we were aware we weren't getting anywhere by charging the plant."

You were then asked if you think that perhaps

1 later in the morning the steam conditions were discussed and
2 you respond:

3 "I think that is true, and I base that on the fact
4 that I think Lee Rogers and his people may have brought that
5 up. I don't think that made much difference from an action
6 standpoint. I think we talked about going against the code
7 release but that is very hard to remember."

8 Then I referred to Zewe's statement that everyone
9 in his view was aware of superheat after the bridge was set
10 up on the RPS system.

11 THE WITNESS: The initial think you read me was
12 out of what interview?

13 MR. MOSELEY: The initial one was out of your
14 group interview with various Met-Ed employees on 4/12.

15 THE WITNESS: Is that the tape that I made?

16 MR. MOSELEY: Yes.

17 THE WITNESS: That tape was made amongst Ross and
18 Zewe and the whole group I believe, right? Was that the
19 tape we are referring to?

20 THE MOSELEY: Let me make sure.

21 THE WITNESS: Because I thought that was the 14th.

22 (Short pause.)

23 MR. MOSELEY: The reference there begins on page
24 28 and 29.

25 THE WITNESS: Bill Zewe's statement of everybody

1 being aware, I am not sure I understand that. From the
2 standpoint of my recollection on April 12th it was certainly
3 better than September or October. I am sure that comes
4 through with some of the statements you have read. I don't
5 believe there was a discussion of superheat in the early
6 hours. I am saying steam conditions were most certainly
7 discussed as a part of the plant conditions in those
8 think-tank sessions, and I can't specifically remember at
9 what point in time that discussion point would have been a
10 strong one.

11 BY MS. MOSELEY:

12 Q Again referring to this, would you conclude that
13 it must have been sometime before the repressurization which
14 occurred between 9 and 10 o'clock?

15 A It could have been that time frame or the time
16 frame of the advertent depressurization which we went
17 through with the thought about the core flood and all. You
18 know, I couldn't pinpoint the exact point quite honestly.

19 Q Is it your statement that you were aware of
20 superheat but you don't know at what time you came to that
21 conclusion? Is that your statement?

22 A I can't remember at what time that point was
23 discussed in the conversations?

24 Q But you were aware of superheat?

25 A Sometime in the morning I think we discussed steam

1 conditions. I don't believe it was at 7:45 or 8:15 in the
2 morning because of the number of other activities that had
3 to take place to implement all the other things that had to
4 occur. At some point in that think-tank Ross or Sellinger
5 or somebody could have discussed that and I wouldn't
6 remember.

7 Q But it was during the morning to the best of your
8 recollection?

9 A I am concluding it was at sometime in the morning
10 because of the conditions we went through in the plant moves
11 we made. That is why.

12 Q Did you on March 28th recognize that temperatures
13 in excess of 705 degrees were above the critical temperature
14 of steam and in fact meant that the system had to contain
15 superheat?

16 A Please ask that again.

17 Q On March 28th did you recognize that temperatures
18 in excess of 705 degrees were above the critical temperature
19 for steam and in fact meant that the system had to contain
20 superheated steam?

21 A I was aware of that, but not as a heavy point of
22 discussion as opposed to the action status and action
23 recommendations and implementation. The conclusion was we
24 had to keep the core cool, and that was the thrust of the
25 pumping of water and looking at heat removal. It was a

1 part of that kind of discussion, yes.

2 Q What was your evaluation of the meaning of
3 superheated steam in the system?

4 A It is very hard to not be clouded by what I have
5 read in the last year or so. I just don't recall
6 discussions of that in those concise terms because the
7 cooling method we were in wasn't recognized anywhere that
8 had ever been studied.

9 The fact that you come in and all the indicators
10 are off scale high wasn't a recognized condition for this
11 reactor plant and it is hard to recall what that meaning was
12 of something that hadn't had much training or discussion in
13 the years of operation. So from a standpoint of what I know
14 today and methods and means of countering this type of
15 problem are different than they were on March 28th. The
16 discussion involved how to cool the core from a condition
17 that we didn't have recognized in any formalized training or
18 implemented document.

19 Q I guess what I am asking, Mr. Miller, is what your
20 evaluation of the meaning of superheat in the system is.
21 Having concluded that there was superheat, and certainly
22 this isn't something that you would have expected, but what
23 was your assessment of this superheat? Did you relate it to
24 core coverage?

25 A I can't today remember in our think-tank

1 discussions the details of those kind of discussions. I
2 just can't remember the evaluation or the conclusions that
3 were reached other than trying to come up with action
4 recommendations from the conditions that existed.

5 Q But I am asking what did you think?

6 A I can't remember what I thought on March 28th any
7 more than what I have said.

8 Q What did you conclude was the source of the
9 superheat, if it wasn't core uncoverage? Again, I am asking
10 what you think.

11 A You know, it is very hard to specifically remember
12 what I thought that day. From the time we got there and
13 started the reactor coolant pumps we knew there wasn't water
14 in the hot legs. Where was the water level at? There was
15 no recognition or instrumentation to tell you that.

16 So what I was thinking was that we had to keep
17 water moving into the core. Where was the level at? We had
18 to make sure we took every precaution through the whole
19 fabric of the thing to keep water moving on to the core, and
20 I can't remember any more of what I thought that day other
21 than the fact that there was recognition that there wasn't a
22 full system. That is why the concern about water. That is
23 why the concern about keeping the water on occurred to me in
24 the early hours. It was the only know method I knew of of
25 assuring core coverage.

1 If you took at the testimony somewhere we were
2 aware that steam pressure was low in the steam generator and
3 therefore natural circulation wasn't very effective. That
4 was aware to us. For the conditions we were in we were no
5 where near saturation pressure in the steam generator. That
6 kind of discussion and conclusion was what I thought on
7 March 28th.

8 To say we had this temperature and therefore we
9 had "X" fuel degradation, I just don't think we had that
10 discussion. We were very clear on the fact that we didn't
11 have a full system, and the recommendations and the thoughts
12 and the conclusions of the think-tank, including my own,
13 were to maintain heat removal and water flow. It was the
14 only thing we knew to do and we were looking at any other
15 action that could be taken to bring the plant to stability.

16 Q But you did not attempt to relate the superheat
17 conditions to what was the cause of this superheat? Am I
18 correct in what you have told me?

19 A I just don't feel we had the evaluation time in
20 the control room to very carefully and calculatingly deduce
21 this is how the plant got to this point. We were concerned
22 about getting it to a recognized point before we discussed
23 how we got it to where it was and what caused it to get
24 there.

25 Everything we did was to try and bring the plant

1 to a stable condition so you could discuss what had happened
2 to the plant. If you had taken the time and critiqued the
3 hours of four to seven in the morning, you wouldn't have
4 been able to perform the emergency plan or handle the plant
5 conditions. We were not in a mode of stability yet.

6 Q It was my impression that that was the purpose of
7 the think-tank was to assess what needed to be done and to
8 assure that that was done, and it is also my impression that
9 one needs to know how you got there in order to know how to
10 get out of it. Do you have a different impression?

11 A I don't have a different impression, but I am
12 saying that the ability to go back in time is somewhat
13 restricted when you are still in a serious condition. So,
14 yes, that is a part of the think-tank purpose, but the other
15 part of the purpose was to figure out what to do the next
16 hour or the next two hours. There was a lot of focus on the
17 requirements of an emergency plan that had to be met with as
18 much importance at that time that the plant had.

19 I am not disagreeing with you, but it is a matter
20 of time and availability of information and the availability
21 of more technical talent. It was, you know, communication
22 with a lot of people who I felt were going to help analyze
23 and to make the next recommendation. That was one of the
24 reasons that the think-tank included the people it did.
25 That is one of the reasons it included the technical

1 people. It included Lee Rogers from B&W. That was the
2 whole purpose of it.

3 Q Do you believe that a very important part of
4 assessing where you go is assessment of how you got there?

5 A I don't disagree with that. I think full
6 assessment while you are in the crisis is hard to arrive at
7 when you are looking at a hundred indications or forty
8 indications and you can come back at a subsequent time and
9 pick the right priority of information to display exactly
10 what happened. I am just saying that the amount of
11 exactness that you can deduce during the crisis is not at
12 the level where you are at today with this chart you have in
13 front of me. The chart took six months to make and I went
14 through a lot of questions and had people in other places
15 for weeks at a time. I am just saying that type of analysis
16 can't be done during a crisis. Yes, I agree with you, but
17 under those conditions.

18 Q Well, we have talked about so far the fact that
19 there was knowledge that the RPISI flow and the problem of
20 let-down flow was increased, the reactor coolant pumps were
21 shut off because they weren't pumping water, the MOV had
22 been opened for some extended period of time, the hot-leg
23 temperatures were significantly higher than one would
24 expect, and in fact were in the superheat condition.

25 Did you infer from these that there was an

1 inventory problem and that the core may be in trouble?

2 A We inferred that there's an inventory problem,
3 and we were certainly aware of some fuel damage because of
4 the readings in the building. But to infer that the core
5 had, say, been empty, we didn't arrive at that point in our
6 minds. I had never discussed that in my whole life prior to
7 March 28th. Therefore I was concerned and action was taken
8 to ensure water went on the core. As to whether the core
9 coverage was of a certain amount based on those things, I
10 can't recall that lucid a discussion of that, other than
11 assurance that the core was kept covered.

12 Q Given these indications, isn't there reason to
13 suspect that it might not be?

14 A There is reason to suspect that it might not be,
15 yes.

16 Q What efforts we made to determine the extent of
17 inventory deficiency on the morning of March 28th?

18 A I guess I don't understand the question.

19 Q There are various ways of inventorying the primary
20 coolant system and from that inferring or calculating the
21 deficiency.

22 A How do you determine the primary coolant system?

23 Q How do you normally do it?

24 A The pressurizer level. We knew that was no good.
25 What else is there? You said that. I don't know that there

1 are many methods of determining primary system inventory.

2 Q I am asking you what did you do on that day? What
3 was done, to your knowledge.

4 A But you stated there were many methods. I am
5 saying that I don't agree with that.

6 Q The question that I asked you was what efforts did
7 you exert on that day to determine this?

8 A From the time we got there and started the reactor
9 coolant pumps and saw them pump a hundred amps we were
10 convinced we didn't have a water level fully in that whole
11 plant. The efforts we had were to assure that the inventory
12 which we couldn't see didn't degrade. I can't remember
13 efforts in the research over how low it had gotten or how
14 deficiency the inventory had been. Today I can't recall
15 discussions along those lines.

16 Q I understand that there were isometric drawings
17 taken out on the basis of the pump performance.

18 A To look at elevations of the plant, where the
19 hot-legs are, where the top of the nozzles are and where the
20 HPI comes in.

21 Q Wouldn't the core exit thermocouples be an
22 indication of core level? Wouldn't the water level be
23 indicated by the nuclear instrumentation and other factors?

24 A Core exit thermocouples weren't even wired out
25 except by a quirk of design. I called for a set of those

1 readings because of my experience in test programs in naval
2 reactors where we used them. They weren't recognized, they
3 weren't in the procedures, their accuracy was in doubt and
4 they were never used to my knowledge in that plant for a
5 core condition.

6 Yes, to day I can very quickly conclude that that
7 is true. I don't believe that was a very rapid conclusion
8 that morning. We looked more towards recognized
9 indicators. That is why we went to the test equipment on
10 the RPS temperatures because they were qualified
11 environmental instruments. The core thermocouples were
12 recognized that I know of. They weren't even wired out in
13 Unit I.

14 MR. STELLO: Norm, I notice you are getting away
15 from the superheated steam. I wonder if we could just chat
16 for a moment, Gary.

17 BY MR. STELLO:

18 Q Normally when you are operating a plant there is a
19 fairly easy way in which to look at where are the hot
20 temperatures, where approximately they are. So if you ask
21 yourself the question do I have superheated steam, given you
22 have talked about it, what do you think about it? You are
23 an engineer. What is going through your mind?

24 A We have overheated something.

25 Q Good. How? What is there in the plant that was

1 capable of generating that high a temperature? Let's try to
2 go through it. You certainly can't do it in the steam
3 generators, right?

4 A You certainly can't.

5 Q There isn't anywhere in the plant where the metal
6 can be hot enough to do it, right? It is higher than any
7 metal temperature we have ever been, true?

8 A True.

9 Q What is left, the core?

10 A The core was the heat source.

11 Q Is it not clear that as an engineer you have to
12 say if I am going to get this steam hotter than saturation I
13 have got to raise metal higher than saturation heat to
14 steam, true?

15 A Or I have got to limit cooling to the core which
16 is normally at a pretty high temperature anyway, the fuel
17 elements themselves.

18 Q That will do it, because you have got water.

19 A We didn't have heat removal. We knew we didn't
20 have good heat removal. We knew that.

21 Q No, no. If you have water and you know you are
22 not going to get superheated steam, if you are transferring
23 heat to water, true? Thermodynamically you can't do it
24 that way. Isn't that true? If the core is covered with
25 water, even if you have poor heat removal, if the heat is

1 going to the water you can't see 700 degree temperatures.

2 A I don't disagree with you. I am not sure of the
3 condition you are in when you have, say, some partial
4 uncoverage and at what point you could end up with hot fuel
5 elements and that type of thing and the exact steam water
6 conditions that would have occurred.

7 Q Okay. But are you saying that in order for you to
8 get superheated steam you really concluded you had to have
9 at some time core uncoverage? The core had to be uncovered?

10 A I guess I am having trouble with -- you know, the
11 plant normally operates with superheated steam coming off
12 the steam generators.

13 Q Out of the steam generators.

14 A Coming out of there with water boiling in there
15 and going up through phases. Now, I am not sure, and never
16 was made that familiar with the conditions that would occur
17 if you start to have conditions in the core where there is
18 superheated regions and ~~superheated~~ boiling regions or what
19 would have occurred in that kind of transition. I am
20 relating it to what I know about a B&W plant.

21 Q But as an engineer you knew in the steam
22 generators the only way you superheat is to have steam in
23 contact with the hot tubes, right?

24 A That is right.

25 Q An analogy then, you have to have steam in contact

1 with the hot fuel elements.

2 A On steam generator you have some level indicators.

3 Q I understand. But I am trying to understand did
4 that analogy allow you to conclude the core is uncovered?

5 A And I can't recall that analogy in discussions on
6 March 28th. You know, I am sure that our discussions were
7 in terms of the inventory deficiency, but I am not sure how
8 far the discussion went relative to the technical terms we
9 are talking of now as far as superheat and lack of
10 superheat, you know what the temperature was and what the
11 degradation of inventory was.

12 Q A few minutes ago you said you clearly knew you
13 busted up fuel.

14 A I said we knew there were some degradation of fuel.

15 Q You busted fuel and you got fission products. I
16 inferred from that that you knew you had poor cooling and
17 the core overheated and busted some fuel, true?

18 A We knew we had some fuel degradation, Vic, and we
19 knew we had insufficient heat removal.

20 Q But I am trying to make certain that you coupled
21 the two. The degradation of the fuel was a result of core
22 cooling.

23 A And I can't remember how close that coupling was
24 on March 28th is what I am trying to say as far as the
25 actual discussion.

1 Q Give me any other interpretation that comes to
2 your mind even now. How do you degrade the core without it
3 being the result of core cooling? Even today can you think
4 of a way?

5 A Of degrading the core without having a lack of
6 core cooling?

7 Q Yes.

8 A No. Unless you are talking of, you know, of some
9 other mechanical damage.

10 Q Oh, yes.

11 A Other than that, right.

12 Q I am talking about the core staying in the fuel
13 without being physically damaged.

14 A Yes.

15 Q So the degradation of the fuel you did couple that
16 morning as a result of the core cooling?

17 A I am saying I can't remember the coupling of that
18 in the discussions of that morning. I can't honestly
19 remember the nice tie we have just discussed.

20 Q I am not looking for nice ties. I am looking for
21 can you conclude anything other than that you knew you had
22 busted fuel somehow, that that was a result of poor
23 cooling? Is it reasonable to conclude that that was
24 understood by the people that were analyzing the problem
25 then?

1 A At some point in the morning that was certainly
2 understood and it is one of the reasons we asked for flow
3 rate from B&W for decay heat, the same reason. How much
4 heat removal do I need for what we are at.

5 Q Good. Now, let me try again looking at the
6 superheat. What do you think was the nature of the core
7 cooling? Describe for me how can you get core cooling in
8 the reactor some two hours after shutdown? What does it
9 mean to you. What does core cooling mean?

10 A Well, core cooling to me means that we knew
11 natural circulation was adequate for the design of the plant
12 and we weren't getting adequate natural circulation. Beyond
13 that point on March 28th I don't believe there was any
14 information available other than the stuff you knew you had,
15 to pump water in it at the flow rates you had available.

16 Q Yes, but I am trying to get you to help me
17 understand poor cooling of the core. What does that mean to
18 you?

19 A And I am saying that what it means is that we were
20 out of a recognized cooling mode and therefore we knew that
21 we had to have more cooling. We didn't know how much more.

22 Q Gary, we are passing each other in the night.
23 Core cooling, let me give you some things that come to my
24 mind. The flow rate in the core was lower than it should
25 be. There was not enough water. I had steam in the core

1 with water. I had steam blanketed fuel. These to me are
2 concepts of inadequate cooling. Are they the kinds of
3 things that you think are inadequate for cooling?

4 A Those are kinds of things that I would connect
5 with that, yes.

6 Q Was any of that connection made during the day,
7 core uncover, steam there?

8 A And I am having a hard time recognizing whether we
9 discussed that specifically or at what point in the day it
10 coupled the way you have, Vic.

11 Q You had a lot of people in the control room.

12 A We didn't have a lot of people in the think-tank
13 though.

14 Q No, but in the control room who hopefully were
15 feeding information to the people there, or I hope that was
16 the management concept you were working under.

17 A That was the management concept.

18 Q Good. Of all of those people that somebody didn't
19 say, hey, if you have got superheated steam there ain't but
20 one way to get it. The core has got to be uncovered. That
21 kind of conclusion never popped up all morning?

22 A In the think-tank meetings, hey, the core is
23 uncovered was not, you know, wasn't brought out to that
24 degree.

25 Q Was it brought out to any degree?

4

1 A The amount of core uncoverage was not, to my
2 knowledge, discussed specifically as much as how do we
3 maintain water in there.

4 Q Gary, not amount, because I can't tell you that
5 even today, how much. Not degree; concept. Core uncoverage
6 caused superheated steam. Did anybody hint at, suggest at,
7 and then you would quickly come to the conclusion I have got
8 to get more water in, right, which you did come to?

9 A As far as the conclusion to get more water in, you
10 know, the recognition early in the morning of inadequate
11 natural circulation left you only one way of doing
12 anything. That was arrived at without even having to have
13 the other discussion you are talking about. We had to put
14 water in. There was nothing else available. It doesn't
15 matter what the conditions were. At 8:30 in the morning I
16 said put water on now even though people were saying don't
17 put water on.

18 Q Because you needed natural circulation.

19 A People that were out in the control room. That is
20 right.

21 Q That is what I am trying to say. That is clear to
22 me.

23 A And it was clear to me, not even needing to know
24 temperatures, just needing to know the steam pressure.

25 Q I understand that, but did you also know that you

1 weren't at that time getting enough water, there wasn't
2 enough water because of superheat?

3 A I didn't know how much water I needed.

4 Q I understand that, too. Do you understand my
5 question? Was there anyone coupling the only way to get
6 superheat was core uncover? Did anybody suggest it?

7 A And I can't remember that. As of today I can't
8 remember that being suggested clearly at any point at least
9 in the early hours in the morning.

10 Q Forget the early hours. At any time that day.
11 Don't put time constraints on it.

12 A I can't remember. You are right, I shouldn't put
13 time constraints. I can't remember it in the afternoon
14 either. You are right.

15 Q I find that very hard to understand that here you
16 are stuck with temperatures that the only way to get them is
17 to have a metal, a heat source beyond anything you ever had
18 in normal operation. You know, the coupling, at least the
19 question is the core uncovered.

20 A Or the question we were asking is is the core
21 covered now. That is the question. We weren't asking has
22 the core been uncovered in the early hours. We were asking
23 how do you keep the core covered now.

24 Q Right.

25 A That is what we were asking ourselves.

1 Q Right.

2 A Using the only systems and methods we had. That
3 is where we were at.

4 Q And how do you know if it is covered?

5 A How do you know?

6 Q Right. If there is superheated steam you should
7 have a question about it. Today you know that for sure.

8 A Today there is a whole wealth of ways of handling
9 this based on this.

10 Q Agreed, but that is not a very sophisticated
11 concept. With all the people there I am trying to
12 understanding how it would be that nobody brings it up. To
13 day that you had superheated steam and then drop it doesn't
14 seem rationale to us. All of us bureaucrats sitting on our
15 duffs in Washington, that is what we were fussing about.

16 A And I think at the time of the crisis, Vic, I
17 really believe we were trying to look for anything that
18 would tell us any other method of arriving at stability more
19 than the coupling you are talking about. Do you know what I
20 am saying? We are saying what else can be done in the plant
21 and what else do we need to do in the plant.

22 Q Let me try one more way. You had a concern and
23 you wanted to put water in. You knew you had busted up some
24 fuel and you knew you weren't getting enough coolant. Those
25 were things you clearly understood that morning, right?

1 A Yes.

2 Q Okay. The only thing you could think you could
3 think of is turn on the pumps and put more water in, right,
4 as an engineer?

5 A As an engineer with some knowledge of the plant
6 that was the only method I knew available.

7 Q As an engineering then wouldn't the next question
8 be how do I find out if that was effective? Did that
9 thought enter you mind?

10 A The thought that entered my mind is how do we
11 determine how much heat removal we need versus much we are
12 putting in, yes.

13 Q What did you consider to be indicators of whether
14 you were being successful or not?

15 A I think we have gone through that. We looked at
16 temperatures in the RCS, we looked at the steam generator
17 pressure and we put an indicator or an a test instrument on
18 the RPS on the hot legs if I remember right. We put that on
19 there because the on-scale meter was off.

20 Q Slow down.

21 A Okay.

22 Q You wanted to look at that temperature. What were
23 you expected it to do?

24 A At the initial stages of looking at it, Vic, there
25 was no high temperature on scale available, so the initial

1 idea was to get some reading in addition to the other
2 information.

3 Q You had a reading then. What were you expecting
4 that reading to do as you added more and more water?

5 A As we added more and more water throughout the day
6 we were expecting that reading to come down.

7 Q So if it stayed superheat it was clear then, was
8 it not, that it wasn't covered with water? Those RTDs took
9 the drawings out and you looked at them, should you not have
10 concluded they weren't covered with water?

11 A Hot-leg RTDs I think are located up above the
12 coolant.

13 Q Yes, the are in that straight run area.

14 A I think that even early in the morning when the
15 pumps started and we looked at the level we knew there was
16 water missing out of the hot legs, yes.

17 Q But my point being that as you kept adding water
18 you knew you never got those thermocouples covered?

19 A I think we knew that those were in a steam
20 condition of some type because I think there was some
21 discussion at some point during the day about how accurate
22 were they in a steam environment versus their qualification
23 which was in a water environment, that type of thing. I
24 mean, I think there was that kind of recognition.

25 A That means you had that part of the system empty

1 of water. So you should add more water. What is another
2 thing that ought to come in your mind? Is there any other
3 indicator? You had this Navy training with the in-core
4 thermocouples. Were you thinking they might tell you if you
5 covered the core back up?

6 A Either me or Lee asked for those initially because
7 that was a part of the initial getting of some indication.

8 Q Indication of what, Gary?

9 A Of temperature. You know, when you go in and you
10 look at the panel on TH which is off scale high we began to
11 look for an instrument on the high end. That is my memory
12 of their initial, you know, why we started looking for, you
13 know, some indicator. And once we had at least an
14 indicator, I don't believe the in-cores were really a point
15 of our discussion any more.

16 Q You never thought of the in-cores as an indicator
17 of water level, that they weren't covered with water?

18 A I don't believe I did, no. I asked for them, and
19 then by the time I got information on them they seemed
20 useless to me because the conversation indicated they
21 weren't reliable. At the same time we got the RTD hooked up
22 to a bridge and that was giving some information.

23 Q On the hot leg?

24 A That is right. But you are asking about heat
25 removal, and I am saying that that was one. There was steam

1 generator down cover we were using, there was steam
2 generator pressure we were using and we were looking at heat
3 removal determination, yes.

4 Q But you looked at the RTDs and concluded that that
5 was also a level indicator, that they were in a steam
6 environment.

7 A I didn't say we concluded it was a level
8 indicator. I am saying that just starting the pumps before
9 that instrument was available I think told us that we
10 weren't going to have a water environment on those RTDs
11 because they are up in the hot leg.

12 Q Okay, so they were in steam. That is what I mean.

13 A And there was even discussion I think of the
14 accuracy of gross versus fine, you know. That is a
15 qualified instrument.

16 Q But you didn't have that same thought with the ---

17 A Didn't even consider them qualified. I mean, in
18 my mind. Had they come back with a consistent set of
19 readings on them that I was aware of then I might have
20 changed my thought process on the in-cores. But I have said
21 before when they came back, you know, there was nothing at
22 all that I could see from them. What came back to me said
23 there is one here, there is one zero, there is one there.
24 It would have been tough to pick the one I was going to use
25 to believe.

1 Q It could have been another connection to
2 superheated steam.

3 A It could have been another connection for
4 superheated steam.

5 Q But that was not made?

6 A It was not made.

7 Q By anyone?

8 A By anyone that I am aware of.

9 Q It could have been an indication of core
10 uncover. That was also not made.

11 A To my knowledge, it was not made. They do sit
12 above the active core though. You mean from the standpoint
13 of the steam ---

14 Q That those thermocouples were uncovered, that was
15 never brought up?

16 A That I don't remember being brought up. We were
17 aware that the RTD was uncovered because we knew where they
18 were at and we knew when we got the elevation drawings out
19 and we knew when the pumps didn't run and we knew the hot
20 legs were not full of water.

21 Q But you made no analysis?

22 A We didn't make an analysis. We didn't go back and
23 discuss the in-cores. That is exactly what I remember. We
24 did not go back on the think-tank or myself even, my inputs
25 for them didn't come back to me. I got those things and I

1 was told they were unreliable and I guess I did not pursue
2 and question the in-cores further once I got the initial
3 shot from one of the people that they were not reliable.

4 Q Okay. Let me ask you now without trying to recall
5 a specific conversation with anyone or anything else. In
6 your mind as you search back now, was there ever a time in
7 the day when you believed the core was uncovered?

8 A As I search back, Vic, I can't honestly remember
9 what point of level I thought the system was at, including
10 the core.

11 Q I am not talking about the degree. Did you ever
12 believe the core to be uncovered? By that I mean the water
13 level, two phase, dropped into the core somewhere? That is
14 the top to the middle, I could care less. Just the fact
15 that it was uncovered. Did that enter your mind?

16 A And I can recall specifically the thoughts of that
17 day.

18 Q That is what I am trying to tell you. Don't try
19 to get specific, just your general impression of how you
20 felt.

21 A I think the general impression was that there was
22 a possibility of some level near the top or maybe partially
23 -- you know, I am saying I think there was thought of some
24 minimum uncoverage as opposed to an empty core.

25 Q The degree is not ---

1 A But the degree is where we were at as far as heat
2 removal.

3 Q Not the degree to which it was uncovered, but
4 whether or not it was uncovered.

5 A I don't believe we felt that if it was uncovered
6 that it was of any magnitude is what I am trying to say,
7 Vic. We might have believed that there was some steam
8 environment on the top of the fuel rods, is what I am saying
9 as opposed to, you know, is the core uncovered. We didn't
10 believe that we were doing anything that was going to put us
11 any further than we were, and that is the best I can do.

12 MR. STELLO: Okay.

13 MR. HARPSTER: Gary, help me out a little bit.
14 One of the things in looking back at this and reviewing the
15 testimony we got into some confusion. When you got down to
16 the trying to start the reactor coolant pumps and obviously
17 you had the low steam pressure in the hot leg, and you saw
18 the hundred amps and from that you tried to draw some
19 conclusion about what the state of your system was. I
20 believe you said was you got out the isometrics now and were
21 trying to draw some inference from that. Do you recall who
22 checked the isometrics?

23 THE WITNESS: I think Ross and Sellinger. That
24 means they were probably out by the computer console and
25 there could have been Zewe and other people there, but I am

1 pretty sure Ross and Sellinger would have been technically
2 the two that were talking to me. That is what I think,
3 Terry.

4 BY MR. HARPSTER:

5 Q George Kunder in his testimony ---

6 A And he could have been another one. It is just
7 the name slipped me.

8 Q George has expressed the concern many times that
9 that morning his belief was that the core was being cooled
10 by steam. In fact he was concerned about building up a
11 boron slurry down there because of the steam.

12 A He was there in the early, early hours. At five
13 in the morning he was there. And he has said that at the
14 point of time of 6:30, somewhere in there.

15 Q But he goes on in his testimony to say he has had
16 this concern throughout the morning and he can never assure
17 himself that he not cooling the core by steam, and in fact
18 when he talks with us at 9:30 in the morning he describes
19 the core as being cooled by superheated steam, some
20 superheated steam mechanism. Did he discuss that in the
21 think-tank that day?

22 A I don't believe so.

23 MR. BLAKE: If there is a question about the time
24 here, Terry, it might help to pull out these Kunder
25 statements that you are referring to.

1 MR. HARPSTER: We have conflicts in the testimony
2 and I am trying to understand what concerns were raised with
3 the think-tank. We have Mr. Kunder with the concern in his
4 testimony that the core is being cooled by steam and is
5 uncovered.

6 MR. BLAKE: To the extent there is a time
7 difference in what he recalls, if we have George's statement
8 here maybe we could take a look at it and sort that out.

9 MR. HARPSTER: I do have George's statement.

10 MR. BLAKE: Maybe we could take a break and look
11 at it.

12 MR. MOSELEY: We are almost ready to go into
13 another subject so I think it would be a convenient time to
14 take a break.

15 MR. HARPSTER: I was just trying to see if Gary
16 recalls George expressing his concern.

17 THE WITNESS: I do not.

18 MR. MOSELEY: Let's take about 10 minutes.

19 (Whereupon, a short recess was taken.)

20

21

22

23

24

25

1 KUNDER: I had thought yeah, I think it was the B loop pumps, because I
2 recalled the flow went down in the B-loop pumps. I believe that they
3 secured the B-loops so that we could still have adequate spray flow and the
4 A-loop gives you more pressure and you get better spray flow, gives you
5 better pressurizer spray control. But at any rate, we finally ended the
6 conversation and Gary and Lee Rogers said they were coming. Joe Logan I
7 think was the first Senior person to come into the Control Room. Best to
8 my recollection we had already secured one set of pumps by the time Joe came
9 in and it was about the same time frame that when, it was either about the
10 time he came in or shortly thereafter that we secured the second set of
11 pumps, because the flow was starting to degrade on the console flow indicator.
12 I seem to recall that it was the flow in the A-loop, two pumps running was
13 up above 60% on the indicator and the flow was degrading and had degraded
14 somewhere I think in the region around 30% so it was clear to me that flow
15 was decreasing and that it was thought we were cavitating. So, the Shift-
16 supervisor secured that set of pumps expecting to go on natural circulation
17 because the pressure was low and we didn't want run into cavitation problems
18 with the pumps. I guess prior to that point I started to get into a dif-
19 ferent thought process, I had a, Bubba Marshall had come into the control
20 room, and Scott Wilkerson was still there and I had asked to have a shutdown
21 margin calculation performed and I wanted to get the boron concentration
22 from the system. I had asked Bubba Marshall to call the lab and get a
23 boron pretty quick. Again I was sort of concern where this water was
24 coming from but at that point I still felt, it still appeared to me that
25 somehow we other water in the system and I didn't know where it had come

1 from. Cause the operators had indicated to me that they didn't have high-
2 pressure injection on for that long that it would have filled the system up
3 and we would have gone solid. I didn't understand that. I had a, let me
4 think. Dick Dubiel had arrived and I told him that I had asked for that
5 boron sample and asked if he'd go down and coordinate and make sure we get
6 the boron sample, get the results of them and I guess it was an interim
7 period of perhaps 15-20 minutes or 30 minutes before Dick got back to me.
8 This was probably close to, when I asked Dick to go down and check on
9 getting the sample I believe it was around between 6:00 and 6:15 that sort
10 of thing, so it would have taken then a certain period of time and by that
11 technicians may have been getting a sample cause that had been asked for a
12 little bit earlier. Dick had called up to me, and I believe it was around
13 6:35 or so maybe 6:40 and he called up the result, and he said the first, I
14 think he said the first two samples indicated 700 ppm boron and he said the
15 next sample he didn't think that was right so they had another sample that
16 was 400 or something, I don't recall the exact numbers but that change all
17 of a sudden really frightened me, because I thought I hope that's a bad
18 sample analysis because I couldn't at that point I started to think my God,
19 maybe were getting demineral water in through some flowpath, I just don't
20 understand.

21 KIRKPATRICK: This was really only a few minutes after the second set of
22 pumps were cut off, probably around 6:30?
23
24
25

KUNDER: It was to far from that time frame. I didn't know what initial boron was I walked over to the status board and it was a little over a 1000 ppms that was the boron concentration that we should have been at at that point in time, then the thought went through my mind, Oh my God, were deboring the system and I told them you got to get another sample and tell me whats wrong, at that point I asked Bubba Bubba Marshall, that is to start looking at the Unit 2 system and see if there's anyway possible we could be getting demineralized water into the system. Then again the primary side I just was not familiar enough with over in Unit 2 and although the basic B&W system is the same, the interconnections and rad waste system are totally different between Unit 1 and Unit 2 and I had very little feel for the various system the configurations and soforth and how we could be getting demineralized water so I went through my head, maybe we had demineralized water in BWST and somehow we may have this in our sample analysis, but nonetheless Bill Zewe initiated emergency boration at that as a precaution. At that point, I knew something was really, really wrong and at some point in time in that same timeframe I was alerted or I even noticed or somebody mentioned that the NIs were kind of high, I went over a looked at sources ranges instrumentation and the source ranges were reading in the range of about 10^5 counts, intermediate range had come onscale and it was about half a decade to almost a decade onscale. The only thing that was going through mind at that point, is that the reactor had gone critical again. I didn't understand what was really happening, I think I understand now, we think we understood after the fact we seen, but at that point in time I thought my God we've been deboring the system, somehow that's how

1 we've been getting all the water in the system and we taken the reactor
2 critical, so I started to urge, we got to get high-pressure injection back
3 on, we got to get some borated water, what we thought was borated water
4 back into the system and Mike Ross was in the Control Room at the time. I
5 remember him commenting to me George we got to do something because, there
6 was a, the guys just set there at console and I guess Joe Logan just weren't
7 sure of what the next step was and all I could think of was get that damn
8 high-pressure injection on, that was the only thing I could think of.
9 There was nothing else to do except to get some borated water into the
10 system until we understand what was going on. And so we did initiate high-
11 pressure injection and I seem to recall I even yelled it out, get it on, I
12 don't care, we got to get that thing initiated and now. So that was done,
13 immediately after we asked for it and continued thereafter. Dick called up
14 very shortly thereafter and I heard him screaming over the page George Kunder.
15 George Kunder, line one and I answered. Dick said, George the sample line
16 had just went up up to 600 mR/hr, and at that point I realize oh my god
17 were failing fuel and I yelled at Joe, I said Joe were failing fuel, Dick
18 gots 600 mR/hr at the sample lines and that was right around 6:45 in that
19 region and I said hey were into site emergency, its the real thing and site
20 emergency was declared. I turned around and told Ron Warren and Dick
21 Bensil and who had been in the Control Room, .. oh I think just before that
22 Ivan Porter who's my lead I&C engineer had come into the Control Room and I
23 briefed him on what had happended, on what the plant was doing and I seem
24 to recall, I may have mentioned something about failed fuel, we were getting
25 high activity in the system and that was all pretty much around the same

1 time frame, but I do recall telling Ron Warren who had been in there and
2 Dick Bensil to get on the phone and start making the phones calls and we
3 went into the emergency procedures and began the emergency response and I
4 don't know, at that time I really started to just starting reacting to the
5 condition and really getting it clear in mind, we were in a real emergency
6 situation and we got to initiate the emergency plan and you know from that
7 point on I was, I don't know how to put it, just keyed up to carry out
8 those emergency plans and keeping the plant in a safe condition. Bill Zewe
9 as I recall pretty much directed his attention to the console and it was
10 around the same time frame that Gary Miller came in, I think he came in, he
11 definately came in after the site emergency was declared, Joe Logan was the
12 Senior guy at the time the site emergency was declared and Gary came in I
13 would estimate 15 minutes or so after the site emergency was initiated and
14 Gary took charge of the emergency as Emergency Director and the emergency
15 teams were formulated. I basically was responsible at that point to work
16 for Joe Logan, carry out any technical activities he needed, make sure
17 communications was established with the State, that was my first concern,
18 to get hold of the Civil Defense and I did put two engineers on it, because
19 through previous emergency drills it just takes a long time to make all the
20 phone calls. The first one of course is to the Civil Defense Duty Officer
21 and maintenance times that goes to get them notified so they could notify
22 the Bureau of Radiological Health and get that part of the plan moving.

23 SHACKLETON: At this time we'll end this tape, its 9:02 p.m., April 24,
24 1979 and we come on other tape.
25

1 SHACKLETON: This is a continuation of the interview of Mr. George A. Kunder.
2 Time is now 9:05 p.m., April 25, 1979.

3
4 KIRKPATRICK: George you were, you had just commented that you had starting
5 making the appropriate calls, Joe Logan was the Senior man on site at that
6 time. Does that make him the Site Emergency Director? And shortly, then,
7 Gary Miller came in. At that time does he assume the ...?

8
9 KUNDER: He did. Gary first appraised himself of the plant conditions and
10 what we had and Gary, I thought, very forcefully took over as the Emergency
11 Director. He announced it, and he indicated that he, myself, Logan, I
12 think he said Ross, and I know he said Deibel were the guys that talked to
13 him, to try and establish good clear communications paths with the people
14 in the Control Room. And there was the... communications were being estab-
15 lished by someone else between the control room and the emergency control
16 station. In otherwords, between ECC and ECS. I was pretty much making
17 sure that the calls were being made to the offsite people and we got some-
18 one... I can't remember who it was anymore... to keep the emergency status
19 board and I wanted to make darn sure that we go the information from the
20 callers, Ron Warren and Dick Bensei, out to the emergency board. That
21 worked fairly well. We had clearly identified who was called at what time.
22 In fact, there was a photograph made of that, so we wouldn't lose that
23 information. That part of the drill got started fairly well.
24
25

1 KIRKPATRICK: Step back a minute, I want to keep the emergency in mind, I
2 want to ask you earlier about the conference call between yourself and Jack
3 Herbein and Gary. Did you keep a log of that or is there a record of your
4 call?

5
6 KUNDER: No. I did not keep a record, Jack or someone on their end may
7 have kept some notes.

8
9 KIRKPATRICK: We're down to the point where the emergency has been declared
10 now. If my sequence is correct, the emergency occurred, you saw radiation
11 increase when Mr. Debiel was down in the lab.

12
13 KUNDER: Dick saw the increase down there. When he told me what his problem
14 was, it was within seconds that the alarms in the back panels of the RMS
15 starting coming in. At this time in my training, I'm not familiar with
16 which alarms go to which area, but I saw the alert and the alarm lights
17 coming in and they all started coming in very, very quickly. I knew that
18 there was probably a dome monitor in each unit. I was not aware that there
19 was other monitors in the reactor building. I'm not sure what they did,
20 but the alarms for the area monitors or the atmospheric monitors in the
21 Auxiliary Building or fuel handling building were apparently going off. A
22 lot of alarms were coming in.

23 KIRKPATRICK: Were you aware they started the reactor coolant pump at that
24 time, or do you recall that?
25

1 KUNDER: I was aware that the coolant pump was attempted to be started. I
2 thought it was only started one time. But I learned a little later that
3 they had tried to start one and it didn't work out, but I observed when
4 they started the--let me think, I think it was the 2B pump, if I'm not
5 mistaken. There was one control switch in the far right. They started the
6 pump, the indicating light was red. I looked at the flow indicator, it
7 read zero. And I seem to recall Mike Ross and Zewe wondering if it was
8 really running. They called for someone to go down to the switchgear and
9 check to see if the breaker was closed. And you know they said it was, and
10 they recognized it probably was running, but you know it was just pumping
11 steam up. There was just no water in the pump and that is why we didn't
12 see the flow indication. About this same time by the way, the intermediate
13 range counts dropped off.

14 KIRKPATRICK: Did that give you any kinda--did somebody report that to you,
15 for instance, or were you watching your intermediate range?
16

17 KUNDER: I wasn't watching. I looked at it just after it went down, just
18 to verify that it was going down?
19

20 KIRKPATRICK: What does that mean to you? At the time, I mean?
21

22 KUNDER: At the time I was sort of relieved, but I still didn't fully
23 understand what we were seeing. I think it was later on when John Kenna,
24 of B&W, had been in the control room that he mentioned that probably was
25

1 due to the fact that we had the core uncovered, and that the the neutron
2 leakage output to the out-of-core detectors was greater, and we were seeing
3 the higher count rate. And that all correlated. You know, after the fact
4 you start thinking about this, and then it fowls up your memory a little
5 bit, because you know--I wasn't--you almost think you recognized it at the
6 time but I don't think I really did. I did not recognize why the counts
7 went down.

8
9 KIRKPATRICK: During the period the pump was off, somebody...

10
11 KUNDER: Excuse me. I think probably what's going through my mind is the
12 high pressure injection was having some effect, but I just can't recall
13 exactly.

14
15 KIRKPATRICK: During the time you had the high pressure injection going in
16 at the normal rate, 200 and some gallons per leg.

17
18 KUNDER: 250.

19
20 KIRKPATRICK: 250, ok. So you felt that would be boron water? Cooling
21 water?

22
23 KUNDER: Right, it would be 2270 ppm.
24
25

1 that called for site emergency.

2 I don't recall exactly what they were doing at that
3 point. Our gears shifted into responding to the emergency
4 condition, and I became involved with assuring that our emergency
5 plan was implemented at that point.

6 I do remember the conversation with John Flint, but
7 that was after we had achieved the general perception that we
8 were having steam voiding in the system, and his explanation or
9 his conclusion as to why we saw the indications we did made sense.
10 They were consistent with what we felt existed in the system.

11 We felt that we had steam and then we did not have
12 the moderation that we normally would have for the neutrons.

13 Q Did you at any time on March 28, 1979, discuss the
14 apparent return to criticality with the subsequent inferences of
15 core uncovering or voiding with Messrs. Miller, Rogers, Herbein,
16 Zewe, or Chwastyk?

17 A I don't remember any discussions.

18 Q To the best of your knowledge, was the count rate
19 behavior or apparent re-criticality reported to the NRC on March
20 28?

21 A I don't remember if that was reported or not. Again,
22 it would be in the tape if I did. If I didn't, it didn't represent
23 a significant item at the time that I had the conversation because
24 the rate count did come down.

25 I don't remember if I associated the increase in the

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20021 (202) 654-2346

1 count rate with the voiding prior to my conversation with the NRC
2 or if that came afterwards. But, the time frame was that it would
3 have been just after John Flint came in the control room that I
4 became aware of the connection between the two.

5 Q In your opinion today, should the information regarding
6 the count rate behavior have been passed along to the NRC or the
7 inferences from it?

8 A All the information that was available should have been
9 passed along to the NRC. At the time, I believed that I had
10 passed on all the information that was available and pertinent
11 within the time frame that I had to discuss it over the phone.

12 BY MR. MOSELEY:

13 Q Let's go back a little to the discussion of Flint's
14 conclusion of the voiding. You were asked if you discussed with
15 some named individuals, was that discussed in the think tank with
16 the management group, to the best of your knowledge?

17 A I don't remember it being discussed. I suspect that
18 by the time we really got into the management team environment that
19 that was a parameter that was passed, and not of immediate concern.
20 It may have been because by that time I had linked the two
21 together in my own mind. I cannot be sure.

22 BY MR. HARPSTER:

23 Q Let me ask you some questions about the in-core
24 instrumentation, George.

25 To the best of your knowledge, what are the core exist-

1 thermocouples used for during normal operations?

2 MR. McBRIDE: At Unit I, at Unit II, or in power plants
3 in general?

4 BY MR. HARPSTER:

5 Q At Unit II.

6 A Now, I am aware that they are used, if anything, for
7 diagnostic reasons.

8 Q I am sorry, prior to the accident.

9 A I don't remember thinking about them prior to the
10 accident.

11 Q Had you had any training on in-core thermocouples at
12 all?

13 A Just the fact that they existed. I was aware of that.
14 But at their termination, they don't go anywhere.

15 Q Are you aware of any other station personnel who would
16 have had training on the in-core thermocouples?

17 A Well, when you say, training on in-core thermocouples,
18 do you mean were there other people who were aware that they
19 existed?

20 Q I was thinking more of training in their use, what they
21 might be used for.

22 A The instrumentation engineers that I became responsible
23 to supervise when I came over to Unit II, of course, were familiar
24 with the fact that they were installed and presumably they knew
25 that they were hooked up.

Logan: Abnormal pump configuration and normally you would want to maintain as much flow as you could through the core to remove the heat.

Hunter: I understand that. I tried to ascertain can you recall then after coming in and maybe talking with Bill with looking the charts over in the control room and then talking with George Kunder do you recall the two more pumps being secured while you were there within the first few minutes?

Logan: Right now I can't recall whether that happened before or after I got there.

Hunter: Did you spend some time Joe with Bill Zewe that morning you know when he came in discussing the plant conditions?

Logan: I didn't have much of an opportunity because when this... My first intention was to see that the calls had been made this was an abnormal situation and I wanted to make sure that one, Miller had been called and informed of the situation. I walked back out Zewe was having problems trying to get this thing under control because of the abnormal indications and my mind is kind of hazey right now as to what went on at that particular time you know trying to decide what we should do. I do recall we tried to start a pump. I can't remember if it was shortly after I got there or not but we had received a report sometime shortly after I got there of a boron sample which indicated a low boron content and as I recall we were concerned whether we were getting an accurate sample. The results were I think were around 700 dpm when we

were running at that time around slightly over 1000 dpm so the concern here was that an accurate sample or not. As I recall we also had an indication about that time of an increase on our source and intermediate range meters. George Kunder I know had was concerned that we might actually that could perhaps have been an accurate indication and as I recall I believe we reinitiated, or we initiated emergency injection they had initiated this before and secured it. I might point out in previous reactor trips we had initiated high pressure injection and subsequently corresponding with that high pressure injection we have the you know sodium hydroxide injection also and this has caused us considerable problems of course in removing the sodium from the plant and they secured the high pressure injection ... I'm getting this ... from Talks that I had with them after this occurred of course, they had secure that when the pressurizer started filling up you know. That indicated that they certainly had enough water in there and they didn't want to put anymore sodium hydroxide in the plant and they secured both the sodium hydroxide and the BWST, the high pressure injection.

Hunter: Okay. When you had discussed with George Kunder earlier you indicated you had discussed the reactor coolant pumps, the problem with the pumps, do you recall any other specific areas that you and George had talked about? net positive suction pressure curve pin compression limits I'm trying to key on anything that you may have discussed. It's looks like at 5:45 you logged in at the gate. It's looks like at 5:45 that all the pumps had been secured.

1 A. Well, I guess eventually, yes, you know. Certainly
2 I wouldn't have expected to get the high radiation alarm in
3 the reactor compartment, no, and that may have been the thing
4 that triggered my mind that we had a very serious problem.

5 Q. Did that lead you to conclude the core had been at
6 least partially uncovered?

7 A. What, the one in the high range?

8 Q. Yes.

9 A. I don't know, at this particular time, what I
10 thought about what had caused it, except we had one hell of a
11 problem, or were going to have one.

12 Trying to -- you know, sitting back with 20/20
13 hindsight and knowing everything we know today, you say, why
14 didn't you recognize that. Again, you have to experience it
15 to appreciate it. You can sit up here and go through the
16 testimony and everything and Monday night quarterback and say,
17 gee, you should have recognized that. You can't. No way.
18 You can't. You can't take people down and fight a fire in
19 the same situation that existed in the actual conditions.

20 BY MR. CRAIG:

21 Q. Concerning your early morning increase in this
22 source range nuclear instrumentation and intermedial nuclear
23 instrumentation, you told the IE investigators again in your
24 May 9, '79, testimony that the source range indication really
25 bothered George Kunder.

1 Did you observe the nuclear instrumentation between
2 six and 5:45? Now, referring to this NSAC chart again, we
3 are looking here at these high levels and the source, which
4 is the blue.

5 A. I can't recall actually looking at them. As I
6 recall the situation, we had had a spike or an increase at
7 the same time that we had received a report of a low boron
8 from the primary coolant, an analysis that we had running.
9 Those two, I think, corresponded about the same time, if I'm
10 not mistaken.

11 The concern at that time, of course, was that we had
12 diluted the primary coolant. In retrospect we hadn't, but
13 that was the inference then; that we had diluted the primary
14 coolant boron concentration.

15 Q. Did you believe that the reactor was or could return
16 to criticality?

17 A. At that particular time, I can't tell you what I
18 thought. I don't believe I thought that we were going
19 critical. We had -- first of all, we had several
20 abnormalities that were going on. The thing was generating
21 heat obviously because it was -- the pumps were secured, so
22 the decay heat was coming in there.

23 The low boron condensation I didn't understand. I
24 didn't see how we could have diluted it, in my own mind,
25 pertaining to the RWST, which was borated around two thousand

1 epm. The facts just didn't jive. It was an abnormal
2 sampling situation because you didn't have stuff being
3 circulated. I don't know what I thought right at the moment,
4 you know.

5 But we started injecting, I believe, at that time,
6 just because that was the indication we had; had a low boron,
7 so we took the precautionary measures.

8 I don't think, at that time, I felt we were going
9 critical, however.

10 2. In your interview before the subcommittee of the
11 Nuclear Regulatory Commission on Environment and Public Works,
12 October 15, 1979, you state on page ten, and I'll quote, "The
13 count rate coming up was because we were -- in fact, we had a
14 bubble in the -- what we were seeing was leaking neutrons."

15 Were you aware, on 3-28-79, that you were seeing
16 leakage neutrons?

17 A. No. That is 20/20 hindsight, trying to explain that.

18 Q. In Mr. Flint's testimony on June 30, 1979, he states
19 that he drew the conclusion that the nuclear instrumentation
20 indications were not a criticality but were a change in the
21 leakage fluxion resulting from a portion of uncover of the
22 core. He says he discussed this with Mr. Rodgers, and Mr.
23 Rodgers told him he would discuss this with Met Ed management.

24 Did you discuss John Flint's conclusion with Lee
25 Rodgers on the day of the accident?

1 A. No, I didn't.

2 BY MR. MOSELEY:

3 Q. Or with anyone?

4 A. No. I don't remember when John showed up, frankly.

5 Do you remember?

6 BY MR. CRAIG:

7 Q. It was --

8 MR. MOSELEY: About ten.

9 BY MR. CRAIG:

10 Q. Nine to 10 time frame.

11 A. This occurred back around six or seven.

12 Q. That's right.

13 A. I did not -- I don't recall having any conversation
14 with John that day. In fact, I don't really recall seeing
15 John that day now. I may have.

16 Lee Rodgers was in there, I remember seeing him.
17 But Lee was, again, mostly talking with Gary Miller. I had
18 no conversation on that particular subject with Lee.

19 Q. You have stated that you didn't have any discussions
20 concerning the apparent return to criticality or increase in
21 count rates with respect to voiding on the day of the
22 accident.

23 A. Restate that, please.

24 Q. I believe you have just told us that you didn't have
25 any discussions which related the increase in count rates and

1 the nuclear instrumentation with the possibility of voiding
2 in the core; is that correct?

3 A. I don't know if I had any conversations. I don't
4 recall discussing it with John Flint. Kunder, I think,
5 raised the issue when we had the count rate increase,
6 combined with this low boron concentration. Whether I
7 discussed anything with him at this particular time, I can't
8 recall.

9 I don't think, as I say, in my own mind, I felt we
10 were critical, however.

11 Q. Do you recall any discussions with Miller, Zewe,
12 Herbein, Chwastyk, or anyone else, at any time, on the day of
13 the accident, concerning the nuclear instrumentation behavior
14 in the morning?

15 A. Right now I don't recall. I may have, when Miller
16 showed up, told him that -- I don't know. Just in telling
17 him what events, as I remembered them, when he arrived, I may
18 have mentioned it. I don't know.

19 BY MR. MOSELEY:

20 Q. I'm a little bit confused. What did you and Kunder
21 discuss in regard to --

22 A. As I recall, we received, at about the time of the
23 count rate increase, a report from a boron concentration that
24 had been run earlier, had been drawn earlier, from the
25 primary coolant. And that report was a low boron

1 concentration. I don't know what the value was, but it was
2 significantly lower than what it should have been.

3 Q. And that was what you discussed with Kunder?

4 A. I remember that coming up, but I can't remember what
5 we said except that, as I recall, if we were not injecting,
6 then we reinitiated injection.

7 Q. And your conclusions, even though you weren't
8 concerned that the reactor was going critical, was that you
9 were having a boron dilution?

10 A. No, that was the inference, because I think George
11 felt that. I couldn't quite agree with that, but the safest
12 thing is to go ahead and inject.

13 Q. What did you believe was happening?

14 A. At this particular time, I don't know. As I say,
15 there was a lot of abnormalities going on, as far as the
16 plant was not in a normal configuration. At that particular
17 time, I don't know what I thought. I'm sure I did not feel
18 we were going critical.

19 BY MR. CRAIG:

20 Q. There was a subsequent boron sample which is even
21 lower than the first one, as I recall.

22 A. I think that's true. I believe there was.

23 Q. Did you draw any conclusion --

24 A. Well, you have to realize we were not circulating
25 water. So the sample that you get can be suspect.

1 BY MR. MOSELEY:

2 Q. But the nuclear instrumentation is not subject to
3 the same problem.

4 A. No, but the nuclear instrumentation that it's
5 subject to, to a lot of heat or other things, can give you
6 some erroneous indications.

7 Q. Did you believe there was that much heat in the area
8 of that instrumentation?

9 A. I don't know what I believed at this particular time,
10 frankly.

11 BY MR. CRAIG:

12 Q. Was the count range behavior passed on to the NRC on
13 3-28-79?

14 A. I did not pass it on. I don't know if it was or not.

15 Q. In your opinion, should it have been, on the day of
16 the accident, reported to the NRC?

17 A. I think they should have been told everything that
18 went on when they got there.

19 BY MR. MOSELEY:

20 Q. What about before they arrived?

21 A. Certainly if -- I'm trying to remember when we
22 actually established communications on a continuous basis
23 with them.

24 Q. It was near eight o'clock.

25 A. Yeah. Anything that went on, I think we should have,

1 A Yes.

2 BY MR. CRAIG:

3 Q On the morning of the day of the accident, did you
4 believe that the reactor was going recritical after the scram?

5 A I did not believe that it was going recritical, but I
6 did not have a good answer for why the increase in count rate.

7 Q Did you at any time on the day of the accident discuss
8 this increase in count rate with Mr. Miller, Kunder, Flint,
9 Herbein or Chwastyk?

10 A Any time that day? With Mr. Miller, Mr. Chwastyk. Not
11 Mr. Herbein. And who else did you say? I'm sorry.

12 Q Mr. Kunder.

13 A Mr. Kunder, yes.

14 Q And John Flint?

15 A Yes, I recall discussing that with Mr. Flint later in
16 the day, yes.

17 Q Can you tell us the reaction to this increase in count
18 rates for any of these people? Mr. Miller, Kunder, Flint or
19 Chwastyk?

20 A I really can't recall exactly what each of the gentlemen
21 expressed to me, other than some way the out-of-core detectors
22 were seeing an increase in flux, and I don't recall exactly
23 what each of them had to say about it at the time.

24 Q At any time on the day of the accident, were these
25 conversations held with respect to voiding in the primary

1 system for core uncover, which would give you the increase in
2 flux at the outer detectors?

3 A Not that I can remember, no.

4 Q In your opinion today, should this increase in count
5 rate and potential for recriticality have been passed on to the
6 NRC on the day of the accident?

7 A Yes.

8 Q To the best of your knowledge, what were the core exit
9 thermocouples used for during normal operation?

10 A Prior to the accident, we did not really use them.
11 They were unavailable in Unit 1, and they were available in Unit 2,
12 and to my knowledge, there were not any existing procedures that
13 really had you use them at all.

14 Q To the best of your knowledge, who would have used
15 the core exit thermocouples?

16 MR. MC BRIDE: On the day of the accident?

17 MR. CRAIG: Previous to the day of the accident.

18 MR. MC BRIDE: Well, that question strikes me as a
19 little odd, because he's just testified that they weren't used.

20 MR. CRAIG: No, he testified that he wasn't aware
21 that they were used. I'll be a little more specific.

22 MR. MC BRIDE: Okay.

23 BY MR. CRAIG:

24 Q I interpreted the response that you didn't believe
25 that they were used, is that Metropolitan Edison personnel didn't

1 that I didn't like right after I walked in." That's the end
2 of the quote.

3 You also said that you asked Bill Zewe if he was
4 injecting, and was he emergency borating. At the time you were
5 watching the nuclear instrumentation, did you believe that
6 the reactor was actually returning to criticality?

7 A I don't know what conclusions I drew. My gut feeling
8 was something was wrong, was the conclusion I drew. I just
9 walked in, and the only conclusion I could draw, she is going
10 to go critical on us for some reason. I remember that's one
11 of the things we looked at. Whether I just walked in or
12 whether it was an -- times were real tough after something
13 like this. But it did bother me very much, and the conclusion
14 the draw, the only thing I could draw, she is starting to go
15 critical, reason or not.

16 Q In Flint's testimony to the Kemeny Commission, he
17 says that he drew the conclusion that the nuclear instrument
18 indications were not a recriticality, but were a change in
19 leakage flux on the core. He says that he discussed this with
20 Rogers, and Rogers told him that he would discuss with Met Ed
21 management.

22 Did Rogers inform you of Flint's conclusion?

23 A No, sir.

24 Q Did you participate in any discussion on March 28th
25 in which Mr. Flint's conclusion or anyone else's similar

1 MILLER: That was discussed plus the excores. We watched both of
2 those. Early in the morning that was discussed if some thing had
3 occurred. You know, we did not see, that I remember, after seven in the
4 morning any kind of an upward response on those. We were looking at
5 those. They had showed an upward response earlier in the morning. In
6 fact early in the morning they probably emergency borated it...things
7 based on the excores going up. And you know they had low boron samples
8 early in the morning and they thought they were getting a low boron
9 when they were probably taking water of the damn core.

10
11 HUNTER: I understand. I don't have any further questions at this
12 time, Gary. I appreciate your time and would also like to indicate
13 that after I review this conversation and would also like to review
14 your transcript. I would like to indicate that I would be getting back
15 and try to cover some of the specific decisions at that time.

16
17 MILLER: I don't have any problem with further interviews. I think you
18 got to remember the further we get the harder it is to become honestly
19 specific and I'll give you the answer as honestly as I can. Testimony
20 gives my logic as best as I can present it and I, also, might say that
21 the level of stress that I felt under that day was almost intolerable
22 because, I think the situation as I've said was one I wasn't schooled
23 in, secondly, the amount of communications I was trying to accomplish
24 were almost intolerable and that I actually removed myself at times
25

1 MR. MOSELEY: We are back on the record.

2 BY MR. MOSELEY:

3 Q Mr. Miller, I would like to go to another subject
4 area now.

5 In your transcript of your discussion with the IIE
6 investigator on May 7, you were asked if the SPND were used
7 or discussed during the accident. Your response in part
8 was, and I quote: "That was discussed plus the ex-cores.
9 We watched both of these. Early in the morning that was
10 discussed. If something had occurred, you know, we did not
11 see, that I remember after 7:00 a.m., in the morning any
12 kind of an upward response on these. We were looking at
13 these. They had shown an upward response earlier in the
14 morning. In fact, earlier in the morning they probably
15 borated it, things based on the ex cores going up, and you
16 know they took low boron samples early in the morning and
17 they thought they were getting a low boron when they were
18 probably taking water off the damn core."

19 On the morning of March 28, what did you believe
20 based on what you saw or were told about the nuclear
21 instrument indications?

22 A I think the samples were pertinent. I have it in
23 my mind because of the samples and the way that I got into
24 this thing. I got a phone call saying that the sample lines
25 in unit I were hot, because the unit sample lines went into

1 unit I.

2 As far as further memory on the use of the
3 ex-cores and the in-cores, we looked at those as an
4 instrument of indication of criticality or recriticality.
5 That is all would think of discussing.

6 Q Was the count rate behavior discussed in the
7 telephone conference call between yourself, Kunder, Rogers
8 and Herbein at approximately 6:00?

9 A I can't recall specifically.

10 Q I am not sure if you asked this question, so I
11 will ask it again.

12 Did you, at any time during the day on March 28,
13 reach any inferences on core uncovering from the nuclear
14 instrumentation indications?

15 A Not that I recall. I also believe that the boron
16 boost in mid-morning was a recriticality as opposed to level.

17 Q I am aware that that was the initial
18 determination.

19 A I don't believe that the conversation went any
20 further than that during the day as far as an indication.

21 Q You don't recall any conversations of that as an
22 indication of core uncovering by anyone during the day on
23 March 28?

24 A Today I don't recall.

25 Q In Flint's testimony to the Kemeny investigators

1 on June 30, Flint says that he drew the conclusion that the
2 instrument indications were not of a recriticality but were
3 a change in liquid flux.

4 He says that he discussed this with Rogers, and
5 that Rogers told him that he would discuss this with Met Ed
6 management. Did Rogers inform you or discuss it with you?

7 A I can't recall a conversation of that context. I
8 don't believe I recalled it in the past either.

9 Q Mr. Kunder has indicated to us, in fact yesterday,
10 that he believed this was discussed in the think-tank
11 meetings. This does not help you to recall this in any way?

12 A No.

13 Q To the best of your knowledge, what are the core
14 exist thermocouples used for, or how are they used in normal
15 operations?

16 A To the best of my knowledge, in fact on March 28 I
17 don't remember them being in the procedures.

18 Q There was no procedure at that time?

19 A There may have been a procedure for use of them on
20 the computer as a computer procedure, but I don't believe
21 any of the procedures for ECCS safety systems recognized or
22 utilized them that I remember.

23 Q What were they routinely used for in non-accident
24 situations?

25 A I personally today cannot recall their being

1 things together, and we know there were discussions about some
2 people were concerned that the core wasn't covered, wasn't being
3 adequately covered, despite all these, and inventory deficiency
4 was not specifically discussed.

5 Am I capturing you correctly?

6 A That's fair to say, to characterize the conversation,
7 yeah.

8 BY MR. CRAIG:

9 Q Our review of your testimony before the Senate indicates
10 that you were aware there was a concern over recriticality
11 before 8:00 a.m. on the morning of 3/28.

12 A I was aware of some of the operators' concerns
13 because they told me about it, yes.

14 Q Did you believe on the morning of 3/28 that the reactor
15 had gone recritical after it scrambled?

16 A No.

17 Q Was the count rate behavior discussed during this
18 6:00 a.m. conference call?

19 A Not that I recall.

20 Q Did you at any time during the day discuss the
21 concern over recriticality with the count rate behavior with
22 Miller, Kunder, Zewe, Herbein or Chwastyk?

23 A Yes, I talked to Bill Zewe about it, when he and I had
24 a discussion. I think that was probably before 3:00 o'clock.
25 Told me they thought they had been going recritical when some

1 of the boron sample analyses had come back low numbers, and
2 maybe this was shortly after 8:00 o'clock. I'm not sure now of
3 the timeframes, but it probably was, because we concluded that
4 we had steam in the system, and I said to him something to the
5 effect that it's reasonable to assume that you're getting steam
6 coming out through your sampling lines, and it's really just
7 flushing your boron out, you're not getting representative fluid
8 samples of boron. Therefore, you're getting low numbers. And
9 it explained it away for me in that case.

10 I don't recall that Zewe ever mentioned anything about
11 count rate at all in that discussion, ~~or any~~ of the boron sample
12 number results.

13 Q Did you ever discuss this with -- the boron samples
14 with Miller, Kunder, Herbein, Chwastyk or John Flint?

15 A I think I did with John when he came in and tried to
16 catch him up with what I had known, what I had been able to find
17 out from either the discussions or the conference call, or plant
18 conditions as I saw them.

19 I think I told him there had been some discussions
20 towards probably the recriticality was a concern, and gave him
21 my conclusions from the sampling results of the piping steam,
22 and those are the only conversations that I recall having with
23 John.

24 Q Did you discuss at any time the neutron instrumenta-
25 tion behavior with respect to voids or core uncover?

1 A Not that I recall, no.

2 BY MR. MOSELEY:

3 Q You don't recall such a discussion with Flint?

4 A No, I do not.

5 BY MR. CRAIG:

6 Q To the best of your knowledge, what are the core
7 exit thermocouples used for during normal operations?

8 A Most of the information from that was accumulated in
9 what we call the ^{PDC} ~~PDC~~ runoff from the computer for the analysis
10 to be performed at Lynchburg on core performance, and it would
11 then be forwarded down as a computer runoff, and the people in
12 Lynchburg in the fuels section would take that information,
13 and then calculate the different performance characteristics of
14 the core overall and come back and form a report, which I think
15 usually only came out about once a year, but, no, those
16 reports were not a required periodic frequency, as I recall,
17 except for the ^{PDC} ~~PDC~~ information being sent down at, I believe,
18 the first time we get to 100 percent power in each start-up,
19 and then some periodic point in time during any ^{one} ~~one~~ at power,
20 we sent a ^{PDC} ~~PDC~~ runoff down to Lynchburg.

21 BY MR. MOSELEY:

22 Q This would just be a --

23 A It would be an encoded computer system, digital
24 numbering system, and as far as reading it in the runoff, it
25 had nothing but a series of numbers that needed to be decoded

1

2

Flint

18

3

information that was available from the computer
4 relatively promptly?

5

A Yes, I was.

6

Q And were you consulting with anyone else
7 as you reviewed that material and analyzed it?

8

A With Bill Zewe, shift supervisor, and Ed Fredricks,
control room operator.

9

10

Q Were you reviewing the computer printout
together, or did you review it yourself and then talk
11 to them?

12

A I reviewed it myself and then talked with them.

13

14

Q What conclusions did you arrive at, based
on the information you acquired from the computer?

15

16

A I decided that at that point in time, I would
have to have discussions with Lee Rogers and with
17 the operators to obtain more information.

18

Q And what information did they give you?

19

20

A They provided the fact that there had been a
turbine reactor tripped and that they had the impression-
21 they had recriticality or an approach to recriticality.

22

23

I looked at the charts and informed them that
in all probability it was not a recriticality but a
24 change in the leakage flux from the core.

25

Q A change in the leakage flux?

1

2

Flint

19

3

A Yes, from the core.

4

Q What was their response?

5

A Just that they had apparently not thought of
this possibility.

7

Q Did they appear to accept your conclusion?

8

A To the best of my knowledge, yes.

9

Q In retrospect, was your conclusion accurate?

10

A Yes.

11

Q Once you had analysed the computer information, and once you had acquired additional information from Zewe and Fredricks, and once you had given them your analysis, did you do anything more?

14

15

A Well, of course, during the time I had reviewed the other strip chart recorders in the control room and talked with Lee Rogers about my findings.

17

18

Q And what did you tell Rogers? Was it the same thing you told them?

19

20

A Essentially the same thing I told them at that
that time, yes, and advised him that we needed to
induce natural circulation or run a reactor coolant
pump.

23

Q What was his response?

24

25

A He said that he would discuss it with Mac Ed
management.

At approximately 0830 on the 20th of March, I arrived at the North gate to the Island only to be stopped due to security personnel restricting anyone from coming on the Island. It took me approximately 20 minutes to a half hour to have the security guards call in and contact the control room to find out if my services were required.

At approximately 0900 I was granted permission to go on the Island; immediately went to the Unit 2 turbine area where we have the entrance for Unit 2 and went directly to the control room. On entering the control room, I noticed that the normal alarms were lit and that the typers were printing out as normally occurs following a turbine/reactor trip. Ah, I also noticed that the Emergency Team for radiation type emergency was in attendance in the control room at this time. I talked with the Control Room personnel and this is primarily with (ah) Bill Zaywee, the Shift Supervisor, Ed Fredricks, the Control Room Operator, and Lee Rogers, Babcock and Wilcox Site Representative, and learned that the conditions were abnormal for this type of a transient. In talking with these personnel and looking at the console indications and the computer printouts, I noted that the hot leg temperatures for the primary system were in excess of 620°F, cold leg temperatures were significantly lower than this, which would be unusual in this condition, pressure was low in the reactor coolant system, all control rods were on the bottom. Indications for the source and intermediate range appeared to be normal, for this period of time following a shutdown condition. I did notice however that there were

several blips on the recorder for source/intermediate range and in conversation with Ed Fredricks he informed me that they thought at the time that they were going critical and that they had added additional boron into the system. At this time, I informed them that in all probability this was not the case, that there had been a change in leakage flux path from the reactor core to the detectors and it was not in fact the reactor going critical again. Looking at the recorder that prints out the steam generator and reactor coolant temperatures on wide range which runs from approximately 0 to 800°F, there were 2 temperatures that were printing up scale on the hot leg temperatures; one approximately 770 degrees, the other approximately 800 degrees. Now these thermocouples are not normally used in this range so I was not certain that they would give an accurate temperature, only indications of approximate ranges. Ivan Porter, Metropolitan Edison I&C engineer, showed me a setup where he had set up a bridge and was reading out a temperature in the back of the control room that was (ah) converting instances was above the normal Rosemont Calibration scale, came out to be approximately 725°F, which tended to back up the indications we'd seen on the other recorder. Talked to various personnel in the Control Room, Gary Miller, the rest of the Operations personnel such as George Kunder, informed me of sequence of events that led up to this position. At this time I again talked with Ed Fredricks and both he and I were convinced that we had in fact a solid steam bubble in both loops of the hot legs. At the time, I attempted to initiate the filling of the steam generator to induce natural circulation or at least remove enough

1 that they had seen super-heated steam in the loops before. When
2 was that occurrence?

3 A It was during some hot functional testing, as I
4 remember.

5 Q You got super-heat without a core?

6 A I don't remember all the details, but they did have that
7 condition where the temperature remained elevated and were steam-
8 bound for an extended period of time in the top of the hot-leg.

9 BY MR. HAPSTER:

10 Q Was there any discussion with regard to this, John?

11 A Not on that day, no.

12 Q You testified that you talked with Lee Rogers on the
13 morning of March 23, 1979, with regard to your analysis of the
14 behavior of the nuclear instrumentation. That is, the apparent
15 re-criticality was caused by a change in the leakage flux with a
16 result of a voiding in the core. What was Lee's reaction?

17 A This refers to the previous answer, where he was on
18 his way to a meeting. I think he understood that it had not
19 actually gone critical again. I am certain that he correctly
20 interpreted the reason for it.

21 Q You further testified that Lee Rogers said that he
22 would discuss your inferences with Met-Ed management. Did you have
23 any discussions on March 28, 1979, with Miller, Herbein, Kunder,
24 Zewe, Mehler or Chwastyk with regard to those inferences?

25 A I remember speaking with Bill Zewe, George Kunder.

1 Again, this goes back to the previous answer, with Ed Fredericks
2 and the nuclear engineers about what I thought the condition was.

3 Q Could you tell us a little bit about the discussions
4 with Kunder and Zewe?

5 A I can only paraphrase it now to the fact that it was
6 not a re-criticality. Basically, it was a change in the leakage
7 flux either due to voiding of the core, or steam blanketing,
8 uncovering, or whatever. I don't know exactly what words I used
9 with which individuals at this time.

10 Q What was Kunder's reaction to this?

11 A I think, basically, his was the reaction the same as
12 the rest of them. I don't know that he really believed what I was
13 telling him.

14 Q Did you have any subsequent discussions with Rogers on
15 that day with regard to the inferences you were drawing?

16 A Not that I can remember.

17 BY MR. HOEFLING:

18 Q At what time did you talk with Kunder, do you recall?

19 A I know that it was sometime between 10:00 and 12:00 or
20 13:00, in that time frame, but I could not pin it down any closer
21 than that.

22 Q It would have been around 10:30?

23 A yes, somewhere around that time.

24 BY MR. HAPSTER:

25 Q John, to the best of your knowledge what are the

1 A I ordered monitoring of everything in the building. I
2 don't remember specifically temperatures, but I remember seeing
3 generator pressures that we checked. Other than just a general
4 check of parameters and equipment in the building, that is all
5 I can stand by. The specifics are a little fuzzy.

6 BY MR. MOSELEY:

7 Q Would that have been to get further confirmation of the
8 reality of the pressure spike that you asked these other para-
9 meters to be checked?

10 A Not primarily. I think that primarily it was to check
11 everything to find out if we could explain that. If we had
12 problems that could be explained by that pressure spike, a steam
13 rupture or something of that nature.

14 I think that after the first few seconds, I knew it
15 was not a steam rupture because the pressure dropped back. It
16 was in that vein, in trying to determine what the hell had gone
17 on.

18 BY MR. CRAIG:

19 Q Did you, or anyone else, to your knowledge, monitor
20 the alarm printer during the pressure spike?

21 A I don't remember specifically assigning anyone to
22 monitor. I don't even remember what the status of the alarm printer
23 was at that time, but if it was real time, it had been caught up,
24 someone was monitoring it. I had either assigned them, or else
25 there was just someone standing around looking at it. I remember

1 there was a bunch of people there.

2 Q Was this information passed on to the NRC, to the
3 best of your knowledge?

4 A Okay, first of all, the NRC was present at the time of
5 the spike. I remember an NRC inspector being, I don't want to
6 say involved because that is not the right word, but he was
7 present at the time Mehler and I were discussing the spike.

8 BY MR. MOSELEY:

9 Q Did you discuss the spike and its ramifications with
10 this NRC inspector?

11 A I did later. We had sort of a general discussion at
12 that time, and the NRC inspector was standing there. Again, I
13 don't remember if he took part in the discussion, or if he just
14 sort of listened to it.

15 After I had talked to Miller, and after in my own mind
16 I was pretty sure that we had gone through a pressure transient
17 in the building, I remember essentially telling that NRC
18 inspector that. The words that come to my mind are: "That
19 explosion was real." It was real. I don't know if I said,
20 explosion, but I said that the pressure spike, or whatever it
21 was, was real. It had actually happened in the building. I
22 remember passing that to him.

23 BY MR. GAMBLE:

24 Q That was after you had spoken with Mr. Miller?

25 A Yes.

1 You have to remember, or at least when it dawned on
2 me what I thought had happened, the first thing I did was to go
3 back to Gary Miller and tell him that there was trouble.

4 Q That is the same conclusion that you passed to Mr.
5 Miller, that you thought that it was real?

6 A Yes.

7 BY MR. CRAIG:

8 Q I don't know how to phrase this properly, but if the
9 NRC inspector had not been there to tell, is this the kind of
10 information that was reportable to the NRC?

11 A Let me say this, during normal circumstances, yes.
12 Even during those circumstances, it was something that would have
13 been. The mode of communication would have assumed that.

14 I am not sure, but if the NRC inspector was not there,
15 we had telephone communication to communicate that to the NRC. I
16 definitely think that it would be reportable in the sense that
17 if it happened during normal power operations or at some other
18 time, other than right in the middle of an accident, it would
19 be properly reportable, the whole bit from the tech specs.

20 I am not sure how the reporting requirements fall
21 during that time period.

22 Q At what time and what logic caused you to conclude
23 that the spike was caused by hydrogen?

24 A The time, I have to say, the time really did not have
25 much meaning on the 28th. I don't think that it was very long

ALDERSON REPORTING COMPANY, INC.

1 simply because it did not take us long to -- It did not take the
2 spike long. The spike was not there very long. Mehler and I did
3 not go into a two-hour or three-hour discussion. It was just a
4 matter of exchanging ideas.

5 It was shortly thereafter that someone related to me
6 that they heard a noise of some type. Again, I don't remember who
7 related that to me. Somehow, the noise, the pressure spike, the
8 operation of the valve which was being operated all came together
9 and it scared the hell out of me. That is when I assumed that we
10 had had some kind of explosion, a hydrogen explosion.

11 Q Your best recollection is that it was on 3-28?

12 A Yes.

13 Q On testified on 5-21-79 that you recommended to Gary
14 Miller that the EMOV should not be cycled. What was the basis
15 for your recommendation not to cycle the EMOV?

16 A The basis for the recommendation was what I have just
17 related. The operation of that valve with the pressure spike,
18 I therefore assumed that there was something wrong with the
19 operator motor, or some kind of connection there that was causing
20 a spark.

21 Q Was your concern based on the failure of the motor for
22 the block valve?

23 A No, I will be quite frank with you, my first concern
24 was, Holy Christ, we had an explosion in there, and if we operate
25 that valve we may have a bigger one. Of course, you know, I did

ALDERSON REPORTING COMPANY, INC.

1 not think it through and the fact that the first burn should
2 have burned anything that was there.

3 Q Were you concerned about localized concentrations of
4 hydrogen?

5 A Well, yes. I will state also that I assumed that the
6 explosion was localized in the pressurizer area. One of my
7 concerns was that there may be other pockets around there, and
8 that would be dangerous.

9 Q Why didn't your concern or recommendation include
10 other equipment inside containment?

11 A At that time, we were not operating any other equipment
12 in the containment. Our mode of cooling was cycling the valves.

13 Q If other equipment was to have been energized, would
14 you have recommended to Gary Miller that that not be energized
15 also?

16 A I will be quite frank with you, I did not think in
17 those terms. As a matter of fact, there was word put out not to
18 operate ^{any of} ~~the~~ the equipment, and I sort of kicked myself for not
19 thinking about that myself.

20 BY MR. HOEFLING:

21 Q When was that word put out, do you recall?

22 A To the best of my recollection, it was on the 28th.

23 Q Who put it out?

24 A I assume that it came from Gary Miller, but I cannot
25 say that Gary Miller told me specifically.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 564-2345

1 Q You mean that it might have been passed along from
2 someone else?

3 A Yes, and I am not sure of that.

4 BY MR. MOSELEY:

5 Q You don't recall who gave you that order or
6 instruction?

7 A I am just trying to think about it.

8 I will be quite frank. Again, I don't remember, but
9 I think Gary Miller was there, but whether he actually said it
10 or not, I don't remember.

11 BY MR. HOEFLING:

12 Q But your best recollection is that it came out on the
13 28th?

14 A Yes.

15 BY MR. MOSELEY:

16 Q Following up on the same thing, do you recall any
17 reason for the order or instruction not to operate equipment? Was
18 any reason for this order or instruction?

19 A I don't remember now if it was stated, or I just
20 assumed that it was so that we did not cause any more sparking.

21 Q You don't recall which?

22 A Can I talk to my lawyer?

23 MR. MOSELEY: We will go off the record.

24 (Discussion was held off the record.)

25 ---

ALDERSON REPORTING COMPANY, INC.

1 MR. MOSELEY: We are back on the record.

2 THE WITNESS: May we have the question asked again?

3 BY MR. MOSELEY:

4 Q The question was, do you recall at the time that the
5 order was given whether or not there was a statement as to why the
6 equipment was not to be operated?

7 A Again, I don't remember specifically that the reason
8 was given or that I just assumed it that this was to prevent
9 sparking in the building.

10 I do remember the circumstances and who was present.
11 Essentially Gary Miller had mentioned, and Brian Mehler was there.
12 Mehler said something to the effect that it was too late, and that
13 he had just started some piece of equipment in the building.

14 I remember some comment of mine to the effect, and
15 this was sometime later, "Don't worry about it because we have
16 burned up ^{what} ~~that~~ was in there anyway."

17 Q That was your comment?

18 A That was my comment.

19 BY MR. GAMBLE:

20 Q To Mr. Mehler?

21 A Yes.

22 Q And Mr. Miller?

23 A To whoever was there.

24 BY MR. MOSELEY:

25 Q Mr. Miller, to your recollection was there?

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 654-2346

1 A Yes, to my recollection he was.

2 BY MR. CRAIG:

3 Q How was that order transmitted?

4 A Again, I don't remember specifically Gary Miller giving
5 that order specifically to me. I do remember that soon after it
6 was given, Gary Miller and myself were discussing something when
7 Mehler walked in. How the order was actually transmitted, I don't
8 know.

9 Q It was not somebody saying to you in a calm voice,
10 "Don't restart any electrical equipment," as opposed to somebody
11 standing back and saying in a loud voice, so that other people
12 could hear, "Don't restart any electrical equipment in the
13 containment."

14 A It was not a general announcement made in the control
15 room. I remember that definitely.

16 BY MR. HOEFLING:

17 Q Would that kind of order or direction be recorded in a
18 log?

19 I am not familiar with plant operation, but normally
20 would something like that be recorded or logged?

21 A It is difficult to answer because I cannot think of an
22 analogy to use during normal operations for an order like that.

23 Q So it is unclear.

24 A Yes.

25 Q So you don't have a feel for one way or the other.

ALDERSON REPORTING COMPANY, INC.

1 A Let me say this. During normal operations, or right
2 now, for that matter, there are a number of ways that we would
3 prevent operation of equipment if we did not want it operated, and
4 that would be tagging it out, which involves a lot of time to get
5 instituted.

6 Prior to that time, it would have been a verbal type
7 of communication to whoever was in charge of the shift. Right now,
8 presently, the shift foreman. If I had a piece of equipment that I
9 did not want run, I would institute the proper tagging, whether it
10 be safety tagging, or a caution tag, or something of that nature,
11 but until the time that the tags were placed, I would give a verbal
12 order by way of the shift foreman not to operate that equipment.
13 But I don't think that they would log it.

14 BY MR. MOSELEY:

15 Q In this circumstance, wouldn't that be sort of well
16 publicized to all the operators in the control room because each of
17 them may have had some reason to operate some equipment?

18 A Normally it would, except for the fact that at the
19 time the word was put out, it started a piece of equipment and
20 nothing happened. So I am not too sure how far we carried it out.
21 I don't think that we did at all because that ^{is} ~~is~~ about the time
22 we were starting the reactor cooling pump.

23 Q This would have been about six o'clock in the afternoon?

24 A Between 4:00 and 10:00, I guess.

25 Q The pump was bumped at about 7:30.

ALDERSON REPORTING COMPANY, INC.

1 A I remember, to the best of my recollection, that it
2 was about that time that we were getting ready to run the reactor
3 cooling pump that all of this happened.

4 Q Could you tell me from your knowledge what precipita-
5 ted at this point in time, some six hours or five hours after the
6 time of the explosion? Had there been discussion of this? What
7 caused the long time period?

8 A I don't know, to tell you the truth. All I can relate
9 is what I remember, and my first impression was, "Oh hell, why
10 didn't I think of that."

11 After I thought about it a little more, I thought,
12 Oh hell, we have already burned it up in there. We have not
13 been recycling the valves, so we have not been putting any more
14 hydrogen in the building."

15 How the order came about, I just don't know.

16 Q I just wondered if you overheard or knew of any
17 conversations in the interim in which this was being discussed?

18 A No, I didn't, or at least I don't remember any.

19 BY MR. GAMBLE:

20 Q Do you recall hearing any comments from any of the
21 personnel who received this order, operators or anyone, indicating
22 that they understood the order was to prevent any sparks?

23 A I don't really remember that the order got out to the
24 control room operators. As I think about it now, there would be
25 no reason to because we had just started some equipment in the

ALDERSON REPORTING COMPANY, INC.

1 building.

2 Whether the word got out to them prior to my knowing
3 what happened, I don't know.

4 Q Was there any discussion amongst the personnel, aside
5 from Mr. Mehler, Mr. Miller and yourself, which you have talked
6 about earlier?

7 Was there any discussion along the lines, "Well, we
8 don't have to worry about this problem because we just started
9 these pumps and nothing happened," any discussions along that
10 line?

11 A The one between Mehler, myself and Miller, I
12 definitely know about.

13 Q Did you hear any of the other people, the operators,
14 talking along these lines?


15 A I don't remember specifically that they did. I
16 vaguely seem to remember, and I don't ^{know} if I am remembering this now
17 from the 28th or not, but I seem to vaguely remember someone
18 saying to me in the control room, after I left Miller and the
19 shift supervisor's office, that "We just started a piece of
20 equipment," or something in that general vein.

21 I don't remember who it was, and I am not even sure
22 that it did happen. I am not sure if that was a carry-on of the
23 conversation. I remember carrying a conversation with Mehler.

24 BY MR. CRAIG:

25 Q With respect to your recommendation that the EMOV

ALDERSON REPORTING COMPANY, INC.



58-1

REACTOR BUILDING HYDROGEN CONCENTRATION
FOLLOWING LOCA

THREE MILE ISLAND NUCLEAR STATION UNIT 2



FIGURE 6A-1C

1 pressures affecting decisions to report items to the NRC?

2 A Would you restate that question again I am not sure
3 that I understood the question.

4 Q I want to know, on 3-28-79 what pressures or influences
5 that you felt which would impact on your decision to either report
6 an item or not report an item to the NRC?

7 A There was none that I was aware of. The NRC inspec-
8 tor was there with me in the control room, and we were exchanging
9 viewpoints.

10 MR. CRAIG: Now, if you want to ask your questions.

11 MR. McBRIDE: Mr. Chwastyk, do you recall having
12 testified previously that subsequent to the pressure spike that
13 occurred in the reactor containment building, you advised the
14 NRC inspector in the control room that you believed that an
15 explosion had taken place in the containment?

16 THE WITNESS: Yes.

17 MR. McBRIDE: Do you also recall testifying that you
18 could not identify at the time of the earlier testimony who that
19 NRC inspector was?

20 THE WITNESS: Yes.

21 MR. McBRIDE: Did there come a time subsequent to that
22 testimony when you learned the identify of that NRC inspector?

23 THE WITNESS: There was a time afterwards that I
24 saw the inspector again, and at that time I learned his name.

25 MR. McBRIDE: What is his name?

1 March 28th?

2 A I don't remember specifically, but I'm sure I must have.
3 I was not trying to keep it a secret or anything. There were
4 all kind of fellow shift supervisors and people I worked with
5 there, I'm sure I must have related it to someone. I don't
6 remember specifically.

7 Q It doesn't seem to have been general knowledge or
8 it doesn't seem to have been generally appreciated that there
9 had been a great deal of hydrogen in the system and a hydrogen
10 explosion until Thursday afternoon or even Friday morning
11 among many people here. Yet you seem to have put this
12 together in your own mind on Wednesday afternoon.

13 A There were people in that control room that knew it
14 happened, and I know specifically there was at least one
15 NRC inspector there. And I don't know who it was, I don't
16 remember his name or what he looks like. But I do know there
17 was an NRC inspector, because I remember him standing behind
18 Mehler when we shut down the spray pumps.

19 Q I want to ask you about that in just a minute, but what
20 I was trying to ask you is whether you can shed any light
21 on why so many people around here didn't seem to really put
22 all this together until Thursday or Thursday night or Friday
23 morning?

24 A I am not sure I understand that. You've got to
25 remember that -- I'm not sure I know what you're getting at.

1 I remember sunshine. What else was happening, I don't remember.

2 BY MR. MOSELEY:

3 Q Can we eliminate this summer, and it would have been
4 last summer?

5 A I really can't. I know that I would know him again
6 if I saw him. I am terribly^e on names, I really am. I have always
7 been that way.

8 BY MR. CRAIG:

9 Q Let's go back for a minute. I have a couple more
10 questions about that.

11 The day you recognized that it was Ne^ely, did you see
12 him walking at a distance? I am not going to get into a quarter
13 mile, but did you go up and look at his badge to get his name;
14 how did you learn that his name was Ne^ely.

15 A I don't remember the specifics behind the first time
16 seeing him, and I was in the control room at the time, and it
17 triggered in my mind that that was the guy.

18 Q Did you walk up to him and say, "Do you remember
19 talking to me the day of the accident"?

20 A No.

21 Q You did not talk to him at all?

22 A No. The only reason I brought it up is because when
23 I talked to the investigator, afterwards he asked me specifically
24 if I remember, and I said, yes, I remembered it was Ne^ely because
25 I saw Ne^ely subsequent to that.

ALDERSON REPORTING COMPANY, INC.

1 BY MR. CRAIG:

2 Q I have three names, maybe you will recognize one of
3 them. Robert Martin, Darwin Hunter, or Owen Shackelton.

4 A I think that I could recognize him again.

5 BY MR. HOFELING:

6 Q Do you know at what time this exchange took place?

7 A What time of the day?

8 Q Yes.

9 MR. FIDELL: Which exchange are you referring to?

10 MR. HOEFLING: The exchange between Joe and the
11 investigator where he informed him that he recognized Neely as
12 the individual.

13 MR. FIDELL: Are you talking of the day of the
14 accident?

15 MR. HOEFLING: No. I am talking about the exchange
16 between Joe and the NRC investigator, where he told the investiga-
17 tor that he recalled who the individual was that he spoke to on
18 the day of the accident. Apparently, that exchange took place
19 on site.

20 THE WITNESS: I can remember exactly where it took
21 place, by the ~~terminal~~ ^{turbine building} in unit two, but I don't remember whether
22 it was fall or summer, or what his name was.

23 BY MR. HOEFLING:

24 Q Do you recall whether it was summer or fall?

25 A It was summer because it was warm. It was a warm day,

ALDERSON REPORTING COMPANY, INC.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 THE WITNESS: I don't think so.

2 MRL FIDELL: Let me also mention, for the record, that
3 the term employed in the subpoena is "pressure spike."

4 BY MR. CRAIG:

5 Q When did you see Mr. Ne^ely and recognized him, that
6 you believed that he was the NRC inspector that you had talked
7 to?

8 A I don't even remember. I have no idea. It was some-
9 time after the interview. I remember one of the inspectors -- I
10 remember one of the first investigators that I gave an interview
11 to, I don't remember the circumstances, but he and I somehow were
12 walking through the plant one day, and he asked me the same
13 question. I told him then that I remembered that it was Ne^ely,
14 and I remembered afterwards. I don't remember who the investigator
15 was.

16 MR. FIDELL: May we have a moment please?

17 BY MR. GAMBLE:

18 Q Did you finish your explanation. You were talking
19 about the time that one of the other investigators interviewed
20 you.

21 A It was at that time that I notified him that I had
22 see Ne^ely and recognized him as the man in the control room.

23 Q That was after the interviews had been completed that
24 you talked to this investigator?

25 A Yes, and I don't know his name.

1 earlier.

2 When it dawned on me what had happened, the first
3 person that I went to was Gary Miller.

4 Q In your discussions with, we will assume it was Mr.
5 Nealy, did you have the perception that he understood what you
6 were telling him?

7 A I assumed that he understood what I told him, that
8 the pressure spike or the explosion, whatever word I used, was
9 real. I assumed that he knew what that meant. I am not sure that
10 that answered your question.

11 Q I am not sure it did either.

12 What I am looking for is whether you felt he perceived
13 the significance of this, either by the questions he asked, or
14 by comments that he made, or by any other actions that you saw him
15 take.

16 A I assumed that he knew what I was talking about, and
17 when he left I just assumed that he went back to notify his
18 chain, whoever it was at that time, which I don't know. That is
19 the only thing that I assumed at that time.

20 BY MR. GAMBLE:

21 Q He did not, in fact, indicate to you what he was
22 going to do when he left?

23 A No. He just walked away.

24 MR. FIDELL: May I ask a question.

25 Did you know Mr. Nealy from before?

1 THE WITNESS: It is Ne^ely.

2 MR. McBRIDE: Do you recall anything about your
3 discussions with Mr. Ne^ely on March 28, 1979, subsequent to the
4 pressure spike?

5 THE WITNESS: The only thing I remember, I related to
6 him that it was a real pressure spike or explosion.

7 MR. McBRIDE: How is it that you came to learn his
8 identity?

9 THE WITNESS: Like I said, I saw him later at the
10 site, and when I saw him I ^{recognized} ~~spoke to~~ him.

11 MR. McBRIDE: Another question is, after your conver-
12 sation with Mr. Miller about the pressure spike, the fact that
13 you believed that an explosion had taken place, did you make any
14 assumption with respect to whether Mr. Miller had passed along
15 that information either to his superiors or to the NRC?

16 THE WITNESS: I assumed -- He was their emergency
17 director, and he would pass that information along up our chain,
18 and also making the necessary NRC notification.

19 BY MR. MOSELEY:

20 Q Let me ask a couple of questions related to that.
21 In answer to the question, you used the term explosion. Was the
22 term explosion used on March 28?

23 A I don't know that. I remember the word "real," that
24 the pressure spike, or the explosion was real, because in the
25 previous discussions I had, there was some doubt like I mentioned

1 pressures affecting decisions to report items to the NRC?

2 A Would you restate that question again I am not sure
3 that I understood the question.

4 Q I want to know, on 3-28-79 what pressures or influences
5 that you felt which would impact on your decision to either report
6 an item or not report an item to the NRC?

7 A There was none that I was aware of. The NRC inspec-
8 tor was there with me in the control room, and we were exchanging
9 viewpoints.

10 MR. CRAIG: Now, if you want to ask your questions.

11 MR. McBRIDE: Mr. Chwastyk, do you recall having
12 testified previously that subsequent to the pressure spike that
13 occurred in the reactor containment building, you advised the
14 NRC inspector in the control room that you believed that an
15 explosion had taken place in the containment?

16 THE WITNESS: Yes.

17 MR. McBRIDE: Do you also recall testifying that you
18 could not identify at the time of the earlier testimony who that
19 NRC inspector was?

20 THE WITNESS: Yes.

21 MR. McBRIDE: Did there come a time subsequent to that
22 testimony when you learned the identify of that NRC inspector?

23 THE WITNESS: There was a time afterwards that I
24 saw the inspector again, and at that time I learned his name.

25 MR. McBRIDE: What is his name?

1 Mr. Mehler. Yes, I did.

2 Mr. Blush. When did that sort of fall out of consideration?

3 You saw it?

4 Mr. Mehler. Yes.

5 Mr. Blush. You discussed it?

6 Mr. Mehler. Yes. The pressure spike came in -- I was
7 actually in the shift supervisor's office at that particular
8 time. What I noticed is the people started to move a little
9 faster, they were securing pumps. So, essentially, I thought
10 we had an ES again, which is an emergency safeguard, but I
11 didn't know whether it was low pressure or reactor buildup
12 pressure. I have never seen reactor buildup pressure go that
13 high. We went out to see what was going on. I don't know if it
14 was me or the other individuals, but the spray pumps were
15 running. To start spray pumps you need 30 pounds of pressure,
16 two out of three, and they were running. I couldn't believe
17 that, I looked at them. I walked over and looked at the charts
18 and that's when I saw the line straight up and straight down.
19 It looked like somebody played with the transmitter. It couldn't
20 have been that or we wouldn't have gotten the spray pumps. I
21 kept - - who was the individual from NRC. I explained it to
22 him. I can't give you his name. He did ask why the spray pumps
23 were running. I explained why they were running and I also
24 pointed the chart out to him.

25 Mr. Blush. It was one of the NRC people in the control room

at the time?

Mr. Mehler. There were a multitude of NRC people in there wandering around, and he asked me a question, so I explained it to him.

Mr. Blush. If you saw him again, would you know who he was?

Mr. Mehler. No.

Mr. Blush. You have been asked that question again, "Would you know him?"

Mr. Mehler. No. I am sure the individual would never remember I explained it to him.

Mr. Blush. What did you explain to him?

Mr. Mehler. He asked me why I was concerned because the spray pumps were running. I told him they would only start at 30 pounds. I said it is impossible to get 30 pounds. I walked over to the chart and looked at it, we got up to 28, according to this chart; 31, it was straight up. I looked at it and said, "That's impossible." I showed it to him.

Mr. Blush. What did he say?

Mr. Mehler. He didn't say anything. He didn't know what was going on. All he did was write down what we told him.

Mr. Blush. And then he walked away?

Mr. Mehler. Basically. Then we went back in the office after we secured from all that. The pressure was down so there was nothing else to do. Someone did make a comment they thought

1 Q I think Mr. Higgins is well over six feet and rather
2 thin, sharp face. You don't think it would have been him?

3 A No. And Neely I know.

4 Q How did you -- strike that. Do you recall whether
5 people in the control room were in respirators at the time
6 that happened?

7 A The time of the discussion, no, we weren't in
8 respirators.

9 Q Do you remember how you identified him as an
10 NRC person?

11 A I seen him earlier in the day in the supervisor's
12 office over on the one side, and when he did come into the
13 office, he had an NRC hat on.

14 Q U.S. NRC, white hard hat?

15 A Yes.

16 Q Were you introduced to him?

17 A No, I wasn't.

18 Q You had conversations with him there in the
19 shift supervisor's office?

20 A The only individual I knew that particular day that
21 was from the NRC by name was Don Haverkamp. All the other
22 gentlemen there, even Mr. Neely, which I know now, I did not
23 know that particular day.

24 Q This is on March 28?

25 A That's correct.

Q You recognized Mr. Haverkamp in the control room?

A I seen him there in the control room. That was only periodically.

Q He was not the one that you recall speaking to?

A I definitely would have known if it was him.

Q Was there anybody else standing there or listening, a party to this conversation that you had with the inspector?

A I wouldn't want to say definitely yes. There's some people I could ask.

Q But as you sit here now, you don't recall another person being a party to the conversation?

A No, and the conversation, like I said, could have only lasted a minute or two, because we were quite concerned with what was going on.

Q Do you remember whether there was a control room operator standing there in front of you, for example?

A I think we did have a control room operator over there that secured the pumps, but whether he listened to the conversation, I couldn't tell you that.

Q You mentioned that you thought that you had given an instruction to secure the spray pumps?

A Yes, and I know other people that say they gave the instruction also.

Q You were not the shift supervisor in charge at that point, were you? Or were you, in fact?

1 Q I think Mr. Higgins is well over six feet and rather
2 thin, sharp face. You don't think it would have been him?

3 A No. And Neely I know.

4 Q How did you -- strike that. Do you recall whether
5 people in the control room were in respirators at the time
6 that happened?

7 A The time of the discussion, no, we weren't in
8 respirators.

9 Q Do you remember how you identified him as an
10 NRC person?

11 A I seen him earlier in the day in the supervisor's
12 office over on the one side, and when he did come into the
13 office, he had an NRC hat on.

14 Q U.S. NRC, white hard hat?

15 A Yes.

16 Q Were you introduced to him?

17 A No, I wasn't.

18 Q You had conversations with him there in the
19 shift supervisor's office?

20 A The only individual I knew that particular day that
21 was from the NRC by name was Don Haverkamp. All the other
22 gentlemen there, even Mr. Neely, which I know now, I did not
23 know that particular day.

24 Q This is on March 28?

25 A That's correct.

1 suggestion being made not to start electrical equipment inside
2 containment?

3 A The only time that I recall was after the hydrogen
4 problem had been surfaced, and then the concern was about
5 starting electrical equipment.

6 Q Which day would this have been, do you know?

7 A It was when -- it was after the NRC was put on alert
8 that they hydrogen bubbles had increased and were increasing
9 in the containment.

10 Q During interviews conducted after the incident, the
11 Metropolitan Edison employees have stated that the 28 psi pressure
12 spike was explained to an NRC inspector. Did you have any
13 discussions with Mehler or Chwastyk on 3/28/79, the day of the
14 accident?

15 A I did not. First of all, I did not know those
16 individuals, who they were, or by name. I did not discuss
17 anything of that sort.

18 Q Do you believe that you could have been told of the
19 28 pound pressure spike that was due to an electrical problem
20 or any other reason, and dismissed it?

21 A I don't think so. I -- again at that point my primary
22 mission was the radiological control of things. Afterwards I
23 had to go out and find out where that particular console was.

24 BY MR. MOSELEY:

25 Q Had you been told, do you think you would have recalled

1 suggestion being made not to start electrical equipment inside
2 containment?

3 A The only time that I recall was after the hydrogen
4 problem had been surfaced, and then the concern was about
5 starting electrical equipment.

6 Q Which day would this have been, do you know?

7 A It was when -- it was after the NRC was put on alert
8 that they hydrogen bubbles had increased and were increasing
9 in the containment.

10 Q During interviews conducted after the incident, the
11 Metropolitan Edison employees have stated that the 23 psi pressure
12 spike was explained to an NRC inspector. Did you have any
13 discussions with Mehler or Chwastyk on 3/28/79, the day of the
14 accident?

15 A I did not. First of all, I did not know those
16 individuals, who they were, or by name. I did not discuss
17 anything of that sort.

18 Q Do you believe that you could have been told of the
19 28 pound pressure spike that was due to an electrical problem
20 or any other reason, and dismissed it?

21 A I don't think so. I -- again at that point my primary
22 mission was the radiological control of things. Afterwards I
23 had to go out and find out where that particular console was.

24 BY MR. MOSELEY:

25 Q Had you been told, do you think you would have recalled

1 it?

2 A Yes.

3 BY MR. CRAIG:

4 Q Did you see the containment pressure increases
5 indicated by the chart recorder at approximately 2:00 p.m. in
6 the afternoon on 3/28?

7 A Could you repeat that?

8 Q Did you see the spike on the chart recorder?

9 A No, I did not. As I've said, I don't even know where
10 that recorder is located at the time.

11 Q Were you aware on 3/28 at about 2:00 p.m. that the
12 containment spray pumps came on?

13 A No, I did not.

14 MR. CRAIG: Let's go off the record just a second.

15 (Discussion off the record.)

16 BY MR. CRAIG:

17 Q Are you aware that you have been identified as the
18 inspector who received an explanation concerning this pressure
19 spike by Brian Mehler?

20 A I was informed by an individual many, many weeks
21 after the accident -- and I don't know if it was Mehler or not,
22 and I turned that over to the investigating group.

23 Q It was Chwastyk, I believe. Which group? The Rogovin
24 group?

25 A No, the special investigating group.

BY MR. MOSELEY:

Q I'm sorry, I missed something here. When did you say you were told?

A Several weeks after the accident, the -- and I'm not -- I think it was Mehler, said he had information about the spike, and I turned it over to the IE investigating group at that point.

Q Several weeks? That would have been in April?

A Yeah, it could have been April. It was when we had -- we were in our site coverage at that point.

BY MR. HOEFLING:

Q What kind of information did he indicate he had?

A I can't remember now, something -- he indicated at that point he had talked to people regarding the spike.

Q NRC people?

A Yes. And so I knew -- we had our investigating team on site, so at that point I turned it over to -- it was Tony Faisano, who is the special investigator.

BY MR. MOSELEY:

Q Would this have been some time before this information was in the newspaper, which would have been early May, I believe?

A This was after.

Q It would have been after that?

A (Witness nodding.)

In fact, I was in the control room one day and he brought up that point.

1 Q To you?

2 A Yes. And I pointed it out to the investigators, that
3 this individual had some concerns and had this information.
4 Again it wasn't my area of expertise. That's why I passed it
5 along.

6 BY MR. CRAIG:

7 Q Were you aware that he believed -- I think it was
8 Chwastyk believed that you were the inspector who was at the
9 recorder during the time of the spike, and that they turned
10 around to you and said, in effect, "We have just had a 28 pound
11 pressure spike inside containment"?

12 A No. I don't even know who he is. I mean now I do,
13 but then I didn't. My main areas in the control room would
14 have been at the instrument panel, for the process monitors and
15 area monitors.

16 BY MR. MOSELEY:

17 Q Isn't that in the near vicinity of the --

18 A It's up in front.

19 Q -- of the containment pressure?

20 BY MR. HARPSTER:

21 Q Let me ask you a question, to help clear this up.
22 You had the operator's console, and then the vertical rods in
23 back. Here is the radiation monitors. Were you in this part
24 here?

25 A No. Up on the panel, in the back, the tall panel in

1 Miller's absence?

2 A Not really, no.

3 Q Nothing perceptible changed while Miller was gone, in
4 terms of how things were run?

5 A No.

6 BY MR. CRAIG:

7 Q Who was in charge when Miller left?

8 A I'm not really sure now, to tell you the truth.

9 Q Do you remember, if you aren't sure, then, who the guy
10 was?

11 A I probably wasn't.

12 Q In previous testimony before the Hart subcommittee,
13 you stated that you were not present during discussions concern-
14 ing the containment pressure spike which occurred at approximate-
15 1:50 on 3/28, and that you did not know of the pressure spike
16 until Friday. Is that still your recollection?

17 A Yes.

18 Q How can you explain the fact that you are present
19 in the control room or the shift supervisor's office during
20 the pressure spike, and the people in the control room and
21 people in the shift super's office have testified that the
22 pressure spike or thud was common knowledge at the time it
23 occurred? In fact, virtually everyone in the Unit 2 control
24 room and/or the shift supervisor's office who was present on
25 3/28 at about 1:50 has testified that they either knew of the

1 spike or heard the thud?

2 A I guess I can't really explain that. All I could say
3 was that there was certainly a lot of activity going on at that
4 time. I don't recall any thud of that type, and if it was a
5 dull type of thud, similar to a main coolant pump check valve,
6 when you start a main coolant pump on a submarine, which is
7 what -- when I discussed it with Gary Miller on Friday, the way
8 he described it, and that is sort of a dull thud in the
9 background.

10 There are lots of noises at a plant that happen at
11 various times, and if you are familiar with the plant, one that's
12 a little bit different sticks out, if you're there all the time.
13 If you're not, and you hear all these various noises, and
14 there are lots of them at a plant -- now if you're not familiar
15 with the noises, what's common and what's not, they don't
16 really register with you, and the odd ones that are not normal
17 don't really stand out as they would to somebody that was very
18 familiar with it and there on an every-day basis.

19 I really think that your characterization of it from
20 the different people that you have talked to isn't correct,
21 because I know that when I discussed it with Gary Miller on
22 Friday, the impression I got from him at that time was that,
23 okay, now that we understand what it is -- Friday, I'm saying
24 now -- now on Friday, March the 30th, we looked back and we
25 got a feel that it was a hydrogen burn or explosion, and tied

introduced just in our calculation or our analytical technique and I don't think that we were able, at least I know I was not able, to pin point whether we were talking about ten percent or ninety percent.

MR. TAYLOR: Yes, I understand.

MR. DUBIEL: But it was definitely beyond the one percent, I think there's the part we were at.

MR. TAYLOR: Now, about a little before two o'clock, according to the sequence of events, there was a larger pressure spike which has been reported as 28 psi. How did that come to your attention, Mr. Miller? That that had happened. Did you see this yourself, or did -- (interrupted).

MR. MILLER: At the time, I was not aware that we had the spike on the chart, or that the safe guard system had re-initiated. It does so happen that I heard a noise. And I did mention to Mike that I heard a noise. But I think that there are, the ventilation makes a noise that's similar. I heard a noise.

MR. TAYLOR: Could you characterize that noise. I mean was it a loud bang, or what?

MR. MILLER: A thud.

MR. TAYLOR: A thud?

MR. MILLER: It was a thud.

MR. TAYLOR: Did it occur to you when you heard that that it might have been an explosion?

MR. MILLER: No sir. It didn't at the time. I didn't

1 as conflicting and you could explain any apparent conflicts
2 and we could approach it that way. I think that might be the
3 preferable way of approaching it.

4 MR. BLAKE: Do you want to take an opportunity, Gary,
5 to review your prior statements or do you just want to tell him
6 whatever it is that you recall right now and then we will go
7 that way?

8 THE WITNESS: I will go right now.

9 MR. BLAKE: Okay, why don't we do that then.

10 At the time that the spike occurred, you know, my
11 thrust was to be leaving the site, like, you know, making last-
12 minute preparations to go to the Lt. Governor's office. I believe
13 I was out in the control room. I don't remember looking at any
14 instruments relative to that incident. I do remember hearing a
15 noise. I do remember that Mike Ross, and I think William Marshall
16 Bubba Marshall is his name, nickname, was standing near me and
17 I think I asked what the noise was. I think I was told that it
18 was the ventilation system.

19 I think I had at that time no awareness of the spray
20 pumping starting that I can remember today or of the spike itself.
21 And I feel that is accurate because when I came in in the days
22 after the accident. I came back early Thursday morning because
23 there were only two emergency directors, Jim Seelinger and myself.
24 Then I believe I came back again either at 6 o'clock or 7 o'clock
25 Friday morning.

1 were made of?

2 Mr. Miller. I knew they were alumelcromel. I would not
3 say I had an intimate familiarity with those particular
4 thermocouples. I am aware of what a thermocouple is and the
5 type of junctions they are, that is the familiarity I have
6 with it.

7 Mr. Arena. You wouldn't know the melting point of
8 alumelcromel?

9 Mr. Miller. I don't believe so off the top of my head.

10 Mr. Arena. Did you personally know it off the top of
11 your head on the morning of the 28th?

12 Mr. Miller. No.

13 Mr. Arena. On the afternoon of the 28th, did you become
14 aware of the occurrence of a pressure spike in the containment
15 in Unit 2?

16 Mr. Miller. In the afternoon of the 28th on that day I
17 was aware of a noise at some point just prior to my leaving
18 the site, and in fact, I believe I asked what was that in fairly
19 strong language. I did not closely evaluate that the 28th,
20 because I was told, I believe, that it was a ventilation system
21 which was changing modes and did make a thud-type noise, and
22 I, based on -- from the standpoint of getting ready to go to
23 the governor's office, I did not come back and evaluate some
24 of the data and events that I was aware of, say, on the 30th.

25 Mr. Arena. Do you remember who told you they thought it was

1 HUNTER: All right. Let us pick up another general item as we go along.
2 In the afternoon at approximately,... after 12, 1300, there was a pressure
3 spike in the containment. Were you present and recall that particular
4 event?

5
6 ROSS: Yes.

7
8 HUNTER: Now can you give us your location at that time and what you recall
9 seeing or hearing or discussing at that time?

10
11 ROSS: Yes. I was near the console at that time and if we are talking
12 about the same time was around 2:00, sometime in that area. And at that
13 time we got a an ES signal and some of the components restarted, decay
14 heat, what have you. We got building isolation again and we took care of
15 that and we looked back and the control room operator said "Jeese the spray
16 pumps are running" and we looked back at the charts at that time. We saw a
17 fairly large spike on the chart and the exact pressure at this time I don't
18 know, ...it was around 30 pounds. My thought at the time and Miller was
19 out there with us and he questioned he said, "jeese you know I thought I
20 heard something, too." We are moving down the road there 100 miles an hour
21 and we looked at it and we said "Jeese the spike was so short it must have
22 been an instrument." That was our reasoning at the time. We reached over
23 and we said you can shut the spray pumps off now because the pressure came
24 right back to 0,... almost very, very rapid return and we shut the spray
25 pumps off. I now know the spray pumps were on about five minutes when

1 don't mean you necessarily have some specific questions that
2 we've asked about your belief on reportability -- but I would
3 like to ask you: To your knowledge, was this information
4 withheld from the NRC?

5 A Again, no information that day was withheld from
6 anybody.

7 Q You stated to the IE Investigators in May that
8 you were aware of the containment pressure spike. You looked
9 at the charts showing the spike, and you said you knew that
10 the containment pumps started. You also said you associated
11 the event with an instrument problem.

12 You were a licensed SRQ at the time, Mr. Ross.
13 Didn't you know of the redundancy which would have to be set
14 aside for the building spray pumps to come on?

15 A Very definitely.

16 Q And you then knew that an instrument or power
17 malfunction couldn't have caused the spray pumps to come on?

18 A You say "knew." We still associated it with some
19 kind of a failure and proceeded. We didn't say: Hey, that
20 couldn't have happened, but we want to write this off. I'm
21 saying that what we concluded was that it couldn't have
22 happened, based on our previous training; therefore, it was
23 an instrument failure -- be that logically right or wrong,
24 that's what we concluded.
25

1 BY MR. CRAIG:

2 Q You concluded that what couldn't happen, specifi-
3 cally?

4 A Any kind of a spike. It couldn't have been there
5 based on that rapid of a change. We seen a change that was
6 "bang, bang," and I said it had to be an instrument failure.
7 and went on.

8 BY MR. MOSELEY:

9 Q And you didn't question that the downside, the
10 return to normal, may have been caused by some failure of the
11 containment vessel?

12 A Definitely not.

13 Q Chwastyk has told us that after the spike he had
14 a survey made of the containment building because he thought
15 the spike was real, and because the pressure had dropped so
16 quickly that the containment could have failed. He also said
17 that he had temperatures and pressures checked as a result of
18 his belief that the spike was real.

19 Were you aware of these actions?

20 A I was not. I'm sure we had temperatures and
21 pressures checked because we were doing that. We were looking
22 at things -- what's the temperature? What's your pressure in
23 the building? We had pressure in the building; we had the
24 building bottled up and we were looking at it. The inspection
25 I have no knowledge of; nor do I have any knowledge that it

1 was done.

2 Q Do you have knowledge particularly that the
3 containment building temperature was checked as a result of
4 the spike?

5 A As a result of the spike?

6 Q Yes.

7 A No, I have no knowledge of that.

8 Q What particular temperatures are you aware of that
9 were made specifically as a result of the spike?

10 A I'm aware of nothing specific as a result of the
11 spike. I am aware that we were looking at pressure, and we
12 were looking at temperature in the building. We wanted to
13 make sure that the emergency core cooling, or the building
14 cooling was keeping the pressure down for any reason, so we
15 kept the pressure low in the building. We wanted to keep what
16 was in the building in the building.

17 Q And Chwastyk didn't discuss any of these actions
18 or their results with you?

19 A No, not at that time. At subsequent times, days
20 later, we inspected the reactor building and we took radiation
21 surveys on top of the dome with a meter and things like that,
22 but at that time I have no knowledge of anything at the time
23 of the spike. We went on to something else.

24 Q But, Mr. Ross, you were the man in charge of
25 operations on that date.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2316

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 564-2345

1 A That's correct.

2 Q Here's Mr. Chwastyk taking actions. He has some
3 concern that this was a real pressure spike. He has people
4 take certain actions and he didn't tell you?

5 A Or he didn't take them that day.

6 Q How was information flowing to you as the Director
7 of Operations on that day?

8 A I was coming out to the control room-- I wasn't
9 spending full time out there -- periodically; receiving
10 information; looking at certain parameters and coming back to
11 the think tank. That's what we were doing that day.

12 Q With whom would you discuss this, any status --.

13 A The shift supervisor.

14 Q Do you feel that that information flow was working
15 on March 28th?

16 A As well as it could under the conditions that we
17 had; yes, sir.

18 Q Even when people say they had various concerns
19 and had actions taken, and you say that you weren't aware of
20 them, and you still conclude that that information flow was
21 working?

22 A I still conclude the information flow was working.
23 I still question whether or not they say things now that we
24 did then, or things we did days later. I've had that problem
25 myself.

Q Your statement to the I&E Investigators in May about Miller's interaction with you at the time of the spike says, and I quote: "My thought at the time -- and Miller was out there with us, and he questioned, he said: Geez, you know, I thought I heard something too. We were moving down the road there 100 miles an hour, and we looked at it, and we said: Gee, the spike was so short, it must have been an instrument." That's the end of the quote.

Doesn't that quote of Miller, "you know, I thought I heard something, too," say that he was saying, in addition to the other evidence of a spike, that he thought he heard something?

A He did say he thought he heard something. That's what his quote says. We didn't associate it with anything -- a ventilation fan shift, dampers go shut -- we just never associated it with anything other than an instrument failure. We had never been trained to say that a hydrogen buildup would happen in that short a period of time. All our training said 60 days, not to worry.

Q Well, you're a little ahead of me. I'm trying to -- before we get to relating it to hydrogen -- I'm trying to understand knowledge that there was a pressure spike.

A We had knowledge that there was a spike indicated.

Q And you and Mr. Miller were standing there, and someone is saying the spray pumps come on, and people are

1 taking actions, and it's your belief that Mr. Miller is aware
2 of these things the same as you were aware of these things?
3 Is that correct?

4 MR. BLAKE: Could we go back and read the first
5 question?

6 MR. MOSELEY: Sure. Did you want the five-minute
7 thing?

8 MR. BLAKE: No, just the question which you started
9 with.

10 MR. MOSELEY: Would you reread the question?

11 MR. BLAKE: I thought you asked half of a question
12 and he answered the second half. I'm not sure what the answer
13 was.

14 THE REPORTER: "Q Your statement to the I&E Inves-
15 tigators in May about Miller's interaction with you at the
16 time of the spike says, and I quote: "My thought at the time" --

17 MR. BLAKE: Could we stop just for a second? You're
18 quoting now Ross' statement from your statement?

19 MR. MOSELEY: Yes.

20 THE REPORTER: " -- and Miller was out there with
21 us, and he questioned, he said: Geez, you know, I thought I
22 heard something, too. We were moving down the road there 100
23 miles an hour. We looked at it and we said: Gee, the spike
24 was so short, it must have been an instrument." That's the
25 end of the quote.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 551-2345

1 "Doesn't that quote of Miller, 'you know, I thought
2 I heard something, too,' say that he was saying, in addition
3 to the other evidence of a spike, that he thought he heard
4 something?

5 "A He did say he thought he heard something. That's
6 what his quote says. We didn't associate it with anything --
7 a ventilation fan shift, dampers go shut -- we just never
8 associated it with anything other than an instrument failure.
9 We had never been trained to say that a hydrogen buildup would
10 happen in that short a period of time. All our training said
11 60 days, not to worry.

12 "Q Well, you're a little ahead of me. I'm trying to --
13 before we get to relating it to hydrogen -- I'm trying to
14 understand knowledge that there was a pressure spike.

15 "A We had knowledge there was a pressure spike
16 indicated.

17 "Q And you and Mr. Miller were standing there, and
18 someone is saying the spray pumps come on, and people are
19 taking actions, and it's your belief that Mr. Miller is aware
20 of these things the same as you were aware of these things?
21 Is that correct?"

22 BY MR. MOSELEY:

23 Q Would you answer that question, then, the last
24 one?

25 A I'm convinced Miller was aware of the spike.

1 Whether or not he was aware of all the ES equipment functions,
2 I can't say. Zewe turned around and said, "Hey, the spray
3 pump's started." That's how I knew it happened.

4 Q And Miller is standing next to you, and one might
5 conclude from that that he must have heard it. Is that
6 correct?

7 A That would be my conclusion. You've got to remember
8 there was a lot of information being passed in that control
9 room at that time.

10 Q I understand.

11 BY MR. CRAIG:

12 Q What about the spike itself as indicated on the
13 recorder? Did you see that?

14 A I looked it. It was long enough. It was from
15 here to there (indicating). I did look at it and seen the
16 spike go up, and I seen it clear right away. They turned to
17 me and said: Can we secure the spray pumps? We looked at the
18 pressure and said: Yes, secure them; no use spraying the
19 building.

20 Q Is it your belief that Gary Miller also saw that
21 chart recording?

22 A I can't say. Gary was in the area. I stepped
23 away and talked to Bill, and we were all kind of in the same
24 area, but I can't conclusively say he knew it and saw the
25 spike. He was in the area.

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 654-2345

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. CRAIG: Can we go off the record for a second?

(Recess.)

MR. HARPSTER: Back on the record.

BY MR. HARPSTER:

Q Mike, could you tell us what you did see in terms of other indications and things like the containment isolation valves and this, what did happen when you got the pressure spike in terms of other indications that were available?

A Well, the primary indication you have of course is the pressure recorder in the reactor building. The thing you do get is a four-pound building isolation signal that causes the valves to reclose anything you've had open, any building isolation valve. At 30 pounds, it causes the building spray pumps to start. If those actions take place, operators are talking saying the building spray pumps started; you hear those kind of things and that would be your indication.

Q Do you have annunciation on your vertical boards of your SFAS logic?

A Yes, "building spray start," a couple of different annunciators you would have. I don't know them all.

Q Things which might be more apparent to people that perhaps didn't have visual perspective, those little reactor building recorders sitting there, "loss of intermediate cooling," things like that?

A Things like that, but it would be a number of alarms

1 coming in and out at that time, whether someone in the back
2 could pick it up and say: Geez, that alarm was caused by this?
3 It's hard for me to say. For the operators, yes, we could
4 pick that up.

5 Q But the SFAS logic would put the big annunciators
6 up there?

7 A Yes.

8 Q That's something that would get your attention.
9 That's not one of the alarms you would lose track of?

10 A It would get your attention; but whether you'd get
11 it in addition to all the other alarms flashing around the
12 control room, I can't say for somebody else.

13 BY MR. HOEFLING:

14 Q Why do you say, Mike, that you were convinced that
15 Gary Miller was aware of the pressure spike?

16 A Because he asked me, "What was that?" And we were
17 in the area, and I guess I probably said something to the
18 effect that we had a spike. And he says, well -- I don't
19 recall ever saying to him, "Hey, Gary, all the spray pumps
20 started, and all the building isolation isolated." I don't
21 recall ever saying that. I don't know what I said on the
22 record, testimony-wise, but I guess my basic reason for saying
23 that is he was in there when it happened; he heard what went
24 on in the control room, basically.

25 Q Do you recall saying to him: We've had a pressure

1 What's the reactor coolant pumps?

2
3 I mean, when we cycled the electromatic relief valve, rather. I'm sorry.
4 And it wasn't until the next morning that I came in, that we were still
5 trying to find out why we had that pressure surge. So we were talking with
6 the electical engineers on how we could possibly go from that DC operated
7 valve over and trip the pressure switches, which are set at 30 pounds for
8 the building spray pumps and their on a logic of 2 out of 3, before you'll
9 start a pump. So, at least we had picked up 4 of those, plus both of the
10 pressure recorders showed an increase. So, he looked at it, and he said,
11 "Bill, there's no way that the, that cycling the electromatic could cause
12 an electrical fault to cause the pressure switches in the building spray to
13 come up." So then we thought, I wonder if the real reason was a hydrogen
14 explosion, because in order to pressurize a volume that large so quickly,
15 it was almost like an explosion. But at first, then I thought, no, 2.1
16 million cubic feet like that - no way. But then I guess we have determined
17 now, pretty well, that it probably was a hydrogen explosion inside the
18 building.

19
20 Did you hear anything in the Control Room when that happened?

21
22 I did not. No.

23
24 O.K.
25

1 I learned later that at least two other people did.

2
3 How did they hear it? I mean -

4
5 Well,

6
7 How did they hear it? Do you have noise monitors or something? Or -

8
9 We do have noise monitors that are in the Reactor Building, loose parts and
10 noise monitoring system. I don't recall hearing on that. But the person
11 in question, who I first learned it, they had heard something. Pardon me,
12 it was Gary Miller, who is the Manager of the Island. And he said that the
13 had heard something. And that he had mentioned it to whoever was beside
14 him at that time. And they thought that it was dampers in the ventilation
15 system which sit directly above the Control Room. And he didn't think
16 anything more of it, at that time. But then as he looked back on it,
17 that's what he feels it was the same time.

18
19 Bill, did these pressure spikes were proceeded by the operation of the
20 EMOB?

21
22 Well, maybe I should clarify that. The one that I was there for was from
23 the electromatic, alright.
24
25

1 O.K.

2
3 I assume that the other one was too. Though I'm not sure of that. It may
4 have been from operating something else from inside the containment. I
5 don't know that for sure.

6
7 Hunter: We're interested in, in you know the - it's important - you saw
8 the - you had the electromatic cycle, Fred opened the valve?

9
10 Right at that instant.

11
12 And at that instant you had the pressure spike. You saw the pressure
13 spike?

14
15 I'm positive. Because he was waiting for my direction on when to open it
16 up.

17
18 O.K.

19
20 Alright. And I said, "Alright Fred, open it up now." As soon as I said
21 now, you know within a fraction of a second, the spike went boom.

22
23 Alright, you saw the spike. You saw it come back down?
24
25

1 Yes. It came up and came right back down.

2

3 Then it leveled out?

4

5 Yes.

6

7 O.K. And so then having the operators disappear in the containment spray
8 pumps - the operator. You - did you - what was your basis for securing the
9 pumps?

10

11 Well, at the - I thought then that it was just a faulty indication and the
12 pressure had come back down to

13

14 Do you have - how many channels of pressure do you have in front of you
15 narrow range and wide range?

16

17 For the Reactor Building itself?

18

19 Right.

20

21 Two. Two separate recorders.

22

23 O.K. then. So you were sure then the pressure was back down?

24

25

1 Yes, I was.

2
3 O.K.

4
5 I was convinced at that time that it was just a false electrical type
6 signal.

7
8 O.K.

9
10 It never entered my mind that it was a hydrogen explosion, at that time at
11 all.

12
13 I - can I - can I - I'll ask you the question of hydrogen analyzers on the
14 containment building - on the Reactor Building. Do you -you apparently do
15 not have that type of

16
17 We need a sample for hydrogen.

18
19 You, I'm sorry go ahead.

20
21 We sample for the hydrogen, alright.

22
23 Later on?
24
25

1 We did later, yes, but I mean normally that's the only way we can determine
2 what the hydrogen concentration is in the Reactor Building. Is through
3 sampling. Or if we run the hydrogen recombiner, we can take - there's a
4 formula for figuring out, based on the reaction chamber temperatures and
5 the heater chamber temperatures. You just take the Delta T and divide it
6 by a constant. You can come out with a relative percentage of hydrogen
7 based on the reaction volume of the chamber, knowing the flow rate through
8 it and everything else.

9
10 O.K. Had you ever had to take a hydrogen sample of the containment before
11 that your aware of? Had you yeah - did you ever, before?

12
13 I'm sure that we have. And, well, the only time that I can remember
14 actually doing that is anytime that we have the building closed for any
15 period of time, alright. We normally go in and take an air sample for the
16 quality of the air. And then they get the results and the shift supervisor
17 reviews the results, to make sure you have the least enough oxygen to
18 support life and that you don't have any combustible vapors in the Reactor
19 Building before you send people in.

20
21 And that would include hydrogen in an analysis?

22
23 I think it's just combustible vapors. There's oxygen on it and I believe
24 the other one is just combustible vapors. Like
25

1 O.K.

2
3 If you'll excuse me at this minute, but hydrogen being a combustible, it
4 would be considered in that.

5
6 Creswell: What would the radiation levels have been in the area of where
7 you could have drawn a hydrogen sample?

8
9 Well, our normal sample point for the building, alright, is a monitor that
10 is right down on the 305 elevation of the Aux Building. Right near the
11 intermediate CRD filters. Right next to the seal return filters and the
12 seal return coolant from the coolant pumps. And at this point in time, I'm
13 not sure of the radiation levels, but throughout the building. They were -
14 I had heard numbers and not just certain areas, but pretty well generally
15 in the 50 R range, at this point.

16
17 So from that information, what would your decision be about drawing a
18 sample or asking for a sample?

19
20 Alright. Your referring to - I seen the pressure spike and did I think
21 about drawing an air sample, at this point or what?

22
23 What things entered your - what sort of things did you have on your mind at
24 point of time regarding that?
25

1 I didn't. I totally thought that it was just an electrical problem.

2
3 O.K.

4
5 I didn't even pursue it any further than that.

6
7 O.K.

8
9 I - I just didn't.

10
11 O.K. Lets assume that you had thought of drawing a sample, would it have
12 been practical to have drawn a sample?

13
14 No. Because at that point, I had learned - and I'm not sure if it was
15 before that or after that, but that the - I believe that it was the Health
16 Physics technician had said that we had had water blowing from the Reactor
17 Building containment monitor.

18
19 That was very early on in the morning though. That was four or five
20 o'clock apparently. Say five a.m. in the morning, wasn't it?

21
22 I'm not sure of the exact time of that. But that stuck in my mind - like
23 now that your asking it, alright. But at that time, I didn't even consider
24 sampling. But just looking back on it, I did recall that they did report
25 that it was blowing some water and we knew that the building was hotter

ar2-19

1 Did you conclude on March 28th that the pressure spike
2 was real?

3 A I did not.

4 Q For whatever reason?

5 A I thought that it was a false indication. I could
6 not conceive how the building of over 2 million cubic feet
7 could pressurize that rapidly, and then be depressurized that
8 rapidly. I had not conceived of that before.

9 BY MR. CRAIG:

10 Q On the day of the accident, did you -- are you aware
11 of anyone else who monitored any parameters such as containment
12 temperatures, reactor coolant pump, air inlet temperatures,
13 steam generator pressures, during or following the spike,
14 pressure spike of 28 pounds?

15 A We had various operators monitoring all portions of
16 the plant, but I was not specifically aware that we were monitor-
17 ing them at particular times or noted any changes at that
18 particular time because of the spike.

19 Q And specifically with respect to containment building
20 temperatures?

21 A No.

22 Q Did you or anyone else, to your knowledge, monitor
23 the alarm printer during or after the spike on the day of the
24 accident?

25 A I don't remember if anyone was monitoring the alarm

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 454-2345

1 CHWASTYK: I don't really remember. It may have been.

2
3 HUNTER: Was the spray valve being used as a flow path?

4
5 CHWASTYK: No.

6
7 HUNTER: You were going to say something I didn't mean to cut you off.
8 These flow paths then being into the reactor coolant drain tank and then
9 out the flooded tank and out the tank at the time of the reactor building
10 sump and the water then was standing in the reactor building. Okay?

11
12 CHWASTYK: Yes.

13
14 HUNTER: Shortly thereafter, there was a reactor building pressure spike
15 and as I understand you had the panel at that time.

16
17 CHWASTYK: Yes, I did.

18
19 HUNTER: Were you aware of that spike at that time?

20
21 CHWASTYK: Yes, I was.

22
23 HUNTER: Can you describe your reaction, your feelings what you thought
24 it was at that time?

1 CHWASTYK: My reactions, I actually saw the recorder, the pressure
2 recorder on the building, spike upward. I didn't know what caused it but
3 the fact that the spray valves started indicated to me that we actually
4 had some kind of pressure spike, either on the sensors on in the building
5 itself. I was not sure. The spike of course started all the building
6 spray pumps, decay heat pumps, etc. The pressure spiked up and it was
7 only up very briefly, as a matter of fact, a couple of heart beats. I
8 know because I missed those heart beats. It came right back down again.
9 I still did not know what caused it so I sort of hesitated on securing
10 all the equipment that started until I thought I had a better feel for
11 what was going on. Of course, I never did because the pressure came
12 down and stayed down, and then I ordered them the building spray pumps
13 and the DHV8s and everything closed. Stopped.

14
15 HUNTER: What was the -- the pressure came back to what level Joe?

16
17 CHWASTYK: It came back to somewhere around zero where I am not sure.
18 It came back to just about where it started from as a matter of fact, I
19 remember that.

20
21 HUNTER: Okay, we...it looks like the system had run about four or five
22 minutes when it was finally secured. Would you consider that amount of
23 time, the time it took you to evaluate the situation and see what was
24 going on?
25

1 CHWASTYK: Well, no that is -- I saw what was going on. I did not know
2 why. That is why I hesitated on shutting the emergency equipment off.
3

4 HUNTER: Okay.
5

6 CHWASTYK: Until I could be absolutely sure that I did not need it.
7

8 HUNTER: When you shut the containment spray pumps off, you had gone up
9 to the 30 lb. trip point or 28 lbs.
10

11 CHWASTYK: Yes.
12

13 HUNTER: You had gone back to two lbs. or close to where it was when you
14 started. You ended up shutting that system off. Can you describe that
15 process for shutting that system down, reset, and the position of the
16 pumps and the valves?
17

18 CHWASTYK: Okay, in this case, after I had come to the conclusion that I
19 did not need the emergency equipment I had asked the, I believe it was
20 Chuck Adams, the shift foreman, who was in the back of the panel, I
21 asked him to shut the DHV8s. About that time Bryan Miller another shift
22 supervisor came over to the panel and asked why the building spray pumps
23 were running. I told them to shut 'em down by going full lock because
24 of course at that time I decided that we did not really need them. And
25

1 essentially, we did not reset the high pressure injection. We went to
2 the whole lock position on all the emergency valves. Now when the man
3 was going to close DHV8s of course we still had the -- but I am not sure
4 of this...I think one of the CROs reset the high pressure...the building...
5 channels for reactor building pressure.
6

7 HUNTER: If you did not reset those, the 108 valves would come back open
8 as soon as you let go of the switch.
9

10 CHWASTYK: That is right and I think after we tried to close the 8s the
11 started to go back open and that is when I had to zero...reset them.
12

13 HUNTER: And the containment spray pumps were in full lock?
14

15 CHWASTYK: Right. We put those directly in full lock so that we did not
16 have any problem.
17

18 HUNTER: Joe, did you take them back out of full lock as soon as everything
19 was reset?
20

21 CHWASTYK: After everything was reset yes I did take them out of full
22 lock. I remember taking all the equipment out of full lock just in case
23 something else did happen and we would have it in standby.
24
25

1 HUNTER: Do you have any feel for that, the time frame?

2
3 CHWASTYK: Oh, I have no idea. It was...there was a lot of things
4 happening. I remember it was just an oh-by-the-way type thing. How,
5 exactly how long after the spike I don't know.
6

7 HUNTER: Do you -- who turned off the containment spray pumps? Speci-
8 fically.
9

10 CHWASTYK: ^{neller} Bryan ~~Miller~~.

11
12 HUNTER: Bryan ~~Miller~~, okay. All right, at that time as far as the
13 cause was strictly a channel or pressure spike in the containment but
14 you did not have any feeling for what would cause that kind of problem?
15

16 CHWASTYK: No, I did not.
17

18 HUNTER: We have indications that some electrical buses tripped and that
19 same time, during that the same time frame possibly do you recall that
20 event?
21

22 CHWASTYK: Yes. I recall something about it but I think at the time I
23 just dismissed it as having anything to do with the reactor building.
24
25

1 HUNTER: Okay, I just wanted to make sure that we clarify that. You sat
2 there at low pressure for a period of time okay, on the core flood
3 tanks, and you had the console?
4

5 CHWASTYK: Yes.
6

7 HUNTER: And you were receiving your orders from who at that time?
8

9 CHWASTYK: For any changes I had to go through Gary Miller who was
10 essentially the man in charge of the control room.
11

12 HUNTER: How did Mike Ross fit in at that time?
13

14 CHWASTYK: Mike Ross apparently had been called in because Jim Floyd,
15 our normal Unit 2 shift supervisor operations, was down in Lynchburg, VA
16 at simulator training, and Mike had been called in. Apparently Mike and
17 Gary...Gary was running this, was totally in charge of it but Mike had
18 been running the control room, and, I guess I am not sure because I
19 wasn't there, was giving suggestions to Gary on what should be done.
20

21 HUNTER: Was Gary giving you the instructions and then you were instruct-
22 ing the changes in the control room?
23
24
25

1 CHWASTYK: Well, yes. Any changes that would come up, now. At this
2 time we were still just maintaining this flow rate through the vessel,
3 the core flood tanks, floating on the vessel.
4

5 HUNTER: Okay Joe, did you recall any specific instructions for main-
6 taining a certain level high pressure injection flow?
7

8 CHWASTYK: Yes, I think 80 gallons a minute seems to be whatever I
9 remember.
10

11 HUNTER: Eighty gallons a minute? Total or ---
12

13 CHWASTYK: If I remember correctly it was eighty gallons a minute.
14 Maintain 80 gallons a minute flow through the vessel. I don't think it
15 was any further instructions than that.
16

17 HUNTER: Again you had the makeup panel. I want to make sure that that
18 was your particular position.
19

20 CHWASTYK: Yes.
21

22 HUNTER: Again, we are talking in the time frame when we were down on
23 the core flood tanks and they had been depressurized. You were floating
24 on the core flood tanks and they were there. We can see this is 11:30 -
25

1 12:00 o'clock, 1300 right in that time frame. Apparently it went on for
2 quite a while...there is a building spike by the way...and then the time
3 frame that the pressure is sitting barely fairly stable. Do you recall
4 maintaining that high pressure injection flow rate for a substantial
5 period of time or at any time during that day did you receive word from
6 somewhere from like Unit 1 or Gary Miller or a source to increase high
7 pressure injection flow?
8

9 CHWASTYK: Well, later on of course, when we went to go solid but that
10 was afterwards somewhere in the neighborhood of 3 or 4 hours later.
11 Prior to that I suggested to Gary Miller that we continue the high
12 pressure injection but stop venting through the pressurizer so we can
13 get the heaters on to establish a bubble back in the pressurizer and
14 sometime later Gary came back to me and told me go ahead and do that, to
15 maintain your flow through the vessel but stop venting and get the
16 pressurizer, get a bubble back in the pressurizer.
17

18 HUNTER: And at time Joe, you closed which valve?
19

20 CHWASTYK: We closed the electromagnetic and the isolation valve I
21 believe.
22

23 HUNTER: So you stopped the flow using both valves? Put the heat, did
24 you put the heaters on at that time?
25

1 CHWASTYK: Yes. I know one thing I don't remember. The heaters were
2 actually on at that time I think they were off, and we turned them on.
3

4 HUNTER: We have a printout on the heater breakers so we may be able to
5 put that together. Okay. So they were either on or you put them on at
6 that time?
7

8 CHWASTYK: That is true.
9

10 HUNTER: Did you in fact verify the pressurizer temperature was increasing?
11

12 CHWASTYK: Yes, we did.
13

14 HUNTER: And where would you verify that, would you watch it on the
15 computer or where would you read it?
16

17 CHWASTYK: I read it on the console temperature indicator.
18

19 HUNTER: Right on the console?
20

21 CHWASTYK: Right.
22

23 HUNTER: Then there was, do you recall when that particular...when that
24 particular change in velocity occurred generally? I am trying to get...maybe
25 there was an event...?

1 CHWASTYK: It was not very long after the spike. Okay, and the reason
2 was I saw the spike of course and it had correlated with Fred Scheimann,
3 who was the shift foreman who was on the console at the time, had just
4 opened the electromagnetic relief valve and the spike occurred.

5
6 HUNTER: Question, Joe. The electromagnetic valve and/or the block
7 valve?

8
9 CHWASTYK: No. The block valve at that time was still open.

10
11 HUNTER: It had been opened from early this morning so you fellows were,
12 in fact, using the electromatic valve itself?

13
14 CHWASTYK: Yes.

15
16 HUNTER: So it corresponded with that particular activity?

17
18 CHWASTYK: That is right, it corresponded with that particular activity
19 and it was some time after the event...someone mentioned that they had
20 heard a loud noise.

21
22 HUNTER: Did you hear the noise?

1 CHWASTYK: No, I did not hear the noise. But that was the point at
2 which I had assumed that we did have some kind of explosion in the
3 building. And that is when I suggested to Gary Miller we no longer
4 cycle the electromagnetic relief valve because it had...the explosion...or
5 rapid rising pressure in the reactor building corresponded to opening
6 the electromagnetic relief valve.

7
8 HUNTER: Okay, did it cross your mind at that time Joe that...that...was
9 fuel damaged? I assume that during your turnover that you realized that
10 you had damaged the core to some degree or did you have any idea?

11
12 CHWASTYK: At the time I wasn't aware of how much damage, like there was
13 not a very good turnover. It was like I said, everybody was pretty busy
14 and I didn't want to stop anybody from what they were doing so I just
15 tried to get a feel for what was happening by looking around and asking
16 the operators at the panel what they were doing. Up until the time or
17 sometime after the explosion and it dawned on me what it was, I didn't
18 know how much core damage we had. Of course, that plus later on when we
19 did start to draw the bubble in the pressurizer at about 100 and...as
20 the pressurizer level was coming down due to the increased temperature
21 in the pressurizer, at about 150 inches I had instructed the control
22 room operators to open up some of the 16s further, okay so that we...it
23 looked like our pressure was dropping so rapidly that essentially I
24 thought at the time we were short some water in the reactor coolant
25

1 or not there was core damage. It was only after the explosion that
2 it dawned on me that we did, in fact, have some core damage in
3 there because the Zirc water reaction created the hydrogen. That
4 is where I got nervous.

5 Until that time, I did not really know what the status
6 of the plant was. I only knew what I was told. But when I put
7 together the explosion and the hydrogen, I knew then that we had
8 suffered at least some core damage. I did not know how to
9 quantify it simply because, you know, it could have been a localized
10 explosion, like I mentioned earlier, or it could have been a minimal
11 amount of hydrogen.

12 That was about the time that I understood that we did
13 have core damage.

14 BY MR. MOSELEY:

15 Q Did you conclude this Zirc water reaction on March
16 28th?

17 A In my mind, you know, when I put the explosion
18 together and it was hydrogen, you know, it came from Zirc water,
19 it was just an assumption I made.

20 Q So you did conclude that the core had heated up
21 sufficiently to cause the Zirc water reaction.

22 A Yes.

23 Q You reached that conclusion in the afternoon of
24 March 28?

25 A Yes.

ALDERSON REPORTING COMPANY, INC.

1 CHWASTYK: My reactions, I actually saw the recorder, the pressure
2 recorder on the building, spike upward. I didn't know what caused it but
3 the fact that the spray valves started indicated to me that we actually
4 had some kind of pressure spike, either on the sensors on in the building
5 itself. I was not sure. The spike of course started all the building
6 spray pumps, decay heat pumps, etc. The pressure spiked up and it was
7 only up very briefly, as a matter of fact, a couple of heart beats. I
8 know because I missed those heart beats. It came right back down again.
9 I still did not know what caused it so I sort of hesitated on securing
10 all the equipment that started until I thought I had a better feel for
11 what was going on. Of course, I never did because the pressure came
12 down and stayed down, and then I ordered them the building spray pumps
13 and the DHV8s and everything closed. Stopped.

14
15 HUNTER: What was the -- the pressure came back to what level Joe?

16
17 CHWASTYK: It came back to somewhere around zero where I am not sure.
18 It came back to just about where it started from as a matter of fact, I
19 remember that.

20
21 HUNTER: Okay, we...it looks like the system had run about four or five
22 minutes when it was finally secured. Would you consider that amount of
23 time, the time it took you to evaluate the situation and see what was
24 going on?
25

HUNTER: Do you have any feel for that, the time frame?

CHWASTYK: Oh, I have no idea. It was...there was a lot of things happening. I remember it was just an oh-by-the-way type thing. How, exactly how long after the spike I don't know.

HUNTER: Do you -- who turned off the containment spray pumps? Specifically.

CHWASTYK: ^{miller} Bryan Miller.

HUNTER: Bryan Miller, okay. All right, at that time as far as the cause was strictly a channel or pressure spike in the containment but you did not have any feeling for what would cause that kind of problem?

CHWASTYK: No, I did not.

HUNTER: We have indications that some electrical buses tripped and that same time, during that the same time frame possibly do you recall that event?

CHWASTYK: Yes. I recall something about it but I think at the time I just dismissed it as having anything to do with the reactor building.

stop

1 CHWASTYK: No, I did not hear the noise. But that was the point at
2 which I had assumed that we did have some kind of explosion in the
3 building. And that is when I suggested to Gary Miller we no longer
4 cycle the electromagnetic relief valve because it had...the explosion...or
5 rapid rising pressure in the reactor building corresponded to opening
6 the electromagnetic relief valve.

7
8 HUNTER: Okay, did it cross your mind at that time Joe that...that...was
9 fuel damaged? I assume that during your turnover that you realized that
10 you had damaged the core to some degree or did you have any idea?

11
12 CHWASTYK: At the time I wasn't aware of how much damage, like there was
13 not a very good turnover. It was like I said, everybody was pretty busy
14 and I didn't want to stop anybody from what they were doing so I just
15 tried to get a feel for what was happening by looking around and asking
16 the operators at the panel what they were doing. Up until the time or
17 sometime after the explosion and it dawned on me what it was, I didn't
18 know how much core damage we had. Of course, that plus later on when we
19 did start to draw the bubble in the pressurizer at about 100 and...as
20 the pressurizer level was coming down due to the increased temperature
21 in the pressurizer, at about 150 inches I had instructed the control
22 room operators to open up some of the 16s further, okay so that we...it
23 looked like our pressure was dropping so rapidly that essentially I
24 thought at the time we were short some water in the reactor coolant
25

16 1 Q Do you think you definitely had made this recommen-
2 dation to Gary Miller by the time we reached shortly after the
3 hydrogen detonation?

4 A Yes, I had made the recommendation earlier. I had --
5 the recommendation to allow me to fill the system -- at that
6 time I didn't say to fill the system, to inject and draw a
7 bubble in the pressurizer. And I assume that was under
8 advisement of Gary Miller and Jack Herbein, who was at the
9 observation center at that time. It was right after the
10 hydrogen explosion and I mentioned that I correlated the
11 opening of the valve with the detonation period that I again
12 went to Gary Miller and explained what I thought had happened
13 as far as the hydrogen detonation and the simultaneous opening
14 of the valve, and it was shortly after that, Gary Miller got
15 back to me and said go ahead and draw the bubble.

16 BY MR. JOHNSTON:

17 Q What was it that you thought had happened that you
18 communicated to Gary?

19 MR. ALLISON: I have a line of questions.

20 MR. JOHNSTON: Okay, I understand.

21 MR. ALLISON: Well, go ahead.

22 BY MR. JOHNSTON:

23 Q Okay. I was just going to ask you, you just stated
24 that when you were aware of the pressure spiked, you went to
25 Gary and said something to him about what you thought it was?

15 1 PORV in the vent valve and try to lower the pressure as much
2 as you can. And a third one that can go with either one, is
3 the max the HPI flow.

4 Did you think at the time that you would have a better
5 chance of cooling the core with some combination of those
6 strategies?

7 A Yes, I did. My initial reaction was of course to
8 let the reactor coolant system fill and that was what I
9 suggested, not long after I took the console and then getting --
10 it was some time after the hydrogen explosion that I insisted
11 to Gary Miller on what I wanted to do and I requested permission
12 to do it.

13 Remember at this time I could not do anything on that
14 console without prior approval from Gary Miller.

15 Q So what was it that you wanted to do then?

16 A I wanted to fill the system going to at some higher
17 flow rate than we were going whether it was 80 gallons a minute
18 or not, I don't remember. But close up the pressurizer,
19 continue with the let-down and increase makeup flow, which
20 we did do eventually.

21 Q So this was your recommendation shortly after you
22 took charge of the control room?

23 A I think it was shortly after, but again, time during
24 that time frame had no meaning because it could have been an
25 hour, it could have been five hours, I don't remember.

1 March 28th?

2 A I don't remember specifically, but I'm sure I must have
3 I was not trying to keep it a secret or anything. There were
4 all kind of fellow shift supervisors and people I worked with
5 there, I'm sure I must have related it to someone. I don't
6 remember specifically.

7 Q It doesn't seem to have been general knowledge or
8 it doesn't seem to have been generally appreciated that there
9 had been a great deal of hydrogen in the system and a hydrogen
10 explosion until Thursday afternoon or even Friday morning
11 among many people here. Yet you seem to have put this
12 together in your own mind on Wednesday afternoon.

13 A There were people in that control room that knew it
14 happened, and I know specifically there was at least one
15 NRC inspector there. And I don't know who it was, I don't
16 remember his name or what he looks like. But I do know there
17 was an NRC inspector, because I remember him standing behind
18 Mehler when we shut down the spray pumps.

19 Q I want to ask you about that in just a minute, but what
20 I was trying to ask you is whether you can shed any light
21 on why so many people around here didn't seem to really put
22 all this together until Thursday or Thursday night or Friday
23 morning?

24 A I am not sure I understand that. You've got to
25 remember that -- I'm not sure I know what you're getting at.

1 Should we have made a press release or something?

2 Q No, I'm really talking about internally, there are
3 quite a few people from Met Ed who have told us and other
4 groups in interviews and depositions that they really didn't
5 appreciate the fact that there had been a possible hydrogen
6 explosion until Thursday or even in some cases Friday
7 morning. Yet, you seem to have figured it out fairly
8 quickly, and you say that there were other people around who
9 probably did or could have or might have.

10 I wondered whether you can recall this being discussed
11 Thursday morning or Wednesday night with other people?
12 Whether you knew if this was common knowledge?

13 A I'm sure that when I was relieved the next morning, I
14 passed that on, and I'm sure, I know that I must have talked
15 to people in the control room. Who specifically, I don't know.
16 Mehler is probably one. I'm trying to think of who else
17 was there. Kunder -- well, no, I didn't talk to Mr. Kunder
18 that day. Mike Ross is a possibility, I guess.

19 I'm fairly certain -- and again, I can't be absolutely
20 certain, but I'm fairly certain I reported it to Gary. I
21 guess my question is, who else was supposed to have known?

22 Q Well, Gary Miller says he doesn't recall himself
23 learning or realizing that there was a hydrogen explosion
24 till Friday morning; that's his best recollection.

25 Q Well, that could very well be true. Again, I can't

1 absolutely -- if Gary said -- I may not have told him what I
2 thought at the time, because I really wasn't certain.

3 Q We can only ask you your best recollection.

4 A I can only give you my best recollection.

5 Q I understand. Let me ask you this: Was there any --
6 strike that. Let me start it a different way: When you
7 saw this and then it together what you thought had happened,
8 that must have been something that gave you some cause for
9 concern?

10 A Yes. It scared the hell out of me.

11 Q Did you think that this was something that better
12 ought not to be generally broadcast around the control room
13 and outside? Was there any reason to keep this fairly close
14 among the people who were there in light of the fact that it
15 was fairly alarming?

16 A I'll say this: I didn't go out in the control room and
17 broadcast it, no. It did scare me, therefore, I'm sure I
18 didn't just make it general knowledge to everybody in that
19 control room. I'm sure I did pick out specific individuals
20 that, my counterpart types of people, and talked to them about
21 it.

22 Q You said you think that you probably discussed it
23 with Brian Mehler, and your best recollection is that you
24 discussed it with Gary Miller. Do you have a pretty specific
25 recollection of who else you may have actually discussed it

1 at the spray pump, he probably looked at the pressure indications
2 also. I don't really remember.

3 BY MR. GAMBLE:

4 Q What about Mr. Miller, was he already aware before
5 you discussed it with him that there had been a pressure spike?

6 A I don't know that. To the best of my recollection, I
7 think I asked someone to tell him that we had just had something
8 happen in the building that caused a pressure spike. I don't
9 remember who that was, and what they did, if they actually told
10 Gary.

11 MR. MOSELEY:

12 Q When you talked to him, he was already aware that the
13 pressure spike had already occurred?

14 A I assume he was, but again I make that assumption
15 because I did ask someone, I don't know who it was, to tell him
16 what had happened here, and "I am not sure what the hell ^{is happening} ~~is~~
17 ~~doing.~~"

18 Q He was back in the shift supervisor's office at the
19 time, as far as you know?

20 A Yes.

21 BY MR. CRAIG:

22 Q Did you, or are you aware of anyone else on the 3-28-79
23 monitoring any parameters such as containment temperatures,
24 reactor coolant pump inlet temperatures, or steam generator
25 pressures during or following the spike?

1 or was it throughout the whole building. You know, I had no
2 means of knowing those things.

3 Q On 3/28 or even 3/29 was the possibility of containment
4 integrity ever being breeched ever discussed?

5 A I am not sure "discussed" would be the proper word.
6 You know, it entered my mind that it may have been breeched. As
7 a matter of fact, the pressure dropping, you know, as fast as
8 it did, one of the things that came through my mind was that
9 possibly it did have some kind of pressure increase in the
10 building, and I think I mentioned this earlier, a steam leak,
11 and simultaneously containment was breeched and we are therefore
12 relieving the pressure. You know, we checked everything we
13 possibly could and found that wasn't the case.

14 MR. MOSELEY: What specifically did you check and whom
15 did you ask to check this?

16 THE WITNESS: Well, things like the steam generator
17 pressures, the containment isolation, you know, the valves to
18 ensure that the valves were closed, that were supposed to be
19 closed were closed, I think, and I don't really remember, you
20 know, I can't say, and this doesn't stand out in my mind, but I
21 think I had someone get the procedure for loss of coolant which
22 describes containment isolation and verify that, you know, what
23 was supposed to be isolated was in fact isolated. You know,
24 reactor coolant pressure, of course. There were a number of
25 things that we did check just to verify the fact that we did still

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20024 (202) 554-2345

1 have containment, and not only to verify that we did still have
2 containment but also to try to determine what caused it, you know,
3 did we have either a loss of coolant or a steam leak or something
4 that caused pressure to go up and simultaneously lost containment.
5 We checked everything we could and didn't find anything.

6 MR. MOSELEY: Did you specifically ask for the radiation
7 monitoring people to make a quick survey around the building to
8 see if there was activity leading out?

9 THE WITNESS: I remember directing someone to make
10 an inspection of the containment. I think it was an operator
11 type person. It wasn't a health, physics or radiation control
12 person,, and it was probably a shift foreman, a senior CRO, or
13 something of that nature, because you must understand how, you
14 know, the chain of command there is. Essentially the shift
15 foreman directs the operators, the control room operators primarily,
16 and the control room operators direct the auxiliary operators
17 who work out in the plant.

18 I asked and directed someone to make an inspection. Now,
19 I don't remember who, you know. It was just a possibility that
20 came into my mind, you know, that something in containment or
21 some part of the structure itself had possibly broken or fell
22 apart. I didn't really believe it but I thought it was something
23 that I had to check anyway.

24 MR. MOSELEY: Did you discuss with Miller, Kunder, Ross
25 or others that you were having these checks made?

1 MR. McBRIDE: Maybe the problem with the question is
2 could you explain who you mean the others to be?

3 THE WITNESS: Let me say, normally I would as part
4 of the report, you know, to the chain, in other words, Gary
5 Miller, I would not only explain what had happened but what I am
6 doing about it. Whether I did that in this case or not, I don't
7 remember.

8 MR. MOSELEY: What about to Ross or Kunder and maybe
9 Zewe? Zewe was the nominal shift supervisor at that time, right?

10 THE WITNESS: It is possible, but I really can't
11 remember. Again, you know, the way I work I would have under
12 normal conditions, and whether or not I did in this case I
13 just can't remember.

14 MR. MOSELEY: You just don't recall.

15 THE WITNESS: I just don't recall.

16 MR. MOSELEY: Do you recall whether you discussed the
17 results of these checks, some statement of confirmation that
18 everything is okay, we have checked the containment and it is
19 still good?

20 THE WITNESS: Again, no, I don't recall, but, again,
21 knowing the way I operate, I assume I would have. I don't recall
22 that I did.

23 BY MR. CRAIG:

24 Q Do you remember how long it took before you got a
25 report back on that check of the containment?

1 A I don't know that I ever got the report back on that
2 outside, you know, check of the containment. I guess I don't
3 remember because I think by the time they could make any kind of
4 inspection I had come up with the idea, and quote if you will,
5 of the hydrogen explosion. And I think after that I just sort
6 of forgot about the containment check.

7 BY MR. HOEFLING:

8 Q Joe, let me go back to something we have already talked
9 about. This is the instruction not to start electrical equipment
10 that we talked about earlier. What you basically said was that
11 the instruction was given on March 28th by Miller not to start
12 any electrical equipment in the containment.

13 Now, we have talked to Brian ^eMahler_A on this same
14 subject, about the instruction and when it was given. This is
15 how that spun out. On October 11th, '79 Brian testified on this
16 subject and he said basically what you have said that he recalled
17 the instruction having been given by Miller on the 28th. After
18 that he had some doubts, reconsideration, what-have-you, and he
19 later testified that he wasn't sure when the instruction was
20 given. He wasn't sure if it was given on the 28th or the 29th.
21 He still recalls such an instruction being given, but he didn't
22 know when it had been given.

23 We talked to Brian about this yesterday and asked him
24 what prompted him to think about this and begin to doubt the
25 time. He indicated that he had some conversations. Specifically

1 HUNTER: After the K-3 relay was jumpered the pump started without.

2
3 MEHLER: We bumped the pump, yes.

4
5 HUNTER: Okay. Let's move on a little further in the day.

6
7 MEHLER: I didn't realize it was that early in the morning we bumped
8 it.

9
10 HUNTER: Yeah, it may be ... it's a little suprising. I have two
11 sheets and the two sheets take us from the four o'clock trip out to
12 where we're going out to 16 hour ... the point where you get the pump
13 back on and then we consider in our investigation or in our program as
14 being from then on its recovery...that you're stable. I just use that
15 as a key.

16
17 MEHLER: Okay.

18
19 HUNTER: Okay. There was a discussion about -- in the afternoon
20 approximately 1:50 or so -- there was a spike in the containment to a
21 high pressure.

22
23 MEHLER: The spike in the containment occurred about 10 of 2. Some-
24 where around 10 of 2 or 2:00.
25

1 HUNTER: Were you in the area when that occurred?

2
3 MEHLER: When that occurred I was in the shift supervisor's office.
4 What alerted me to it is I noticed the CROs moving over towards the
5 makeup pumps and starting to secure them, and that indicated that we
6 had probably another ES. And there's two conditions that could have
7 caused it. Either low pressure, which we were already at, or a high
8 reactor building pressure of four pounds.

9
10 HUNTER: Okay, Brian, did you notice that the containment spray pumps
11 were on at that time?

12
13 MEHLER: Yes I did, I walked out and I went to the left side of the
14 console where the building spray pumps are. Previous to that I glanced
15 over the RP pressure indication and it was reading roughly in the
16 neighborhood of one to two pounds. At that particular point I looked
17 at the spray pump and they were running and I didn't know why, because
18 they should start at 30 pounds. So we secured the spray pumps because
19 there was no need to put the sodium hydroxide into the containment
20 all over the equipment.

21
22 HUNTER: Okay, Brian. Did you have the wide range pressure trench
23 recorder available to you for reactor pressure?
24
25

1 MEHLER: Oh yes.

2
3 HUNTER: Did you look at that?

4
5 MEHLER: Yes, after we secured the spray pumps I went back and checked
6 the recorders. And definitely there was a spike aligned straight up.
7 It went up to approximately 32 to 33 pounds and it came down in the
8 same line.

9
10 HUNTER: What did this mean to you? Did it mean anything at that
11 time?

12
13 MEHLER: First thought in my mind that someone was screwing with the
14 transmitter.

15
16 HUNTER: Do you know what activity the shift was involved in at the
17 time that today ignition or explosion occurred?

18
19 MEHLER: I didn't know at that particular moment what activities were
20 involved. Later on I found out.

21
22 HUNTER: Okay. And what did you find out later?

23
24 MEHLER: Well, later the only activity that could have caused the
25 explosion was some kind of spark because they opened the block valve --

1 no, no it was not the block valve. It was the vent valve from the
2 pressurizer to relieve some water. And that was the only thing that
3 could have given us detonation of the hydrogen.
4

5 HUNTER: Were they using the vent valve and the block valve on the
6 pressurizer? At different times?
7

8 MEHLER: At different times, yes.
9

10 HUNTER: What's the difference between using a vent valve and a block
11 valve for that activity? Is is a smaller line?
12

13 MEHLER: Maybe I screwed up.
14

15 HUNTER: Is it a smaller line?
16

17 MEHLER: The vent valve is 137 and that is smaller. I could be wrong
18 in that, it might have been the block. But I know it was one or the
19 other that they did open at that specific moment when...
20

21 HUNTER: Does the vent valve or block valve are those -- is that a
22 limitorque type motor on it? Is that electrical motor drive, that
23 type of a motor?
24
25

1 MEHLER: Yes. An electromatic has a pilot valve on top of it, which
2 causes that to open. The pilot valve actuates first.

3
4 HUNTER: Okay. There was some discussion that the ventilation reactor
5 building, refueling building and auxiliary building ventilation was
6 restarted at nine o'clock. Do you recall any discussion about that?

7
8 MEHLER: I don't know when it was restarted. I do know it was running
9 later in the day. I do remember seeing the control switches taped to
10 the "on" position.

11
12 HUNTER: Okay. You don't know when it was turned off or when it was
13 started?

14
15 MEHLER: It would have automatically tripped on the high radiation
16 levels.

17
18 HUNTER: Okay. Which high radiation levels automatically trip it?

19
20 MEHLER: Both the reactor buildings. I am sorry, not the reactor
21 building. Fuel handling buildings, aux building, and probably it
22 would have also tripped on the stack monitor, probably.

23
24 HUNTER: To restart that do you have to reset the actual radiation
25 monitor?

1 Q Which meant that there had been a pressure signal
2 that went through and started the building spray pumps?

3 A Right.

4 Q Then I think in your I & E interview you said later
5 you told Gary Miller --

6 A No, I don't believe I did say that. I did say that
7 I told an NRC man standing right along side of me and I
8 pointed out the pressure spike to him and told him that it
9 happened and why the building spray pumps came on because he
10 wanted to know.

11 Now you're going to ask me his name.

12 Q No, I'm not interested in that strangely enough.

13 A Well, I don't know it.

14 MR. ALLISON: Give me just a second to look at my
15 notes.

16 (Discussion off the record.)

17 BY MR. ALLISON:

18 Q Now, after looking at it in that initial dismissal,
19 did you later realize that there had been pressure in the
20 containment that caused that spike on the instrument?

21 A Yes.

22 Q Do you have any idea what could cause that kind of
23 a rapid pressure spike?

24 A I know Joe and I talked about it later on that day,
25 about what could have caused it and I don't think hydrogen

Acc. Federal Reporters, Inc.

444 NORTH CAPITOL STREET
WASHINGTON, D.C. 20001
(202) 247-3700

1 entered into it. We thought maybe some kind of chemical
2 reaction or something happened because it was up and down so
3 quick.

4 Q That is Joe Chwastyk?

5 A Yes.

6 Q So you really didn't have a good diagnosis?

7 A I personally didn't think hydrogen could form that
8 quick in the building to that concentration to cause it in
9 that period of time.

10 Q Did you connect the spike with the fact that it
11 just happened after the vent valve had been opened?

12 A No, later on, yes... Two days later when everyone
13 became concerned, yes.

14 Q But not on the 28th?

15 A We were told, someone must have connected it,
16 because we were told not to start any pumps, not to do anything
17 that could give an ignition.

18 Q Were you told that on the 28th?

19 A Yes, in a supervisor's office. I forget who told
20 us that, so it was someone who was honed in on something.

21 Q It sounded like somebody made a connection with
22 hydrogen?

23 A Who, I don't know. I would have to make an assump-
24 tion and I don't want to do that.

25 Q Did you make any recommendations to Gary Miller --

nw 13

1 entered into it. We thought maybe some kind of chemical
2 reaction or something happened because it was up and down so
3 quick.

4 Q That is Joe Chwastyk?

5 A Yes.

6 Q So you really didn't have a good diagnosis?

7 A I personally didn't think hydrogen could form that
8 quick in the building to that concentration to cause it in
9 that period of time.

10 Q Did you connect the spike with the fact that it
11 just happened after the vent valve had been opened?

12 A No, later on, yes. Two days later when everyone
13 became concerned, yes.

14 Q But not on the 28th?

15 A We were told, someone must have connected it,
16 because we were told not to start any pumps, not to do anything
17 that could give an ignition.

18 Q Were you told that on the 28th?

19 A Yes, in a supervisor's office. I forget who told
20 us that, so it was someone who was honed in on something.

21 Q It sounded like somebody made a connection with
22 hydrogen?

23 A Who, I don't know. I would have to make an assump-
24 tion and I don't want to do that.

25 Q Did you make any recommendations to Gary Miller --

Acc. Federal Reporters, Inc.

444 NORTH CAPITOL STREET
WASHINGTON, D.C. 20001
(202) 347-3700

89-1

nw 14

1 with regard to that pressure spot either immediately after it
2 happened or later on on the 23th?

3 A No. It's very hard. I would like to put the time
4 together, but I can't. I can't. I do know sometime after the
5 pressure spike happened we were told not to start equipment
6 because they assumed that it could happen again and they
7 probably put it that there was hydrogen in there, but that was
8 sometime after 1:50. Now how far past that, I don't know.
9 And I do not, I said -- well, to Gary Miller I said -- he said
10 don't start any more oil pumps and I said we don't have to, I
11 already tested them all, because they were concerned -- but he
12 far into the afternoon at that time, I don't know whether it
13 was 4:00, 2:00 or what, but it was sometime after.

14 Q Now basically this was a site involvement in the
15 plant operation when you went out to see what happened, was it
16 not? When the radiation alarms came in, did you become
17 involved in emergency plan business?

18 A Basically I became involved in setting up -- I sent
19 somebody downstairs to the control room down there to establish
20 communications and we were making notifications immediately.
21 I went through the procedures to make sure we were doing them
22 all and sometime in that medium -- oh boy, Jim Schielinger
23 showed up and took control of that. I then, sometime along the
24 line that day, we broke vacuum and we were going through the
25 atmospherics and the State of Pennsylvania said no and I got

Ace Federal Reporters, Inc.

444 NORTH CAPITOL STREET
WASHINGTON, D.C. 20001
(202) 347-3700

89-2

1 Wednesday or 6 Thursday?

2 Mr. Mell. I came to the plant about 6 o'clock Wednesday,
3 and I worked through until the following morning, until 7 or 8
4 o'clock in the morning.

5 Mr. Arena. During that time in the control room, did things
6 quiet down a little in terms of the number of people there and
7 all of that during the duration of the shift from that night until
8 the next morning?

9 Mr. Mell. What do you mean by quiet down?

10 Mr. Arena. The impression we have gotten is at least,
11 certainly during the afternoon of Wednesday, there were lots of
12 people in the control room, there were plant people, NRC people,
13 B&W people -- maybe to back up, when you got to the control room
14 at 6, how many people were there?

15 Mr. Mell. The control room was full, but the people were
16 -- like we have a roped-off area up there in the front.

17 Mr. Arena. The lines around the floor?

18 Mr. Mell. Most of the people were behind that line to where
19 the operator could get up there and operate. Our bosses were
20 there suggesting different things, talking to us, allowing us to
21 essentially -- I didn't have any problem to operate up there.
22 There were a lot of people there, but even when I got there at
23 6 o'clock it wasn't that excitable. People were quiet and doing
24 their job.

25 Mr. Arena. But did the control room stay full during the

1 night?

2 Mr. Mell. I really couldn't tell you. We were so busy all
3 night. I never kept track.

4 Mr. Arena. During that night, what do you recall being --

5 Mr. Blush. Before you go on to that night, I have a question
6 about the 28th. Was there any discussion when you came on about
7 whether or not the core coverage was being maintained? Were
8 people concerned as to whether or not the core was covered at
9 that point?

10 Mr. Mell. Well, when I first came on, or there shortly
11 afterwards, we were worried about getting the reactor coolant
12 pumps started. Because we were worried about getting them
13 started, I would say, yes, they were concerned about coverage
14 to the core because you start the reactor coolant pump, you have
15 got water in there.

16 Mr. Blush. But I mean, do you remember that being factored
17 into the consideration of starting the reactor coolant pump,
18 that they were not certain that the core was covered?

19 Mr. Mell. Nothing was said to me, if that's what you are
20 asking.

21 Mr. Blush. That's what I am asking.

22 Mr. Mell. Although they were concerned about starting the
23 reactor coolant pump. To me that would mean they were concerned
24 about getting water into the core.

25 Mr. Arena. And when did they finally get that pump started,

1 do you remember?

2 Mr. Mell. A time?

3 Mr. Arena. Yes. About 8 o'clock?

4 Mr. Mell. I really couldn't tell you the time frame because
5 that was quite some night.

6 Mr. Blush. Early on in the shift?

7 Mr. Mell. Early on in the shift, yes.

8 Mr. Arena. Did they try to start more than one and were
9 only able to get one going, do you recall? Was it a cautionary
10 thing of trying to get one going and see if it would be advisable
11 to start the others?

12 Mr. Mell. We started the one. In order to start that, we
13 had to jump routes and different relays, starting interlocks.
14 As far as I know, we were going to start another one, but that
15 was cancelled for some reason. I really couldn't tell you why.
16 Discussions were going back and forth all night trying to figure
17 out what would be the best way to take care of it. I believe
18 they were discussing starting the second one.

19 Mr. Arena. While you were on shift, did they go ahead and
20 get any other reactor pumps going?

21 Mr. Mell. Did we start one?

22 Mr. Arena. You got one started?

23 Mr. Mell. Right.

24 Mr. Arena. And subsequent to that one, did you start any
25 others?

1 Mr. Mell. Not to my knowledge.

2 Mr. Arena. Back to the evening. The control room was full
3 about 6. Did it stay full until the next morning or did it
4 thin out a little bit behind the line, people were going home?

5 Mr. Mell. I can't tell you.

6 Mr. Arena. Do you remember hearing during that time frame
7 any discussions about the existence or the presence of hydrogen
8 either in containment or in the system itself?

9 Mr. Mell. Hydrogen itself, no. That we did have a bubble,
10 yes, we talked about that after we started the reactor coolant
11 pump. The way the plant was responding it wasn't responding
12 normally and one of my co-workers suggested we had a bubble some-
13 where.

14 Mr. Blush. Who was that?

15 Mr. Mell. Ted Elljes. He suggested as soon as we started
16 the pump, that reacted sluggishly and there probably was a bubble
17 somewhere. He suggested it was in the steam generator, being a
18 higher point.

19 Mr. Arena. During the evening, do you remember anybody
20 looking at or discussing the reactor building containment pressure
21 strip chart?

22 Mr. Mell. That was shown to me when I came in on the after-
23 noon. The man I relieved showed that to me. He said today they
24 both went up and the pumps came on. So he said they looked at
25 it, the pressure went back down, they turned the pumps off.

RADIATION EMERGENCY PROCEDURE 1670.3

GENERAL EMERGENCY PROCEDURE

1.0 Discussion

A General Emergency is an incident which involves areas external to the site boundary and will require assistance from off-site support groups. A General Emergency is declared when:

- a. The Reactor Building high range gamma monitor indicates 8R/hr.

OR

- b. The radiation level at the site boundary is 125 mr/hr.

OR

- c. The liquid effluent radiation monitor (RML-7) indicates greater than $6.8 \times 10^{-3} \mu\text{C/CC}$.

2.0 Objective

To outline action required in the event that a General Emergency is declared.

3.0 Symptoms

Examples of symptoms of a General Emergency are as follows:

- 1. Off-site survey results indicate dose levels, down-wind from the site boundary, in excess of 30 Rem to the thyroid or 5 Rem to the whole body.

RADIATION EMERGENCY PROCEDURE 1670.3

2. Radiation monitor Rm-G8 indicates an exposure rate of 8 R/hr. in the dome of the Reactor Building.
3. Radiation monitor RM-L7 detects radioactivity in excess of $6.8 \times 10^{-3} \mu \text{Ci/cc}$ in the discharge to the Susquehanna River.

4.0 General Emergency Immediate Action

I. Station Superintendent/Assistant Superintendent/Shift Supervisor (back shift and holidays).

1. The initial actions and responsibilities are delineated in 1670.2 (Site Emergency Procedure).
2. Declare a General Emergency when any or all symptoms listed above are present.
3. In addition to 1 above, the Station Superintendent/Assistant Superintendent shall:
 - a. Request off-site support group assistance from any or all of the following, if results of off-site radiation monitor survey indicate dose rates that could result in a 2 hour off-site exposure in excess of 30 Rem to the thyroid or 5 Rem to the whole body. (See Figure #2)
 1. AEC Brookhaven (RAP) Radiation Assistance Program
 2. Radiation Management Corporation
 3. Medical Consultants

NOTE: Telephone numbers of above are listed in

Contact List Radiation Emergency Procedure 1670.14

4. Pennsylvania Bureau of Radiological Health.
5. State Police shall be notified to establish road blocks in the vicinity of Three Mile Island as indicated in Figure 1 of the Interface Plan found in Section 3 of the Emergency Plan.

RADIATION EMERGENCY PROCEDURE 1670.3

4. Inter-act and provide information to various groups outlined in the Interface Plan found in Section 3 of the Emergency Plan, i.e., Civil Defense, Bureau of Rad. Health, Coast Guard and State Police.
5. In the event Three Mile Island and/or off-site agency monitoring teams determine that the off-site radiation doses to the public exceed dose outlined in the State of Pennsylvania Radiation Protection Guide, found in the Met-Ed Radiation Emergency Plan (Section 4), recommend to State of Pennsylvania representatives that affected portions of the LPZ be evacuated according to Section 3 of the Radiation Emergency Procedure 1670.4.

NOTE: The State of Pennsylvania Radiation Protection Guide values for probable evacuation of LPZ are greater than 5 Rem whole body or greater than 30 Rem to the thyroid.

6. In the event the Bureau of Radiological Health cannot be contacted and the situation is catastrophic, causing severe danger to the local population, as determined by the Off-Site Monitoring Team, then the Station Superintendent/Assistant Superintendent, in conjunction with the State Police, will initiate evacuation of affected portions of the LPZ in accordance with Section 3 of the Radiation Emergency Procedure 1670.4. The Station Superintendent/

RADIATION EMERGENCY PROCEDURE 1670.3

Assistant Superintendent will use the following dose criterion for initiating LPZ evacuation in the event the Bureau of Radiological Health cannot be contacted.

1. Greater than 5 Rem whole body and/or greater than 30 Rem Thyroid.

II Duties of the following personnel during a General Emergency are outlined in Radiation Emergency Procedure 1670.2 -- Site Emergency.

- a. Shift Supervisor
- b. Control Room Operator
- c. Supervisor of Operations
- d. Station Engineer
- e. Supervisor of Maintenance
- f. Nuclear Engineer
- g. Radiation Protection Supervisor
- h. Chemical Supervisor
- i. Radiation Monitoring Teams
- j. Emergency Repair Party
- k. Security Guards

NOTE (1): It shall be the responsibility of all the above to provide maximum assistance and information possible to the various off-site groups, i.e., AEC, State of Pa., Bureau of Radiological Health, State Police, Civil Defense and Coast Guard.

NOTE (2): Should the General Emergency occur during other than normal working hours, then the Shift Supervisor will assume the duties of the Station Superintendent/Assistant Superintendent, Station Engineer, Radiation Protection Supervisor, Supervisor of Maintenance, until suitably relieved.

RADIATION EMERGENCY PROCEDURE 1670.3

NOTE (3): On determining that a possible General Emergency exists, the Shift Supervisor will immediately contact appropriate plant management in accordance with Administrative Procedure #1014 (Recall of Standby Personnel), found in Section 7, Three Mile Island Emergency Plan.

5.0 Post Emergency Action

1. Post Emergency Actions following a General Radiation Emergency are as outlined in Section 5 of Radiation Emergency Procedure 1670.2 (Site Emergency).
2. In addition to 1 above:
 - a. If portions of the LPZ were evacuated, persons will be provided shelter, food and clothing by the Civil Defense Organization of the State of Pennsylvania for duration of High Radiation levels in the LPZ.
 - b. If road blocks were established and no evacuation of the LPZ was initiated, the road blocks would be removed on direction from the State Bureau of Radiological Health.
 - c. Evacuated personnel will be permitted to reoccupy the LPZ when conditions are declared safe by the Pennsylvania Bureau of Radiological Health.

P R O C E E D I N G S

MR. GAMBLE: This interview is being conducted as a portion of the Nuclear Regulatory Commission's investigation into the exchange of information between the Metropolitan Edison Company and the NRC on March 28th, 1979.

At this time if you would raise your right hand to administer an oath.

Whereupon,

WILLIAM DORNSIFE

was called as a witness and, having been first duly sworn, was examined and testified as follows:

E X A M I N A T I O N

BY MR. GAMBLE:

Q Will you please state your full name for the record.

A William Paul Dornsife.

Q Okay. Thank you.

BY MR. MOSELEY:

Q Mr. Dornsife, it was perceived by the plant staff that shortly following the automatic shutdown of the reactor, the reactor was returning to criticality, as indicated by the source and intermediate range instrumentation.

To your knowledge, on 3/28, was this knowledge provided to the Commonwealth of Pennsylvania by the Met Ed or GPU organization?

A Not initially. The only indication that we got that

1 they were having some problem with return to criticality was a
2 boron concentration reading they did give us at about 9:00 a.m.,
3 when I talked to Gary Miller, and I think they were saying that
4 the levels were -- it's on my notes -- 100 parts per million
5 boron, which was way down from what it was before the trip, and
6 they suspected that a possible reason was a primary secondary
7 leak, and when the reactor pressure went low, they could have
8 got some secondary water into the primary. That's the informa-
9 tion they gave me concerning it.

10 Q Did they mention to you the source and intermediate
11 range instrumentation readings?

12 A No.

13 BY MR. CRAIG:

14 Q What discussions did you have with Gary Miller by
15 way of explanation of the 100 ppm reading?

16 A I was really pressed for time. In fact, I was about
17 half an hour late going to the Lieutenant-Governor's office
18 when I finally got the information, so I didn't have any chance
19 to ask any follow-up questions. It was just a matter of him
20 filling me in on information he had. It was not a real good
21 interchange, by me asking him questions. I just didn't have
22 the time to do it. It took a while for me to get ahold of him,
23 first of all, to get the information. I was really rushed for
24 time to get over there for the briefing. So it was just him --
25 a one-way information flow, basically. Very little. I asked

1 Q Yes.

2 A Yeah, there was a lack of direct communications with
3 what was going on. We had the open line, but again it was a
4 delay in getting information when we needed it. There could
5 have been better communications.

6 Q Do you feel the utility saw no need to pass this
7 information on to you?

8 A That could have been part of it.

9 Q Do you feel that other organizations within the
10 state may have received this, that is the --

11 A No, I can't imagine who, because we were the only ones
12 in direct communications with the plant at that point.

13 Q Okay.

14 A Now, unfortunately I wasn't invited -- it was an
15 oversight on the state's part -- to the meeting that occurred
16 in the afternoon with the operator, so I don't know what
17 information was passed during that meeting.

18 Q We intend to talk with others about that.

19 A Okay.

20 Q On March 28th, the reactor coolant pumps had been
21 secured and were unable to pump water because of the significant
22 voiding in the reactor coolant system hotlegs.

23 To your knowledge, on March 28, was this information
24 provided to the Commonwealth of Pennsylvania?

25 A Not that directly. The information -- the best

1 information I was able to sort out was the pumps were not
2 running, but the plant was being cooled by forced -- by a
3 feed-and-bleed method, and that there wasn't anticipated to be a
4 problem in continuing to use that method.

5 There was an indication that Gary Miller told me in
6 the conversation there was a possibility that there were bubbles
7 or some voids in the systems, but certainly not indicating the
8 core could have been uncovered. But there were fuel failures,
9 probably due, in his opinion, probably due to the low pressure
10 transient, some gap activity being released.

11 Q But specifically in terms of the voiding in the hotlegs
12 and the fact that the pumps were not pumping water, that was not
13 passed on to you as a specific piece of information?

14 A No, no.

15 Q Should this information have been passed on?

16 A Yes.

17 Q And again, if we can differentiate between how you
18 might have felt on March 28th and how you feel today, if you
19 would.

20 A It would have made a difference, obviously. It
21 would have probably prompted more questions. Any of these bits
22 of information could have, you know, sprung the point, "Hey,
23 you know, if this is the case, what are some of these
24 parameters?"

25 Q But on March 28th, you believe you would have felt

BY MR. HOEFLING:

Q But on March 28th, you felt that you were getting the information from the site you needed?

A Yeah. We had no reason -- I think I indicated to the Rogovin group, I never had any reason to believe they were holding anything back.

BY MR. MOSELEY:

Q Do you believe that other organizations within the state may have received this information?

A If they did, I don't know who. I don't know if any other organization would understand what it would mean.

Q Going to another specific, the reactor coolant pumps had been secured and were unable to pump water because of significant voiding in the reactor coolant system hotlegs.

To your knowledge, was this information passed on to you at BRP by Met Ed or GPU?

A I don't know that I got it, but I know there were notes to the effect that there were voids in the system, that there was something about -- some information come through to the effect --

Q Do you want to refer to this?

A (Witness examining document.)

There was something some place about, "We are going to shut the pump down to avoid cavitation," but I don't know if that's written.

1 Okay, here is an indication that they knew there was a
2 void in there alluded to as a bubble, which would suggest that --

3 Q I guess maybe the question that we can -- if I can
4 rephrase it slightly differently. Did you have a perception on
5 March 28 that they could not run the pumps because of the
6 amount of voiding that existed in the loops?

7 A I think it was on the -- I knew on the 28th, there
8 was words to the effect that there were voids in the system.

9 Q I'm trying to get some feel for cause and effect.

10 A The thing is, I'm not a nuclear engineer. Bill was
11 doing most of the talking. We knew things were not wonderful.
12 That's about as far as I can legitimately talk about it.

13 Q Okay.

14 A And without going into speculation or whatever.

15 Q Do you feel that this information, that is the fact
16 of the amount of voiding and its effect on primary coolant
17 pump operation, do you feel that should have been passed on to
18 you at BRP?

19 A It should have been passed to the state, yes, and I
20 think in a way maybe it was, sort of, you know, in light of
21 you have voids in the system, you have to kill the pump to
22 avoid cavitation. You know, to that extent.

23 Now to the extent of how big this void was physically,
24 you know, in terms of the bottom line being the core is uncovered
25 we didn't have that information, or that didn't sink in. It

1 would have asked for more information. I don't believe that we --
2 you know, the technical features of what was happening
3 individually with components in the reactor at that time, we
4 considered important for our activities related to the accident.

5 We didn't know, for example, that NRC had not been
6 contacted until 8:00 o'clock. We assumed they were contacted
7 at the same time we were contacted, and that they were on their
8 way.

9 So, you know, by -- and they were in contact with
10 them over the telephone, the same way they were in contact with
11 us, only someone else -- we didn't ask. We just made the
12 assumption the NRC was aware of what was going on, and they
13 were handling that aspect of it.

14 Q Okay. I think you have answered generically a number
15 of questions I have here, but I think just for clarity we would
16 go through these and get a specific answer to some of these.

17 Do you feel that other organizations within the state
18 may have received the -- again right now I'm specifically talking
19 about the source range and intermediate range nuclear
20 instrument readings?

21 A No.

22 Q On March 28th, the reactor coolant pumps had been
23 secured and were unable to pump water because of significant
24 voiding in the reactor coolant system hotlegs.

25 To your knowledge, was this information passed on to

1 you?

2 A I am not sure if that -- I didn't look again at these
3 notes, especially the notes that Bill took, before coming over
4 here. We had another minor problem today at Three Mile Island.

5 Q I'll be happy to let you review them, if that would
6 help you.

7 A I don't think so, early on. Later in the day we may
8 have been told that. We knew that there were some voids early
9 on, some voids in the system, but I don't know if that -- if
10 the actual reactor coolant pump problem we were privy to during
11 the first day.

12 Q You were not sure or don't know -- and I'd like for
13 you to say which -- but let me finish the question, whether or
14 not you had a belief that the pumps could not be run because of
15 the extent of the void?

16 A I was under the impression that the pumps were shut off
17 because of vibration, and I believe that information came from
18 NRC inspectors onsite, rather than from the operators.

19 Q So this would have come some hours later?

20 A Well, it would have come after 9:00 o'clock, 9:30 in
21 the morning, when they arrived. The time, you know, went by so
22 fast it seemed like they were there before we had plotted the
23 dose rates across the river, so it -- and we were talking to them..

24 Q Again I'd like to ask you if you believe this informa-
25 tion -- again on the ability of the reactor coolant pumps to

1 wasn't said in those words, or wasn't understood, whatever.
2 It's one of my key points before the action, was if the core is
3 uncovered, you have necessarily big trouble, and to that point
4 I used to have sort of a set point in my mind that if the core
5 is uncovered, you are going to pack up the folks and move them
6 out, and if I had known that on the 28th, you'd still have a
7 wrecking crew still trying to get me off the wall, to be perfectly
8 honest.

9 Q Well, I'm not sure this is worth further pursuit, but
10 let me try it.

11 A Try it.

12 Q The sense that I am trying to understand is whether
13 or not you had the feeling that this voiding was of high
14 significance in leading us down to this core uncover, or that
15 it was an operational inconvenience.

16 A It sort of had the flavor of an operational incon-
17 venience, if memory serves.

18 Q Why do you feel this information wasn't passed on to
19 you?

20 A The way you are phrasing the question suggests that
21 this was indeed the case, and they knew it, right? Am I to assume
22 that?

23 Q Yes.

24 A Okay. The framework of your question is indeed a
25 fact. Assuming that that was the case, I have no idea why it

1 this is something he should have told you?

2 A Yes.

3 Q Okay. Or they should have told you.

4 A Yes.

5 Q Again I would like to ask you why you feel this
6 information was not passed on to you.

7 A Again probably the same reasons I gave for the other.

8 Q Okay. And then I will ask you -- I won't go through
9 the list of questions again, but could I ask you whether you
10 feel that other organizations within the state may have been
11 given this information?

12 A I don't believe so, not to my knowledge.

13 Q Another fact, the electromatic relief valve had been
14 stuck open for a period in excess of two hours. To your knowledge
15 on March 28th, was this information passed on?

16 A Yes, it was, in conversation with Gary Miller, he
17 told me the valve had been stuck open. The indication was faulty,
18 and it wasn't indicating the proper position on the indicator,
19 and the valve was now closed. But this was again at 9:00 a.m.

20 Q Did he tell you how long the valve had been open?
21 Maybe not two hours, but a long time? Or do you recall a period
22 of time?

23 A I think he indicated it was open for a fairly long
24 period of time, I believe.

25 Q Okay. Before we started the interview, you gave us

1 some notes that had been taken on that day. Can you refer to
2 those notes and point to us the note that you may have made
3 that would reflect on this?

4 A (Witness examining document.)

5 I don't believe it's on those particular notes, but I
6 did write a more detailed list of things that Gary did tell me
7 very shortly, a few days after this particular conversation,
8 because at that point I realized it was going to become a very
9 critical piece of information.

10 Q Do you have a copy of that?

11 A Yes, I do.

12 Q Could we take a look at that?

13 A This is basically my recollection of the first -- of
14 what I did from 0700 when I first received the call from
15 Clarence Deller up until, oh, about 9:00 a.m., when I received
16 a call from Gary Miller. It includes that conversation. And
17 this again has not been given to anybody officially. This
18 information -- and this has been given in other records -- this
19 is something I wrote down on my own after, I would say, two
20 weeks after the incident occurred.

21 Q I was going to ask you to try to identify when this
22 was prepared. Would you say it was within two weeks?

23 A I would say within two or three weeks after, yes.

24 Q Then I'm trying for as much specificity as we can get
25 here, would you say by the middle of April?

1 A Yes, I would say by the middle of April.

2 MR. MOSELEY: Let's take a short break.

3 (Recess.)

4 MR. MOSELEY: During the short recess, we have
5 reviewed the three pages of notes or report -- I don't know
6 how to title it.

7 THE WITNESS: Recollection is probably more like it.

8 BY MR. MOSELEY:

9 Q An area I would like to pursue just a little bit more
10 has to do with what Miller told you about the valve having
11 been stuck open and the block valve having been closed.

12 Do you recall any discussions of inventory deficiency
13 or deficiency of primary coolant as a result of this valve
14 having been open for an extended period of time?

15 A Other than him saying possibly there were voids in
16 the system, he didn't know how big, I believe he might have said
17 possibly the candy canes could have been blocked.

18 Q Did he relate the opening of the valve or the valve
19 having been open as the cause of these bubbles or voids?

20 A I believe so, yeah. That would be obvious, the only
21 way to do it, to remove the inventory from the system. I don't
22 know if he specifically said that. It was just, you know,
23 assumed on my part that was the reason.

24 Q But that's an assumption you made on March 28th, based
25 on what Mr. Miller had told you?

1 A I believe so, yes.

2 BY MR. HARPSTER:

3 Q Do you recall, in looking at your notes, the plant
4 was characterized as being stable at some later point. Was
5 this as a result of the block valve having been closed, that
6 they now felt that the transient was stable?

7 A I believe it was that, along with the feed-and-bleed
8 cooling they thought was taking place as being a stable mode.

9 BY MR. MOSELEY:

10 Q Did Miller characterize this, the open block valve,
11 as being the cause of why the plant was in the condition it was
12 in?

13 A I don't think directly, but I inferred that was the
14 case.

15 Q Can you give us any benefit of your recollection of
16 what he actually said to you?

17 A It's been so long ago. It was difficult to write
18 those recollections or other set of papers. I really have no
19 idea. Things were going so fast at that point, a lot of it was
20 a blur.

21 BY MR. CRAIG:

22 Q Did you believe the plant was stable when you got
23 that report?

24 A Yeah. I guess so. That was what I told everybody.
25 I didn't really question, I didn't have time to question that

1 FASANO: What time did you actually take over the console?

2
3 ILLJES: I think the log says around 1820, or somewhere in 1800.

4
5 FASANO: O.K. So it was close to 6:30?

6
7 ILLJES: Right. 6:30 p.m.

8
9 FASANO: You actually started to manipulate approximately 12.5 minutes and
10 when you go back again, when you just got to the control room, how did it
11 appear to you? How were things being conducted?

12
13 ILLJES: Well, the shift supervisor was running it. He was at the console
14 and he was directing each and every move of the control room operator, and
15 that's the way we operated more or less the same way. Anything that we
16 did, any recommendations that we did, went through the shift supervisor.

17
18 FASANO: This was Mr. Zewe at the time, when you came in?

19
20 ILLJES: When we came in, I believe Joe Chwastyk had relieved Bill Zewe.
21 He was directing our operations at the time.

22
23 FASANO: Let's see. The primary, you were on the primary?

1 ILLJES: The primary side. We were taking care of the reactor coolant
2 pumps, pressurizer, make up system. That's the left hand side of the
3 console.

4
5 FASANO: That would be close to the reactor building, wide range-narrow
6 range indication?

7
8 ILLJES: Correct, correct.

9
10 FASANO: Do you recall being briefed on the wide range-narrow range reactor
11 building indications?

12
13 ILLJES: I was told that they had a spike on both indications of the reactor
14 building pressure recorder. There was some discussions as to what it was.
15 A hydrogen explosion was discussed. This was later on in the evening.

16
17 FASANO: How late in the evening?

18
19 ILLJES: Oh my.

20
21 FASANO: You took the controls at 6?

22
23 ILLJES: At 6. Well....
24
25

1 FASANO: 6:20 or so?

2
3 ILLJES: No, I would say it was more... It was later cause we were... It
4 was after we drew a bubble. O.K. If I want to relate it, I would say it
5 was after we drew the bubble in the pressurizer which we did after that.
6 As far as what time that was mentioned, as far as we discussed it, I know
7 it was discussed when we turned over, when we came in, but we didn't make
8 any bones about it because we were interested in getting flow through the
9 reactor and the bubble in the pressurizer and so. They had recovered from
10 the building isolation high pressure injection. They had recovered from
11 that situation, and our concern was cooling the reactor and insuring it had
12 flow. Later on when we had things stablized, we had a bubble in the pressur-
13 izer and had a reactor coolant pump running and that term area, we were
14 discussing with, I can't remember if it was one of our engineers. But we
15 did have a pressure spike. We pulled it out and I don't know who wanted a
16 copy but we made a couple copies of the chart.

17
18 FASANO: O.K. This was sometime after 6?

19
20 ILLJES: Somewhere.... Hell, I would say it was after 8:00.

21
22 FASANO: After 8:00 that night?

23
24 ILLJES: Yea, I'd say it was if I had to put a time on it.
25

1 FASANO: Let's go back a bit. When you first came in, where there xerox
2 copies of that at that time?

3
4 ILLJES: I don't know.

5
6 FASANO: You didn't see any?

7
8 ILLJES: I didn't see any.

9
10 FASANO: Discussion was not really centered on that? Or was it centered on
11 that to any degree that you remember?

12
13 ILLJES: No, it wasn't centered on that.

14
15 FASANO: As far as the ...?

16
17 ILLJES: It was over.

18
19 FASANO: Were you there when they were talking about it?

20
21 ILLJES: Not when I came in. I was there and I wasn't involved in any
22 discussion until it was brought up.... Except when it was turned over it
23 was mentioned that we did have a pressure spike, when we turned over. That
24 was the only thing that was mentioned, and that they had recovered from
25 reactor building isolation.

1 FASANO: So a pressure spike was discussed at the turn over, when you first
2 came in, about 3:45. And then somewhere about 8:00 further discussion and
3 also xerox copies?

4
5 ILLJES: Right.

6
7 FASANO: And apparently...

8
9 ILLJES: I think we remembered the xerox machine wasn't working too good

10
11 FASANO: At this time you discussed what and with whom, if you can remember?

12
13 ILLJES: We talked, I talked about it with the trainee on our shift, who
14 was Chuck Mell. And the person that asked for the information, and I don't
15 remember who that was, whether it was an NRC inspector or a B&W representa-
16 tive.

17
18 FASANO: Was any discussion related to this? Was the hydrogen burn or was
19 a real spike or was this discussed as an electrical spurious signal possibly?

20
21 ILLJES: This was discussed that evening but we also talked about it several
22 times after that and I cannot separate the two different discussions but as
23 far as I remember we related it to a cycling of the electromatic relief
24 isolation, which is a DC operated valve I believe and that has a contact in
25 there which will cause arcing which possibly could ignite the hydrogen.

1 That was discussed, but I can't say we discussed it that night. We didn't
2 really have that much time to do a lot of discussion, but we talked about
3 it and when I walked away from the panel, the guy that wanted the copy, you
4 know, he wanted it now, and I had to walk away from the panel to make sure
5 that the other guy, my shift supervisor, was there while I walked away
6 so...

7
8 FASANO: On the first evening, can you recall if on that first evening you
9 were discussing after 8:00 that it was possibly a hydrogen burn?

10
11 ILLJES: As far as I know that possibility was discussed that evening.

12
13 FASANO: With this engineer, you don't know whether he was GPU or NRC or
14 what? Can you recall?

15
16 ILLJES: No, I won't say. I don't remember. No. We... It was also that
17 night, you know, that we determined that we had a hard bubble and what that
18 bubble was, you know, we had talked about that too, you know... What is the
19 gas and is it hydrogen or other and all that water that went through the
20 reactor and out into the RC drain tank and out into the reactor building.

21
22 FASANO: So at that time it appeared to be still inconclusive within your
23 own ...?
24
25

REPORT OF INTERVIEW

Karl E. Plumlee, Radiation Specialist, Radiation Support Section, Fuel Facility and Materials Safety Branch, Office of Inspection and Enforcement, Region I, was interviewed telephonically on December 2, 1980, by Roger A. Fortuna and David H. Gamble of the Office of Inspector and Auditor (OIA). Plumlee indicated that he did not have his notes regarding the TMI accident readily available, therefore, his responses were based entirely upon his recollection.

Plumlee said he arrived at TMI's North Gate around 10:00 to 10:30 am on March 28, 1979, with four other Region I employees: Ronald Nimitz, Charles Gallina, Donald Neely, and James Higgins. He believed it took about a half hour to get in and that by 11:00 am they were certainly in the room adjoining the Unit 1 Control Room (CR). Upon arrival they were informed by Met Ed that all personnel entering the Unit 2 CR had to wear respirators; because respirators were in short supply, Met Ed asked that only two NRC inspectors go to the Unit 2 CR. Plumlee recalled that Neely and Higgins donned respirators and left for Unit 2 CR. He did not believe there was much delay after their arrival in Unit 1 before they left, so he estimated their departure time at 11:00 am. Plumlee said that Nimitz, Gallina, and he remained at Unit 1.

Plumlee said they established telephone contact from Unit 1 to Region I shortly after arriving. He recalled that about 11:30 George Smith (his branch chief) asked him to survey the radiation levels outside the buildings out of a concern over possible airborne releases. Plumlee said he conducted these surveys with Joe Manosky (a Met Ed plant operator) from about 11:30 until noon. Plumlee said he did not go inside Unit 2 then or anytime that day; he surveyed as close as Unit 2's innermost fence. Plumlee understood that Nimitz and Gallina continued to review Met-Ed's efforts in the Unit 1 CR during the time he (Plumlee) was surveying.

Plumlee said he returned to Unit 1 shortly after noon. He said that by this time Raymond Smith and another Region I inspector had arrived. Plumlee said that not long after he returned with his outside surveys, he discussed the condition of the plant with the senior Met Ed manager in Unit 1: Plumlee believed it was James Seelinger. Plumlee said they discussed things such as the plume and whether it came from the plant or the steam dump lines. Plumlee recalled that he informed Seelinger that because the wind was variable, the airborne radiation probably would get into Unit 1's air intake structure. Plumlee said it was only about a half hour later that the Unit 1 CR area became filled with airborne

radiation and the NRC inspectors were asked to leave because they did not have respirators. Plumlee said that he, Nimitz, and (he believed) Raymond Smith and the inspector who arrived with Raymond Smith all moved off the site to a reception center. Plumlee said Gallina remained at Unit 1. Plumlee said that he and Nimitz then performed (separately) offsite radiation surveys with Met Ed personnel. He believed that he next returned to the site about 5:00 or 6:00 pm that day, but that Nimitz did not return until the following day (March 29, 1979).

Plumlee related that he and the other inspectors were briefed on the status of TMI before they left Region 1 on the morning of March 28, 1979. Plumlee said that at the briefing he understood George Smith to say that one of Met Ed's samplings of the reactor containment atmosphere showed it contained 2.4 percent hydrogen. Plumlee said that when he sought to confirm this with George Smith after the briefing, George Smith said that he (Plumlee) was mistaken and George Smith actually had imparted that the containment had 2.2 pounds overpressure. Plumlee indicated that this exchange had him thinking about hydrogen during the day. He said that based on this concern, during his conversation with Seelinger (just before being asked to leave Unit 1 in the early afternoon), he asked Seelinger if he had any better information about hydrogen content in the Unit 2 containment. Plumlee explained by way of background that the only gas analyzer at TMI which could detect hydrogen was in Unit 1; so samples pulled from Unit 2 were taken to Unit 1 to be analyzed. Plumlee recalled that Seelinger had a sequence of numbers representing the percentage of hydrogen in each of the samples tested. He recalled that Seelinger had varying amounts, with a lower current figure than the one Plumlee thought George Smith mentioned (2.4 percent), but with another figure that was higher than 2.4 percent. Plumlee said that Seelinger indicated he had been in contact with a number of people in Unit 2 CR and that some Met Ed personnel had guessed that there might have been an explosion based upon the reduction in hydrogen levels. Plumlee understood that Seelinger received his instructions that day from TMI Station Manager Gary Miller, but Plumlee did not know whether the conjecture about the hydrogen explosion came from Miller.

Plumlee said his conversation had to have occurred between the times he arrived at Unit 1 (about 11:00 am) and left (about 1:00 pm) on March 28, 1979. He said that based upon surrounding events, he would estimate the time to have been sometime between 12:00 and 12:30 pm.

Plumlee did not recall anyone being with him when he discussed hydrogen with Seelinger. Plumlee said he did discuss with Gallina what he learned from Seelinger. Plumlee said Gallina was manning the telephone to Region 1 at the time and it was just at this time that they were told to leave Unit 1 because of the airborne radiation. Plumlee said that they (he and Gallina) did not report his information to Region 1 because they assumed the inspectors in Unit 2 CR (Neely and Higgins) were providing this information. He said it did not occur to him that the inspectors in Unit 2 CR did not know everything he knew. Plumlee said that in retrospect he has no indications that Neely or Higgins actually knew of the hydrogen content of the containment.

Plumlee related that two or three days after the accident, he and Gallina discussed his conversation he had had with Seelinger. He said that Gallina then indicated that he believed it occurred later in the day on March 29, 1979 (the day after the accident). Plumlee indicated, without refuting his recollection of when the conversation had occurred in relation to other events, that the conversation thus could have been either on the 28th or the 29th of March 1979.

Plumlee believed that in general, Unit 2 management was only following the policies they were expected to follow. He explained that it appeared Met Ed's main interest was to get the plant back on line to start generating electricity. Plumlee felt this influenced much of the underlying logic for the actions of Met-Ed personnel, and it is something of which they are not now proud. Plumlee said they followed a strict attitude of "mind your own business" vis-a-vis NRC until the problems got big enough that they realized it could not be done. Plumlee expressed the opinion that Met Ed only told NRC what it was bound to tell and that at his level, Met Ed personnel pretty much only provided the information that was asked of them.

INVESTIGATORS'NOTE: During his May 30, 1979, interview by IE (for "NUREG-0600"), Plumlee, described a number of details he received during a briefing re TMI about 8:15 a.m. on March 28, 1979. One of the details he recalled receiving was "...the fact that the containment building had the hydrogen present in the atmosphere in a significant quantity. I don't know whether it was 2% or 3%, but it was well above the detection limit..." (Tr.5 at line 8).

REPORT OF INTERVIEW

Karl E. Plumlee, Radiation Specialist, Radiation Support Section, Fuel Facility and Materials Safety Branch, Office of Inspection and Enforcement, Region I, was reinterviewed on December 3, 1980, by David H. Gamble of the Office of Inspector and Auditor. Plumlee indicated he had located his notes for March 28, 1979, and was providing OIA with a copy. He said the notes were taken on single sheets of paper which he numbered consecutively at the time. He said he was providing all his notes for the 28th except one page that only contained motel information.

Plumlee said it was common knowledge, even in Unit 1, that the trips associated with the hydrogen explosion had occurred. He said that it was obvious that the only thing that could have caused these trips (e.g., the actuation of the containment sprays) was a pressure increase in the containment. Plumlee said his notes reflect that he was at the North Gate on his way out at 1:30 pm; therefore, he estimated that he was asked to leave Unit 1 sometime around 1:20 pm. Plumlee said that by 1:50 pm he was probably at the observation center.

Plumlee said the first time he heard about the spike was from Gallina. He believed that Gallina told him about it immediately after he (Plumlee) informed Gallina about his conversation with Seelinger about hydrogen in Unit 2's containment.

Plumlee recalled that Gallina said he received this information either from the NRC inspectors in Unit 2 or from a Met-Ed person, such as Greg Hitz who was relaying information. Plumlee said that his belief that Gallina already knew of the pressure spike indicates that his (Plumlee's) conversation with Seelinger may have been on March 29, 1979, or even later.

Plumlee then related that the possible reasons Met-Ed and NRC may have had for keeping some details about the accident from being widely disseminated must be considered. He said that, if it were known that the accident was far beyond anything anticipated and that the fuel had lost much of its cladding, they would have run the risk of some Met-Ed employees walking out, some number of NRC inspectors deciding against going in, and a major problem of frightened citizens jamming the highways leaving the area.

Plumlee recalled what he thought he heard George Smith say during their briefing regarding hydrogen content of the containment. Plumlee said his guess at the time was that Met-Ed had told NRC (probably Smith or Eldon Brunner - another Region I branch chief) about the hydrogen and Smith "slipped" when he mentioned hydrogen during his briefing. Plumlee said that it was for this reason that he broached the subject of hydrogen with Seelinger.

Interview of Former Met-Ed Employee

James L. Seelinger, Manager, Facilities Advance Planning, Government Products Division, Pratt and Whitney Aircraft Group, United Technologies Corporation, West Palm Beach, Florida, (formerly Unit 1 Superintendent, Three Mile Island Nuclear Station), was interviewed telephonically at his residence on December 23, 1980, by David H. Gamble of the Office of Inspector and Auditor. Also participating in the conference call on behalf of Seelinger was Harry H. Voigt, Esq., of Lebouf, Lamb, Leiby, and MacRae, 1333 New Hampshire Avenue, N.W., Washington, D.C.

Seelinger stated that he knew NRC Inspector Karl Plumlee and recalled Plumlee's presence at TMI on the day of the accident (March 28, 1979). Seelinger said he could not recall any conversation around mid-day with Plumlee and could not recall discussing hydrogen content in the Unit 2 containment with him anytime that day. Seelinger said the only conversation he remembered having with Plumlee on the day of the accident was that night when they discussed radiation readings Plumlee had taken from a car off Route 230.

Seelinger was not aware of any analyses completed that day of the gas content in the Unit 2 containment. He was aware of one unsuccessful attempt to draw a sample in the morning by one of Richard Dubiel's employees. Seelinger said he recalled first hearing of data on hydrogen content in the Unit 2 containment sometime after the day of the accident - although he was not sure just when.

1 Dave Limroth who is a superintendent I still am required to support the
2 individual units superintendent, with the appointment of technical superin-
3 tendent, it allowed me to go through him to assist in priority between the
4 two units. Also, gave us a better direction in trying to support both of
5 them on a day-to-day operation. The superintendent technical support then
6 reports directly to the station manager as does the unit superintendent
7 from each unit.

8 DONALDSON: Then the, your group essentially is somewhat autonomous in that
9 the line or chain of command goes directly from yourself through one additional
10 supervisor directly to the station superintendent.

11 DUBIEL: That's correct. Station superintendent, the exact title means
12 Station Manager which is Gary Miller.

13 DONALDSON: Under you, would you briefly outline the first line supervisors
14 under your command?

15 DUBIEL: To the foremen level?

16 DONALDSON: That would be two levels, right?

17 DUBIEL: That's correct.

1 DONALDSON: OK let's take it down to the foremen level.

2
3 DUBIEL: OK. In the area of health physics I have Tom Mulleavy, reports
4 directly to me as radiation protection supervisor and below Tom, reporting
5 to Tom there are four radiation protection foremen. Did you want names,
6 Dale?

7
8 DONALDSON: Why don't you go ahead and fill those in.

9
10 DUBIEL: The four radiation protection foremen are: Joe Deman, Pete Velez,
11 Bob McCann, and Fred Huwe. They report directly to Tom, and are radiation
12 protection foremen. Also reporting to Tom are two radwaste foremen, Jim
13 Smith, and Leo Hydrick. Reporting directly me is a health physics engineer,
14 Len Landry who reports to me and works closely with Tom in handling most of
15 the project oriented problems, something that isn't a day-to-day type of a
16 problem. Also there is a radwaste engineer, Ed Fuhrer, who reports directly
17 to me, again working hand in hand with Tom in trying to solve some of the
18 problems associated with radwaste that are a little bit beyond the ability
19 or the scope of the foremen. In the chemistry area I have four, let me
20 back up, three chemistry foremen there is no chemistry supervisor in an
21 attempt I have and intended to follow through on as to structure similar to
22 the HP site. There is no chemistry supervisor so the three chemistry
23 foremen are all on a equal level. There is a unit 1, and I will refer to
24 it as a Plant Chemist, Gary Reed. Gary is very knowlegeable chemist in the
25 area of systems chemistry, demineralization, evaporation, the effects of

CRAWFORD: 7:10 to 7:15.

ESSIG: 7:10 to 7:15 and it was apparent then from the calculation anyway whether it was right or wrong at that time you assumed it was right since you couldn't find any errors in it that there was an apparently a dose rate of 40 R per hour in Goldsboro and that was perceived to be confirmed by dispatching the onsite teams survey at point GE-8 which is in the general direction of the predicted value of Goldsboro and then that measurement came back in at 0746 according to your sheet there.

CRAWFORD: Right and between the time that I told Dick Dubiel and I guess I came back and there was a lot of conversation between Dubiel, myself, and Jim Seelinger mostly between Dubiel and Seelinger that I was kind of standing there listening to you know what reasons there could be that the Dome Monitor was so high that this calculation was so high could that in fact be an actual number or could it be a bad number. I don't know how long that conversation went on.

ESSIG: Okay. Mike were you involved in any of those conversations between Dubiel and Seelinger? Were you asked for any input on this monitor as to whether or not it was reading?

BENSON: I don't correctly remember any. I may have to talked with Howard. I remember talking about the possibility of steam damage to it. I'm not sure if Howard got that from conversation with Dick and Jim or how it come about. I don't remember directly talking to Dubiel.

PRELIMINARY NOTIFICATION - NOT FOR PUBLIC DISCLOSURE

TMI-2

No: PN-NRC:I-38
Date: 3/28/79

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known at the time of this notification. IT SHOULD BE SPECIFICALLY NOTED THAT THIS NOTIFICATION MAY CONTAIN INFORMATION THAT LATER MAY BE DETERMINED TO BE INACCURATE OR INCONSISTENT.

Facility: Three Mile Island Unit 2
Middletown, Pennsylvania
(Docket No. 50-320)

Subject: NUCLEAR INCIDENT AT THREE MILE ISLAND - UNIT 2

The licensee notified Region I at approximately 7:45 AM of an incident at TMI-2 which occurred at approximately 4:00 AM at 98% power when the secondary feed pumps tripped due to a feedwater polishing system problem. This resulted in a turbine trip and subsequent reactor trip on High Reactor Coolant Pressure. A combination of Feed Pump Operation and Pressurizer Relief - Steam Generator relief valve operation caused an RCS cooldown. At 1600 psig, Emergency Safeguards Actuation occurred. All ECCS components started and operated properly. Water level increased in the Pressurizer and Safety Injection was secured manually approximately 5 minutes after actuation. It was subsequently resumed. The Reactor Coolant Pumps were secured when low net positive suction head limits were approached.

About 7:00 AM, high activity was noted in the RCS Coolant Sample Lines (approximately 600 mr/hr contact readings). A Site Emergency was then declared. At approximately 7:30 AM, a General Emergency was declared based on High Radiation levels in the Reactor Building. At 8:30 AM site boundary radiation levels were reported to not be significant (less than 1 mr/hr). The source of activity was stated to be failed fuel as a result of the transient, and due to a known previous primary to secondary leak in Steam Generator 8.

Contact:	D. Haverkamp	R. Keimig	E. J. Brunner	5240
	Prepared by	Section Chief	Branch Chief	Ext.

Distribution:

Dudley Thompson, Executive Officer for Operations Support, HQ
N. C. Moseley, Director, Division of Reactor Operations Inspection, HQ
G. Klingler, PN Coordinator

Transmitted to HQ 11:42 am 3/28/79
(TIME)

Transmitted to Other Regions _____
(TIME)

PRELIMINARY NOTIFICATION - NOT FOR PUBLIC DISCLOSURE

The Region RI Incident Response Center was activated at 8:10 AM and direct communications with the licensee and IE:Headquarters was established. The Response Team was dispatched at 8:45 AM and arrived at the site at 10:05 AM.

At 10:45 AM the Reactor Coolant System Pressure was being held at 1950 psig with temperature at 250°F in the cold leg. By 10:45 AM, Iodine-131 levels as high as 1.25×10^{-8} uc/ml and radiation levels of 3 mr/hr had been detected offsite.

There is significant media interest at the present time because of concern about potential offsite radiation/contamination. The Commonwealth of Pennsylvania and EPA have been informed. Press contacts are being made by the licensee and NRC.

1 this is something he should have told you?

2 A Yes.

3 Q Okay. Or they should have told you.

4 A Yes.

5 Q Again I would like to ask you why you feel this
6 information was not passed on to you.

7 A Again probably the same reasons I gave for the other.

8 Q Okay. And then I will ask you -- I won't go through
9 the list of questions again, but could I ask you whether you
10 feel that other organizations within the state may have been
11 given this information?

12 A I don't believe so, not to my knowledge.

13 Q Another fact, the electromatic relief valve had been
14 stuck open for a period in excess of two hours. To your knowledge
15 on March 28th, was this information passed on?

16 A Yes, it was, in conversation with Gary Miller, he
17 told me the valve had been stuck open. The indication was faulty,
18 and it wasn't indicating the proper position on the indicator,
19 and the valve was now closed. But this was again at 9:00 a.m.

20 Q Did he tell you how long the valve had been open?
21 Maybe not two hours, but a long time? Or do you recall a period
22 of time?

23 A I think he indicated it was open for a fairly long
24 period of time, I believe.

25 Q Okay. Before we started the interview, you gave us

1 A Yes, I would say by the middle of April.

2 MR. MOSELEY: Let's take a short break.

3 (Recess.)

4 MR. MOSELEY: During the short recess, we have
5 reviewed the three pages of notes or report -- I don't know
6 how to title it.

7 THE WITNESS: Recollection is probably more like it.

8 BY MR. MOSELEY:

9 Q An area I would like to pursue just a little bit more
10 has to do with what Miller told you about the valve having
11 been stuck open and the block valve having been closed.

12 Do you recall any discussions of inventory deficiency
13 or deficiency of primary coolant as a result of this valve
14 having been open for an extended period of time?

15 A Other than him saying possibly there were voids in
16 the system, he didn't know how big, I believe he might have said
17 possibly the candy canes could have been blocked.

18 Q Did he relate the opening of the valve or the valve
19 having been open as the cause of these bubbles or voids?

20 A I believe so, yeah. That would be obvious, the only
21 way to do it, to remove the inventory from the system. I don't
22 know if he specifically said that. It was just, you know,
23 assumed on my part that was the reason.

24 Q But that's an assumption you made on March 29th, based
25 on what Mr. Miller had told you?

1 Q Yes.

2 A Yes. I think --

3 BY MR. GAMBLE:

4 Q Mr. Gerusky, during the time interval from when you
5 received the calculated dose rate of 10-R per hour, and when
6 you received the actual Goldsboro other-side-of-the-river
7 measurements that caused everyone to discount the calculated
8 reading, was there any other information passed during that
9 time, any other onsite measurements or any other kind of informa-
10 tion which would tend to discount the original reading?

11 A I don't remember. I know that we were not very -- we
12 didn't really believe that evacuation would have to take place.
13 I don't think there was any time in there we felt we would have
14 to evacuate people. We just didn't want to take any chances,
15 even, until that reading came back.

16 BY MR. HOEFLING:

17 Q And how long was that, again?

18 A I don't know. I think in reconstructing it, or at
19 least the telephone -- the PEMA telephone duty log indicated
20 it may have been an hour, which surprised me a little bit the
21 first time I heard that, six months ago at another one of these
22 briefings.

23 BY MR. MOSELEY:

24 Q Going back, I have one more specific period to touch
25 on, as we have done in others. George Kunder, who is the utility

1 superintendent of Technical Support, told the Senate Investigative
2 Group that he and others had been concerned that the core had
3 been uncovered for a period of hours after 6:45 a.m.

4 To your knowledge, was this information passed on to
5 the Commonwealth of Pennsylvania?

6 A No, not until Friday, with Joe Hendrie's probably
7 second or third telephone call, or the visit to the Governor's
8 office where he informed us of that.

9 Q Should this information have been passed on to you?

10 A As a matter of fact, it may have been Thursday
11 night, in a telephone call from the Governor back to the onsite
12 NRC inspector, who said, "There are more problems than we
13 anticipated. There is a possibility the core was uncovered."
14 I didn't even know that telephone call took place at all until
15 reading it in one of the reports of one of the committees.

16 Q This was late Wednesday night?

17 A Thursday.

18 Q Thursday.

19 A That's when things started happening, Friday morning.

20 Q Yes.

21 A Thursday night and Friday morning, Washington started
22 to get involved.

23 Q I'm not sure, did you answer when I said -- did I
24 ask you, should this information have been passed on to you?

25 A Oh, hell, yes. I mean if --

1 any direct knowledge about this, I think we ought to ask the
2 questions of him.

3 George Kunder, the superintendent of Technical
4 Support at Three Mile Island, told the Senate Special Investigatic
5 that he and others had been concerned that the core had been
6 uncovered for a period of time after 6:45 a.m.

7 To your knowledge, on March 28th, was this information
8 passed on to the Commonwealth?

9 A No, it was not.

10 Q Should it have been?

11 A Yes, it should have been.

12 Q Why, in your view, was this information not passed on?

13 A Well, primarily because the people who were believing
14 that were not talking to us. It was the final data coming from
15 the utility to us, not the dissenting opinions. But I think
16 we should have been alerted that there is a question of whether
17 the core is uncovered, or whether the core is covered.

18 Q The fact that someone --

19 A There are people that believe the core may have been
20 uncovered, and why, you know, why they believe it.

21 Q Then if we are trying to characterize this, according
22 to my little list here, then you would say -- would you categorize
23 it as the utility didn't recognize or adequately evaluate this
24 information? Would it fit in that category?

25 A I believe it would fit in that category, yes.

1 arrived in the office, and the two of us were talking to the
2 person on the phone -- I think it was Dick Dubeal who we were
3 talking to at that point, and he gave us a quick and dirty
4 update based upon what we knew at the time, and it was very
5 quick and dirty.

6 We assumed NPC was on its way and had been told at
7 the same time, so I didn't pursue it any further, other than
8 what was happening offsite.

9 Q Then you didn't have a perception at that point as
10 to the extent of core coolant that had been lost?

11 A No, nor the failed fuel. There had to be failed fuel
12 to get those kind of readings. That was just, you know, an
13 automatic reaction. I wrote it down. I have no idea what --
14 it didn't make -- it didn't -- although it was hectic in the
15 background, there was an awful lot of noise on the telephone,
16 and it appeared that things were going to -- getting worse
17 rather rapidly, it still didn't seem like it was, you know,
18 approaching a loss-of-coolant type accident, the kind where
19 you would have a severe -- you know, a major loss-of-coolant
20 accident, from the telephone conversation. They were having
21 some problems, but nothing that serious at that point. That was
22 the general impression that I got from the telephone conversa-
23 tion.

24 Q It was perceived by the plant staff that -- this is
25 on the morning of March 28th -- that shortly following the

1 A No. Again, they didn't think we needed to know that
2 information. It was irrelevant to our activities.

3 Q During a good part of the day on March 28th, there
4 was superheated steam in the reactor coolant system.

5 To your knowledge, on March 28, was this information --

6 A No, to my knowledge, it was.

7 Q To your knowledge it was not. Should it have been?

8 A Well, in retrospect, yes.

9 Q On March 27th, what would you have answered?

10 A Yeah, I think so.

11 Q There was a serious inventory deficiency, a loss of
12 water or absence of water, voids in the large part of the --
13 both the steam generators and the hotlegs.

14 To your knowledge, on March 28th, was this inventory
15 deficiency communicated to the Commonwealth?

16 A Yeah, I believe we had information that the -- that
17 both -- both were dry and there may have been a leak from the
18 primary to the secondary side some time during that day, and
19 that may have come from that meeting with the Lieutenant Governor.

20 Q Was this the secondary side that was dry?

21 A Secondary side being dry.

22 Q I am thinking about the primary side and the extent of
23 the voiding, rather than that there was a void.

24 A No, I'm sure it was not. If it was, it didn't register
25 with me as being important.

1 Q March 27, same answer?

2 A We have always said if they had known that the core
3 was -- if the core had been uncovered and they couldn't get it
4 covered again, we would have evacuated people with no questions
5 asked. But we felt if we knew the core was uncovered, they
6 would have known the core was uncovered, and they could have
7 gotten it covered again. It just doesn't seem reasonable to me
8 that they knew the core was uncovered and didn't do something
9 about covering it.

10 Q Can you recall any other information which should have
11 been passed on to yourself or BRP on March 28, but was not?

12 A No. I really don't know how much they knew on
13 March 28th.

14 BY MR. GAMBLE:

15 Q I have one thing, Mr. Gerusky. It is something
16 more about the dose rate in Goldsboro. Do you know of any
17 subsequent recollections, if not by your office, maybe by PEMA
18 or anyone, as to the events that occurred during that early
19 time, the first reports of the calculated dose rates, the first
20 readings? Has anybody written any reports or recollections on
21 that?

22 A I don't understand your question.

23 Q I'm talking about the --

24 A Did anybody get anything in between the time?

25 Q No, no, no. Subsequent, days, weeks, months later, did

1 Q Now you have testified to others, and in fact I
2 notice on your note sheet of your knowledge of the 10-R per hour
3 prediction in Goldsboro --

4 A That's what they gave us.

5 Q Are there other records, notes, or reports or
6 accumulated recollections, any of those things, that might
7 contain additional information concerning --

8 A That particular --

9 Q -- that particular -- for instance, that we could use
10 to nail down more precisely the time in which you received
11 that information. Did you personally receive that?

12 A I think it was on the speaker phone. If I wrote it
13 down, I received it one way or the other, either on the speaker
14 phone or direct phone. Margaret Reilly was there, and she
15 went to get the maps to start her plot of the wind direction,
16 wind speed, and she -- so we both received the information, I
17 believe, over the speaker phone.

18 Q Do you recall what was told you -- what specifically
19 was told you which caused you to no longer give any credibility
20 to the 10-R per hour reading? I'm talking about surveys. What
21 surveys were made, for instance?

22 A Yeah, we were told that there were no onsite readings
23 of any consequence, in that wind direction. We were also told
24 that the containment pressure was still very, very low, and
25 that this was designed -- that the calculation he was using was

1 A Yes.

2 Q -- from the state on March 28th. Is that your view?

3 A Yeah. Essentially it was my feeling earlier on,
4 and maybe it's wrong, but that's the feeling I had.

5 Q So whatever information wasn't passed on, there may
6 have been a variety of reasons which would include that maybe
7 they didn't think you were interested in it, or --

8 A They forgot to tell us, or they didn't realize it
9 was a problem.

10 Q Okay. Any others that we could add to that list?

11 A Not really. I think it sort of characterizes the
12 situation.

13 Q Okay. Mr. Gerusky has testified and, in fact, it
14 appears on this note which he had taken, that there was a 10-R
15 per hour calculation made at Goldsboro.

16 A A projection, yes.

17 Q For Goldsboro. Were you aware of this on March 28th?

18 A Yeah, that was very early. That was on the order of
19 7:30, quarter to 8:00 in the morning.

20 Q Are there any other records, documents or any other
21 material that might bear on the information that was exchanged
22 with you, you or any other members of BRP, about this, other
23 than this note that I have in my hand?

24 A I have the distinct recollection at one time I wrote
25 some of this stuff down, especially having to do with some of

300 7TH STREET, S.W., REPORTERS BUILDING, WASHINGTON, D.C. 20021 (202) 554-2316

1 information I was able to sort out was the pumps were not
2 running, but the plant was being cooled by forced -- by a
3 feed-and-bleed method, and that there wasn't anticipated to be a
4 problem in continuing to use that method.

5 There was an indication that Gary Miller told me in
6 the conversation there was a possibility that there were bubbles
7 or some voids in the systems, but certainly not indicating the
8 core could have been uncovered. But there were fuel failures,
9 probably due, in his opinion, probably due to the low pressure
10 transient, some gap activity being released.

11 Q But specifically in terms of the voiding in the hotlegs
12 and the fact that the pumps were not pumping water, that was not
13 passed on to you as a specific piece of information?

14 A No, no.

15 Q Should this information have been passed on?

16 A Yes.

17 Q And again, if we can differentiate between how you
18 might have felt on March 28th and how you feel today, if you
19 would.

20 A It would have made a difference, obviously. It
21 would have probably prompted more questions. Any of these bits
22 of information could have, you know, sprung the point, "Hey,
23 you know, if this is the case, what are some of these
24 parameters?"

25 Q But on March 28th, you believe you would have felt

1 A I believe so, yes.

2 BY MR. HARPSTER:

3 Q Do you recall, in looking at your notes, the plant
4 was characterized as being stable at some later point. Was
5 this as a result of the block valve having been closed, that
6 they now felt that the transient was stable?

7 A I believe it was that, along with the feed-and-bleed
8 cooling they thought was taking place as being a stable mode.

9 BY MR. MOSELEY:

10 Q Did Miller characterize this, the open block valve,
11 as being the cause of why the plant was in the condition it was
12 in?

13 A I don't think directly, but I inferred that was the
14 case.

15 Q Can you give us any benefit of your recollection of
16 what he actually said to you?

17 A It's been so long ago. It was difficult to write
18 those recollections or other set of papers. I really have no
19 idea. Things were going so fast at that point, a lot of it was
20 a blur.

21 BY MR. CRAIG:

22 Q Did you believe the plant was stable when you got
23 that report?

24 A Yeah. I guess so. That was what I told everybody.
25 I didn't really question, I didn't have time to question that

1 much the information he was giving. We were relying on their
2 information at that point.

3 Q Well, if you could describe your impression of the
4 plant, why you inferred it was stable. The feed-and-bleed
5 method implies that they are cooling the core. Did Miller tell
6 you he had a cooldown rate, that the plant was being cooled
7 effectively?

8 A I recall someone along the line mentioning a cooldown
9 rate. Whether it was in that conversation or not, I'm not sure,
10 but I believe at one point on that day somebody mentioned a
11 cooldown rate.

12 Q In the morning or afternoon?

13 A Again, I don't know. I only believe somebody mentioned
14 a cooldown rate at some point.

15 BY MR. GAMBLE:

16 Q Somebody from Met Ed?

17 A Yeah.

18 BY MR. MOSELEY:

19 Q But you don't recall whether that was morning or
20 afternoon?

21 A No, I don't.

22 BY MR. CRAIG:

23 Q Could you relate that to before or after the
24 Lieutenant Governor was briefed by the Met Ed people?

25 A No, I can't. I really can't.

"Recollections" prepared by W. Dornsife in April 1979
Times are approximate

- 0705 - Received call from C. Deller, PEMA duty officer indicating that TMI has a site emergency and to call plant to get details
- 0706 - Called Maggie to inform her and verify number to call at plant site - only number we had was thru plant switchboard 944-4041
- 0707 - Called plant site - had difficulty getting through switchboard to Unit 2 control room - finally gave switchboard my home number to have control room directly call me
- 0710 - Shift supervisor called back to my home number. He told me the plant had suffered a transient and RB [reactor building] radiation level was high initiating the site emergency - things sounded very confused at this point in time - I tried to get a status of important safeguards without very much success - they did tell me that reactor was shutdown and RB pressure was about 1 or 2 psi - SI [safety injection] had been initiated and was cooling core - They informed me that they had sent out monitoring teams and there was no detectable radiation levels outside the plant. I then heard in background the announcement to evacuate the Unit 2 fuel handling and auxiliary buildings. At this point a health physics type got on the phone and things sounded extremely confused and finally he hung up saying he would call back.
- 0720 - Called office - talked to Diane - told her briefly about what had happened and I was on my way in to the office - told her first technical type who arrives in office should call Unit 2 control room immediately. I arrived in office about 0750. Tom was there with open line established to plant control unit. Plant had declared a general emergency about 0730 due to high radiation levels in the reactor building. There still were no releases outside plant. Met Ed monitoring teams were out and around.

I talked to plant to get a later status. As I recall, they said they were being core cool by feeding with makeup pumps and bleeding out through pressurized electromechanical relief valve. From the information that I was getting it sounded as if plant conditions were stabilized (In reality the core was probably being uncovered at this time and fuel damage was continuing).

For the next hour or so we kept getting plant status reports periodically. (The open line was not manned continuously by Met Ed. They would come to the phone when ready to report). Things seemed to remain the same with still no release occurring. At about 0900 I was asked by Middendorf or Duncan to go brief the Lt. Governor and attend a press briefing that was scheduled for about 1000. I called back to plant to get more details on what had initiated accident and what the present status was in order to brief Lt. Governor and Governor. At this point, Gary Miller, plant superintendent, came on the line and briefed me on what had occurred. His briefing was as follows (based partly on notes and partly on recollection):

At 4:00 a.m. a turbine trip from 98% power occurred - reactor shutdown automatically - violation of tech specs in that aux feed was valued out temporarily S/G may have boiled dry - electromechanical relief valve lifted but did not reseal - indication in control room (elec signal to valve) indicated that it had reseated - block valve upstream is now closed - High pressure safety injection was initiated - all safeguard system operated as designed - pressurizer may have gone solid and low pressure in primary probably caused flashing and bubbles in primary - may have temporarily lost main coolant circulation - even currently stabilized and cooling normally on A S/G - possible primary to secondary leak in B S/G - B S/G has been isolated - 100 ppm Boron in primary may have been diluted

by secondary to primary feedback thru tube leakage - there has probably been a slight amount of failed fuel no speculation as to amount RB dome monitor reading 600 R/hr - RB pressure or approximately 1 psig - fence post dose \leq 1 mr/hr - wind blowing to west currently sending monitoring team to Goldsboro

cooling mode - have
forced circulation water

at giant offset sample

$< 1 \text{ mm/hr}$

1923 latest

behind warehouse Pick G 6-17
B window open 150

80 Pick G

if low vacuum
vent to atmosphere with A 5/6
which is clean

200 01.10.11

(215) 488-1362

600 SM111

1000 psi 350 F°

15°F/hr - 3 to 4 hour

Self 7-54 C3 | Darnsife notes
Governor's office ~ 0900 3/28/79

100 ppm B

1 lb Pb per

fine port < 1 mm/hr

violation of the spec

primary

B SG bottled up

evacuate gas then

people going to Goldboro to monitor

shutdown

HP injection

primary to secondary leak

failed fuel - Temp lost HC watches.

600 R/hr

may have ^{had} bubble in primary

2030

2/28/79

~~2030~~

A RCP running 325°F in both loops

1100 psi in

cooling down A S/B with vacuum
shift bubble to pressure at 785 psi
lost some heater prep

25. F 300 psi into shutdown

cooling mode - have

forced circulation water

all recent offsite samples

< 1 mm/hr

1923 latest

behind window Pick 6 C-17

B window open 150

80 Pick 6

if low vacuum

sent to atmosphere with A S/B
which is clean

End of shift

2030

01-10-10

10-10-10

10-10-10

10-10-10

10-10-10

10-10-10

10-10-10

01-80-001 Volume 1 (3/28/79 - 3/30/79)
General Communications Record
TMI-2 Transient of 3/28/79

01-80-001
VOL. 1
(0745 3/28/79 to 0818 3/30/79)
GENERAL COMMUNICATIONS
RECORD
TMI-2 TRANSIENT
G.K. WANDLING & D.G. CULBERSON

CLASSROOM B ^{BEAM} 1105

TMI-2

CALL @ 1105

3/28/77 Page

~ 0400 98% Power

Loss of FW (POLISHERS SCREENED UP)

HPI

TRIP. TRIP
EXT. TRIP OF HIGH PRESS

PRZ SOLID

RCS PRES \geq 2500 #

DRAIN TANK RAPTURE DISC BLEW

FUEL LEAK?

800 R/HK IN DOME?

LOST FLOW INDICATIONS, TRIPPED PUMPS

INDICATION OF PRI-SEC. LEAK

0800 300° - 1500 #

SITE IN STATE OF EMERGENCY - ONLY ROS

AND MILLER HAVE BEEN ALLOWED ON SITE

THIS MORNING.

DON ROY, ET AL, CONTACTED - WILL SET UP

TASK FORCE - KARRASCH TO LEAD.

0900 - PRELIMINARY TASK FORCE / INFO MTG CLASSROOM

TO GET RECOMMENDED ACTIONS:

1. IMMEDIATE OPERATIONS:

ENSURE CORE COVERED / BEING COOLED (HPS &)

CALL BIFF FLOYD (TRNG) TO MET FD (INFO FROM
PRI/SEC LEAK B S/G

60,000 R IN DOME?

10⁴ COUNTS ON MONITOR # 748 (200 BACKGROUND)

100 MR/HR AT PERSONNEL ACCESS OUTSIDE BLK

TO DINE OFF-SCALE HIGH

NAT CIRC. COOLDOWN

IC TEMP 450° F (COMPUTER)

TC 250° F

ON SITE EMER

ON : OFF SITE RADIATION NEGLIGIBLE

WATER IN AIR LINES OF VALVES OF POLISHERS

WENT SHUT → LOSS OF FW (COND. PUMPS → BOOST)

ESPAS ACT.

WENT SOLID

STOPPED MU PUMPS, EST. LETDOWN

RUPTURE DISC BLOWN (SEMI-RED RLV2)

AUX FW INITIATION BUT NO FLOW TO S/G'S

~ 12 MIN > TRIP, S/G'S NOT DRY

LOW PRES OR 1200# (@ SATURATION?)
(POSSIBLE GAS BUBBLE)

SAW 1/3 DECREASE IN FLOW - TRIPPED RCP

* NEED RADIOCHEMIST - FUEL PROBLEM } START TO ST
YOCHEM/DILL (LRC) } ASAP* TO

CALL FROM SCHAEDEL @ ~ 1145 (HAD JUST TALKED
TO ROGERS)

2821
3407

~ SAME STORY ABOUT TRANSIENT

RCP: S/B

7 GOING SOLID STN B4B, IN LOOP

ACT. IN ATMO (LOW LEVEL) REPORTED

RELEASE FROM MRT ED TO NEWS.

RAD. TEAMS DOING SURVEILLING

NRC SENT TEAM TO ENVEST.

PH/SEC LEAK "B" S/L (S/L SAMPLES
"B" S/L ISOL.

KARASCH
WHAT TO DO
w/ w/o RCP

COOLING DOWN ON "A" S/L (FEEDING)

HPZ FROM BUST 12 HRS SHORTED OUT / STOPPED

USING GLEET ISOL. VALVES TO CONTROL

300° RCS ~ 115° (TC) (STRAT. CH. 111)

~ 2100 # RCS PRES. (PLANT SOLID?)

PLANS APPARENT TO COOLDOWN + DEPRESSURE

SPEC OF FUEL LEAKAGE - NO IND. OF FUEL L.S.

SOME LEVEL INCREASE IN RB SUMP

CCW + SI HAS BEEN INTERRUPTED

HIGH MOISTURE LEVEL IN RB

ROGERS TO CALL BY 1155 IF NOT, WE SHOULD
CALL SCHAEDEL

BEFORE STARTING A RCP

MEASURE RCP MOTORS PHASE TO PHASE

PHASE TO GROUND

KELLEY, WINKS, TWILLEY SHOULD GO TO OBSERVATION
CENTER TO GET ON SCRE OK

3781 - WAR ROOM

GET DATA ON COOLDOWN

SCHAEDEL CALL TO WAR ROOM @ ~ 130

RCS 495# FLOATING ON CFT'S

700° TA (NORTHWEST BRIDGE)

PRZ FULL

CONTROLLING WITH ELEC. RELIEF VALVE

HPI FROM BUST - SWITCHING OVER TO BLEED
TANKS (IN PROCESS)

"B" 5/6 ISOL. ~ 60% FULL OPERATE LEVEL

MIN. C/D FROM "A" 5/6

ATMOS DUMP VALVES IS HEAT SINK

GLAND SEAL LOST ON TRAB - COND. VAL. BRO

EMER. FLOWTR SYSTEM TO "A" 5/6 THROUGH

NORTH FLOWTR NOZZLES

NO #S FOR RADIATION

ACTIVITY IN ED SYSTEM

< 1 MR AT SITE SEC. FENCE (WORD PROJ.
EARLY THIS MORNING)

AIRBORNE ACT IN AUX BLDG & CONTROL ARE.
(RB Sump TO AUX BLDG SUMP BEFORE
ISOLATION)

TRIED TO START RCPs BUT DRAIN ON -
~ 100 AMPS (PUMPING STOP) - PUMPS REMAIN
OFF - NOT SURE WHY THEY WERE OFF.
TWILLEY, WINKS, KELLY AT SCHAEDEL'S HOME
TO GO TO SITE OBS. CENTER

ROGERS TO CALL SCHAEDEL @ ~ 3⁰⁰ :

CONTACT HIM FOR NEEDED SUPPORT

FLINT ALSO ON-SITE

Jim MOORE - GARY BROUGHTON (METE/GPI) GOING
SITE ALSO.

PLAN TO GO ON DA AS SOON AS POSSIBLE -
RECOMMENDED TO SCHAEDEL/ROGERS

1. COOL DOWN DATA

2. TRUE RCS TEMP BEFORE GOING ON DA

3. ^{CONFIRM} CORE OUTLET TEMP. NOW BY PIZ THER.

SINCE THIS IS FLOW PATH

BWST LEVEL ~ 37' LAST KNOWN

KLINGAMAN CALLED BY DEEDENS TO GET COMM-
CATION LINK FROM SITE TO B&W SPANGLER

MESSAGE GIVEN TO UNIT 1 TO GO TO UNIT 2

"PUT IN 500 GPM DORATED WATER VIA HPI
(AT LEAST 400)

JIM
FLOYD

ELECT. RELIEF VALVE STUCK OPEN (BLEW RUP. DISC
(EMBR.)

DELAY IN AUX. FLOWTR BECAUSE OF BAD INDIC

(PUMPS RUNNING - VALVES IND. OPEN BUT NOT)

RCP'S STOPPED BECAUSE OF IND. OF CAVITATIONS

COND. OFF GAS ALARM - 5/6 LEAK

> 60 K R READING BECAUSE OF MOISTURE (BAD
INST.)

~ 100 R BEST ESTIMATE FROM 100 MA AT

THE PERSONNEL HATCH.

RB PRES ~ 2 1/2 IN. ^{INITIAL} WENT TO ~ 4" ~ 6 HRS

AFTER TRANSIENT

KENNEDY/DEMPSEY

CAN'T MEGGAR RCP MOTORS - ^{MOISTURE} NOT MAJOR CONCERN
IF NOT SIG.

CAN ALLOW UP TO ~ 30 MINS VIB. TEMP.

TO OF RCP'S (SPRAY LINE LOOP RCP'S IF
POSSIBLE)

POSSIBILITY THAT RCP'S ARE NOT TRULY CONNECT

(SHEARED DRIVE PIN) BECAUSE NO LOAD AMP

SHOULD BE ~ 100 (WHICH IS WHAT THEY WERE)

IF CONNECTED SHOULD BE SIGNIF. > 100 AMP

N400 GREE SCHAEDEL (JUST TALKED TO SITE)

DIFFICULT TO ESTABLISH DIRECT COMMUN. WITH SITE

COLLAPSED BUBBLE IN "A" LEG { GOOD IND. T. P.

NORMAL LETDOWN + PRZ.

TRYING TO COLLAPSE BUBBLE IN "B" LOOP

190" 460° 560 # - IN PRZ. (BUBBLE)

TRYING TO GET ON DH VIA SUCTION FROM

BWST

WHAT CONSIDERATIONS DO WE HAVE FOR
RUNNING RCP'S (AT LEAST ONE) IN "B" LOOP? (DH
DROPLINE SIDE) 540°?

STILL FLOATING ON CFT'S ~ 400-500 #?

2A RCP HAS ENDS OF LEAKAGE (UNSURE)

DATA AVAIL. FROM REACTIMETER TAPES.

"A" 5/6 FILLED TO 80% - "B" 6 ~ 50%

400 → 500 GPM FLOW RECOMMENDED TO SCHAEDEL

RCP STR-

↳ BASED ON 100 DAY CORR

? ~ ENDS SINCE 2

↳ CONSERVATIVE

30 MILS VIB. LIMIT

HPI > SAT. COND'G FOR LOOP

GOOD AMP READING

NUC. SERVICE (WATER)

PROPER (NORMAL) PREREG'S FOR STE

NOT FLIBRATING STM AT SEALS

@440

550° TH

450# RCP

FROM CONTROL ROOM
SUPERHEATED CONDITIONS

ATTACHMENT C

Transcript of phone call from Gary Miller at TME about 9:30 A.M., March 28, 1979, to George Troffer, Reading, to assist in providing info for Met-Ed Communications Services staff by reporting on what he said to Lt. Governor Scranton.

MILLER: Lt. Governor - - I had no choice but to talk to him.

What I said and its probably not in very good verbage is that this morning very early we experienced a turbine trip. Two problems were in the secondary plant not the nuclear plant. When the unit trips from 100 percent, the reactor sometimes trips from 100 percent and it did. There was very high power. That's not a problem and not unexpected. When the reactor trips due to high pressure, its one of the parameters that normally trips the reactor. At the same time it was in the reactor building and due to the high pressure we had some relief valve lift which released from the reactor coolant to the building floor. This was not a break or a leak or anything that was designed to release at a high pressure. Obviously on all reactor pressure that doesn't occur. But it didn't on this one. That gave us indication of reactor building radioactivity because of the reactor coolant being released to the floor of the building. It's got radioactivity in it.

In addition to this the plant obviously experienced a pressure and temperature change fairly fast. I didn't say this to them -- I'm just saying it to the group. I was on the phone with a nuclear engineer over there so he knows about fuel pins. I said yes we may have had some fuel pin leakage. I don't know that right now. That's part of small term assessment on this thing and that's economic. He asked if I had any melting on fuel. I said I don't have any indication of melted fuel, but I may have had some fuel pin leakage which is not abnormal in the industry. I didn't say any at the present but I did say that we had reactor coolant released in the building which was giving radioactivity on the monitor.

When we get that, I said our emergency plan mandates that when I see it in the reactor building I assume it's getting out. Therefore, I go into the general emergency. I fully gear-up like I already got an

2001170535

emergency in the public. That means that I put people on stations, I closed the gates, I get the State Police, I make all the phone calls and I say subsequent to doing everything in the plant we have had confirmation very rapidly the number 1. (?) From the time the incident started we have had no release to the environment especially above background. We have had no indication of a millirem an hour that I know of. We know where the wind is moving -- it is moving slowly to the west. We have people at the west site boundary. We had a helicopter fly over to Goldsboro. We had the meters taken out at York Haven -- if I have to go back I will. Never had any indication. We have been in communications with Molloy in the State for most of the day. We had no action level by the plan for the public.

We do not expect any additional or any release. We are in the process of taking the plant to a cold shutdown to evaluate the situation and that evaluation is probably more economically damaging than anything else -- from the public standpoint.

Is Troffer there?

TROFFER: Yes.

MILLER: I don't expect any effect on the public. That's what I had said to people. I didn't have any time to think about it.

TROFFER: That sounds good. Did anybody have an overdose?

MILLER: Nobody had one. Nobody had an overdose or an overexposure. We have surveyed all the areas internally and roped the appropriate areas off.

We had nobody, as a result of the incident, that got any overexposure. We have taken reactor coolant samples afterwards. We may have used up a lot of quarterly doses of some people. I had nothing at the time of the incident. I may have had some exposures of people during the action

we needed to take in the correction of this thing in the plant. I have some people that I'm not totally sure of but I don't believe that we have anybody overexposed. And we didn't overexpose anybody at the time of the incident do to anything. For example, I have a chemist foreman that went into a room to get a sample for me. He may have gotten a fairly good dose. I wouldn't expect that he exceeded his limit.

OK, George. When I come back and re-assess this thing I may find some doses higher than I expect right now because I've had people doing things that must be done. I've got full dosimetry on anybody out there -- full body count and everything else. That's too much detail but that's just so you know. I will say I've had nobody overexposed. And I will say that we will have to fully evaluate that as a result of the incident when we can collect all the people from this thing. It will effect nobody inadvertently, George.

TROFFER: Do you know when we will be able to decide when people should come to work -- I think we are thinking about the Observation Center overcrowding.

MILLER: The best thing is that I am keeping them here now. I guess I wanted to be damn sure I had total control of the cooldown before I worried about that. I have had some people come to work. I've got one guy in charge of the Observation Center.

I believe that it's Gary Hahn. I have had Shovlin bring in whoever is needed. I've sent the contractors that didn't get there home.

TROFFER: So we did not do that. We did not call off the contractors and send them home.

MILLER: I didn't call them off. There were some on-site but the ones that went to the center I probably sent home. We did send them home. We made that

decision. It's just been too hard to worry about them. They probably went home anyway. I've been here since 7:00 in the morning and I've been up since 4:00 and I don't think I'll worry about the economic consequences of the contractors. To get them out of our way to be honest with you. If anybody was on-site I kept them to use them.

KLINGAMAN: We did not send our people home though, right Gary.

MILLER: I've got them on hold at the Observation Center. I put Gary Babin in charge to be sure that they didn't go home or wander around like what happened to me in August. I have brought on those people that Shovlin needs. Through him. I've got to go back and assess the people right now. Quite frankly, up to now it's been Jack, Lee Rodgers and the plant -- I've haven't had a shot at that. Jim Seelinger's in charge of that and he's pretty aware of what we're doing.

I just talked to the State and I gave them the scenario that I just gave you, but not with that kind of detail. So they're going to release something whether I like it or not probably.

I did talk to Maggie (DER) and Dornsife which I had known personally. I'm pretty sure I know them well enough that they will release something that will help. I told Maggie that if she has any problems getting us she should call Jack's office and he'll talk to her. I think you should tell Morena that she shouldn't treat Maggie as someone she doesn't know -- if she doesn't know her -- in case I need something. She's probably going to get a lot of questions from management over at the Governor's office.

TROFFER: I think we ought to go ahead cancel this Friday tour now.

MILLER: Yeah, I love that idea. George, I'll tell you what. I'm not sure that I'll be working here Friday! Just kidding. If there's anything else that you need I'll be in the Unit #2 Control Room. You can get me through that. I think you ought to release something. I think we should.

KLINGMAN: I think I better verify one thing. There are rumors going back and forth as to what we have. My understanding is that what we have is a general emergency declared sometime this morning. And it's still an official general emergency.

MILLER: The emergency was declared sometime around 7:00. I guess I could be off a little bit.

KLINGMAN: Yes, I got a call around 7:15.

MILLER: We did declare a general emergency here -- that's true.

ROSTER: The sooner we back properly from a general to a site, the better.

MILLER: The reason we have not, and you're right George, is because to be honest with you we've been testing the plant. We don't know where the hell the plant was going. See the situation we're in is a delicate one because we actually have plant integrity. If we had a leak we'd be all right -- as far as we'd have a lot more economic consequences. We've been trying to figure out how to cool down in the most expeditious fashion without releasing and without damaging too much. That's taking a pretty hard assessment. I'll work on getting out of the emergency right now.

1 went out to cross-check. They should have known, there was
2 adequate time.

3 Q Did you have the feeling that the information that
4 was being presented was colored or being put in its best light,
5 or some --

6 A No. I was very disgusted, that it was a typical
7 utility trying to play down a nuclear power plant problem.
8 That was my impression of what the discussion in the Lieutenant
9 Governor's office, that they were acting in the Lieutenant
10 Governor's office the same way they were apparently acting with
11 the press outside. You know, trying to say that there was not
12 a problem, and that everybody was making a big deal out of
13 nothing.

14 Q Do you believe this was despite the fact they knew
15 that there was a problem of more serious proportions than they
16 were discussing?

17 A I don't know. I think they were very disturbed that
18 they had to be in the Lieutenant Governor's office, rather than
19 being at the plant. They didn't want to be there, they wanted
20 to get out in a hurry, and they were trying to tell us in effect,
21 "We are going to handle it, it's none of your business. The
22 NRC is down there. Don't worry."

23 BY MR. HOEFLING:

24 Q What led you to believe that they were downplaying
25 their presentation?

Mr. CHENEY. That is understood. But it seems to me that one of the risks in this particular accident—obviously, the containment vessel worked and there was no problem. There would have been if there had been a breach on the containment vessel.

Mr. MILLER. That is true.

Mr. CHENEY. If you had any kind of a breach at all, given the levels of radioactivity that have been measured internally, they obviously would have been very serious, and it strikes me that the most serious point in terms of potential leaks was that point at which there was the hydrogen explosion. That is the only time we came remotely even close, conceivably, to breaching the containment vessel.

Mr. MILLER. If you had to pick a point where you came the closest, not arguing what "close" means, that is true.

Mr. WEAVER. Let me ask you this: Can you see the flag? That is the Rayburn House Office Building across the way. Can you see the flag on it? It is right in the middle over there.

Mr. MILLER. I cannot see the flag.

Mr. WEAVER. Well, it is right up there. I watch it frequently.

But during this period of time—Friday, Saturday, Sunday—my office is right up there. We watched that flag constantly to see which way the wind was blowing.

I want to ask you this: Knowing everything you know, not being on this job, would you have been as concerned? Your information is coming from the newspaper; the hydrogen bubble is in there; would you have watched that flag?

Mr. MILLER. I do not know the answer to that. I just do not know the answer. I can tell you this, I have a daughter that lives 10 minutes away from the plant and I never moved her.

Mr. SHEIMANN. My family also lives within 15 miles of the plant and I never moved them.

Mr. WEAVER. Of course, you would have never left the plant yourself.

Mr. MILLER. But I certainly would not hurt my daughter. That is the best way I can describe it. If I thought there was danger, then I certainly would have. If I had, in my own mind, from what I have been trained and known, if I had been sitting where you were—my parents were calling me trying to find me because of the kind of things that were printed in the newspaper. I was inside, communicating what I thought was accurate information. But none of it got out.

Mr. WEAVER. But you said yourself—

Mr. CHENEY. None of it got out through the press?

Mr. MILLER. The context that I read days later disappointed me.

Mr. WEAVER. There is no question that it is an imperfect system. It is hard to make judgments on that.

But you said a little while ago that if you had known that there had been hydrogen in the containment, that you would be more concerned.

Mr. MILLER. That is right. It would have been another problem that day which would have had to have been assessed and had to have been dealt with, and I would have dealt with it.

By 2 in the afternoon I had the ability to talk to people in Lynchburg or anywhere else, and I would have been talking to them.

Mr. WEAVER. The danger of the hydrogen in the core, in the reactor core, was that it could push the water down so that it revealed the core; is that the danger?

Mr. MILLER. If you had depressurized the system at that time, if you had dropped the pressure, then it would have expanded and possibly put a gas bubble over the core. And again, you would have had—you see, it is still making heat and you would not have been taking the heat away. The core would have heated up again.

Mr. WEAVER. How about an explosion in the reactor vessel?

Mr. MILLER. I never detected that that was a serious concern, personally. I did not know how it was going to initiate. I heard discussions. I think we were more concerned from the depressurization and uncovering standpoint.

Mr. WEAVER. What would an explosion have done to the core; do you have any idea?

Mr. MILLER. I do not know where we were going to get the explosion internally. We have no oxygen. If you want to go in and put a bomb in there and explode it, yes, that is a concern. But that is the context.

Mr. WEAVER. I am talking about the hydrogen in there.

Mr. MILLER. The concern on the hydrogen was that it would expand and uncover the core again, not an explosive concern, therefore. But we knew we could strip it out. We knew it would take time, and that was the context of that concern.

Mr. WEAVER. If you were not afraid of an explosion, why did you not burn it out?

Mr. MILLER. You cannot. You must have oxygen.

Another thing, you can get it out of the reactor system by taking gas out of the reactor system. It is something we do, we know how to do. We do that in operations. I just told you we put hydrogen in. When we take a plant down for maintenance, we do take the gas out of it normally. So that is not an abnormal operator action. So we knew we could degas it. Our concern was to do that without depressurizing, so it did not uncover.

Mr. CHENEY. Who did you talk to in terms of making the decision as to whether or not to recommend an evacuation? Was that strictly your own decision?

Mr. MILLER. During the day of the 28th, after the night of the 28th, I had a pretty senior management structure that had taken effect. In other words, the vice presidents of two of our companies were helping me or had taken charge of the overall operation.

They had taken control of the ultimate decisionmaking from me by that night. That day I dealt with my health physics guy, who was coordinating all of the offsite teams. He was using the Environmental Protection Agency guidelines and the emergency plan guidelines, which give you action levels at certain readings, to take action. You go indoors, you stop eating food, this type of thing.

He was dealing with the State radiological health people direct, Zuruski—I do not know the titles—and Rally, Margaret Rally, who we deal with normally on this type of thing. Then we would say we did not recommend an evacuation, and then would concur with that decision.

Mr. CHENEY. Your decision not to recommend an evacuation, is that a judgment call or is that based upon procedures that are spelled out?

Mr. MILLER. It is based upon procedures that are spelled out, plus judgment.

Mr. CHENEY. You get a certain numerical reading?

Mr. MILLER. If I get 5R whole body projected dose, then I am told to evacuate. If I get 0.5, I tell people to go indoors. But that is my recommendation to the State. It is their responsibility to decide that.

Mr. CHENEY. They decide whether or not to evacuate?

Mr. MILLER. That is their decision. It is their decision as to whether or not they move people. I am supposed to give them all the information I can and make a recommendation.

Mr. CHENEY. But your recommendation is almost automatic?

Mr. MILLER. It is based on action levels in the guide. But the judgment part is based upon what I know the plant is doing. So I must give them input into whether I think the consequence in the plant is going to get severely worse quickly. So that is the judgment, if you call it that.

The other part says that I have done these offsite surveys that give me this level of radiation. The Environmental Protection Agency says that if you are going to get beyond 5R or 25R thyroid, you do this, and that is the basis of moving people.

Mr. CHENEY. You never came close to that?

Mr. MILLER. We never came anywhere near that. We were a thousandth of that.

Mr. CHENEY. What was your reaction when the Governor made the decision to evacuate children and pregnant mothers?

Mr. MILLER. That was not made on the 28th.

Mr. CHENEY. I know. That was much later.

Were you involved in that at all?

Mr. MILLER. I thought it was precautionary, and it was a personal decision on his part. He is the Governor of the State and he has different concerns than I do. I did not think it was necessary. But he lives in a different world.

Like I told him, I did not move my daughter and I would not move her.

Mr. CHENEY. How old is she?

Mr. MILLER. Ten.

Mr. SCOVILLE. This goes back to the issue of the hydrogen bubble and its danger, the hydrogen bubble in the reactor cooling system. Although you said there was no particular concern in your mind regarding the explosion of that bubble over the weekend, Saturday and Sunday, were you aware of discussions that oxygen was being produced by radiolysis?

Mr. MILLER. There was discussion there could possibly be production of oxygen, that is right.

Mr. SCOVILLE. Did you believe it?

Mr. MILLER. There were an awful lot of technical people on the site at this time, and there was a senior group making decisions and deciding which data and which assumptions were going to be taken as the ones to go on. It was hard to decide because of the number of assump-

Mr. WEAVER. Let us stop for a moment and go off the record.

[Discussion off the record.]

Mr. MILLER. When you get beyond the 28th and start talking about the number of calculations being made about various things, there were so many people making them that I was not aware of all of them. I was an implant guy at that time, and my opinions are not the ones you should take to make a judgment.

Mr. WEAVER. We are taking them all.

Mr. SCOVILLE. I guess the point of my question was really this: When you were deciding which procedure—you said there were many procedures you could pursue to get rid of the bubble. Was the fact that it was contemplated by some that oxygen was being produced and the bubble might explode a significant factor in making the determination as to what procedure you were going to follow?

Mr. MILLER. No; you would take gas out with the same procedure, take it out using that system the way Bill and I described.

Mr. SCOVILLE. To your knowledge—and I understand you may not know this—was the theory of producing something that Met Ed came up with or did it come from the NRC?

Mr. MILLER. I do not believe it came from either. I think it came from a separate consultant that they both had talked to personally, possibly an expert on hydrogen and oxygen.

Mr. SCOVILLE. Thank you.

Dr. MYERS. Were you concerned that water in the containment or the fact that sodium hydroxide had been sprayed might have caused equipment—or degradation of equipment, of instruments, such that you might lose control at some point?

Mr. MILLER. No; the reason for that would be that we were designed to pump that whole tank into the building.

Dr. MYERS. Pump the tank into—

Mr. MILLER. If you had a loss, a LOCA, a loss of coolant accident, the whole 500,000-gallon tank goes in the building. You have a safety tank on the outside of the building with boric water in it. You put that water in to keep the core down, keep the core cool. You would pump 500,000 gallons of water right into the building.

Dr. MYERS. But with that water going into the containment, would that cause disruption of the 480-volt power supply or cause equipment failures or whatever?

Mr. MILLER. You would have had enough instrumentation left to operate what you needed to at that point.

Dr. MYERS. So you were not concerned that the conditions in the containment, whether by rising water levels or the fact that sodium hydroxide or the fact of radiation or temperature or whatever, might cause loss of instruments or equipment?

Mr. MILLER. If I had to pick, we could have lost pressurizer level and steam generator level, which would have complicated the operation for us.

Dr. MYERS. That is one reason why I think some people were concerned, if you lost control of that equipment inside, that then you would know less of what was going on and you would not be able to—

Mr. MILLER. That is true. At the time, during the day on the 28th, though, we had only pumped 20 feet of that tank into the building, and

1 part of that kind of discussion, yes.

2 Q What was your evaluation of the meaning of
3 superheated steam in the system?

4 A It is very hard to not be clouded by what I have
5 read in the last year or so. I just don't recall
6 discussions of that in those concise terms because the
7 cooling method we were in wasn't recognized anywhere that
8 had ever been studied.

9 The fact that you come in and all the indicators
10 are off scale high wasn't a recognized condition for this
11 reactor plant and it is hard to recall what that meaning was
12 of something that hadn't had much training or discussion in
13 the years of operation. So from a standpoint of what I know
14 today and methods and means of countering this type of
15 problem are different than they were on March 28th. The
16 discussion involved how to cool the core from a condition
17 that we didn't have recognized in any formalized training or
18 implemented document.

19 Q I guess what I am asking, Mr. Miller, is what your
20 evaluation of the meaning of superheat in the system is.
21 Having concluded that there was superheat, and certainly
22 this isn't something that you would have expected, but what
23 was your assessment of this superheat? Did you relate it to
24 core coverage?

25 A I can't today remember in our think-tank

1 with the hot fuel elements.

2 A On steam generator you have some level indicators.

3 Q I understand. But I am trying to understand did
4 that analogy allow you to conclude the core is uncovered?

5 A And I can't recall that analogy in discussions on
6 March 28th. You know, I am sure that our discussions were
7 in terms of the inventory deficiency, but I am not sure how
8 far the discussion went relative to the technical terms we
9 are talking of now as far as superheat and lack of
10 superheat, you know what the temperature was and what the
11 degradation of inventory was.

12 Q A few minutes ago you said you clearly knew you
13 busted up fuel.

14 A I said we knew there were some degradation of fuel.

15 Q You busted fuel and you got fission products. I
16 inferred from that that you knew you had poor cooling and
17 the core overheated and busted some fuel, true?

18 A We knew we had some fuel degradation, Vic, and we
19 knew we had insufficient heat removal.

20 Q But I am trying to make certain that you coupled
21 the two. The degradation of the fuel was a result of core
22 cooling.

23 A And I can't remember how close that coupling was
24 on March 28th is what I am trying to say as far as the
25 actual discussion.

1 Q Give me any other intreprétationd that comes to
2 your mind even now. How do you degrade the core without it
3 being the result of core cooling? Even today can you think
4 of a way?

5 A Of degrading the core without having a lack of
6 core cooling?

7 Q Yes.

8 A No. Unless you are talking of, you know, of some
9 other mechanical damage.

10 Q Oh, yes.

11 A Other than that, right.

12 Q I am talking about the core staying in the fuel
13 without being physically damaged.

14 A Yes.

15 Q So the degradation of the fuel you did couple that
16 morning as a result of the core cooling?

17 A I am saying I can't remember the coupling of that
18 in the discussions of that morning. I can't honestly
19 remember the nice tie we have just discussed.

20 Q I am not looking for nice ties. I am looking for
21 can you conclude anything other than that you knew you had
22 busted fuel somehow, that that was a result of poor
23 cooling? Is it reasonable to conclude that that was
24 understood by the people that were analyzing the problem
25 then?

1 A At some point in the morning that was certainly
2 understood and it is one of the reasons we asked for flow
3 rate from B&W for decay heat, the same reason. How much
4 heat removal do I need for what we are at.

5 Q Good. Now, let me try again looking at the
6 superheat. What do you think was the nature of the core
7 cooling? Describe for me how can you get core cooling in
8 the reactor some two hours after shutdown? What does it
9 mean to you. What does core cooling mean?

10 A Well, core cooling to me means that we knew
11 natural circulation was adequate for the design of the plant
12 and we weren't getting adequate natural circulation. Beyond
13 that point on March 28th I don't believe there was any
14 information available other than the stuff you knew you had,
15 to pump water in it at the flow rates you had available.

16 Q Yes, but I am trying to get you to help me
17 understand poor cooling of the core. What does that mean to
18 you?

19 A And I am saying that what it means is that we were
20 out of a recognized cooling mode and therefore we knew that
21 we had to have more cooling. We didn't know how much more.

22 Q Gary, we are passing each other in the night.
23 Core cooling, let me give you some things that come to my
24 mind. The flow rate in the core was lower than it should
25 be. There was not enough water. I had steam in the core

1 you were aware that the HPCI was secured for a long period,
2 that the pumps were pumping steam, that the EMOV had been open
3 for an extended period, that the hotleg temperatures were higher
4 than expected.

5 What evaluations did you make of the significance of
6 this?

7 A Our evaluations weren't very thorough that day,
8 admittedly, but the evaluation we made is we didn't have a known
9 method to cool the core, and we were trying to cool the core
10 with high pressure injection.

11 Q And you made no recommendations based on this
12 information?

13 A Well, the recommendation was establish circulation,
14 and that's what we were trying to do.

15 Q And again all this information didn't tell you that
16 there was a severe shortage of coolant?

17 A It does today. It would to anybody. Then it didn't
18 clam up and hit me in the face, no.

19 BY MR. HARPSTER:

20 Q Let me go back and ask you a question, Mike. I'm
21 trying to understand what was going on through the morning.
22 I have a picture of what your concerns were. As I understand
23 it, you understood that the loop was voided. Now you're
24 pumping it with HPI and it's going out the MOV, and you're
25 - trying to assure yourself that the core is being cooled, and

MAILGRAM SERVICE CENTER
MIDDLETOWN, VA. 22645



4-028971E129 05/09/79 ICS IPMMTZZ CSP WSHB
8145368859 MGM TDMT JOHNSTOWN PA 433 05-09 1155A EST

*Logins to
Gunn's
RDO
Harold Dorn
John Davis*

MR VICTOR GILINSKY, COMMISSIONER
THE NUCLEAR REGULATORY COMMISSION
WASHINGTON DC 20555

THIS IS A COPY OF MAILGRAM SENT TO THE HONORABLE MORRIS K UDALL
WASHINGTON DC 20515

THE STORY IN THE NEW YORK TIMES OF MAY 6 1979 REPORTING ON THE VISIT OF
YOUR SUBCOMMITTEE TO THE THREE MILE ISLAND PLANT IS GROSSLY IN ERROR.


THE "PRESSURE SPIKE" WAS NOT IN THE REACTOR VESSEL. THE PRESSURE GAGE
WHICH SHOWED A SPIKE AT ABOUT 158PM ON THE DAY OF THE ACCIDENT READS
PRESSURE WITHIN THE REACTOR CONTAINMENT BUILDING.

THE PRESSURE SPIKE DID INITIATE CONTAINMENT BUILDING SPRAY WHICH IS
DESIGNED TO COOL THE STEAM RELEASED INTO THE CONTAINMENT BUILDING AND
TO SCRUB ANTICIPATED IODINE IN THE DESIGN BASIS ACCIDENT. SINCE
BUILDING PRESSURE DID NOT INDICATE THE CONTINUING NEED FOR BUILDING
SPRAY, THE OPERATOR TURNED OFF THE SPRAY PUMPS. IT WAS THIS ACTION AND
THE BUILDING PRESSURE RECORDER THAT MR FLOYD REFERRED TO AS BEING IN
VIEW OF THE NRC INSPECTORS IN THE CONTROL ROOM AT THE TIME.

THERE IS NO EVIDENCE THAT ANYONE INTERPRETED THE "PRESSURE SPIKE" AND
THE SPRAY INITIATION IN TERMS OF REACTOR CORE DAMAGE AT THE TIME OF THE
SPIKE NOR THAT ANYONE WITHHELD ANY INFORMATION.

ON THE EVENING OF THURSDAY MARCH 29 WHEN THE TECHNICAL STAFF SENT TO
THE SITE TO INVESTIGATE THE ACCIDENT WAS REVIEWING AND CORRELATING
PLANT DATA FROM THE NUMEROUS SOURCES, THE SPIKE WAS NOTED AND
POSTULATED TO BE THE RESULT OF A HYDROGEN OXYGEN EXPLOSION WITHIN THE
CONTAINMENT BUILDING. THE TECHNICAL STAFF RECOGNIZED THAT THE PROBABLE
SOURCE OF ANY HYDROGEN WAS A ZIRCONIUM WATER REACTION IN THE REACTOR
CORE. THE PRESENCE OF HYDROGEN WOULD INDICATE THAT HIGH TEMPERATURE
CONDITIONS MUST HAVE EXISTED IN ORDER TO RESULT IN SIGNIFICANT REACTION
AND HYDROGEN PRODUCTION. THIS RECOGNITION LED TO MEASUREMENTS TO DEDUCE
THE EXTENT OF A HYDROGEN BUBBLE WITHIN THE PRIMARY REACTOR COOLING
LOOP. THE RESULTS OF THESE MEASUREMENTS WERE PROMPTLY REPORTED TO THE
NRC ON FRIDAY MARCH 30. IN ADDITION THE FIRST GAS SAMPLE FROM THE
CONTAINMENT BUILDING ATMOSPHERE TAKEN AT 4AM ON MARCH 31 REVEALED THE
PRESENCE OF HYDROGEN GAS AND A REDUCED OXYGEN LEVEL WHICH WERE
SUPPORTIVE OF THE PREVIOUS POSTULATE.

I REGRET THAT THIS ASPECT OF THE ACCIDENT HAS BEEN MISUNDERSTOOD AND
INACCURATELY REPORTED. I THINK THE FULL UNDERSTANDING OF THE THREE MILE
ISLAND ACCIDENT IS OF SUCH VITAL IMPORTANCE TO THE NATION THAT THE WORK



OF YOUR COMMITTEE AND THE OTHER BODIES THAT WILL BE INVESTIGATING THE
▶ ACCIDENT SHOULD NOT BE DEFLECTED BY INACCURATE REPORTING FOUNDED ON
PRESUMPTIONS OF DUPLICITY. SINCERELY

H DIECKAMP, PRESIDENT
GENERAL PUBLIC UTILITIES CORP
1001 BROAD ST
JOHNSTOWN PA 15907

— 11:55 EST

MGMCOMP MGM

NRC FORM 335 (7-77)		U.S. NUCLEAR REGULATORY COMMISSION BIBLIOGRAPHIC DATA SHEET		1. REPORT NUMBER <i>(Assigned by DDC)</i> NUREG-0760	
4. TITLE AND SUBTITLE <i>(Add Volume No., if appropriate)</i> Investigation into Information Flow During the Accident at Three Mile Island				2. <i>(Leave blank)</i>	
				3. RECIPIENT'S ACCESSION NO.	
7. AUTHOR(S)				5. DATE REPORT COMPLETED	
				MONTH January YEAR 1981	
9. PERFORMING ORGANIZATION NAME AND MAILING ADDRESS <i>(Include Zip Code)</i> U.S. Nuclear Regulatory Commission Office of Inspection and Enforcement Washington DC 20555				DATE REPORT ISSUED	
				MONTH January YEAR 1981	
				6. <i>(Leave blank)</i>	
				8. <i>(Leave blank)</i>	
12. SPONSORING ORGANIZATION NAME AND MAILING ADDRESS <i>(Include Zip Code)</i>				10. PROJECT/TASK/WORK UNIT NO.	
				11. CONTRACT NO.	
13. TYPE OF REPORT			PERIOD COVERED <i>(Inclusive dates)</i>		
15. SUPPLEMENTARY NOTES				14. <i>(Leave blank)</i>	
16. ABSTRACT <i>(200 words or less)</i> <p> This report was prepared in response to a request from NRC Chairman Ahearne that directed the Office of Inspection and Enforcement to resume its investigation of information flow during the accident at Three Mile Island (TMI) that occurred on March 28, 1979. This investigation was resumed on March 21, 1980. The transfer of information among individuals, agencies, and personnel from Metropolitan Edison was analyzed to ascertain what knowledge was held by various individuals of the specific events, parameters, and systems during the accident at TMI. Maximum use was made of existing records, and additional interviews were conducted to clarify areas that had not been pursued during earlier investigations. Although the passage of time between the accident and post-accident interviews hampered precise recollections of events and circumstances, the investigation revealed that information was not intentionally withheld during the accident and that the system for effective transfer of information was inadequate during the accident. </p>					
17. KEY WORDS AND DOCUMENT ANALYSIS			17a. DESCRIPTORS		
17b. IDENTIFIERS/OPEN-ENDED TERMS					
18. AVAILABILITY STATEMENT			19. SECURITY CLASS <i>(This report)</i>		21. NO. OF PAGES
Unlimited availability			N/A		
			20. SECURITY CLASS <i>(This page)</i>		22. PRICE
					\$

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

POSTAGE AND FEES PAID
U.S. NUCLEAR REGULATORY
COMMISSION

