

GL80072

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

July 31, 1980

TO ALL OF OPERATING LICENSES TO ALL LICENSEES OF OPERATING PLANTS AND
APPLICANTS FOR OPER AND HOLDERS OF CONSTRUCTION PERMITS

SUBJECT: INTERIM CRITERIA FOR SHIFT STAFFING

This is to provide you with the manning requirements item (1) of our letter of May 7, 1980. Pending completion of the long-term development of criteria for shift staffing and administrative controls, the NRC staff has developed interim criteria for licensees of operating plants and applicants for operating licenses. Except for senior reactor operators, described in these interim criteria for shift staffing shall remain as de Standard Review Plan, Section 13.1.2, NUREG 75/087. Special requirements regarding the utilization and qualifications of an on-shift technical advisor to the shift supervisor were provided in our letter of October 30, 1979.

We have changed the previous requirements for senior reactor operators and now require that there be one licensed senior reactor operator in the control room at all times, other than during cold shutdown conditions. This will therefore require that there be a minimum of two senior reactor operators at each site at all times, other than during cold shutdown conditions, to assure the availability of one senior reactor operator in the control room without affecting the freedom of the shift supervisor to move about the site as needed. The criteria for reactor and auxiliary operators are stated below and the required staffing levels for selected station configurations and various plant operating modes are summarized in the enclosed table.

At any time a licensed nuclear unit is being operated in Modes 1-4 for a PWR (Power Operation, Startup, Hot Standby, or Hot Shutdown respectively) or in Modes 1-3 for a BWR (Power Operation, Startup, or Hot Shutdown respectively), the minimum shift crew shall include two licensed senior reactor operators (SRO), one of whom shall be designated as the shift supervisor, two licensed reactor operators (RO) and two unlicensed auxiliary operators (AO). For a multi-unit station, depend upon the station configuration, shift staffing may be adjusted to allow credit for licensed senior reactor operators (SRO) and licensed reactor operators (RO) to serve as relief operators on more than one unit; however, these individuals must be properly licensed on each such unit. At all other times, for a unit loaded with fuel, the minimum shift crew shall include one shift supervisor who shall be a licensed senior reactor operator (SRO), one licensed reactor operator (RO) and one unlicensed auxiliary operator.

Adjunct requirements to the shift staffing criteria stated above are as follows:

- a. A shift supervisor with a senior reactor operator's license, who is also a member of the station supervisory staff, shall be onsite at all times when at least one unit is loaded with fuel.

8008150060A

- 2 -

- b. A licensed senior reactor operator (SRO) shall, at all times, be in the control room from which a reactor is being operated. The shift supervisor may from time-to-time act as relief operator for the licensed senior reactor operator assigned to the control room.
- c. For any station with more than one reactor containing fuel, the number of licensed senior reactor operators onsite shall, at all times, be at least one more than the number of control rooms from which the reactors are being operated.
- d. In addition to the licensed senior reactor operators specified in a., b., and c. above, for each reactor containing fuel, a licensed reactor operator (RO) shall be in the control room at all times.
- e. In addition to the operators specified in a., b., c., and d. above, for each control room from which a reactor is being operated, an additional licensed reactor operator (RO) shall be onsite at all times and available to serve as relief operator for that control room. As noted above, this individual may serve as relief operator for each unit being operated from that control room, provided he holds a current license for each unit.

Auxiliary (non-licensed) operators shall be properly qualified to support the unit to which assigned.

- g. In addition to the staffing requirements stated above, shift crew assignments during periods of core alterations shall include a licensed senior reactor operator (SRO) to directly supervise the core alterations. This licensed senior reactor operator may have fuel handling duties but shall not have other concurrent operational duties.

These criteria do not relieve licensees of any special requirements for additional operators which may have been imposed for individual units.

General application of revised shift staffing criteria will be the subject of a rulemaking proceeding. However, these interim criteria will be effective for plants receiving operating licenses during the interim period (including TMI-1). Licensees of plants already holding operating licenses shall examine their current staffing practices and capabilities in light of these interim criteria and advise this office within 90 days of receipt of this letter of the date by which their shift staffing could be in compliance with these criteria. Licensees of operating plants shall take steps to meet the revised criteria as soon as practical, but no later than July 1, 1982. In your response to this letter, you are requested to discuss your plans,

schedules and commitments to meet these staffing criteria. Holders of construction permits who have not as yet applied for an operating license should factor these criteria into their recruitment and crew training plans.

- 3 -

In addition, licensees of operating plants and applicants for operating licenses shall include in their administrative procedures (required by license conditions) provisions governing required shift staffing and movement of key individuals about the plant. These provisions are required to assure that qualified plant personnel to man the operational shifts are readily available in the event of an abnormal or emergency situation.

The administrative procedures shall also set forth a policy concerning over-time work for the senior reactor operators, reactor operators, and shift technical advisor required by these interim criteria. These procedures shall stipulate that overtime shall not be routinely scheduled to compensate for an inadequate number of personnel to meet the shift crew staffing requirements. In the event that overtime must be used, due to unanticipated or unavoidable circumstances, the following overtime restrictions shall be followed:

- (1) An individual shall not be permitted to work more than 12 hours straight (not including shift turnover time).
- (2) An individual shall not be permitted to work more than 24 hours in any 48 hour period.
- (3) An individual shall not work more than 72 hours in any 7 day period.
- (4) An individual shall not work more than 14 consecutive days without having two consecutive days off.

However, recognizing that circumstances may arise requiring deviation from the above restrictions, such deviation may be authorized by the plant manager or higher levels of management in accordance with published procedures and with appropriate documentation of the cause.

The limitations on overtime follow the guidance provided in IE Circular 80-02, except for the requirement noted above on the restriction on use of overtime in circumstances that are unavoidable.

Operating license applicants shall complete these administrative procedures before fuel loading. Development and implementation of the administrative procedures at operating plants will be reviewed by the Office of Inspection and Enforcement beginning 90 days after the date of this letter.

Sincerely,

Darrell G. Eisenhut, Director
Division of Licensing

Enclosures:
As stated

cc: OR Licensees, and OL Applicants
CP Holders Service Lists

PLANTS UNDER OL REVIEW

1. Farley 2 5 50-364
2. Byron 1/2 50-454, 455
3. Braidwood 1/2 50-456/457
4. LaSalle 1/2 50-373, 374
5. Midland 1/2 50-329,330
6. McGuire 1/2 50-369, 370
7. So. Texas 1/2 50-498, 499
8. Shoreham 50-322
9. Waterford 50-382
10. Grand Gulf 1/2 50-416/417
11. Diablo Canyon 1/2 50-275, 323
12. Susquehana 1/2 50-387, 388
13. Salem 2 50-311
14. Summer 1 50-395
15. San Onofre 2/3 50-361, 362
16. Bellefonte 1/2 50-438, 439
17. Watts Bar 1/2 50-390, 391
18. Sequoyah 1/2 50-327, 328
19. Comanche Peak 1/2 50-445, 446
20. North Anna 2 50-339
21. WPPSS-2 50-397
22. Fermi 2 50-341
23. Zimmer 1 50-358

PLANTS UNDER CONSTRUCTION

1. Palo Verde 1/2/3 50-528, 50-529, 50-530
2. Perry 1/2 50-440, 50-441
3. Cherokee 1/2/3 50-491, 50-492, 50-493
4. Beaver Valley 2 50-412
5. St. Lucie 2 50-389
6. Vogtle 1/2 50-424, 50-425
7. River Bend 1/2 50-458, 50-459
8. Clinton 1/2 50-461, 50-462
9. Forked River 50-363
10. Wolf Creek 1 50-482
11. Jamesport 1/2 50-516, 50-517
12. Nine Mile Point 2 50-410
13. Millstone 3 50-423
14. Bailly 1 50-367
15. Limerick 1/2 50-352, 50-353
16. Rope Creek 1/2 50-354, 50-355
17. Marble Hill 1/2 50-546, 50-547
18. Seabrook 1/2 50-443, 50-444
19. Sterling 1 50-485
20. Hartsville 1/2/3/4 50-518, 50-519, 50-520, 50-521
21. Phipps Bend 1/2 50-553, 50-554
22. Yellow Creek 1/2 50-566, 50-567
23. North Anna 3/4 50-404, 50-405
24. WPPSS 1/3/4/5 50-460, 50-508, 50- 513, 50-509
25. Callaway 1/2 50-483, 50-486

26. Harris 1/2/3/4 50-400, 50-401, 50-402, 50-403
27. Catawba 1/2 50-413, 50-414
- .

PLANTS UNDER CP REVIEW

1. Pilgrim 2 50-471
2. Greenwood 2/3 50-452, 50-453
3. Perkins 1/2/3 50-488, 50-489, 50-490
4. Allens Creek 1 50-466
5. Montague 1/2 50-496, 50-497
6. New Haven 1/2 50-596, 50-597
7. Erie 1/2 50-580, 50-581
8. Pebble Springs 1/2 50-514, 50-515
9. Clinch River 50-537
10. Black Fox 1/2 50-556, 50-557
11. Skagit 1/2 50-522, 50-523
12. Davis Bess 2/3 50-500, 50-501
13. Haven 50-502
14. Greene County 1 50-549
15. FNP 50-437
- .

ALL POWER REACTOR LICENSEES

- | | |
|--|--|
| Docket No. 50-348
Farley Unit 1 | Docket No. 50-3
Indian Point Unit 1 |
| Docket No. 50-313
Arkansas Unit 1 | Docket No. 50-247
Indian Point Unit 2 |
| Docket No. 50-368
Arkansas Unit 2 | Docket 50-286
Indian Point Unit 3 |
| Docket No. 50-317
Calvert Cliffs Unit 1 | Docket No. 50-155
Big Rock Point |
| Docket No. 50-318
Calvert Cliffs Unit 2 | Docket No. 50-255
Palisades |

Docket No. 50-293 Pilgrim Unit 1	Docket No. 50-409 Lacrosse
Docket No. 50-325 Brunswick Unit 1	Docket No. 50-269 Oconee Unit 1
Docket No. 50-324 Brunswick Unit 2	Docket No. 50-270 Oconee Unit 2
Docket No. 50-261 H. B. Robinson Unit 2	Docket No. 50-287 Oconee Unit 3
Docket No. 50-10 Dresden Unit 1	Docket No. 50-334 Beaver Valley Unit 1
Docket No. 50-237 Dresden Unit 2	Docket No. 50-302 Crystal River 3
Docket No. 50-249 Dresden Unit 3	Docket No. 50-335 St. Lucie Unit 1
Docket No. 50-254 Quad-Cities Unit 1	Docket No. 50-250 Turkey Point Unit 3
Docket No. 50-265 Quad-Cities Unit 2	Docket No. 50-251 Turkey Point Unit 4
Docket No. 50-295 Zion Unit 1	Docket No. 50-321 Edwin I. Hatch Unit 1
Docket No. 50-304 Zion Unit 2	Docket No. 50-366 Edwin I. Hatch Unit 2
Docket No. 50-213 Connecticut Yankee (Haddam Neck)	Docket No. 50-315 D. C. Cook Unit 1

- 2 -

Docket No. 50-316 D. C. Cook Unit 2	Docket No. 50-344 Trojan
Docket No. 50-331 Duane Arnold	Docket No. 50-333 FitzPatrick
Docket No. 50-219 Oyster Creek Unit 1	Docket No. 50-267 Ft. St. Vrain
Docket No. 50-309 Maine Yankee	Docket No. 50-272 Salem Unit 1
Docket No. 50-289 Three Mile Island Unit 1	Docket No. 50-244 R. E. Ginna 1

Docket No. 50-320 Three Mile Island Unit 2	Docket No. 50-312 Rancho Seco
Docket No. 50-298 Cooper Station	Docket No. 50-206 San Onofre 1
Docket No. 50-220 Nine Mile Point Unit 1	Docket No. 50-269 Browns Ferry Unit 1
Docket No. 50-245 Millstone Unit 1	Docket No. 50-260 Browns Ferry Unit 2
Docket No. 50-336 Millstone Unit 2	Docket No. 50-296 Browns Ferry Unit 3
Docket No. 50-263 Monticello	Docket No. 50-346 Davis-Besse 1
Docket No. 50-282 Prairie Island Unit 1	Docket No. 50-271 Vermont Yankee
Docket No. 50-306 Prairie Island Unit 2	Docket No. 50-338 North Anna 1
Docket No. 50-285 Ft. Calhoun	Docket No. 50-280 Surry Unit 1
Docket No. 50-133 Humboldt Bay	Docket No. 50-281 Surry Unit 2
Docket No. 50-277 Peach Bottom 2	Docket No. 50-266 Point Beach Unit 1
Docket No. 50-278 Peach Bottom 3	Docket No. 50-301 Point Beach Unit 2

- 3 -

Docket No. 50-305
Kewaunee

Docket No. 50-29
Yankee-Rowe

Docket No. 50-267
Ft. St. Vrain