

February 25, 1985  
NRC/TMI-85-014

MEMORANDUM FOR: Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
  
Bernard J. Snyder, Program Director  
TMI Program Office

FROM: William D. Travers, Deputy Program Director  
TMI Program Office

SUBJECT: NRC TMI PROGRAM OFFICE WEEKLY STATUS REPORT FOR  
February 16, 1985 - FEBRUARY 23, 1985

REACTOR BUILDING ACTIVITIES:

On Wednesday, February 20, 1985, GPU Nuclear was able to guide a small television camera and light to the lower reactor vessel head and examine a small region below the core support structure. The television pictures revealed rubble which had the appearance of a gravel pile with some of the pieces being "fist" size and several inches across. The size of the gravel pieces were compared to the diameter of the light fixture and appear to be nominally three to four inches long and about half as wide. Further examinations on Thursday, February 21, 1985, revealed similar type material located at the periphery of one of the six inch diameter flow holes in the lower diffuser plate of the core support assembly. These examinations support the concept that some molten material was generated in the core area and resolidified and collected in the lower plenum area. The composition of the rubble pile can not be determined from video inspection of this material. Specifically, the possibility that once-molten fuel forms a part of this rubble cannot be confirmed nor discounted via this technique. The licensee has, however, begun preliminary planning to remove a sample for laboratory analysis of material content. The rubble appears to be about 30 inches deep (15-20 tons) in the lower reactor vessel head area. These early examinations also indicate that, in the limited areas examined, the core thermal shields, lower flow distributor, instrumented incore guide tubes, and reactor vessel walls were not visibly degraded.

In a separate effort, EG&G Idaho, Inc., under contract to DOE, has an ongoing program to examine a limited number of debris particles previously removed from the reactor in 1984. Recent results from these examinations indicate that temperatures of at least 5100°F were reached in some areas of the core during the 1979 accident. Uranium dioxide melts at 5100° F.

*LDK-5  
TMI*

8503040548 850225  
PDR ADOCK 03000320  
R PDR

OFFICE >						
SURNAME >						
DATE >						

AUXILIARY AND FUEL HANDLING BUILDING ACTIVITIES:

Refurbishment of the "A" spent fuel pool has continued with the installation of the fuel canister transfer mechanism. Decontamination efforts this period have included scabbling in the Decay Heat Vaults and the Auxiliary Building elevator pit. Operation of the cesium elution system has continued.

**ORIGINAL SIGNED BY:**  
William D. Travers

William D. Travers  
Deputy Program Director  
TMI Program Office

Attachments:

1. Liquid Effluent and Environmental Data
2. Plant Status

OFFICE ▶	TMIPD <i>DK</i>	TMIPD <i>CC</i>	TMIPD <i>PG</i>	TMIPD			
SURNAME ▶	DCollins:ms	CCowdill	PG	WTravers			
DATE ▶	2/25/85	2/25/85	2/24/85	2/ /85			

INTERNAL DISTRIBUTION

EDO

OGC

Office Directors

Commissioner's Technical Assistants

NRR Division Directors

NRR A/D's

Regional Administrators

IE Division Directors

TAS

EIS

TMI Program Office Staff (10)

PHS

EPA

DOE

RI Division Directors

Public Affairs, RI

State Liaison, RI

TMIPQ HQ r/f

TMI SITE r/f

CENTRAL FILE

NRC PDR

LOCAL PDR

TMI-2 Project

Section File

ATTACHMENT 1

LIQUID EFFLUENT AND ENVIRONMENTAL DATA

Environmental Protection Agency

Based on EPA's sampling results, liquid effluents being released from the TMI site are within regulatory limits and in accordance with NRC requirements and the City of Lancaster Agreement.

Lancaster Water Sample: Composite sample taken over seven days

Period Covered: February 3, 1985 - February 9, 1985

Results: Gamma Scan Negative for reactor related radioactivity

TMI Water Samples: Seven daily composited samples

Period Covered: February 2, 1985 - February 9, 1985

Results: Gamma Scan Negative for reactor related radioactivity

NRC Environmental Data

The NRC operated continuous outdoor air sampler at the TMI site did not detect any reactor related radioactivity.

<u>Sample</u>	<u>Period</u>
HP-458	February 13, - February 20, 1985

<u>Volume</u>	<u>Results</u>
331.7 m <sup>3</sup>	LLD = 1.1 E-13 uCi/cc I-131 LLD = 1.1 E-13 uCi/cc Cs-137

ATTACHMENT 2

PLANT STATUS

Reactor Vessel Configuration: Reactor vessel open with modified internals indexing fixture installed

Core Cooling Mode: Heat transfer from the reactor coolant system (RCS) to reactor building ambient

Available Core Cooling/Makeup Sources:  
Standby pressure control (SPC) system  
Reactor coolant bleed tank (RCBT) water transfer system  
Mini decay heat removal (MDHR) system  
Decay heat removal (DH) system

Reactor Coolant System:

Average Cold Leg Temperature: 59°F

Core:

Average Incore Thermocouples:\* 81°F  
Maximum Incore Thermocouple:\* 91°F

Reactor Building:

Temperature: 56°F  
Pressure: -0.05 psig

Airborne Radionuclide Concentrations:

Tritium: 6.7 E-8 uCi/cc  
Particulates: 2.7 E-10 uCi/cc predominately Cs-137

\*Uncertainties exist as to the exact location and accuracy of these readings.