

50320-840301
March 1, 1984

NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-TMI-84-03A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation and is basically all that is known by NRC staff on this date.

Facility: GPU Nuclear Corporation
Three Mile Island, Unit 2
Docket Number 50-320

Licensee Emergency Classification:
X Not Applicable


Subject: REACTOR BUILDING POLAR CRANE LOAD TEST (UPDATE)


The qualification load test of the reactor building polar crane was completed February 29, 1984. A series of lifting maneuvers was completed with a 214 ton weight to check the functioning of all parts of the lifting equipment. This load test qualifies the crane to lift the 170 ton reactor vessel head scheduled for this summer.

Media interest occurred because licensee has issued a press release. The Commonwealth of Pennsylvania was informed. The Commonwealth of Pennsylvania was informed.

This updated notification is issued for information only and the NRC plans to continue monitoring events as they occur.

The NRC TMI Program Office received notification of this occurrence by monitoring of licensee activities and this information is current as of 8:00 AM.


Contact: T. Moslak 590-1141


A. Fasano 590-1123


J. Barrett 590-1120

Distribution:

H. St. <u>8:44</u>	MNBB <u>8:45</u>	Phillips <u>8:46</u>	E/W <u>8:49</u>	Willste <u>8:50</u>	Air Rights <u>8:55</u>
Chairman Palladino	EDO	NRR	IE	NMSS	SP
Comm. Gilinsky	PA		OIA	RES	B. Snyder
Comm. Roberts	MPA		AEOD		
Comm. Asselstine	ELD			INPO <u>8:47</u>	MAIL:
Comm. Bernthal				NSAC <u>8:44</u>	DCS Processing
SECY	R:I <u>8:40</u>	R:II <u>9:07</u>	R:III <u>9:13</u>		ADM:DMB
ACRS	R:IV <u> </u>	R:V <u>9:25</u>			OELD:
CA					J. Tourtellotte
PDR					DOT:(Trans. Only)

8403060435 840301
PDR I&E
PNO-TMI-84-003 PDR