



LER

Metropolitan Edison Company  
Post Office Box 480  
Middletown, Pennsylvania 17057

Writer's Direct Dial Number

May 11, 1981  
LL2-81-0060

Office of Inspection and Enforcement  
Attn: Mr. Boyce H. Grier  
Director  
Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406



Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)  
Operating License No. DPR-73  
Docket No. 50-320  
LER 79-014/OIL-0 Final Report

This letter transmits the final report for the TMI-2 accident of March 28, 1979 as required by Recovery Technical Specification 6.9.1.10. Also enclosed is the Licensee Event Report, Attachment A hereto.


The report is in the form of four attachments to this letter. These attachments correspond to the four categories of information set forth as required in the above Technical Specification, i.e.:

Attachment B A summary of Technical Specification violations related to events which occurred during and after\* the transient of March 28, 1979.

Attachment C A summary of the cause(s) of the accident.

Attachment D A sequence of events which occurred during the transient.

Attachment E A summary of corrective actions (both short and long term) which were taken as a result of the March 28, 1979 accident.



\*It is our understanding that "after", as used here, means until the date of the Order suspending our License to operate TMI-2 (July 20, 1979).

1E22  
S/

8107020 197

S

Mr. Boyce H. Grier

-2-

LL2-81-0060

We believe that this report is in compliance with the requirements of Technical Specifications 6.9.1.10 and, as such, makes it no longer necessary to submit the quarterly reports, which have also been required by the same Technical Specification, as discussed in our letter, LL2-81-0092 of April 8, 1981.

Sincerely,



G. K. Hovey  
Vice-President and  
Director, TMI-2

GKH:RIN:vjf

Attachments

cc: L. Barrett, Deputy Program Director  
Dr. B. J. Snyder, Program Director - TMI Office

Writer's Direct Dial Number

October 6, 1981

LL2-81-0228

Office of Inspection and Enforcement  
Attn: Mr. Ronald C. Haynes, Director  
Region I  
U. S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, PA 19406



Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)  
Operating License No. DPR-73  
Docket No. 50-320  
Final Report of the Quarterly Report Series

In our submittal of the Final Report of the Quarterly Report Series (LER 79-014/01L) transmitted by LL2-81-0060 on May 11, 1981, page 48 of Attachment C, Sequence of Events was inadvertently omitted. Enclosed, please find a copy of that page for insertion into the Final Report. We regret any inconvenience this omission may have caused.

Sincerely,

A handwritten signature in cursive script that reads "G. K. Hovey".

G. K. Hovey  
Vice-President and  
Director, TMI-2

GKH:RBS:djb

Enclosure

cc: L. H. Barrett, Deputy Program Director  
Dr. B. J. Snyder, Program Director, TMI Program Office

IEO1  
s  
1/1

8110200136 811006  
PDR ADOCK 05000320  
S PDR

LICENSEE EVENT REPORT

ATTACHMENT A

CONTROL BLOCK: \_\_\_\_\_ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 P A T M 1 2 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5  
7 8 9 LICENSE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE JO 27 28 CAT 58 29 30

CON'T  
0 1 REPORT SOURCE L 6 0 5 0 0 0 3 2 0 7 0 3 2 8 7 9 8  
7 8 9 DOCKET NUMBER 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

0 2 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
Event description -- On Marcy 28, 1979 during full power operation the Unit exper-  
0 3 ienced a loss of Feedwater. For further details see Attachment D to LL2-81-0060  
0 4 Consequence of Event -- Gross building and equipment contamination. Off-site health  
0 5 effects were minimal.  
0 6 Releases - Liquid 0.3Ci I-131  
0 7 Gas 14 Ci I-131, 9.7E6 Ci Xe 133, 1.0 E Ci Xe 133 M, 9.6E4 Ci Xe 135.

0 9 SYSTEM CODE C B (11) CAUSE CODE X (12) CAUSE SUBCODE Z (13) COMPONENT CODE V A L V E X (14) COMP SUBCODE X (15) VALVE SUBCODE B (18)  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

(17) IER, NO REPORT NUMBER 7 9 (18) EVENT YEAR 7 9 (19) SEQUENTIAL REPORT NO. 0 1 4 (20) OCCURRENCE CODE (21) REPORT TYPE (22) REVISION NO. 0  
ACTION TAKEN X (18) FUTURE ACTION X (19) EFFECT ON PLANT A (20) SHUTDOWN METHOD C (21) HOURS > 8 E 4 (22) ATTACHMENT SUBMITTED Y (23) NRC FORM SUB. N (24) PRIME COMP SUPPLIER N (25) COMPONENT MANUFACTURER D 2 4 3 (26)

1 0 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
1 0 Cause Description -- See Attachment C to LL2-81-0060.  
1 1 Corrective Actions -- Immediate -- See Attachment D to LL2-81-0060.  
1 2 Other -- See Attachment E to LL2-81-0060.  
1 3  
1 4

1 5 FACILITY STATUS E (28) % POWER 0 9 7 (29) OTHER STATUS N/A (30) METHOD OF DISCOVERY A (31) DISCOVERY DESCRIPTION (32) See Attachment D to LL2-81-0060  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 6 ACTIVITY RELEASED OF RELEASE M (33) M (34) AMOUNT OF ACTIVITY (35) See Itme 10 LOCATION OF RELEASE (36) R. B. to Atm. IWTs to River  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 7 PERSONNEL EXPOSURES NUMBER E 3 (37) TYPE B (38) DESCRIPTION (39) Estimated 5500 MANREM  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 4 PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION (41) N/A  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 7 LOSS OF OR DAMAGE TO FACILITY TYPE B (42) DESCRIPTION (43) Core damage, gross plant contamination, water damage in containment  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

1 7 PUBLICITY ISSUED Y (44) DESCRIPTION (45) Extensive, all media -- continuing  
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47 48 49 50 51 52 53 54 55 56 57 58 59 60

8107020204

TECHNICAL SPECIFICATION VIOLATIONS SUMMARY

The NRC performed an intensive review (reported in NUREG-0600 and NUREG-0760) of activities related to the March 28, 1979, accident and identified, in its letters of January 23, 1980, and January 27, 1981, those items it considered to be non-compliances. These letters included some items which the NRC, in its opinion, considered to be Technical Specification violations.

To make the record more complete, we have reviewed available records and interviewed people knowledgeable of events during and after the accident to develop a list of other non-compliances with Technical Specifications. The resulting list may not be complete, but it reflects all such Technical Specification non-compliance events we have been able to identify. It is important that this list be kept in the proper perspective in that many of the non-compliances were a consequence of the accident or resulted from subsequent inaccessability (because of high radiation levels) to equipment and instruments.

TMI-2 LIMITING CONDITIONS FOR OPERATION  
VIOLATED BUT NOT REPORTED IN NUREG-0600 OR 0760

<u>Reorder Tech Spec. No.</u>	<u>Description/Discussion</u>	<u>Date</u>
3.0.3	<u>Shutdown Requirements</u> - not in cold shutdown within 30 hours.	March 29
3.0.4	<u>Mode changes</u> - Various changes in operational modes occurred without meeting various LCO's.	Various
3.1.2.9 and 3.5.4	<u>Borated Water Sources - Operating</u> - The Borated Water Storage Tank remained below the minimum volume of 445,620 gallons for more than 12 hours.	April 1
3.3.3.8 - Table 3.3.-11	<u>Fire Detection - Instrument</u> - Reactor Building smoke detectors were inoperable.	March 28
3.4.1	<u>Reactor Coolant Loop</u> - Reactor Coolant Pumps in the B Loop were secured. Reactor Coolant Pumps were secured for about 3 hours in both loops.	March 28
3.4.4	<u>Pressurizer</u> - Pressurizer level exceeded 385"	March 28
3.4.5	<u>Steam Generators</u> - less than 18 inches	March 28
3.4.6.1	<u>Reactor Coolant System Leakage</u> - > 10 GPM identified leakage.	March 28
3.4.7	<u>Chemistry</u> - Reactor Coolant System chlorine was greater than 0.15 ppm.	March 28
3.4.8	<u>Specific Activity</u> - Primary coolant sample indicated high iodine activity (> 1.0 $\mu\text{Ci}/\text{gm}$ Dose Equivalent) ( $\geq 100/\text{L}^2\text{Ci}/\text{gm}$ )	March 29
3.4.9.1	<u>Pressure/Temperature Limits</u> - Exceeded maximum heatup/cooldown limits during the time frame following the reactor trip. (100° F/hr.)	March 28

<u>Tech. Spec. No.</u>	<u>Description/Discussion</u>	<u>Date</u>
3.4.9.2	<u>Pressurizer</u> - Exceeded maximum heatup/ cooldown limits during the time frame following the reactor trip. (100° F/hr)	March 28
3.6.1.4	<u>Internal Pressure</u> - Primary containment pressure exceeded +3 psig.	March 28
3.6.1.5	<u>Air Temperature</u> - Primary containment temperature exceeded 130°F.	March 28
3.6.2.2	<u>Spray Additive System</u> - The NaOH tank remained below 13,275 gallons for greater than 72 hours.	April 1
3.6.5	<u>Reactor Vessel Skirt Area Fans</u> - The reactor vessel skirt area fans were inoperable.	March 28
3.21.4	<u>Activity - Secondary Coolant System</u> - > 0.10 $\mu\text{Ci/gm}$ Dose Equivalent I-131	March 28
3.7.10.1	<u>Fire Suppression Water System</u> - The Unit 1 River Water Intake Motor Fire Pump was down with a worn impeller and the Unit 1 River Water Intake Diesel Fire Pump blew a head gasket.	April 28
3.7.10.2	<u>Deluge/Sprinkler Systems</u> Fuel Handling Building Exhaust Filter (AH-F-10 A/B) were isolated.	March 28
4.0.3.	<u>Surveillance Time Interval</u> - Exceed surveillance requirement on time interval - See pp. 4-10	Various
4.0.4	<u>Operational Mode Changes</u> - Mode Changes made without performing necessary surveillances.	Various

<u>Description</u>	<u>TS No.</u>
Incore Detector Channel Calibration	4.3.3.2.B
Seismic System Calibration	4.3.3.3.1 4.3.3.3.2
Pressurizer Level and Temperature Calibration	4.3.3.5
Reactor Coolant System Flow - NNI	4.3.3.5
Rx Building Sump Level & Rx Building Cooler Excess Condensate Level Switches Calibration	4.4.6.1.B 4.4.6.1.D
Safety Injection, RCS Pressure Low Channel Calibration	4.3.2.1.1
Reactor Building Isolation & Cooling Channel Calibration	4.3.2.1.1
FW Latching System Channel Calibration	4.3.2.1.1 4.3.2.1.2
H2 Recombiner Channel Calibration	4.6.4.2
4KV Bus 2-1E & 2-2E Undervoltage Relay Calibration	4.3.2.1
Emergency D.G. Load Sequence Relay Calibration	4.8.1.1.2(C.6) 4.8.1.2
Steam Generator Water Level	4.3.3.5 4.3.3.6
4KV Bus 2-3E & 2-4E Undervoltage Relay Calibration	4.3.2.1
Reactor Building Air Pressure	4.3.3.6
MU Storage Tank Level	4.3.3.5
RB Auto Sump Suction Calibration	4.3.2.1.1
FW Line Rupture Automatic Detection Calibration	4.3.2.1.1
CFT Level & Pressure Calibration	4.3.3.6
Low Pressure Injection Flow Channel Calibration	4.3.3.6
High Pressure Injection Flow	4.3.3.6
Secondary Coolant Specific Activity	4.7.1.4
Isotopic Analysis for Dose Equivalent Iodine	4.7.1.4



<u>Description</u>	<u>TS No.</u>
RCS Average Temperature	4.3.3.6
Steam Generator Pressure Calibration	4.3.3.6
RB Spray Pump Flow	4.3.3.6
Source Range Channel Functional Test	4.3.1.1.1
MU Pump Valve Functional Test	4.1.2.3 4.1.2.4 4.0.5.6
DHR Pump Functional Test and Valve Operability Test	4.1.2.5 4.5.2.F.2
Control Rod Movement	4.1.3.1.2 4.1.3.2.2
RPS Functional Tests	4.3.1.1.1
RB Pressure Hi Hi Channel Activation	4.3.2.1.1 Table 4.3-2(3a,b)
Logic Channel Functional Test	N/A
Area & Process Monitor - RMS Channel Functional Test	4.3.3.1
Containment Monitor - RCM Channel Functional Test	4.3.3.1 4.4.6.1.A&C
RB Cooling Unit Operation	4.6.2.3.A
H2 Purge Cleanup System	4.6.4.3.A
E.F. System Valve Lineup Verification and Operability Test; and Turbine Driven E. Feedpump Operability Test	4.7.1.2.A
FH Building Cleanup-Remote Start & Operability Check	4.9.12.A
Safety Injection - RCS Pressure Low Channel Functional Test	4.3.2.1.1 4.3.2.1.2
RB Isolation & Cooling/Safety Injection RB Pressure Hi Channel Functional Test	4.3.2.1.1
Reactor Building Spray Pump Functional Test and Valve Operability Test	4.6.2.1.b

<u>Description</u>	<u>TS No.</u>
Boric Acid Pump Functional Test	4.1.2.7 & 4.1.2.6
NSSCW Pump Functional Test & Valve Operability Test	4.0.5
Rx Building Emergency Cooling Booster Pumps Functional Test and C/D Nuclear Services River Water Valve Operability Test	4.6.2.3.b 4.0.5.6
Spent Fuel Cooling Pump Functional Test	4.0.5
Safety Injection Manual Actuation & Actuation Logic Functional Test	4.3.2.1.1, 4.7.4.1(1) 4.5.2.e 4.7.3.1.1
R.B. Isolation & Cooling Manual Initiation and Actuation Logic Functional Test	4.3.2.1.1 4.6.2.2.6 4.6.2.3.1 4.6.3.1.2.a 4.7.7.1
4 KV ESF Bus Undervoltage Relays Channel Functional Test	4.3.2.1.1
H2 Mixing System Remote Start & Operability Test	4.6.4.4.a
Main Steam Isolation Valves A-Power	4.0.5, 4.6.3.1.3, 4.7.1.5
Main Steam Isolation Valves A-Power Operation/B Cold Shutdown	4.7.1.5
Hydrogen Recombiner Functional Test	4.6.4.2.A
In-Service Testing of Valves During Normal Plant Operations	4.0.5 4.6.3.1.3
In-Service Testing of HVAC Valves	4.0.5
Valve Operability Test During Cold Shutdown and Remote Indication Functional Test	N/A
Seismic Instrumentation Functional	4.3.3.3.1
RB Hatch Leakrate & Interlock Test	4.6.1.1.B 4.6.1.3.B.C
Control Rod Drop Times	4.1.3.5
RPS Response Times	4.3.1.1.3
ESFAS Response Time Testing	4.3.2.1.3
RCS Total Flow	4.2.5.2

<u>Description</u>	<u>TS. No.</u>
CF Tank Isolation Valve Alarm	4.5.1.D
D.B. Removal Isolation & Interlock Test and Valve Operability and Remote Indication Functional Tests	4.5.2.D.1 4.05 4.5.3
LP Injection System Leakage	4.5.2.D 3a & b
Hydrogen Recombiner Operational Test	4.6.4.2.B.2.3&4
H2 Purge System - Performance Analysis	4.6.4.3.B&d
Class IE Distribution System Source Transfer Test	4.8.1.1.1.B/ 4.8.1.2.1.B
Emergency Feedwater Valve Actuation	4.7.1.2.C.8
Rod Position Indication Functional Test	4.1.3.4
Class IE Distribution System Functional Test	4.8.1.1.2.C 4.8.1.1.2.C.5 4.8.1.1.2.C.2 4.8.1.2 4.3.2.1.1 4.0.5
Station Storage Batteries - Service Test	4.8.2.3.2 4.8.2.4.2
Pressurizer Code Safety Valve Check	4.4.2 4.4.3
Control Room Emergency Ventilation Performance Analysis	4.7.7.1.C 4.7.7.1.e.&3
Building Spray Stem Leakage	4.6.2.1.D
Main Steam Safety Valves	4.7.1.1
FH Building Air Cleanup Performance Analysis	4.9.12.B 4.9.12.d.1&3
Emergency Diesel Generator Loading Test	4.8.1.1.2.C.4 4.8.1.2
Control Room & FHB-RMS Channel Functional Test	4.7.7.1.e.2 4.9.12.d.2
Inaccessible Valve Remote Indication Functional Test	

<u>Description</u>	<u>TS No.</u>
Station Storage Batteries - Performance Discharge Test	4.8.2.3.2.E
RB Spray Nozzle	4.6.2.1.E
NAOH Solution Flow Rate Check	4.6.2.2.D
RCS Chemistry	4.4.7
RCS Specific Activity	4.4.8
Fuel Canal Boron Concentration	4.9.1.2
CF Tank Boron Concentration	4.5.1.B
ECCS Containment Emergency Sump Inspection	4.5.2.D.2
OTSG Eddy Current Testing	4.4.5.1 thru 4.4.5.5
Diesel Generator Inspection	4.8.1.1.2.C.1
RV Internals Vent Valve Inspection	4.4.10.1.b
Hydraulic Snubber Inspection	4.7.8.1
RV Material Surveillance Specimen Inspection	4.4.9.1.2
Reactor Coolant Pump Flywheel Inspection	4.4.10.1.A
Minimum Temperature for Criticality	4.1.1.4.B
Rod Program Surveillance	4.1.3.8.A
Power Level Cut-Off Xenon Equilibrium	4.1.3.9
Containment Integrity	4.5.2.c 4.6.1.1, 4.6.1.3A
RPS Setpoints vs. RCP Combinations	4.4.1
CR Emergency Ventilation System Operability	4.7.7.1.f,g
CR Emergency Ventilation System Charcoal Analysis	4.7.7.1.C.2,d
H2 Purge Charcoal Analysis	4.6.4.3.e,f
H2 Purge Charcoal Analysis	4.6.4.3.c

<u>Description</u>	<u>TS. No</u>
FH Building Air Cleanup System Performance Analysis	4.9.12.e,f
FH Building Air Cleanup System Charcoal Analysis	4.9.12.c
Reactivity Anomaly	4.1.1.2
Power Distribution	4.2.2.1.2 4.2.3.1,2
Shutdown Margin Determination	4.1.1.11(d)(e)
Moderator Temperature Coefficient	4.1.1.3.2(a)(b)
Structural Integrity Test	4.6.1.6
Containment Integrated Leakage Testing	4.6.1.2 a,b,c,f
Reactor Building Local Leak Rate Testing	4.6.1.2(d)(f)(h)
Intermediate Range Channel	4.3.1.1.3
Manual Reactor Trip Channel Functional Test	4.3.1.1.1 Table 4.3-1, Item 1
Check Valve Operability Test During Cold Shutdown	4.0.5.2
Core Flooding System Check Valve Functional Test	4.0.5.2
Fuel Handling Bridge Hoist Test	4.9.6
Fuel Handling Building Service Crane Interlocks	4.9.7
Fire System Deluge/Sprinkler System Inspection	4.7.10.2B1&2
Fire Detection Circuit Operational Check	4.3.3.8.3
Fire System Detection Instrumentation Functional Test	4.3.3.8.1
Fire Detection Circuit Operational Test	4.3.3.8.2
Spare H2 Recombiner Channel Calibration	N/A
Spare Hydrogen Recombiner Functional Test	N/A
Spare Hydrogen Recombiner Operational Test	N/A
Reclaimed Boric Acid Tank Temperature	4.1.2.8 4.1.2.9

<u>Description</u>	<u>TS No.</u>
Incore Backup Recorder Calibration	3.2.1 thru 3.2.5
Boric Acid Mix Tank Temperature & Level	4.1.2.8.A 263 4.1.2.9.A 263 4.5.9
Reclaimed Boric Acid Tank Level & Temperature Calibration	4.1.2.8.A 263 4.1.2.9.A 263
Decay Heat Removal Temperature	4.4.9.2
Containment Air Temperature	4.6.1.5
Spent Fuel Storage/Fuel Storage/Spent Fuel Surge Tank Level Calibration	4.9.11
Reactor Coolant System Leakage	4.4.6.2
Diesel "DF-X-1A" (DF-X-1B) Generator Protective Relaying	N/A
Atmospheric Radiation Monitors Calibration	N/A
Letdown Flow Calibration	N/A
Liquid Radiation Monitor Calibration	N/A
Radiation Monitor Calibration G-M Tube Area Monitors	N/A
RTD Input Functional Calibration (Computer)	N/A
Thermocouple Input Functional Calibration (Computer)	N/A
Differential Pressure Gage Calibration	N/A
Pressure Gage Calibration	N/A
Pressure Transmitter Loop Calibration	N/A

N/A denotes surveillance activities not directly required by Technical Specifications but necessary for actions required to be carried out, i.e. "Implied Technical Specifications."

A SUMMARY OF THE  
CAUSE(S) OF THE ACCIDENT

A number of reports have been generated that have included discussions on the cause of the March 28, 1979 accident at TMI-2. These reports include The Report to the Commissioners and the Public by Mitchell Rogovin (NUREG/CR-1250), The President's Commission on the Accident at Three Mile Island (The Kemeny Report), the Office of Inspection and Enforcement Report Number 50-320/79-10 (NUREG 0600), and the findings of the TMI-2 Lessons Learned Task Force (NUREG 0578/0585). Corrective actions based on the findings of the above reports have been taken when appropriate. For the purpose of this report, the licensee feels the causes of the accident are included among the causes and potential causes discussed in the above mentioned reports.

SEQUENCE OF EVENTS  
THREE MILE ISLAND  
March 28, 1979



**TABLE OF CONTENTS**

1.0	Introduction
2.0	List of Figures
3.0	List of References
4.0	List of Symbols
5.0	Associated Sequence of Events

<b>PAGE</b>	
3	
4	
7	
10	
11	

2.0 LIST OF FIGURES

Figure No.	Title	Reference
1	Summary of Reactor Coolant System Parameters (-15 to 120 seconds)	1, 2a
2	Summary of Steam Generation Parameters (-15 to 120 seconds)	1
3	Reactor Coolant System Pressure, Saturation Pressure and Pressurizer Level (-3 to 30 minutes)	1, 2a, 2b, 2c
4	Reactor Coolant System Pressure and Pressurizer Level (-1 to 8 hours)	1, 2c, 2a, 2b
5	Reactor Coolant System Pressure and Saturation Pressure (-1 to 20 hours)	1
6	Reactor Coolant System Loop A & B, Hot and Cold Log Temperature (-2 to 30 minutes)	1
7	Reactor Coolant System Loop A & B, Hot and Cold Log Temperature (60 to 120 minutes)	1
8	Reactor Coolant System Loop A & B, Hot and Cold Log Temperature (-1 to 8 hours)	1, 3p
9	Steam Generator A & B, Level and Pressure (-2 to 30 minutes)	1
10	Steam Generator A & B, Level and Pressure (60 to 120 minutes)	1
11	Steam Generator A & B, Level and Pressure (-1 to 8 hours)	1
12	Reactor Coolant System Pressure (-20 to 120 seconds)	1
13	Reactor Coolant System Pressure (-20 to 120 minutes)	1, 2c, 2a, 2b
14	Reactor Coolant System Pressure (-1 to 20 hours)	1, 2a, 2b, 2c
15	Reactor Coolant System Loop A & B Flow (-20 to 120 seconds)	1
16	Reactor Coolant System Loop A & B Flow (-2 to 30 minutes)	1
17	Reactor Coolant System Loop A & B Flow (-20 to 120 minutes)	1
18	Reactor Coolant System Loop A & B Flow (-1 to 8 hours)	1
19	Reactor Coolant System Loop A & B Flow (-2 to 20 hours)	1
20	Reactor Coolant System Loop A, Hot and Cold Log Temperature (-20 to 120 seconds)	1
21	Reactor Coolant System Loop A, Hot and Cold Log Temperature (-2 to 30 minutes)	1
22	Reactor Coolant System Loop A, Hot and Cold Log Temperature (-20 to 120 minutes)	1

Slide No.

Title

REFERENCE

43	Steam Generator A & B Operating Level (-2 to 20 hours)	1
44	Reactor Coolant Drain Tank Pressure (-20 to 120 seconds)	1
47	Reactor Coolant Drain Tank Pressure (-5 to 30 minutes)	1
48	Reactor Coolant Drain Tank Pressure (-20 to 120 minutes)	1
49	Reactor Coolant Drain Tank Pressure (-1 to 8 hours)	1
50	Reactor Coolant Drain Tank Pressure (-2 to 20 hours)	1
51	Reactor Building Temperature and Pressure (-1 to 20 hours)	2j
57	Reactor Building Temperature at Elevations 310, 330 and 333 feet (0 to 20 hours)	3j
53	Reactor Coolant System Makeup Tank Level (0 to 30 minutes)	1
54	Reactor Coolant System Makeup Tank Level (0 to 8 hours)	1
55	Reactor Coolant System Makeup Tank Level (0 to 20 hours)	1
56	Intermediate Range and Source Range Monitors (0 to 4 hours)	3k
57	Intermediate Range and Source Range Monitors (-1 to 20 hours)	3k
58	Computer Alarm Printer Log Time (-1 to 20 hours)	2a
59	Emergency Feedwater Pumps Discharge Pressure (0 to 14 minutes)	2a
60	TMI Unit 2 Pump Operating History (-1 to 20 hours)	2a
61	Pressure Spray Valve (BC-01) Position (0 to 30 minutes)	1
62	Pressure Spray Valve (BC-01) Position (0 to 20 hours)	1
63	Electrically Bailed Block Valve (BC-2) Position (0 to 10 hours)	1, 2a, 3j, 4b
64	Electrically Bailed Block Valve (BC-22) Position (0 to 20 hours)	1, 2a, 3j, 4b
65	TMI Unit 2 Control Room Layout	6c

7. Van Witsbeck memorandum regarding Thi Unit 2 Operating Staff and POREC Sequence of Brown Review Meeting (1)

8. Thi Staff Interviews Conducted By Met-Ed/CPU (1)

- a. Ken Bryan dated April 24, 1978
- b. Joe Buman dated April 23, 1978
- c. Craig Faust dated March 30, 1978 and April 6, 1978
- d. Ed Frederick dated March 30, 1978 and April 6, 1978
- e. John Flint dated April 20, 1978
- f. Craig Faust and Ed Frederick dated March 29, 1978
- g. Jim Floyd dated April 20, 1978
- h. Don Hiller dated March 30, 1978
- i. Josephine Gingrich dated March 30, 1978
- j. Dale Leudermilch dated March 30, 1978
- k. Hugh McGovern dated March 29, 1978 and May 4, 1978
- l. Brian Mahler dated April 23, 1978
- m. Steve Hall dated March 30, 1978
- n. Frederick Schumann dated March 30, 1978
- o. Bill Lous dated March 30, 1978 and April 6, 1978
- p. Dick Subiel, Gary Miller and Jim Seelinger dated April 12, 1978

9. Thi Staff Interviews Conducted by MSC (1)

- a. Craig Faust dated April 21, 1978
- b. Terry Daugherty dated April 22, 1978
- c. Frederick Schumann dated April 23, 1978
- d. Ed Frederick dated April 23, 1978
- e. Bill Lous dated April 23, 1978
- f. John Flint dated April 23, 1978 and July 2, 1978
- g. Joe Buman dated April 24, 1978
- h. Dick Subiel dated April 24-25, 1978, May 8, 1978 and May 22, 1978
- i. Mike Ross dated April 25, 1978 and May 19, 1978
- j. George Kunder dated April 26, 1978, May 17, 1978, May 23, 1978 and July 11, 1978
- k. James Higgins dated May 1, 1978
- l. Donald Wooley dated May 2, 1978 and May 5, 1978
- m. Michael Jaconski dated May 2, 1978
- n. Michael Benson and Ronald Crawford dated May 3, 1978, May 22, 1978 and June 6, 1978
- o. Thomas Leach dated May 3, 1978
- p. Lee Boger dated May 4, 1978
- q. David Zeiten dated May 5, 1978
- r. Gary Miller dated May 7, 1978
- s. Richard Bannor and Michael Kuhn dated May 8, 1978
- t. Jim Seelinger dated May 8, 1978
- u. Lynn Wright dated May 9, 1978
- v. Joe Logan dated May 9, 1978
- w. Jack Herbsin dated May 10, 1978
- x. Ken Bryan dated May 15, 1978 and July 11, 1978
- y. Tom Davis, Jr. dated May 16, 1978
- z. Scott Wilberson dated May 16, 1978
- A. Walter Harshbail dated May 17, 1978
- B. Brian Mahlen dated May 17, 1978
- C. John Donmachie dated May 17, 1978

(1) This information was not available to the Operator on March 20, 1978.

4.0 LIST OF SYMBOLS

Indications

ST	Electrical Status Light
MS:	Misc:
SC	Stripchart Recorder
AM	Annunciator
PL	Control Room Panel
AP	Alarm Printer
MP	Multiport Recorder
UP	Utility Printer

Parameters

T	Temperature
P	Pressure
L	Level
F	Flow
A	Amperage
V	Vibration

Plant Identifiers

RC	Reactor Coolant
PR	Pressurizer
C	Loop Cold Leg
B	Loop Hot Leg
SG	Steam Generator
MS	Main Steam
RB	Reactor Building
RCBT	Reactor Coolant Drain Tank
LD	Ladings
ESF	Engineered Safety Features
EF	Emergency Feedwater
SI-1	Source Range Monitor
SI-3	Intermediate Range Monitor
SI-4	Intermediate Range Monitor
SC-F	Reactor Coolant Pump
HP-F	Makeup Pump
FW-F	Feedwater Pump
DH-F	Darcy Heat Pump
EF-F	Emergency Feedwater Pump

This table in conjunction with Figure 65 "TMI Unit 2 Control Room Layout", is provided as a guide to understanding the entries under the "Information Available to the Operator" column in the Annotated Sequence of Events.

the heated water storage tank was approximately 55 feet. The Pressurizer Spray Valve (SC-41) and Manual, except Pumps 6 and 7, were in manual control while opening reactor coolant into the Pressurizer to equilibrate boron concentrations between the Pressurizer and the remainder of the Reactor Coolant System. The Pressurizer Relief Valves discharge header thermocouples indicated cool-down between 104F and 100F due to leakage through one of the three Pressurizer Relief Valves (RC-32, RC-31A or RC-31B). An RC-31B high temperature alarm had been received at -2:17 (0123) and was reset at -2:28 (0132). Temperatures recorded were 100F for the alarm and 191.4F for the alarm reset.

The following table lists Steam Generator parameters prior to the accident.

Table of Steam Generator Parameters\*

	Steam Generator A	Steam Generator B
Loop Feedwater	3,745.9 MPPH	3,700.3 MPPH
Operating Level	562	57.42
Startup Level	158.8 inches	103.4 inches
Steam Pressure	910 psig	889.6 psig
Feedwater Temperature	482.7F	482.7F
Steam Temperature	593F	594F

\* MPPH - Million Pounds Per Hour

† The difference between Steam Generators A and B parameters are typical of normal operation.

Steam Generator Feedwater Pumps 1A and 1B (FW-P-1A and FW-P-1B), Condensate Booster Pumps 2A and 2B (CD-P-2A and CD-P-2B) and Condensate Pumps 1A and 1B (Co-P-1A and Co-P-1B) were in service. The heater drain pumps were on line to

Information Available to the Operator      Reference

Item      Event

-00:00:05 (04:00:33) Approximate	The Condensate Proliferator relief valves went about simultaneously. The cause of their failure closure has not been firmly established.	Local indication at the condensate Proliferator Panel.	24,26,28, 29,30
-00:00:09 (04:00:38) Approximate	Condensate Booster Pump 2A and 2B (CO-P-2A and CO-P-2B) tripped on low suction pressure. No computer printout occurred because the auto/manual switch for the condensate system was in the manual position.	Communicator window (AM) at Panel 17 (PL17), motor (MR) indicating motor overage (A) and electrical status lights (ST) at Panel 3 (PL3).	34
-00:00:09 (04:00-34)	Condensate Pump 1A (CO-P-1A) tripped. This was the result of a wiring error in the 4160 volt switchgear bus control circuit which tripped condensate pump 1A (CO-P-1A) when condensate booster pump 2A (CO-P-2A) tripped with the auto/manual switch in the normal position. Condensate pump 1B (CO-P-1B) apparently remained on line.	AM at PL17, MR(A) and ST at PL3 when printer (AP) out-put of alarm/trip and on/off (delay time between alarm printer output and real time approximately 8 seconds).	24,26,34
00:00:00 (04:00:37)	Feedwater Pumps 1A and 1B (FW-P-1A and FW-P-1B) tripped on low suction pressure caused by the loss of Condensate Booster Pumps 2A and 2B (CO-P-2A and CO-P-2B). This resulted in a loss of feedwater flow to both steam generators.	AM at PL13 and PL17, speed and characteristic wave position strip-chart recorder (SC) at PL37, speed MR at PL4, pump discharge pressure (P102C) MR at PL3, AP alarm/trip (Delay = 8 seconds)	24,26,34
00:00:00 (04:00:37)	The Main Turbine and Main Generator tripped in accordance with plant design.	Turbines AM at PL3 and PL17, voltages MR and ST at PL3, AP alarm/trip (Delay = 8 seconds)	24,26,34
00:00:00 (04:00:37)	All three Emergency Feedwater Pumps 1, 2A and 2B (EF-P-1, EF-P-2A and EF-P-2B) started.	Generator: AM at PL19, voltages MR and ST at PL4A, AP alarm/trip (Delay = 0 seconds)	24,26
00:00:04 (04:00:41) Approximate	The Electromechanical Relief Valve (EC-RV) opened at the setpoint of 2255 psig.	All EF-P's: ST and MR(P102C) at PL4 MR-P's 2A and 2B: MR(A) at PL4. AP on/off (Delay = 0 seconds)	1

September 4, 1968  
 TSC 044, Rev 3

Time	Event	Information Available to the Operator	Reference
00:00:10 (0400:47) Approximate	The operator verified that all control and safety rods were tripped and fully inserted in the Reactor core.	RT at PIA, AP norm/trip and Yoc/no (Delay 0 seconds)	00, 20
00:00:13 (0400:50) Approximate	The operator attempted to start Reactor Coolant Makeup Pump A (M-F-123) however, he released the control switch before the required 3.5 seconds had elapsed and the pump tripped.	AM at PIA, RT and MB(A) at PIA, AP norm/trip (Delay 0 seconds)	20, 24, 26, 28, 30, 30, 30
00:00:13 (0400:50)	The Condenser Motrol low level alarm was received. The level was identified to be 21.72 inches.	MB at PIA, AP low (22.5 inches)/norm/trip (30 inches) (Delay 0 seconds)	20
00:00:14 (0400:51)	The Emergency Feedwater Pump (EF-F-1, EF-F-2A and EF-F-2B) normal discharge pressure alarm was received (Figure 3).	MB (Figs 2) at PIA, AP low (setpoint = 875 psig)/norm (Delay 5 1/2 seconds)	20
00:00:14 (0400:51)	Pressure Monitor Groups 1 through 5 automatically energized on a result of reactor coolant pressure decreasing below the margin setpoints of 2100 psig for Groups 1 through 3 and 2120 psig for Groups 4 and 5.	RT at PIA, AP norm/trip (Delay 3 1/2 seconds)	20
00:00:15 (0400:52)	The Reactor Coolant System Pressure level reached a peak value of approximately 256 inches (Figure 3).	SC at PIA, MB (uncompensated) at PIA	1
00:00:15 (0400:52) Approximate	Steam Generator levels were approximately 87 inches (Figure 4). Steam pressure was 1018 psig in Steam Generator B and 1042 psig in Steam Generator A (Figure 3).	SO L; MB (Startup Range) at PIA, MB (Wide Range) at PIA, 1 SC (Operating Range) at PIA and PLS SC P; MB at PIA, SC at PLS	1
00:00:15 (0400:52) Approximate	The Unit 2 Shift Supervisor announced on the Plant Page System that Unit 2 turbine and reactor had tripped.	Announcement made on Plant Page System	SC
00:00:15 (0400:52) Approximate	The Electronic Relief Valve (ER-82) should have shut at this time (closure setpoint of 2205 psig). The Electronic	RT at PIA	1, 60



Control System setpoint of 36 inches for the programmed opening of the Emergency Feedwater Valves (EF-V11A and EF-V11B) which would admit feedwater to the Steam Generators. In addition, the Emergency Feedwater Bleed Valves (EF-V12A and EF-V12B) were shut which also prevented feedwater flow until they were opened eight minutes after the start of the transient. The reason for the bleed valves being shut is not known. The last documented operation of these valves was during the performance of surveillance testing of the Emergency Feedwater System on the morning of March 26, 1979.

00:00:16 (0400155)	The Pressurizer Spray Valve (RC-V1) shut.	SC at P1A	1
-----------------------	---	-----------	---

00:00:20 (0400:57) Approximate	The Steam Generator Safety Valves remained and the Turbine Bypass Valves (MB-F-25A, MB-F-25B, MB-F-26A and MB-F-26B) modulated stem flow to the Main Condenser to control Steam Generator pressure at 1010 ± 10 psig (Figure 34).	Turbine Bypass Valves: MB and ST at P1J 00 F; MB at P1A, SC at P1J7	1
--------------------------------------	---	--	---

00:00:23 (0401:02) Approximate	A "Water Hammer" was noted in the condensate pump discharge piping by an Auxiliary Operator. The piping was displaced approximately 2.5 to 3.0 feet according to the Auxiliary Operator. The pipe movement caused a leak in the flange joint on condensate booster pump (CO-F-7A). It also severed an instrument air line which caused reject inhibit valve CO-457 to fail shut.	Unit 2 Control Room notified of "Water Hammer"	34, 06, 01, 07
--------------------------------------	--	--	----------------

Information Available to the Operator

Event

Time

REFERENCE

00:00:15 (04:01:12) Approximate	Steam Generator B level reached the Integrated Control System setpoint of 30 inches at which the Emergency Feedwater Valve (EF-V118) opens (Figure 40). Feedwater was not admitted to Steam Generator B because Emergency Feedwater Block Valve (EF-V128) was shut. EF-V128 is normally open.	50 L: AM (24 inches) at FL17, MB (Startup Range) at FLA 1, 8c AP low (24 inches)/normal (Delay = 30 seconds) EF-V11A and EF-V11B: MB at FLA EF-V12A and EF-V12B: ST at FLA
00:00:41 (04:01:15)	The operator started Reactor Coolant Makeup Pump A (MU-P-1A) and opened High Pressure Injection Valve (HI-V168). With Reactor Coolant Makeup Pumps A and B (MU-P-1A and MU-P-1B) operating and delivering approximately 400 gallons per minute the Pressurizer level rate of decrease slowed (Figure 31).	MU-P-1A: AM at FLB, ST and MB(A) at FLJ, 1, 2a, 2c, 8d, 9c, 3d, 3e AP norm/trip (Delay = 43 seconds) MU-V168: ST at FLJ, Injection flow MB at FL B
00:00:54 (04:01:31)	The Reactor Coolant System Pressurizer Level reached an indicated minimum level of approximately 158 inches (Figure 31).	SC at FLA, MB (compensated) at FLJ 1
00:00:57 (04:01:34) Approximate	Pressurizer level started increasing (Figure 31). Reactor Coolant System hot leg and cold leg temperatures reached approximately 377° (Figure 6). The Reactor Coolant System Tank pressure was 11 psig and increasing (Figure 47).	PER L: SC at FLA, MB (compensated) at FLJ 1 SC Tc: MF at FL10 SC Tq: SC at FLA, MF at FL10 and MB at FLA SCRT P: MB at FLJA
00:01:00 (04:01:33)	The Pressurizer Safety Valve (SC-S1A) discharge line high temperature alarm was received. This alarm was expected and resulted from back flow in the common discharge header shared with the Electromagnetic Relief Valve (SC-R2).	MP at FL10 AP high (200F)/normal (Delay = 30 seconds)

PLANT STATUS

The Reactor Coolant System was recovering from the initial loss of feedwater flow transient. The Reactor Coolant System pressure was decreasing and the Reactor Coolant Pressurizer level had begun to increase (Figures 1 and 3). The divergence of Reactor Coolant System pressure and Pressurizer level

Information Available to the Operator

Reference

2a

Event

Time

00:01:26 (0402:03)	A Reactor Coolant Bypass Tank temperature normal alarm was received and printed out a temperature of 85.5F. This indicated the Reactor Coolant Bypass Tank temperature was increasing and had reached the normal range.	MR at PLSA AP high (120F)/norm/low (75F) (Delay = 1 minute)	1, 3a
00:01:45 (0402:22) Approximate	Steam Generators A and B had boiled dry at this time. This was indicated by a steadily decreasing Steam Generator pressure (Figure 9) while Reactor Coolant System hot leg and cold leg temperatures were increasing (Figures 21 and 26).	SG P1, MR at PLSA and SG at PLS SG T1, SG at PLS, HP at PLSB and MR at PLS	1, 3a
00:02:00 (0402:37) Approximate	The Unit 2 shift supervisor noted all Condensate Pumps, Condensate Booster Pumps and Steam Generator Feedwater Pumps were tripped. Note: It is believed that Condensate Pump 1B (CO-P-1B) continued to operate throughout the first hour. This is based on a lack of any computer alarm printout for a pump trip or low condensate pump discharge header pressure.	PU-P-1A/1B: AM at PLS5 and PLS7 CO-P-1A/1B: AM at PLS7 CO-P-2A/2B: AM at PLS7	5d, 7, 8r, 9b, 31, 9E
00:02:02 (0402:39)	The Safety Injection portion of Engineered Safety Features trains A and B actuated as Reactor Coolant System pressure reached 1640 psig. Reactor Coolant Makeup Pump 1B (MR-P-1B) tripped automatically as a result of the actuation of Safety Injection. The Engineered Safety Features design is such that Makeup Pumps 1A and 1C are normally used for High Pressure Injection. The normal minimum High Pressure Injection flow rate is 1000 gallons per minute. If Makeup Pump B is running, it is automatically tripped when Safety Injection actuation occurs. Decay Heat Removal Pumps (DR-P-1A and DR-P-1B) Decay Heat Closed Cooling Water Pumps (DC-P-1A and DC-P-1B) and the Emergency Diesel (DF-X-1A and DF-X-1B) also started automatically on Engineered Safety Features trains A and B actuation. The	MRP51: AM at PLS3, ST at PLS and PLS3 AP norm/actuation (Delay = 2 minutes) MR-P-1B: AM at PLS, ST and MR(A) at PLS AP norm/trip (Delay = 2 minutes)	2a, 2b, 5c, 6a, 6c
		MR-P-1A, 1B: ST at PLS and PLS3, MR(A) at PLS3, MR (P9102) at PLS3. AP Norm/low and on/off (Delay = 2 minutes)	

Summary

Event

Information Available to the Operator

Reference

001041:08 In an attempt to gain control of the rapidly increasing pressurizer  
(00103:13) level the operator throttled the High Pressure Injection Isolation  
Apparatus Valves (HI-V16A and HI-V16B).

NO at PLS

04, 06, 08

PLANT STATUS

The Reactor Coolant System pressure was 1420 psig and steadily decreasing to the saturation pressure of the Reactor Coolant System hot leg temperature (Figure 3). The confirmed Reactor Coolant System depressurization was due to the failure of the Electromechanical Relief Valve (EC-RV) to reset, and reduction in High Pressure Injection flow rate. Engineered Safety Features, which actuated High Pressure Injection when pressure reached 1640 psig, had been bypassed by the operator to permit manual control of the Reactor Coolant Makeup Pumps and the High Pressure Injection Isolation Valves.

As the Pressurizer level continued to increase, the operator stopped Reactor Coolant Makeup Pump C (RM-P-1C) and throttled the High Pressure Injection Isolation Valve (HI-V16A and HI-V16B) to an attempt to control the Pressurizer level and not take the Pressurizer "online" (Figures 3 and 32). The Reactor Coolant Drain Tank Relief Valve (DR-T-RV) had opened at 120 psig and a high temperature alarm had been received on the temperature and pressure of the tank continued to increase. The Steam Generators had boiled dry as indicated by a continuously decreasing steam pressure while Reactor Coolant System hot leg and cold leg temperatures increased (Figures 21, 26 and 33). This was due to the Emergency Feedwater Block Valve (EF-V12A) and EF-V12B being closed. The operator did not realize EF-V12A and EF-V12B were shut. The Steam Generators startup level indication remained at approximately 10 to 14 inches. In accordance with operating procedures a level of 8 inches or less in a Steam Generator was considered indicative of a dry Steam Generator.

Information Available to the Operator

Event

Time

Reference

Time	Event	Information Available to the Operator	Reference
00:05:30 (0406:27)	<p>Reactor Coolant System pressure stopped its sharp decrease and began to increase. The alarm value reached was approximately 1350 psig (Figure 3). As the Reactor Coolant System pressure decreased and the Reactor Coolant System temperature increased, the Reactor Coolant System hot legs reached a saturation temperature-pressure relationship at about 1350 psig which resulted in the formation of steam in the hot legs. The pressure throughout is due to the existence of adequate decay heat within the Reactor Coolant System to generate steam at a rate which exceeded the loss of energy through the Electromagnetic Relief Valve and other Reactor Coolant System heat losses.</p>	<p>SC P1 IM and SC at P1A SC T1 SC at P1A, MB at P110 and MB at P1A</p>	1, 2a, 3a, 3b
00:05:54 (0406:31)	<p>Reactor Coolant System pressure/level increased beyond the range of the instrument indication (i.e. greater than 400 inches).</p>	SC at P1A, MB (uncompensated) at P13	1
00:06:24 (0407:01)	<p>The Unit 2 Shift Supervisor again attempted to start Condensate Booster Pump 2B (CB-P-2B). The pump stopped immediately due to low suction pressure. Further attempts to start this pump were then abandoned.</p>	<p>AP at P117, MB(A) and BT at P13 AP alarm/strip (Delay = 3 minutes)</p>	2a, 2d, 02
00:06:36 (0407:11)	<p>The Letdown Cooler 1A (MC-C-1A) outlet high temperature alarm was received. A temperature of 1378 was recorded.</p>	AP alarm/high (1337) (Delay = 4 minutes)	2a
00:06:58 (0407:15)	<p>The operator reduced Letdown flow in response to the Letdown Cooler 1A high temperature alarm and low Reactor Coolant Pressure. The Letdown flow returned to normal. A flow rate of 71.4 gallons per minute was recorded.</p>	<p>MB at P13 AP Range 5 to 160 gpm (Delay = 4 minutes)</p>	2a, 02, 0r, 0d

Time	Event	Information Available to the Operator	Reference
00:08:23 (0409:10)	The Reactor Coolant System hot leg and cold leg temperatures began to decrease as a result of the feedwater added to the Steam Generators (Figure 6). Steam Generator pressure increased as the Steam Generators again functioned as a heat sink for the Reactor Coolant System (Figure 3).	BC FI, BC at PLA, MF at FL10 and IM at PLA SD FI, IM at PLA, BC (FWS) at FL17 AP low (860 psig)/norm/high (910 psig) (Delay = 6 minutes)	1, 5a
00:08:33 (0409:10) Approximate	The Reactor Coolant System pressure began to decrease, reflecting the decrease in Reactor Coolant System temperature (Figures 3 and 4).	IM and BC at PLA	1, 2a, 3a, 5a
00:08:59 (0409:34)	Condensate Pump 1A (CO-P-1A) tripped. It is believed this pump trip was the result of an unsuccessful attempt to start Condensate Booster Pump 2A (CO-P-2A).	AM at FL17, IM(A) and ST at FL3 AP norm/trip and on/off (Delay = 7 minutes)	2a, 5d
00:09:05 (0409:42) Approximate	The operator recognized the condensate reject flow path was bled off and suspected the condensate polluting demineralizers to be the source of blockage. He attempted to establish the condensate flow by opening the Condensate Polluters Bypass Valve (CO-P12). The Valve did not respond.	ST at FL17	5d, 8c, 8f, 8h, 9a
00:09:13 (0409:50)	The condensate booster pump suction header low pressure alarm was received. A pressure of 14.7 psig was recorded.	AP norm/low (15 psig) (Delay = 3 minutes)	2a
00:10:00 (0410:37) Approximate	An Auxiliary Operator discovered a leaking flange in the booster pump suction piping. After reporting this to the Control Room, he then closed Condensate Booster Pump 2A Suction Valve (CO-P27A).	Unit 2 Control Room notified of leaking flange	5d, 8h, 8h, 9b, 9f, 9F
00:10:18 (0410:55)	The Reactor Coolant System Pressurizer level indication came on scale.	BC at PLA, IM (uncompensated) at FL5	1

Time	Event	Information Available to the Operator	Reference
00:10:24 (0411:01)	The operator stopped, restarted and again stopped Reactor Coolant Makeup Pump 1A (M0-P-1A) during the next four seconds.	AM at PLS, ST and MR(A) at PLS AP norm/strip (Delay = 8 minutes)	2a, 3c
00:10:48 (0411:25)	The Reactor Building Sump high level alarm was received. Setpoint is 4.550 feet from the bottom of the Reactor Building Sump.	AP norm/high (4.65 feet) (Delay = 8 minutes)	2a
00:11:43 (0412:20)	The operator started Reactor Coolant Makeup Pump 1A (M0-P-1A) after an unsuccessful attempt to start the pump at 00:11:40 (0412:17).	AM at PLS, ST and MR(A) at PLS AP norm/strip (Delay = 8 minutes)	2a
00:12:00 (0412:37) Approximate	Condensate Hotwell level indication increased off-scale high (greater than 50 inches).	SC at PLS7	3c
00:13:13 (0413:50)	The operator stopped Decay Heat Removal Pumps 1A and 1B (DH-P-1A and DH-P-1B).	ST at PLS3 and PLS, MR (PINSCH) at PLS AP on/off and norm/strip (Delay = 11 minutes)	2a, 9d
00:13:27 (0414:04)	Condensate Booster Pump suction header pressure returned to normal. A pressure of 17.0 psig was recorded.	AP norm/low (15 psig) (Delay = 7 minutes)	2a
00:14:51 (0415:28)	The Reactor Coolant Drain Tank Rupture Diaphragm (M0-226) burst at about 192 psig (Figure 47). Design burst pressure is 200 ± 25 psig. The contents of the Reactor Coolant Drain Tank were released to the Reactor Containment Building atmosphere. This resulted in a rapid increase in Reactor Containment Building Pressure (Figure 31).	ECST P; AM at PLSA (125 psig), MR at PLSA	1
00:15:40 (0416:17) Approximate	The operator stopped the two operating Reactor Drain Pumps. These pumps had been maintaining the pressure in the condensate system.	AM at PLS7, ST at PLS	5d, 9a
00:15:43 (0416:20)	The condensate Booster Pump low discharge pressure alarm was received. A pressure of 307 psig was recorded.	AP norm/low (310 psig) (Delay = 13 minutes)	2a
00:15:57 (0416:34)	The Venturator Pump low suction header pressure alarm was received. A pressure of 289.4 psig was recorded.	AP norm/low (Delay = 13 minutes)	2a

Information Available in the Operator

Event

Time

Reference

Time	Event	Information Available in the Operator	Reference
00:21:00 (0423:37) Approximate	The Unit 2 Shift Supervisor confirmed the Reactor Coolant Drain Tank parameters and concluded that the drain tank rupture discharge (MS-424) had ceased. This conclusion was based on the existing high temperatures and low pressure in the Reactor Coolant Drain Tank coupled with the low discharge pressure of the operating Leakage Transfer Pump(s) 9A and/or 9B (MS-9-9A and/or 9B).	MS-T F; MS and AS (125 psig) at PL1A MS-T Z; MS at PL1A	Sc, Oc, Se
00:21:30 (0423:35)	The Unit 1 Shift Supervisor requested the computer to print the outlet temperatures (SC-10-T21, SC-10-T22 and SC-10-T23) of the Electromagnetic Relief Valve (SC-02) and the Pressurizer Safety Valves (SC-21A and SC-21B). Respective values of 263.4V, 263.2V and 275.1V were indicated. The operator attributed the temperature levels to the normal condition of the discharge header following the initial opening and closing of the Electromagnetic Relief Valve (SC-02) and believed the Electromagnetic Relief Valve (SC-02) to be shut.	MF (Delay = 9 minutes) AF high (200V/pscm) (Delay = 21 minutes) MF at PL10	Sc, Oc, Sr, SA
00:23:00 (0423:37) Approximate	The operator placed the Turbine Bypass Valves (MS-F23A, MS-F23B, MS-F24A and MS-F24B) under manual control and opened them slightly to promote additional cooling of the primary coolant.	MS-F23A/24A; MS and ST at PL3 MS-F21A/24B; MS and ST at PL3	Sc
00:23:00 (0423:37) Approximate	High radiation alarms were received at the Radiation Monitor Fensl from Intermediate Cooling Letdown Coolers A and B Radiation Monitors (IC-2-101 and IC-2-102). This alarm is periodically received because of its low alarm setpoint and sensitivity to background radiation. The Intermediate Cooling Letdown Cooler Radiation Monitors are physically located east to the Reactor Building Sump. It is believed that the alarms were the result of increased background radiation levels caused by the discharge of	MS and MF on PL12	Sc, Sr, Se, SI



Time	Event	Information Available to the Operator	Reference
00:32:23 (0433:00) Approximate	The following radiation monitor readings increased and then leveled off. (a) Gas channel of the Station Vent (HF-R-219) monitor (b) Iodine channel of the Pool Boiling Building Exhaust Duct (before filter) (HF-R-211A) monitor (c) Particulate channel of the Fuel Boiling Building Exhaust Duct (before filter) (HF-R-211A) monitor (d) Iodine channel of the Fuel Boiling Building Exhaust Duct (after filter) (HF-R-211B) monitor. (e) Particulate channel of the Pool Boiling Building Exhaust Duct (after filter) (HF-R-211B) monitor (f) Gas channel of the Fuel Boiling Building Exhaust Duct (after filter) (HF-R-211B) monitor (g) Particulate Channel of the Hydrogen Purge Duct (HF-R-229) monitor (h) Iodine Channel of the Hydrogen Purge Duct (HF-R-229) monitor	MR and WF at PL12	3f, 5b
00:32:36 (0433:13)	Incore Thermocouple E-10 signal indication went out-of-range (OF to 700F).	AP T (Delay = 24 minutes)	2c
00:36:08 (0436:45)	The operator stopped Emergency Feedwater Pump 2B (HF-P-2B) after filling both Steam Generators to an indicated level of about 38 inches on the startup range (Figure 41).	ST, MR (DISCH) and MR(A) at P14 AP on/off and low (875 psig)/norm (Delay = 24 minutes)	1, 2a
00:38:10 (0438:47)	The auxiliary operator stopped Reactor Building Sump Pump 2A (MSL-P-2A) to prevent overflowing the Miscellaneous Waste Holdup Tank (MSL-T-2).	AP on/off (Delay = 31 minutes)	2a, 5b, 8k, 8b

Time	Event	Information Available to the Operator	Reference
00:29:21 (0439:58)	The Condensate high temperature alarm was received. A temperature of 110.39 was recorded.	AP alarm/high (Delay = 40 minutes)	2a
01:00:47 (0501:24)	The operator stopped Circulation Water Pump 1B, 1C, 1D and 1E (CW-P-1B, 1C, 1D and 1E) to activate a logic circuit which transferred steam generator pressure control from the Turbine Bypass Valves (MS-V25A, MS-V25B, MS-V26A and MS-V27B) to the Power Operated Emergency Main Steam Dump Valves (MSV-2A and MSV-3B). This was done to stop steaming to the condenser which was increasing Hotwell Level. Steam Generator Pressure Control was then maintained by intermittent use of MS-V1A and MS-V3B until the use of MSV-3B was terminated at 1:26:23 (0527:00) when Steam Generator B steam line was isolated and until MSV-2A was shut at 01:54:30 (0655:27) after regaining condenser hotwell level control.	MS(A and P) and ST at PL17 AP on/off (Delay = 40 minutes) MS-V25A/26A; MS and ST at PL3 MS-V25B/26B; MS and ST at PL5	2a, 6c, 9a, 9b
01:09:23 (0510:04) Approximate	A Radiation/Chemistry Technician drew a Reactor Coolant System sample for boron analysis after the reactor trip. The boron analysis results indicated a boron concentration of slightly over 100 parts per million.	Unit 2 Control Room notified of boron analysis	9a, 9b
01:10:34 (0511:31)	The Reactor Building Air Cooling Coil's Emergency Discharge Temperature signal indication cycled in and out of computer range (Range 0F to 200F) within the 30 second scan time. This trend continued intermittently for the remainder of March 28, 1979 and is believed to have been a periodic malfunction in the computer input signal.	MS(B) at PL15 AP bed/normal (OW to 200F) (Delay = 30 minutes)	2a
01:12:11 (0512:48)	The operator requested the computer to print the current alarm conditions relative to the Reactor Coolant Pumps. The following alarms were received.	MS (Delay = 0 minutes)	2c

Item \_\_\_\_\_ FRISK \_\_\_\_\_ Information Available to the Operator \_\_\_\_\_ Reference \_\_\_\_\_

Feedwater Valve (RF-0113). Steam Generator Pressure Control was being accomplished using pump operated Emergency Main Steam Pump Valve (MSV-1A and MSV-2B).

0113:23  
(0314:04)

The Shift 2 Shift Supervisor stopped Reactor Coolant Pump 2B (RC-P-2B) to preclude the possibility of damage to the Reactor Coolant Pump from operation near the minimum net positive suction head limits. Additional factors which contributed to the decision were high pump vibration and erratic reactor coolant flow rate.

RC-P-2B: ST, MM(A) and MM(F) at PLA, AM at PLS  
AP norm/rcsp (Boley 2 o minutes)  
BCF 7: AM at PLS, AM and MM at PLS  
BC 7: MM and SC at PLA

20, 44, 50, 52,  
54, 56, 58, 60

0113:42  
(0314:19)

The Shift 2 Shift Supervisor stopped Reactor Coolant Pump 1B (RC-P-1B) to preclude the possibility of damage to the Reactor Coolant Pump from operation near the minimum net positive suction head limits. Additional factors which contributed to the decision were high pump vibration and erratic reactor coolant flow rate.

RC-P-1B: ST, MM(A) and MM(F) at PLA, AM at PLA  
AP norm/rcsp (Boley 2 o minutes)  
BCF 7: AM at PLS, AM and MM at PLS  
BC 7: MM and SC at PLA

20, 44, 50, 52,  
54, 56, 58, 60

0114:15  
(0314:31)

Steam Generator B steam pressure rapidly decreased from approximately 920 psig to approximately 145 psig over the next 20 minutes. This was in response to reduced heat transfer in Loop B as a result of stopping Reactor Coolant Pump 1B and 2B (RC-P-1B and RC-P-2B). Concurrent with this the water level in Steam Generator B started to rise. The rapid rise in Steam Generator B level was a result of a lower steaming rate in Steam Generator B and an unequal division of feed water flow between Steam Generators 4 and 5. The unequal flow was caused by an imbalance in steam pressure between the steam generators with Steam Generator B having the lower steam pressure (Figure 10).

BC 7: MM at PLA, SC at PLS  
BC 1: MM (Startup Range) at PLA

1, 50, 52

References

MS-748/791 ST at PLS  
MS-723/203 MS and ST at PLS

MS-748/791 ST at PLS  
MS-723/203 MS and ST at PLS

Information Available to the Operator

MS-748/791 ST at PLS  
MS-723/203 MS and ST at PLS

Event

The operator about Steam Generator 3 Main Steam Isolation Valves (MS-748 and MS-773). He suspected a Steam Generator 3 to Reactor Building leak based on the large difference in steam pressure of approximately 300 psig between the two Steam Generators, the variations of flow and level experienced while controlling Steam Generator 3 and the increased Reactor Building pressure and temperature. Steam Generator 3 was isolated completely at this time.

The Shift Supervisor directed an auxiliary operator to energize Core Flood Tanks 1A and 1B (CF-7-1A and CF-7-1B) Breaker to give the control room the capability to close isolation valves (CF-7-1A and CF-7-1B). There are no records which indicate the Core Flood Tanks were isolated. It was felt that the system was stable since the pressurizer level was high and the tendency was therefore to isolation as much as possible and not to add makeup water. The Core Flood Tanks were later flooded on the Reactor core by depressurizing the Reactor Coolant System at 07:18:57 (1119:34).

The reactor out-of-core intermediate Range Channel (RI-4) indication increased from a minimum detectable indication of less than 1.0 x 10<sup>-11</sup> ampere to approximately 1.6 x 10<sup>-11</sup> ampere (Figure 36). Correspondingly, the out-of-core Source Range Channel (SI-1) indication increased from about 1.6 x 10<sup>6</sup> to approximately 2.0 x 10<sup>6</sup> counts per second (Figure 36). The indicated increase was not due to reactor core neutron flux level increases but rather an increase in neutron leakage from the reactor core as a result of the formation of steam in the reactor vessel.

01:20:23  
(0320:00)  
Approximate

01:20:23  
(0320:00)  
Approximate

01:20:00  
(0320:33)  
Approximate

06:00 entry at time 02:47:31 (0448:00)

Information Available to the Operator

Information Available to the Operator

MI-9-1C: AM at P1A, RT and MI(A) at P1J  
AP none/trip (Delay to a minute)

Event

cooling water to the reactor core. Makeup Pump C (MI-P-1C) started automatically. Makeup Pump A and C (MI-P-1A and MI-P-1C) are now operating.

Note: The duration of this manual Safety Injection is not known because of the loss of alarm printer data during the period 01:41:22 (0113129) to 01:47:31 (0448104). However, based on the sequence of events printed below Pump IC was stopped prior to 01:26:41 (0629128).

The reactor out-of-core Intermediate Range Channel (MI-4) indication rapidly increased from  $1.6 \times 10^{11}$  to  $3.3 \times 10^{11}$  cps and then rapidly decreased to a minimum detectable level of  $3.0 \times 10^{11}$  cps (Figure 56). The reactor out-of-core Source Range Channel (MI-1) indication showed a corresponding rapid increase from  $2.0 \times 10^4$  to  $5.2 \times 10^4$  counts per second and then rapidly decreased to  $1.5 \times 10^3$  counts per second. After Source Range Channel (MI-1) immediately started increasing. These responses are attributed to changes in moderator density caused by liquid displacing steam in the reactor vessel.

A Radiation/Chemistry Technician took a condenser vacuum pump exhaust sample for radiochemistry analysis per procedural requirements after a reactor trip. The results of the analysis indicated radioactivity levels were not above background. The results of the analysis are listed below.

Potassium 40	4.860 B-06	mCi/ml
Cesium 137	1.555 B-06	mCi/ml
Xenon 135	1.816 B-03	mCi/ml
Total	6.385 B-06	mCi/ml

MI-1: AM and SC at P1A  
MI-4: AM and SC at P1A

MI-2 Control Room notified of Condenser Vacuum pump results.

See entry at time 01:47:31 (0448104)

Item

01:41:00  
(0113137)  
Approximate

01:41:31  
(062100)

Time Event Information Available to the Operator Remarks

01:41:23  
(0531:00)  
Approximate  
A Radiation/Chemistry Technician drew a reactor coolant system sample for analysis of the boron concentration per the request of the Shift Supervisor. The boron analysis yielded a value of approximately 400 parts per million boron. The other checks on shift performed on independent boron analysis of another sample and obtained similar results. The two values recorded were 402 and 407 parts per million boron.

01:21:27  
(0521:04)  
Approximate  
Reactor Coolant System Loop A hot leg temperature began to increase, reflecting steam formation in the upper reactor core region (Figure 22).  
SC at P1A, MP at P1B and MR at P1A  
1,30

01:24:00  
(0524:37)  
Approximate  
The reactor out-of-core intermediate Range Channel (RI-0) indication increased from less than 1.0 x 10<sup>-11</sup> emperes to approximately 1.0 x 10<sup>-10</sup> emperes (Figure 36). A corresponding increasing trend was recorded on the reactor out-of-core Source Range Channel (RI-1) indication (Figure 36). The indicated increase was not due to faster neutron flux level increase but rather an increase in neutron leakage from the reactor core as a result of the steam formed in the reactor vessel. The formation of steam was contributed to by (1) increased reactor core temperatures, (2) throttled Reactor Coolant Makeup Pump flow, (3) the absence of Reactor Coolant System flow, and (4) the decreased Reactor Coolant System pressure which resulted from the open Electronic Relief Valve (ER-82) and the increased Reactor Coolant System cold leg density caused by filling Steam Generator A. After the

RI-1: MR and SC at P1A  
RI-3: MR and SC at P1A  
RI-4: MR and SC at P1A  
M,30

Time	Event	Information Available to the Operator	Reference
02:02:00 (0402:37)	Condenser Hotwell level indication came back on scale (less than 50 inches).		3c
02:02:26 (0403:03) Approximate	Reactor Coolant System Loop B hot leg temperature began increasing (Figure 28).	SC at PLA, MP at PL10 and MB at PLA	1
02:03:42 (0404:19)	Steam Generator A level indication reached 50% on the operating range (Figure 45). This level was established by the operator to induce natural circulation.	SC at PLA and PL3	1, 6c, 8c
02:10:00 (0410:37) Approximate	The Unit 2 Shift Supervisor directed the operator to initiate emergency boron of the Reactor Coolant System via both Makeup Addition Valves (MB-V10 and MB-V127) using both Boric Acid Transfer Pumps 4A and 4B (CA-P-4A and CA-P-4B). This was done in response to an increased neutron flux indication on the reactor out of core source and Intermediate Range channels in conjunction with the results of two boron analysis which indicated the boron concentration in the Reactor Coolant System to be approximately 400 parts per million. Based on these indications it was believed that a reactor testart was in progress. Emergency boron continued until it was terminated at approximately 03:22:00 (0722:37).	MB-V10; ST at PL3 CA-P-4A/4B; ST at PL3 Borations; Match Controller at PL3	3c, 6c, 8c, 9d, 9e, 9f, 9g, 9h, 9c, 9i, 9j, 9k
02:10:42 (0411:19)	Reactor Coolant System Loop A hot leg temperature indication increased offscale, greater than 620F (Figure 23).	AM at PL8 (high at 612F), SC at PLA, MP at PL10 and MB at PLA	1
02:14:23 (0415:00) Approximate	The Reactor Building Air Sample (RB-R-227) particulate channel increased. It eventually went off scale, at 02:34:23 (0635:00).	AM, MB and MP at PL2	3e
02:17:53 (0418:30)	The Unit 2 Relieving Shift Supervisor requested the computer print	MP (Delay 90 minutes)	2c, 8a, 9E

radiation emitters began to increase.

- (a) Reactor Building Purge Air Exhaust Duct A (RP-B-225)-particulate
- (b) Reactor Building Purge Air Exhaust Duct B (RP-B-226)-particulate
- (c) Auxiliary Building Purge Air Exhaust (RP-B-223)-particulate, SO<sub>2</sub>, and iodine

(d) Auxiliary Building Heating & Ventilation monitor gas channel (indication was off scale within 20 minutes).

(e) Reactor Building Air sample (RP-B-227) gas channel (indication was off scale within 10 minutes).

Several radiation alarms were received at the Control Room Radiation Monitor Panel.

04, 06, 08

AP, MB and WP at PUA3

02:43:00  
(0443:00)  
Approximate

A Radiation/Chemistry Technician took a reactor coolant sample. A gamma spectrum analysis was performed at 02:51:23 (0451:00) and indicated a gross beta-gamma activity of 140.7 mCi/ml. The results of the analysis are listed below.

Unit 2 Control Room notified of gross beta-gamma analysis results.

Krypton 85	1.437 E+01	mCi/ml
Rubidium 88	2.647 E+00	mCi/ml
Sodium 24	6.277 E-02	mCi/ml
Neodymium 90	1.498 E-01	mCi/ml
Iodine 131	1.731 E+01	mCi/ml
Iodine 132	2.294 E+01	mCi/ml
Iodine 133	3.202 E+01	mCi/ml
Iodine 134	9.646 E+00	mCi/ml
Iodine 135	2.147 E+01	mCi/ml
Barium 133	5.807 E+00	mCi/ml
Zinc 65	2.240 E+00	mCi/ml
Cesium 134	2.856 E-01	mCi/ml
Cesium 137	2.944 E-01	mCi/ml
Cesium 138	5.121 E+00	mCi/ml
Total:	1.403 E+02	mCi/ml

Fuel Handling Building Monitor (RP-B-218) indicated radiation level began to increase.

MB and WP at PUA3

04, 06

02:51:23  
(0451:00)  
Approximate

The operator attempted to start Reactor Coolant Pump 1A (RC-P-1A). The pump would not start.

ST, MB(A), MB(F) and SC(F) at PUA, MB at PUA, AP norm/ctrlp (Delay 2 s)

04, 08, 06

02:46:13  
(0446:00)  
Approximate

also entry at time 02:47:31 (0447:00)



Time	Events	Information Available to the Operator	Reference
02152:26 (0653:03)	Condenser hotwell level indication returned to normal. A level of 34.94 inches was indicated.	MB(L) at FL5, AF low (22.5 inches)/normal/high (36 inches) (Delay = 3 minutes)	2a
02153:16 (0653:53)	The operator attempted to start Reactor Coolant Pump 1B (RC-P-1B). The pump would not start.	BT, MM(A), MM(F) and GC(F) at FLA, AM or FLA. AP norm/trip (Delay = 4 minutes)	2a, 4c, 9a
02154:09 (0654:46)	The operator started Reactor Coolant Pump 2B (RC-P-2B). A reactor coolant system flow rate of 10 million pounds per hour was experienced for approximately 5 seconds.	BT, MM(A), MM(F) and GC(F) at FLA, AM or FLA. AP norm/trip (Delay = 5 minutes)	1, 2a, 3a, 4c, 9a, 9j
02154:15 (0654:52)	Steam Generator B atom pressure rapidly increases from approximately 140 psig to approximately 720 psig in the next two minutes.	MB at FLA, SC at FL17	1
02154:19 (0654:56)	The operator de-energized Pressurizer Heater Groups 1 through 5. Eleven pressurizer heater groups were available at this time.	BT at FLA AP norm/trip (Delay = 5 minutes)	2a
02154:23 (0655:00) Approximate	Water Gas Discharge Monitor (WDG-B-1480) increased and went off scale. Notes: This monitor is located in the Auxiliary Building at an elevation of 305'0".	MB and MF at FL12	2a, 5b
02154:23 (0655:00)	Unit 1 control room was notified of the site emergency in effect in Unit 2.	Announcement made on Plant Page System	4a, 4f, 8a
02154:33 (0655:10)	The following incore thermocouple temperatures decreased to less than 700F over the next seven minutes. The increased reactor core cooling was a result of Reactor Coolant Pump 2B (RC-P-2B) operation.	AP norm/had (out of range OF to 700F) (Delay = 6 minutes)	2a
	7B - 623.7F 1B - 596.0F 17C - 624.8F 14H - 653.6F		
	10C - 599.0F 2C - 623.8F 13C - 670.6F 7B - 679.7F		

Time Event Information Available to the Operator Reference

Source Range Channel (SI-1) indication showed a corresponding  
 method decrease which indicated the steam in the reactor core  
 region was displaced by liquid (Figure 36). The steam was  
 displaced in the reactor vessel when Reactor Coolant System  
 flow was established. After the Reactor out-of-core Source  
 Range Channel (SI-1) indication rapidly decreased, it  
 immediately started increasing.

0213:12 (0653:46) The operator initiated pressurizer spray flow to stop the rapid rise  
 in Reactor Coolant System pressure. Pressurizer spray flow was main-  
 tained until 03:13:27 (0714:04) in an effort to cool the Reactor  
 Coolant System and reduce Reactor Coolant System pressure. 1,89,84,8r

0215:13 (0453:50) The operator removed the bypass signal from the Safety Injection  
 portion of Engineered Safety Features trains A and B. 2a

0215:26 (0654:03) Condenser hot well low level alarm was received. The level was  
 21.82 inches. 2a

0215:48 (0456:15) The operator started Circulating Water Pump 1E (CH-F-18). 2a,8a,8J

0215:07 (0656:44) The operator opened Main Steam Isolation Valves (MS-V-4B and 7B) and  
 steamed to the steam chest and main steam lines for approximately  
 12 seconds to stop the rapid increase in Steam Generator B pressure.  
 MB (A and F) and ST on FL17  
 AP on/off (Delay = 11 minutes)  
 MB -V4B/7B; ST at FL15  
 SC F; MB at FLA and SC at FL17  
 AP open/closed (Delay = 11 minutes) 2a,9J

0215:23 (0458:00) The Emergency Control Station was established in Unit 1 Health  
 Physics Laboratory. Onsite and offsite radiation monitoring  
 teams were formed to measure radiation levels. Unit 2 Control Room notified of the Elementary  
 Control Station status. 2a,9F

Time	Event	Information Available to the Operator	Reference
03:05:46 (0705:49)	Steam Generator B level indication reached 60% on the operating range (Figure 45). This level was maintained during the next 8.5 hours.	SC (operate range) at PLA and PLS	1
03:06:40 (0707:17)	Condensate Storage Tank B low level alarm was received. A level of 19.96 feet was recorded.	AP low (10 ft)/norm/high (29 ft) (Delay = 13 minutes)	2a
03:10:27 (0711:04)	The operator stopped Emergency Feedwater Pump 2A (EF-P-2A). Both Steam Generators had levels of about 60% on the operating range (Figure 45).	EF-P-2A: ST, NR(A) and NR(P) (SC) at PLA SG L1: SC (Operate Range) at PLA and PLS	1, 2a
03:11:10 (0711:47)	Condenser hotwell level returned to normal. The level was 21.07 inches.	NR at PLS AP low (22.5 inches)/norm/high (36 inches) (Delay = 15 minutes) RC-V2: ST at PLA	2a 1, 3), 3a, 4a, 8a
03:12:28 (0713:05) Approximate	The operator opened the Electronic Relief Block Valve (RC-V2) to reduce Reactor Coolant System pressure and Pressurizer level after attempts to reduce the pressure by using the pressurizer spray flow were unsuccessful.	NR at PLS AP high (200F)/norm (Delay = 15 minutes)	2a
03:12:28 (0713:05)	The Electronic Relief Valve (RC-V2) discharge line high temperature alarm was received. A temperature of 347.7F was recorded.	NR at PLS AP high (200F)/norm (Delay = 15 minutes)	2a
03:12:35 (0713:12) Approximate	The reactor out-of-core Intermediate Range Channels (NI-3 and NI-4) indications decreased to less than 1.0 x 10 <sup>-11</sup> ampere (Figure 36).	NI-3: NR and SC at PLA NI-4: NR and SC at PLA	3a
03:12:33 (0713:30)	The operator stopped Reactor Coolant Pump 2B (RC-P-2B) based on indicated zero flow and motor running current of less than 100 amperes. Normal Reactor Coolant Pump operating current is approximately 600 amperes. Later a close examination of the flow recorder trace indicated a small amount of reactor coolant flow had existed.	ST, NR(A), NR(F) and SC(F) at PLA, NR (trip) at PLS AP norm/trip (Delay = 16 minutes)	2b

Time	Event	Information Available to the Operator	Reference
03:19:45 (0720:22)	The operator manually initiated the Safety Injection portions of Engineered Safety Feature trains A and B as a result of low Reactor Coolant System pressure (Figure 4). The Safety Injection automatic actuation setpoint is 1640 psig.	AM at P113, ST at P13 and 13 AP bypass/cont/trip (Delay = 19 minutes)	2a, 7, 8, 9, 2a, 2b
03:20:13 (0720:50)	Reactor Coolant Makeup Pump 1C (MR-P-1C) started automatically on the Engineered Safety Feature train A actuation. Reactor Coolant Makeup Pumps 1A and 1C (MR-P-1A and MR-P-1C) were operating. NOTE: During an Engineered Safety Features actuation Safety Injection utilizes Reactor Coolant Makeup Pumps 1A and 1C (MR-P-1A and MR-P-1C).	ST and MR(A) at P13, AM at P1A AP norm/trip (Delay = 19 minutes)	2a, 5c, 6c
03:20:23 (0721:00) Approximate	The following radiation monitors registered increased radiation levels: (a) Primary Coolant Letdown HI (MR-B-720 B1) (b) Primary Coolant Letdown Lr (MR-B-720 LD) (c) Intermediate Cooling Letdown Cooler B (IC-B-1091) (d) Intermediate Cooling Letdown Cooler A (IC-B-1092) (e) Intermediate Cooling Letdown Cooler Outlet (IC-B-1093) (f) Plant Effluent Unit II (MPL-B-1311) (g) Decay Heat Closed A Loop (DC-B-3399) (h) Decay Heat Closed B Loop (DC-B-3400) (i) Nuclear Service Closed Cooling (NS-B-3401) (j) Spent Fuel Cooling (SF-B-3402)	AM, MR and MP at P112	3d, 5b

Information Available to the Operator

Event

Time

Reference

the stripchart ended at 1100:00, 4/2/79.

(a) Reactor Building Furge Air Exhaust Duct A (RP-B-223) -

Particulate Monitor

(b) Reactor Building Furge Air Exhaust Duct B (RP-B-226) -

Particulate Monitor

(c) Auxiliary Building Furge Air Exhaust (RP-E-222)

(d) Auxiliary Building Heating & Ventilation Radiation Monitor gas

channel

The Reactor Building Furge Air Exhaust Duct Iodine Monitors indicated

1 x 10<sup>5</sup> counts per minute. The gas channel of the Reactor Building

Duct A Radiation Monitor indicated 5 x 10<sup>5</sup> counts per minute.

03:24:23 Fuel Handling Building Exhaust Filter Outlet Radiation Monitor

(0323:00)

(RP-E-221B) and Unit Vent Stack Radiation Monitor (RP-E-219) alarmed

high. As a result the Fuel Handling Building Supply Fan

(AH-E-9A and AH-E-9B) stopped automatically.

03:22:00 The operator stopped the boric acid addition to the Makeup

(0322:37)

Tank (MU-T-1). This addition was associated with the emergency

boration initiated at 02:10:00 (0610:37).

PLANT STATUS

The Reactor Coolant System was at minimum forced reactor coolant flow with all Reactor Coolant Pumps (RC-P-1A, RC-P-1B, RC-P-2A, RC-P-1B, and RC-P-2B) stopped. After attempts to establish natural circulation failed, the operator started Reactor Coolant Pump 2B (RC-P-2B). However, based on a no flow indication (Figure 18) and a pump running current of less than 100 amps, Reactor Coolant Pump 2B was stopped after 19 minutes. Steam was

M, N, 6c

SC and BT at PL 23

RP-V10:BT at PLS

CA-P-4A/hjBT at PLS

Borations: Batch Controller at PLS

2c, 6c, 8c, 9d  
9b, 9c, 9j, 9a  
9c, 9i, 9e, 9k  
(1)

(1) Informal discussions with the operators to clarify their interviews.

Information Available to the Operator

Reference

Event

Generator D. So was unable to establish flow through the Steam  
 Booster A sample line.

A gamma spectrum analysis of the Steam Generator B sample was  
 performed at 01:23:23 (0728:00) and indicated radioactivity  
 levels were not above background. The results of the analysis  
 are listed below.

Potassium 40	4.840 E-06	mCi/ml
Cobalt 58	1.333 E-06	mCi/ml
Iron 55	1.836 E-07	mCi/ml
Total	6.385 E-06	mCi/ml

The Control Room personnel questioned these results since they  
 felt that Steam Booster B was contaminated. It was later  
 determined that the steam generator sample steam lines leading  
 to the Plant Primary Chemistry Laboratory were reversed. The  
 determination of the level of radioactive materials in both steam  
 generators was made by re-aligning the sample line discharge to  
 the Unit 2 Secondary Chemistry Laboratory and analyzing the  
 sample from each Steam Generator with a tritilar (MR-14). The  
 results indicated that only Steam Generator B was contaminated.  
 A gamma spectrum analysis of these samples was not performed.

03:25:36  
 (0726:33) The Reactor Coolant System Pressurizer high level alarm cleared. A  
 level of 238 inches was recorded.

2a AM at PLB  
 AP low (200 inches)/norm/high (240 inches)  
 (Delay = 37 minutes)

01:27:33  
 (0727:10) The operator bypassed the Safety Injection portion of Engineered  
 Safety features (trains A and B).

2a AM at PLJ, ST at PLJ and PLI3  
 AP norm/bypassed (Delay = 37 minutes)

03:27:23  
 (0728:00) The radiation level indicated on the Auxiliary Building Access  
 Control Corridor Radiation Monitor (RP-B-233) increased.

2b AM, MB and WF at PL 13

Time	Event	Information Available to the Operator	Reference
03:32:00 (033237)	The operator stopped Reactor Coolant Makeup Pump 1C (MR-P-1C) because pressurizer level was rapidly increasing. Indicated Pressurizer level was 373 inches (Figure 4).	MR-P-1C: ST and MR(A) at PLS, AM at PLS AP norm/crisp (Delay = 42 minutes)	1, 2a, 3a
03:35:23 (033500)	The operator isolated the Reactor Building Air Sample Line after it was reported to be blowing air into the Auxiliary Building.	ST at PLS3	4c
03:40:00 (034033)	The operator opened the Electromechanical Selfed Block Valve (SC-72) in an attempt to decrease Pressurizer level, which had increased offscale (greater than 400 inches).	SC-72: ST at PLS	1, 31, 3a
03:40:28 (034105)	The Pressurizer Safety Valves (SC-81A and SC-81B) discharge line high temperature alarms were received. Respective temperatures of 201.67 and 205.27 were recorded.	MF at PLS0 AP High (3007)/norm (Delay = 43 minutes)	2a
03:44:03 (034440)	The following Incore Thermocouple temperatures increased to greater than 700F during the next three minutes (50, 48, 46, 50, 50, 28, 78, 148, 90, 78, 104 and 87). The increase temperatures were in response to stopping Reactor Coolant Makeup Pump 1C (MR-P-1C). Note: (*) This Incore Thermocouple temperature cycled near 700F until Safety Injection actuated on High Reactor Building pressure at 03:56:04 (035641).	AP norm/Red (out of range 8F-708F) (Delay = 43 minutes)	2a
03:44:23 (034500) Approximate	The Fuel Handling Building Exhaust Fans (AE-E-10A and AE-E-10B) or AE-S-10C and AE-E-10D) stopped. Alcheros radioactive contamination levels in Unit 1 Fuel Handling Building and Auxiliary Building started to increase. The reason these fans stopped is unknown.	Exhaust Fan: SC and ST at PLS3 Radiation Levels: MB and MF (Unit 1 Control Room)	3a, 3c
03:44:23 (0345:20) Approximate	Using a resistance bridge and conversion tables, Plant Staff determined the Reactor Coolant System Loop A hot leg temperature	Measurement performed in Unit 2 Control Room by Plant Engineer and discussed with Operator-1	3a, 3d

Time	Event	Information Available to the Operator	Reference
01:55:19 (0756:16)	Intermediate Cooling Pump 1B (IC-P-1B) was tripped automatically by the Engineered Safety Features train B actuation.	AM, ST, MB (P16ICN) and MB(F) at PLS AP on/off (Delay = 46 minutes)	2a, 6a
01:55:19 (0756:16)	The Reactor Building Isolated automatically as part of the Engineered Safety Features train B Actuation.	AM at PLS, ST at PLS and PLS AP Isolation/over (Delay = 46 minutes)	2a
01:55:19 (0756:16)	The Control Room Ventilation System should have aligned to internal recirculation upon actuation of Engineered Safety Features train B. In the recirculation mode the Control Room air exhaust flow is diverted to the supply duct and the supply flow is reduced to maintain a positive Control Room pressure. The exhaust flow recorder was out of service on March 28, 1979 and this flow diversion cannot be verified. However a reduction in the control room supply flow was experienced.	SC and ST at PLS	6c, 3c
01:55:16 (0756:23)	The Reactor Building Isolation and Cooling portion of Engineered Safety Features train A actuated on Reactor Building high pressure. The setpoint is 3.36 psig (Figure 31).	AM at PLS, ST at PLS and PLS AP act/trip (Delay = 46 minutes)	2a, 6a
01:55:16 (0756:23)	Intermediate Cooling Pump 1A (IC-P-1A) tripped automatically by the Engineered Safety Features train A actuation.	AM, ST, MB (P16ICN) and MB(F) at PLS AP on/off (Delay = 46 minutes)	2a
01:56:04 (0756:41)	Reactor Coolant Makeup Pump 1C (RC-P-1C) was started automatically by the Engineered Safety Features train B actuation.	AM at PLS, ST and MB(A) at PLS AP start/trip (Delay = 46 minutes)	2a
01:56:23 (0800:00) Approximate	Waste Gas Tank Discharge A (WGC-T-1485) monitor indication increased from $5 \times 10^2$ counts per minute to $3 \times 10^3$ counts per minute at approximately 05:00:00 (0900:37). Note: This monitor is located in the Auxiliary Building at an elevation of 305 feet.	MB and MF at PLS	3a, 4a



Time	Event	Information Available to the Operator	Reference
04:07:01 (0807138)	The operator removed the defeat signal from the Reactor Building Isolation and Cooling portion of Engineered Safety Features train A. Train B remained defeated.	AM at FL13, ST at FL3 and FL13 AP norm/defeated (Delay = 52 minutes)	2a
04:08:37 (0809114)	The operator started Reactor Coolant Pump 1A (RC-P-1A) to re-establish Reactor Coolant System flow.  NOTE: During the previous run of Reactor Coolant Pump 2B (RC-P-2B), due to the flow and current indication observed, it was thought that the pump might not have started. For this reason it was decided to observe the starting current during a Reactor Coolant Pump start. Reactor Coolant Pump 1A (RC-P-1A) was started and a correct starting current was observed by the operator. As before, the indicated pump current rapidly decreased to less than 100 amperes.	ST, MB(A), MB(F) and SC(F) at FL3, AB at FL3 AP norm/trip (Delay = 31 minutes)	2a, 9a
04:09:14 (0809131)	The operator stopped Reactor Coolant Pump 1A (RC-P-1A) after observing zero flow indication and a running current of less than 100 amperes.	ST, MB(A), MB(F) and SC(F) at FL3, AB at FL3 AP norm/trip (Delay = 31 minutes)	2a, 9a
04:10:10 (0810147)	The operator stopped Intermediate Cooling Pump 1B (IC-P-1B).	AM, ST, MB(FIGS) and MB(F) at FL3 AP on/off (Delay = 53 minutes)	2a
04:16:23 Approximate	The Auxiliary Operator started the Fuel Handling Building Exhaust Fans (AH-E-10A and AH-E-10B or AH-E-10C and AH-E-10D) and the Auxiliary Building Exhaust Fans (AH-E-8C and AH-E-8D). He also placed Control Room Bypass Filter Fan 4B (AH-E-4B) in service.  NOTE: When the Control Room Bypass Filter Fan is running the Control Room atmosphere is filtered continuously.	SC and ST at FL13	2a, 2b, 6a, 9a

<u>Time</u>	<u>Event</u>	<u>Information Available to the Operator</u>	<u>Reference</u>
02:30:00 (0630:37) Approximate	Self powered neutron detectors reading on backup Incore detector recorders A and B came back on scale and started to rise rapidly. These recorders monitor 36 of the 164 incore detectors available.	MP at PL14 AP bad/norm (0 to 2000nA) (Delay = * minutes)	3c
02:31:23 (0632:00) Approximate	The Incore Instrument Panel Area Monitor (HP-R-213) reading began to increase.	AM, MR and MP at PL12	3a,5b
02:33:02 (0633:39)	The operator started increasing Steam Generator B level from 93 inches on the Startup Range to 60% on the Operating Range (Figure 45).	MR (Startup Range) at PL4, MR (Wide Range) at PL4 SC (Operate Range) at PL4 and PL5	1,9a
02:38:25 (0639:00) Approximate	The Letdown Cooler A monitor (IC-R-1092) indicated radiation level increased offscale. The levels indicated on the following radiation monitors began to increase:  (a) Makeup Tank Area Monitor (HP-R-206) (b) Fuel Handling Building S. (HP-R-210) (c) Reactor Building Dome (HP-R-214)	AM, MR and MP at PL12	3a,3d,5b
02:39:23 (0640:00) Approximate	The Unit 1 hot machine stop area monitor (RM-C4) reached the alarm setpoint (2.5 mR/hr). An inspection of the area by Radiation/Chemistry Technicians revealed that the Unit 2 Reactor coolant system sample lines were the source of the increased radiation levels. It takes approximately forty minutes for a representative sample on Unit 2 to reach this area due to the sample line length and flow rates employed.	Unit 2 Coolant Room Notified of Increasing Radiation Levels on Unit 2 Sample Lines.	5b,9h,9p,10
02:44:23 (0645:00) Approximate	Incore Instrument Panel Area Monitor (HP-R-213) indication increased offscale high. The levels indicated on the following	AM, MR and MP at PL12  *See entry at time 02:47:31 (0648:08)	3a,3c,3e,5b

Time	Event	Information Available to the Operator	Reference
04:23:54 (0824:31)	The operator overrode Pressurizer Heater Groups 1 through 5 by putting the heater controls in the automatic mode. Eleven pressurizer heater groups were available at this time.	AM at PLS, ST at PLA, AP on/off (Delay = 58 minutes)	2a
04:26:09 (0826:46)	The Reactor Coolant Makeup Tank level increased offscale high (greater than 100 inches) and remained offscale for 42 seconds (Figure 3A).	SC at PLS	1
04:27:02 (0827:39) Approximate	The operator started Reactor Coolant Makeup Pump 1C (MR-P-1C) after an unsuccessful attempt to start the pump at 04:26:59 (0827:36).	ST and MR(A) at PLS, AM at PLS, AP norm/trip (Delay = 58 minutes)	2a, 5c, 9a
04:30:30 (0831:07)	Pressurizer Heater Group 10 tripped due to a ground fault and was de-energized for the remainder of March 29, 1979. Ten pressurizer heater groups were available at this time.	AM at PLS, ST at PLA, AP norm/trip (Delay = 58 minutes)	2a
04:30:45 (0831:22)	The operator stopped Condensate Vacuum Pumps 1A and 1C (VA-P-1A and VA-P-1C) and broke Main Condenser vacuum after experiencing difficulty with the operation of the Auxiliary Boiler.	Pumps: ST at PLS, AP on/off (Delay = 60 minutes) Vacuum: AM and SC at PLS	2a, 8a, 9a, 10
04:30:45 (0831:22) Approximate	The operator opened Power Operated Emergency Main Steam Dump Valve A (ME-V1A) to induce natural circulation in Steam Generator A. Steam Generator B was still isolated.	ME (Valve demand outpoint) at PLS	8f, 8a, 9a, 10
04:33:20 (0834:07)	The plant staff requested the computer to print the following reactor thermocouple outlet temperatures. The following values were recorded.	OP (Delay = 0 minutes) AP norm/bad (out of range OP to 700P)(Delay = 60 minutes)	2c, 9a, 9a, 9a, 9b
	11L = 480.97	9C = 488.87	
	11E = 488.07	8B = 511.77	
	12X = 488.87	7B = 436.77	
	13H = 488.87	6C = 441.97	
	13O = 533.07	5O = 488.87	

Time	Event	Information Available to the Operator	Remarks																					
04:49:23 (0900:00) Approximate	Condenser Vacuum Pump Exhaust radiation monitor (M-4-74B) decreased to $1 \times 10^4$ counts per minute.	MR and BC at #12	3, 36																					
04:59:23 (0900:00) Approximate	Incore Thermocouple readings obtained by the Fleet Staff using a resistance bridge and a conversion table placed (fuel assembly exit temperatures in the range of 2177 to 2300 (Figure 30).	Unit 2 Control Room notified of measured fuel assembly exit temperatures	43, 46, 50, 54, 57, 60, 67																					
04:59:23 (0900:00)	A Radiation/Chemistry Technician drew a Reactor Coolant System sample. A radiation level of 200 $\mu$ R/hr (beta-gamma) was measured at six inches from the surface of the 50-100 milliliter sample. A beta analysis was performed and a value of 248 parts per million beta was obtained. A gamma spectrum analysis was completed at 07:38:23 (11)9:00 and indicated a total beta-gamma activity of 1354 $\mu$ CI/ml. No further samples were taken for the remainder of March 28, 1979. The results of the analysis is listed below.	Unit 2 Control Room notified of beta and gamma beta-gamma analysis results	40, 48, 54, 57																					
	<table border="1"> <tbody> <tr> <td>Iodine 131</td> <td>6.149 <math>\pm</math> 0.1</td> <td><math>\mu</math>CI/ml</td> </tr> <tr> <td>Iodine 133</td> <td>1.438 <math>\pm</math> 0.02</td> <td><math>\mu</math>CI/ml</td> </tr> <tr> <td>Xenon 133</td> <td>4.493 <math>\pm</math> 0.02</td> <td><math>\mu</math>CI/ml</td> </tr> <tr> <td>Xenon 135</td> <td>2.466 <math>\pm</math> 0.02</td> <td><math>\mu</math>CI/ml</td> </tr> <tr> <td>Rubidium 88</td> <td>6.037 <math>\pm</math> 0.02</td> <td><math>\mu</math>CI/ml</td> </tr> <tr> <td>Krypton 85</td> <td>2.884 <math>\pm</math> 0.02</td> <td><math>\mu</math>CI/ml</td> </tr> <tr> <td>Total:</td> <td>1.554 <math>\pm</math> 0.03</td> <td><math>\mu</math>CI/ml</td> </tr> </tbody> </table>	Iodine 131	6.149 $\pm$ 0.1	$\mu$ CI/ml	Iodine 133	1.438 $\pm$ 0.02	$\mu$ CI/ml	Xenon 133	4.493 $\pm$ 0.02	$\mu$ CI/ml	Xenon 135	2.466 $\pm$ 0.02	$\mu$ CI/ml	Rubidium 88	6.037 $\pm$ 0.02	$\mu$ CI/ml	Krypton 85	2.884 $\pm$ 0.02	$\mu$ CI/ml	Total:	1.554 $\pm$ 0.03	$\mu$ CI/ml		
Iodine 131	6.149 $\pm$ 0.1	$\mu$ CI/ml																						
Iodine 133	1.438 $\pm$ 0.02	$\mu$ CI/ml																						
Xenon 133	4.493 $\pm$ 0.02	$\mu$ CI/ml																						
Xenon 135	2.466 $\pm$ 0.02	$\mu$ CI/ml																						
Rubidium 88	6.037 $\pm$ 0.02	$\mu$ CI/ml																						
Krypton 85	2.884 $\pm$ 0.02	$\mu$ CI/ml																						
Total:	1.554 $\pm$ 0.03	$\mu$ CI/ml																						
04:59:23 (0900:00)	Intermediate Cooling Pump Area monitor (MF-2-107) and the Reactor Building Emergency Cooling Reactor Pump Area monitor (MF-2-204) indications began to increase.	MR and BC at #12	3, 36																					
05:11:23 (0912:00)	The Emergency Control Station was moved from Unit 1 Health Physics Laboratory to Unit 2 Control Room after experimenting increased levels in airborne radioactive materials.	Unit 2 Control Room notified of relocation of the Emergency Control Station	45, 46, 50, 54																					

Information Available to the Operator

Event

Time

Reference

Relief Bleed Valve (BC-22) was cycled to monitor its effect, resulting in increased Reactor Building pressure. The first Engineered Safety Features actuation on high Reactor Building pressure was received and, four minutes later, bypassed by the operator to re-establish cooling water to plant equipment within the Reactor Building. The Reactor building pressure continued to remain above the isolation trip setpoint for approximately 1.4 hours (Figure 5). The Station Manager made the decision to maintain continuous High Pressure Injection and increase Reactor Coolant System pressure in an attempt to condense the superheated steam and get in the Reactor Coolant System. This first attempt lasted for approximately 2 hours.

05:28:00 (0928:37) Approximate	The operator increased Reactor Coolant System pressure from 1250 psig to 2100 psig during the evening 45 minutes. Reactor Coolant System pressure was then maintained at 2100 psig (Figure 4).	AB (Low-2035 and Low/Loop-1000) at PLS MS and SC at PLS AP (many clearing alarms) (Delay = 60 minutes)	2a
05:23:34 (0924:11)	The operator removed the defect signal from the Reactor Building Isolation and Cooling portion of Engineered Safety Features train A.	AB at PLS, BT at PLS and PLS AP occur/defeated (Delay = 00 minutes)	2a
05:23:34 (0924:28)	The Reactor Building Isolation and Cooling portion of Engineered Safety Features train A actuated on Reactor Building high pressure. The setpoint is 3.28 psig (Figure 5).	AB at PLS, BT at PLS and PLS AP occ/trip (Delay = 90 minutes)	2a,6a
05:23:34 (0924:11)	Intermediate Cooling Pump IA (IC-P-1A) tripped automatically on the Engineered Safety Features train A actuation.	AB, BT, MS (Pulsed) and MS(B) at PLS AP on/off (Delay = 00 minutes)	2a
05:23:47 (0924:24)	The operator defeated the Reactor Building Isolation and Cooling portion of Engineered Safety Features train A.	AB at PLS, BT at PLS and PLS AP occur/defeated (Delay = 00 minutes)	2a

Time	Event	Information Available to the Operator	Reference
05:36:44 (0937:11)	The Safety Injection logic of the Engineered Safety Features tripped A and B reset automatically on increasing Reactor Coolant System Pressure. The setpoint is 1665 psig.	AN at FLJ, ST at FLJ and FLJ AP trip/norm (Delay = 95 minutes)	2a
05:39:27 (0940:04)	The Pressurizer Safety Valve (RC-210) discharge line high temperature alarm reset. A value of 197.4F was recorded.	NP at FLJ0 AP high (100F)/norm (Delay = 97 minutes)	2a
05:41:06 (0941:53)	The operator removed the bypass signal from the Safety Injection portion of Engineered Safety Features trains A and B. At this time all Engineered Safety Features are in an armed condition.	AN at FLJ, ST at FLJ and FLJ AP norm/defaulted (Delay = 100 minutes)	2a
05:43:09 (0943:46) Approximate	The operator opened the Electromechanical Relief Block Valve (RC-V2) to stop the Reactor Coolant System pressure increase. During the period 05:43:09 (0943:46) thru 07:38:57 (1139:34), the operator attempted to condense the steam in the Reactor Coolant System by maintaining High Pressure Injection and controlling the Reactor Coolant System pressure at approximately 2100 psig by cycling RC-V2 (Figure 4). The Reactor Building pressure and temperature reflected the cycling of RC-V2 (Figure 45).	RC P: NR and SC at FLA RC-V2: ST at FLA RA P: SC at FLJ RB Y: NP at FLJ3	1,3,3a,9, 9a,9b,9c,10
05:43:27 (0944:04)	The Electromechanical Relief Valve (RC-22) discharge line high temperature alarm was received. A value of 214.7F was recorded.	NP at FLJ0 AP high (100F)/norm (Delay = 100 minutes)	2a
05:44:01 (0944:38)	Pressurizer Safety Valve (RC-213) discharge line high temperature alarm was received. A value of 205.4F was recorded.	NP at FLJ0 AP high (100F)/norm (Delay = 101 minutes)	2a
05:44:27 (0944:04)	Pressurizer Safety Valve (RC-214) discharge line high temperature alarm was received. A value of 205.3F was recorded.	NP at FLJ0 AP high (100F)/norm (Delay = 103 minutes)	2a

Information Available to the Operator

Event

Time

Reference

06:14:23 (1015:00) Approximate	The Emergency Control Station was moved from Unit 2 Control Room to the Unit 1 Control Room due to increased airborne radioactivity levels.	
06:17:00 (1017:37) Approximate	Personnel in Unit 2 control room were required to wear respirators due to increased airborne radioactivity levels.	
06:19:23 (1020:00) Approximate	The operator started the Fuel Handling Building Exhaust Fans (AH-E-10A and AH-E-10B or AH-E-10C and AH-E-10D) and the Auxiliary Exhaust Fans (AH-E-9C and AH-E-9D). These fans ran for approximately 3 minutes at which time they stopped.	SC and ST at PL25 3g, 2h
06:19:23 (1048:00) Approximate	The operator started the Fuel Handling Building Exhaust Fans (AH-E-10A and AH-E-10B or AH-E-10C and AH-E-10D) and the Auxiliary Building Exhaust Fans (AH-E-9C and AH-E-9D). Airborne contamination levels in Unit 1 Fuel Handling and Auxiliary Buildings began to decrease.	3g, 2h, 3t, 2u, 4g
07:06:23 (1107:00) Approximate	Two Nuclear Regulatory Commission Region 1 inspectors entered Unit 2 Control Room to evaluate the operational and radiological status of Unit 2.	4h, 5m, 5n
07:09:31 (1109:08)	The operator started Emergency Feedwater Pump 2A (EF-P-2A) to increase Steam Generator A level from 95H to 100H on the operating range.	2a ST, SB(A) and MB (P018CB) at P1A AP on/off and low (875 psig)/norm (Delay = 116 minutes)
07:09:41 (1110:18)	The plant staff requested the computer to print the following Incore Thermocouples Outlet temperatures. The following values were recorded. 8H - ans.07 9H - ans.07	2c, 9f AP norm/hed (out of range 07 to 700F) (Delay = 11' minutes)

8C - ans.07

9C - ans.07

Time	Event	Information Available to the Operator	Reference
07143:01 (1143:38)	<p>The Safety Injection portion of Engineered Safety Features tripped</p> <p>A and B actuated on Reactor Coolant System pressure decreased to less than 1640 psig. However, initiation did not occur because of the manual bypass previously introduced.</p>	<p>AN at PL13, ST at PL3 and PL13</p> <p>AP norm/action (Delay = 144 minutes)</p>	2a
07143:46 (1144:23)	<p>Pressurizer Heater Groups 1 and 2 tripped and re-energized after 2 seconds when the pressurizer heater control selector switch was placed in the manual position.</p>	<p>ST at PLA</p> <p>AP norm/trip (Delay = 145 minutes)</p>	2a
07150:16 (1150:53)	<p>The operator de-energized Pressurizer Heater Groups 1 and 2 to coollet in lowering Reactor Coolant System pressure. Seven pressurizer heater groups were available at this time.</p>	<p>ST at PLA</p> <p>AP norm/trip (Delay = 145 minutes)</p>	2a
07158:15 (1158:53)	<p>The operator initiated pressurizer spray flow to coollet in lowering Reactor Coolant System pressure. Pressurizer spray flow was maintained until 09:07:24 (1308:01).</p>	<p>FSR SPRAI; ST at PLA</p> <p>SC FI; HE and SC at PLA</p>	1, 8c, 8e
07159:37 (1200:14)	<p>The operator requested the computer to print the outlet temperature (SC-10-T13) of Pressurizer Safety Valve (SC-31B). A temperature of 206.17 was recorded.</p>	<p>UP (Delay = 0 minutes)</p> <p>AP high (200F)/norm (Delay = 148 minutes)</p> <p>HF at PL10</p>	2c
0811:26 (1212:03)	<p>Core Flood Tank IA (CF-T-1A) high level alarm was received. The level was 13.32 feet.</p>	<p>AE and HE at PL8</p> <p>AP norm/high (13.3 feet) (Delay = 150 minutes)</p>	2a
0816:58 (1217:35)	<p>Pressurizer Safety Valve (SC-31A) discharge line high temperature alarm reset. A temperature of 192.9F was recorded.</p>	<p>HF at PL10</p> <p>AP high (200F)/norm (Delay = 154 minutes)</p>	2a
0817:58 (1223:33)	<p>Pressurizer Safety Valve (SC-31B) discharge line high temperature alarm reset. A temperature of 192.9F was recorded.</p>	<p>HF at PL10</p> <p>AP high (200F)/norm (Delay = 156 minutes)</p>	2a



Time	Event	Information Available to the Operator	Reference
09:54:56 (1255:33)	Core Flood Tank 1A (CF-T-1A) normal level alarm was received. The level was 13.1 feet. This indicated the Core Flood System injected a small amount of water into the Reactor Coolant System.	AB and MB at PLS. AP norm/high (13.3 feet) (Do. 17 = 150 minutes)	2a, 2b
09:04:18 (1304:53)	The operator stopped Reactor Coolant Makeup Pump 1C (MR-P-1C) and returned the Reactor Coolant Makeup System to one pump operation.	AB at PLS, BE and MB(A) at PLS	2a, 2c
09:04:23 (1303:00) Approximate	Personnel in Unit 1 Control Room were required to wear respirators due to increased airborne radioactivity levels. Personnel not essential to control room operations were moved to the Observation Center.	AB, MB and NP (Unit 1 Control Room) Unit 1 Control Room air sample data	4g, 4b
09:07:24 (1300:01)	The operator noticed Pressurizer Spray flow.	PIS SPRAY: ST at PLS SC P: MB and BC at PLS	1, 6c, 6d
09:14:23 (1315:00) Approximate	The operator shut the Electromechanical Balled Check Valve (EC-93).	ST at PLS	3j
09:16:58 (1317:35)	The Electromechanical Ball Valve (EC-82) discharge line high temperature alarm reset. A temperature of 192.77 was recorded.	MP at PLS AP high (2007)/secm (Delay = 170 minutes)	2a
09:20:28 (1311:05) Approximate	The operator opened the Electromechanical Balled Check Valve (EC-72).	ST at PLS	3j
09:20:28 (1311:05)	The Electromechanical Ball Valve (EC-82) discharge line high temperature alarm was received. A temperature of 220.47 was recorded.	MP at PLS AP high (2007)/secm (Delay = 167 minutes)	2a
09:20:00 (1320:37) Approximate	The operator shut the Electromechanical Balled Check Valve (EC-72).	ST = PLS	3j
09:20:18 (1320:55)	The operator started the plant computer on a two minute stop	MP (Delay = 8 minutes)	2c

Item \_\_\_\_\_ Event \_\_\_\_\_ Information Available to the Operator \_\_\_\_\_ Reference \_\_\_\_\_

from the reaction between aluminum fuel cladding and the reactor coolant had collected in the Pressurizer. This gas had been vented through the Electromechanical Relief Valve (ERV) to the Reactor Coolant Drain Tank and released to the Reactor Building through the Drain Tank rupture diaphragm (DRD-216) which had been breached. The hydrogen concentration in the containment eventually reached an explosive mixture. The detonation resulted in a Reactor Building pressure spike of 28 psig with a corresponding rapid increase in Reactor Building air temperature.

09:09:43 (1350:20) Approximate	Motor Control Centers 31A and 42A were lost. These motor control centers supply power to the Seal Water Pumps which furnish seal water to many of the Robotic System Pumps in the Auxiliary Building.	Local indication at the Robotic panel	26, 26, 33, 60
09:09:44 (1350:31)	The Reactor Building isolation and cooling portion of Engineered Safety Features trains A and B actuated on high and high-high Reactor Building pressure (Figure 51). The setpoints are 3.38 psig and 28 psig respectively. This was a result of the 28 psig Reactor Building pressure impulse from the hydrogen detonation. Reactor Building isolation, cooling and containment spray were actuated.	AH at PL3, ST at PL3 and PL3 AP summary (Delay = 159 minutes)	26, 26, 33, 60
09:09:44 (1350:21)	Reactor Coolant Removal Pump 1A and 1B (08-P-1A and 1B) started and Intermediate Cooling Pump 1A and 1B (1C-P-1A and 1B) tripped automatically on the Engineered Safety Features Train A and B actuations.	08-P-1A/1B: ST at PL3 and PL3, MH (P310C) at PL3 M(A) at PL3, AP on/off and overtrip (Delay = 159 minutes)	26
09:09:47 (1350:23)	Reactor Coolant Makeup Pump 1C (08-P-1C) started automatically by the Engineering Safety Features Train A actuation.	1C-P-1A/1B: AH, ST, MH (P310C) and MH (P) at PL3 AP on/off (Delay = 159 minutes)	26, 5c

Time	Event	Information Available to the Operator	Reference
09:09:09 (1330:25)	Reactor Building Spray Pumps 1A and 1B (8R-P-1A and 1B) started automatically upon actuation of Engineered Safety Features train A and B.	ST at PLS and PLS3 AP norm/trip (Delay = 160 minutes)	2a
09:09:58 (1330:33)	Reactor Coolant Pumps 1A and 1B (8C-P-1A and 8C-P-1B) inlet air high compressor alarms and Pressurizer Safety Valves (8C-R1A and 8C-R1B) discharge line high temperature alarms were received.	8C-P-1A/1B Y: AP norm/high (1227)(Delay = 161 minutes) 8C-R1A/1B: AP norm/high (Delay = 161 minutes)	2a
09:30:09 (1330:66)	The operator defeated the Reactor Building Isolation and Cooling portion of Engineered Safety Features train A.	AM at PLS, ST at PLS and PLS3 AP norm/defeated (Delay = 162 minutes)	2a
09:30:09 (1330:66)	The operator started Intermediate Cooling Pump 1A (1C-P-1A).	AM, ST, MB (FpISCM) and MB(F) at PLS AP on/off (Delay = 162 minutes)	2a
09:30:11 (1330:68)	The operator defeated the Reactor Building Isolation and Cooling portion of Engineered Safety Features train B.	AM at PLS, ST at PLS and PLS3 AP norm/defeated (Delay = 162 minutes)	2a
09:30:11 (1330:68)	The operator started Intermediate Cooling Pump 1B (1C-P-1B).	AM, ST, MB (FpISCM) and MB(F) at PLS AP on/off (Delay = 162 minutes)	2a
09:30:24 (1331:01)	The operator stopped Reactor Coolant Makeup Pump 1C (8R-P-1C).	AM at PLS, ST and MB(A) at PLS AP norm/trip (Delay = 162 minutes)	2a, 5c, 7M
09:51:58 (1332:33)	The Electromechanical Relief Valve (8C-R2) and the Pressurizer Safety Valve (8C-R1A) discharge line high temperature alarm reset. Respective temperatures of 180.5F and 178.6F were recorded.	MP at PLS0 AP High (2007)/norm (Delay = 162 minutes)	2a
09:52:20 (1332:52)	The Electromechanical Relief Valve (8C-R2) discharge line high temperature alarm was received. A temperature of 208.8F was recorded. It is believed that this was a result of the operator cycling the Electromechanical Relief Valve (8C-R2).	MP at PLS0 AP High (2007)/norm (Delay = 161 minutes)	2a

Time	Event	Information Available to the Operator	Reference
09:59:26 (1400:03)	The following Incore Thermocouple temperatures decreased to less than 700F over the next minute. This was a result of Core Flood Tank (CF-T-1A) discharging into the reactor vessel. SL - 687.2F 13L - 644.7F 10R - 681.9F 00R - 681.4F	AP norm/had (out of range 0F to 700F) (Delay = 140 minutes)	2a
10:00:58 (1401:35) Approximate	The operator opened the Electromechanical Relief Block Valve (EC-V2).	RT at PLA	3J
10:00:58 (1401:35)	The Electromechanical Relief Valve (EC-R2) and the Pressurizer Safety Valve (EC-R1B) discharge line high temperature alarms were received. Respective temperatures of 206.7F and 208.0F were recorded.	HF at PL10 AP high (200F)/norm (Delay = 139 minutes)	2a
10:04:30 (1405:07)	The operator initiated pressurizer spray flow to coolant in lower Reactor Coolant System pressure. Pressurizer spray flow was maintained until 11:05:54 (1406:31).	PER SPRAY: RT at PLA EC P: NR and OC at PLA	1, 6a
10:05:25 (1406:02)	The operator energized Pressurizer Heater Groups 1 and 2. Six pressurizer heater groups were available at this time.	RT at PLA AP norm/trip (Delay = 136 minutes)	2a
10:07:19 (1407:56)	The operator de-energized Pressurizer Heater Groups 1 and 2. Six pressurizer heater groups were available at this time.	RT at PLA AP norm/trip (Delay = 134 minutes)	2a
10:22:58 (1424:35)	Pressurizer Safety Valve (EC-R1B) discharge line high temperature alarm reset. A temperature of 192.9F was recorded.	HF at PL10 AP high (200F)/norm (Delay = 132 minutes)	2a
10:26:18 (1428:55)	Reactor Coolant System Loop A hot leg temperature decreased to within the instrumentation range (Figure 26). This was the result of the steam in Loop A hot leg condensing.	OC at PLA and PL10, NR at PLA, AR at PL3	1, 9J, 9B, 9J, 9H
10:29:19 (1430:00) Approximate	At the request of the Pennsylvania State Government, the Metropolitan Edison Company Vice President of Generation traveled to	Announcement made to personnel in Unit 2 Control Room	9A, 9B, 9E, 10

Time	Event	Information Available to the Operator	Reference
10:38:31 (1448:28)	The operator energized Reactor Heater Groups 1 and 2. Six pressure heater groups were available at this time.	RT at 1/A AP warn/trip (Delay = 100 minutes)	2a
10:39:33 (1450:10)	The Reactor Heat Acquisition System mastering tape was removed and another tape started by plant staff personnel. This operation was required daily due to the computer sampling rate of these records and the tape storage capability. The reconstruction was off line between 10:33:23 (1454:10) to 10:57:23 (1458:00).	Unit 2 control room notified of reactor heater tape changeout.	1
11:00:13 (1500:10)	The alarm printer malfunctioned between 11:00:13 (1501:10) to 11:01:36 (1502:13). During this period the alarm printer function was performed by the utility printer.	AP (Delay = 0 minutes) Paper feed problem in printer	2a, 2c
11:07:35 (1509:12)	Reactor level started decreasing from 390 inches to 17A inches over a period of 13 minutes (Figure 33).	SC AT PL 4, AB (High/High = 315 inches, High = 300 inches, Low = 280 inches and Low/Low = 00 inches) at PL 9.	1
11:09:23 (1510:00)	The airborne radioactivity level in Unit 2 Control Room reduced to a level such that personnel were permitted to remove respirators.	AP, MB and WP at PL 2 (air supply) Unit 2 control room air sample data	6b, 6c
11:12:08 (1512:37) Approximate	The operator shut the Electronic Balled Check Valve (EC-72).	RT at 1/A	31, 6a
11:13:47 (1516:26)	Reactor Coolant System Loop A cold leg temperature started to increase from 213F to 412F indicating the occurrence of some external circulation in Loop A (Figure 24)	WP at PL 10	1, 31, 36
11:18:34 (1519:11)	The operator started Reactor Coolant Makeup Pump IC (MR-F-1C) to stop the top 18 fall in the Pressurizer level.	AB at PL 9, MB(A) and ST at PL 3 AP warn/trip (Delay = 04 minutes)	1, 2a, 2c, 36

Item	Event	Information Available to the Operator	Reference								
11:55:46 (1536:25)	The operator stopped Booster Coolant Makeup Pump 1C (M-F-1C).	AP at PLA, MR(A) and ST at PL3	2a, 3c								
11:56:38 (1536:13)	The operator started filling Steam Generator 8 from 578 to 978 on the operating range in an attempt to induce natural circulation (Figure 39). The 978 level was reached at 11:57:04 (1537:41).	AP norm/ctrl (Delay = 83 minutes) SC (operating range) at PLA and PL3	1								
11:57:12 (1545:54)	The operator merged Pressurizer Heater Groups 1 and 2. Six pressurizer heater groups were available at this time.	ST at PLA AP norm/ctrl (Delay = 84 minutes)	2a								
11:59:33 (1550:00) Approximate	The Fuel Handling Building Submerg Ventilation flow fluctuated during the next three hours. The reason for this flow fluctuation is unknown.	SC and ST at PL23	2a								
11:52:04 (1552:40)	Steam Generator 8 Level Indication reached 978 on the operating range (Figure 43). The operator stopped Emergency Feedwater Pump 2B (E-F-2B).	SC (operating range) at PLA and PL3 ST, MR(A) and MR (Pulsed) at PLA AP on/off and low (875 gal)/norm (Delay = 85 minutes)	1, 2a								
12:10:35 (1611:32)	The plant staff requested the computer to print the following items: Thermocouple outlet temperatures. The following values were received. <table border="1" data-bbox="842 1093 1118 1520"> <tr><td>50 = 666.87</td></tr> <tr><td>58 = 596.87</td></tr> <tr><td>59 = 666.87</td></tr> <tr><td>67 = 666.87</td></tr> <tr><td>68 = 666.87</td></tr> <tr><td>77 = 666.87</td></tr> <tr><td>78 = 666.87</td></tr> <tr><td>80 = 666.87</td></tr> </table>	50 = 666.87	58 = 596.87	59 = 666.87	67 = 666.87	68 = 666.87	77 = 666.87	78 = 666.87	80 = 666.87	MP (Delay = 8 minutes) AP norm/fwd (out of range 89 to 7000) (Delay = 90 minutes)	2a, 9c
50 = 666.87											
58 = 596.87											
59 = 666.87											
67 = 666.87											
68 = 666.87											
77 = 666.87											
78 = 666.87											
80 = 666.87											

Note (666.87) indicates the signal was outside of the computer range (89 to 7000)

Information Available to the Operator

Time	Event	Reference
13:05:29 (1706:08)	Pressurizer Safety Valve (SC-810) discharge line high temperature alarm reset. A temperature of 192.8F was recorded.	2a
13:13:10 (1713:47)	The operator started Condensate Vacuum Pump 1A (VA-F-1A).	2a

PLANT STATUS

All Reactor Coolant Pumps (RC-F-1A, RC-F-2A, RC-F-1B and RC-F-2B) were stopped. Steam and gas existed in the Reactor vessel head and Loop B hot leg. The steam in Loop A hot leg had been condensed and natural circulation flow had been established in this loop. Condensate vacuum was established after returning the Auxiliary Steam Boiler to service. Steam Generator A level was 97% of the operate range (Figure 39). Steam Generator B was isolated, with a level at 93% of the operate range (Figure 39). The Electromagnetic Relief Block Valve (RC-V2) was open, keeping the Reactor Coolant System depressurized to 650 psig (Figure 12). Venting through the Electromagnetic Relief Valve (RC-E2) to the Reactor Building resulted in an increase in hydrogen concentration. The subsequent hydrogen denatation caused a 28 psig pressure pulse in the Reactor Building. Attempts to use the Core Flood System to cool the core during the last six hours had limited success. The reactor core was being cooled by (1) High Pressure Injection flow into the Reactor Coolant System and then to the Reactor Building floor via the Electromagnetic Relief Valve (RC-E2) and (2) Core Flood Tank A partial discharge.

13:15:00 The operator shut the Electromagnetic Relief Block Valve (RC-V2) in  
 (1715:37) an attempt to condense the remaining steam in the Reactor Coolant System by increasing Reactor Coolant System pressure (Figure 12).

1.31.30.44.  
93.96.90.10

ST at P1A

Information Available to the Operator

Time	Event	Reference
14:43:15 (1843:52)	The operator stopped Reactor Coolant Makeup Pump 1C (MF-P-1C) to slow the rapid increase in Reactor Coolant System pressure.	MF-P-1C: AM at PLS, MB(A) and ST at PLS AP norm/trip (Delay = 0 minutes) SC P1, MB and SC at PLS
14:48:22 (1848:59)	The alarm printer malfunctioned due to paper feed problems. A-0 reinit the alarm summary data from 14:48:22 (1848:59) to 15:09:52 (1910:29) was deleted.	AP (Delay = 0 minutes) Paper feed problem in printer
14:54:35 (1855:17) Approximate	Reactor Coolant System pressure reached 2332 psig (Figure 14).	MB and SC at PLS, AM (Low/Low = 1900 psig Low = 2055 psig and High = 2500 psig) at PLS
14:59:23 (1900:08) Approximate	The following radiation monitors indication came on scale and continued decreasing. (a) Reactor Building Purge Unit Area radiation monitor (MF-B-3236) (b) Auxiliary Building Access Corridor radiation monitor (MF-B-232) (c) Waste Disposal Storage Area radiation monitor (MF-B-318) (d) Fuel Handling Building Exhaust Unit Area radiation monitor (MF-B-3240)	AM, MB and MP at PLS2
15:11:22 (1911:29)	The Fuel Handling Building radiation monitor (MF-B-215) and Control and Service Building Corridor radiation monitor (MF-B-234) indication was steady at about 10 counts per minute. The operator requested the computer to print a summary of Reactor Coolant Pumps and Makeup Pumps parameter status.	MP (Delay = 0 minutes)

2c




Information Available to the Operator

Time


Time	Event	Information Available to the Operator	Reference
15133:07 (15133:44)	The operator manually bypassed the Safety Injection portion of Engineered Safety Features Train A and B.	AM at PLS, ST at PLS and PLS AP norm/bypassed (Delay = 0 minutes)	2a
15133:18 (15133:55)	Safety Injection activation logic of the Engineered Safety Features Train A and B reset on increasing Reactor Coolant System pressure. The output is 1603 psig.	AM at PLS, ST at PLS and PLS AP norm/trip (Delay = 0 minutes)	2a
15138:42 (15139:19)	The operator stopped Reactor Coolant Makeup Pump IC (RM-F-1C).	AM at PLS, MM(A) and ST at PLS AP norm/trip (Delay = 0 minutes)	2a, 3a
15139:27 (15140:04)	The operator removed the Bypass signal from the Safety Injection portion of Engineered Safety Features Train A and B.	AM at PLS, ST at PLS and PLS AP norm/bypassed (Delay = 0 minutes)	2a, 3c
15145:14 (15149:33)	The operator started Reactor Coolant Makeup Pump IC (RM-F-1C).	AM at PLS, MM(A) and ST at PLS AP norm/trip (Delay = 0 minutes)	2a, 3c
15149:39 (15150:36)	The operator started Reactor Coolant Pump 1A (RC-F-1A); Reactor Coolant pressure decreased from 2150 psig to 1300 psig, Loop A cold leg temperature decreased from 343F to 260F and Loop A hot leg temperature remained offscale low (i.e. less than 320F) (Figure 14 and 14).	BC-F-1A; ST, MM(A), MM(F) and BC(A) at PLS AM (trip) at PLS AP norm/trip at PLS (Delay = 0 minutes) BC IC; MP at PLS BC P; MM and BC at PLS	1, 2a, 3a, 4a, 5a, 6a, 7a, 9, 10a
15150:08 (15150:43)	Reactor Coolant System Loop B hot leg temperature decreased from offscale high (greater than 420F) to offscale low (less than 320F) (Figure 19).	AM (high = 412F) at PLS, SC at PLS and MP at PLS	1
15150:13 (15150:50)	The operator began to bypass the Safety Injection portion of Engineered Safety Features Train A and B because Reactor Coolant System	AM at PLS, ST at PLS and PLS AP norm/bypassed (Delay = 0 minutes)	2a

Time	Event	Information Available to the Operator	Reference
16:59:23 (2100:00)	The operator increased the nitrogen cover gas pressure on Core Flood Tanks 1A and 1B (CG-F-1A and 1B) to 600 psig.	MM(P) at PLS	4b, 4c
17:26:23 (2122:00)	The operator opened Decay Heat Valve (DH-V-107) in preparation for placing the Decay Heat System in service. It was later decided not to use this mode of Reactor Coolant System cooling.	Unit 2 control room authorized the valve to be opened.	4b
17:29:23 (2130:00)	The operator started transferring the contents of the Auxiliary Building Neutralizer Tank (AN-V-08) pre-accident water, to Unit 1. This was done to allow water in the Auxiliary Building Sump to be transferred to this tank.	Local indication at the Rad Waste Pool	4b, 4c, 4d, 5a
18:14:23 (2233:00)	Reactor Coolant Leddown flow was lost. It is suspected this was due to plugging of either the leddown cooler, orifices or purification filters.	MM(P) at PLS	4b, 4c
<b>PLANT STATUS</b>			
20:00:00 (0000:37)	Reactor Coolant Pump 1A (RC-P-1) was operating. Reactor coolant flow in the core had been re-established. The steam present in Loop A and B had been condensed; however, a non-condensable gas space still existed in the reactor vessel head. The existence of the gas space was not known by the operators. Reactor coolant temperature and pressure were stable at approximately 240F and 1103 psig with the pressurizer level at 369 inches. Decay heat was being removed by steaming Steam Generator A to the Main Condenser. Steam Generator B was isolated and was believed to have a reactor coolant side to feedwater side leak. Reactor Coolant Makeup Pump 1B (RM-P-1B) was operating supplying		

**Figure 1**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Summary of Reactor Coolant System Parameters**



**Figure 3**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Reactor Coolant System Pressure, Saturation Pressure and Pressurizer Level**



**Figure 5**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Reactor Coolant System Pressure and Saturation Pressure**




FIGURE 7




FIGURE 9





FIGURE 11





**Figure 13**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Reactor Coolant System Pressure**




FIGURE 15




FIGURE 18




FIGURE 20




FIGURE 22




Figure 2A  
 M. 2 Loss of Coolant Accident 3/28/79  
 Loop A Cold and Hot Leg Temperatures






FIGURE 27




**Figure 28**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**RCS Loop 8 Cold and Hot Leg Temperatures**





**Figure 30**

**TMI-2 Loss of Coolant Accident 3/28/79  
Reactor Coolant System Exit Fuel Assembly Temperature at Approximately  
04:59:23 (0900:00)**



Note: These values do not include connections for the reference junction which was reading approximately 75F.

FIGURE 32




FIGURE 34





FIGURE 36



**Figure 38**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Turbine Header Pressure Loop A and Loop B**




FIGURE 40




FIGURE 42




FIGURE 44






FIGURE 46




FIGURE 48





FIGURE 50



**Figure 52**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Rx Building Temperature Recorder**  
**AH-YMTR-5017, Panel 25**








FIGURE 54




**Figure 56**  
**TMI-2 Loss of Coolant Accident of 3/28/79**  
**Intermediate and Source Range Nuclear Instrumentation**



**Figure 58**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Computer Alarm Printer Lag Time**



**Figure 80**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Pump Operating History**



**Note 1:** No computer printout is available which indicates when condensate pump 18 was secured or when leakage transfer pumps 9A and 9B were started.

Δ Ran for short period (less than 5 minutes)


∇ Stop/start in less than 1 minute

— Start      Run      Stop




**TMI-2 Loss of Coolant Accident 3/28/79**  
**Electromatic Relief Block Valve (RC-V2) Position**

**Figure 83**



**Figure 84**



A SUMMARY OF  
CORRECTIVE ACTIONS

The NRC made a very intensive study of procedural activities carried out prior to and for a short time following the March 28, 1979 accident and published its findings in NUREG-0600, also known as "Office of Inspection and Enforcement Investigation Report Number 50-320/79-10." This report led to the identification of a number of items of concern as set forth in the NRC letter of October 25, 1979. Succeeding correspondence, which addressed corrective actions, included:

- \*Met Ed letter of December 5, 1979
- \*NRC letter of January 23, 1980
- \*Met Ed letter of May 19, 1980
- \*NRC letter of November 21, 1980
- \*Met Ed letter of December 15, 1980
- \*Met Ed letter of January 9, 1981

This series of letters set forth:

- \*NRC concerns
- \*Licensee's proposed corrective actions, addressing NRC's concerns
- \*NRC's response to the proposed corrective actions, indicating acceptability of the latter to the NRC.

An additional corrective action is in the form of a new TMI-2 Emergency Plan, transmitted to the NRC on December 31, 1981 via TLL 700.

We believe that these referenced documents provide the required information on "Corrective Actions." Those corrective actions (long and short term) which uniquely deal with an operating reactor will be addressed at an appropriate time should the decision be made to propose the restart of TMI-2.