

JUN 15 1983



GPU Nuclear Corporation
Post Office Box 480
Route 441 South
Middletown, Pennsylvania 17057
717 944-7621
TELEX 84-2386
Writer's Direct Dial Number:

May 19, 1983
4410-83-L-0082

81-022


Office of Inspection and Enforcement
Attn: Mr. J. M. Allan
Acting Regional Administrator
Region I
US Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
Updated Licensee Event Reports

The Licensee Event Reports listed in Attachment 1 have been updated and are enclosed as Attachment 2 to this letter.

If you have any questions, please contact Mr. J. J. Byrne of my staff.

Sincerely,

B. K. Kanga
Director, TMI-2

BKK/RDW/jep

Attachments

CC: Mr. L. H. Barrett, Deputy Program Director - TMI Program Office
Dr. B. J. Snyder, Program Director - TMI Program Office

8305310001 830519
PDR ADOCK 05000320
S PDR

IE22

LIST OF UPDATED LICENSEE EVENT REPORTS

<u>LER NO.</u>	<u>LER NO.</u>
80-01	81-12
80-05	81-20
80-07	81-22
80-12	81-23
80-49	81-32
80-54	81-34
80-55	81-35
80-56	81-36
80-57	81-38
81-04 *	82-34
81-08	
81-10	

* Event date on original Licensee Event Report was incorrect. This revision corrects the event date.

LICENSEE EVENT REPORT
NARRATIVE REPORT
TMI-II
LER 81-022/03X-1
EVENT DATE - September 9, 1981

I. EXPLANATION OF OCCURRENCE

A surveillance procedure, Gas Partitioner Channel Calibration, was scheduled for performance September 2, 1981 with late date of September 4, 1981. During the time interval of September 2, 1981 to September 4, 1981, the Chemistry Technicians, who are shared with Unit 1, were heavily involved with the Unit 1 Hot Functional Testing and Accident Analysis Training. The surveillance which was located in Unit 2 Chem. Lab., was not performed. When the Chemistry Foreman checked on the surveillance September 8, 1981, he found it not completed and immediately assigned a technician to perform the surveillance.

II. CAUSE OF THE OCCURRENCE

Heavy technician workload combined with a lack of familiarity with surveillance schedules and laboratory operations by the new Chemistry Foreman.

III. CIRCUMSTANCES SURROUNDING THE OCCURRENCE

At the time of the occurrence, the Unit 2 facility was in a long-term cold shutdown state. The reactor decay heat was being removed via loss to ambient. Throughout the event there was no effect on the Reactor Coolant System or the core.

IV. CORRECTIVE ACTIONS TAKEN OR TO BE TAKEN

IMMEDIATE

Completed the surveillance satisfactorily September 8, 1981.

The Chemistry foreman was counseled by the Chemistry Supervisor on the importance of surveillance performance and on improved methods for getting work done on time utilizing his existing resources.

LONG TERM

Unit II presently employs its own Chemistry Technicians. This is designed to prevent further occurrences of the above event when technicians were shared between Unit I and Unit II.

V. COMPONENT FAILURE DATA

N/A

LICENSEE EVENT REPORT

Attachment 1

CONTROL BLOCK: 118219151

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

7 8 9 14 15 25 26 30 57 58 59

CON'T 7 8 9 14 15 25 26 30 57 58 59

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | A surveillance procedure for channel calibration of gas partitioner was performed
0 3 | past the scheduled expiration date for the calibration. There was no effect on the
0 4 | health and safety of the public. Since the calibration was performed within the
0 5 | action period there were no safety implications.

7 8 9 10 11 12 13 18 19 20 21 22 23 24 26 27 28 29 30 31 32 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | The calibration was performed late due to heavy manpower loads in conducting Unit I
1 1 | Hot Functional Tests and due to a new Chemistry Foreman not being familiar with plant
1 2 | procedures. The instrument was calibrated, and the foreman was counseled. Unit 2 pre-
1 3 | sently employs its own chemistry technicians, in order to prevent further occurrences
1 4 | of the above event when technicians were shared between Units I and II.

7 8 9 10 12 13 14 44 45 46 47

7 8 9 10 11 12 13 44 45 46 47

7 8 9 11 12 13 44 45 46 47

7 8 9 11 12 13 44 45 46 47

7 8 9 11 12 13 44 45 46 47

7 8 9 10 11 12 13 44 45 46 47

NAME OF PREPARER: R. B. Swartzwelder

PHONE: (717) 948-8693