#### TMI Unit-2 Technical Information & Examination Program




# TMI Offers Unique Opportunity

Researchers are taking advantage of the unique opportunities offered by the TMI Unit-2 accident that occurred on March 28, 1979. Damage to the reactor core and the release of fission products within the system give researchers the opportunity to:

- measure the performance of instrumentation, electrical, and mechanical equipment within the reactor containment building during and after the accident,
- determine physical damage to surfaces, components, and equipment resulting from radiation exposure,
- assess core damage for metallurgical and physical behavior of fuel, clad, and core components during and after the accident, and
- assess new technological developments for decontamination and the disposal of radioactive waste.

These activities will add to current knowledge on light-water-reactor behavior following accidents involving core damage. The results could lead to improvements in plant safety, reliability, regulation, and operation. Also, the information will benefit those engaged in the design, construction, operation, and maintenance of nuclear power plants.



Three Mile Island—Location of the nation's most severe commercial nuclear power plant accident.

#### TM Unit-2 Technical Information and Examination Program Update

This first publication of the TI & EP Update introduces the TMI-2 Technical Information and Examination Program.

The *Update* is specifically designed to highlight data and information obtained as a part of the TMI-2 Information and Examination Program. Since this is the initial *Update*, our intent is to provide an introduction of the program. The *Update* will be issued as sufficient data or information is obtained to justify publication. Only summaries will be provided in the *Update*; however, more detailed information will be available in a data bank which is currently under development. In a later *Update*, a procedure for obtaining this information will be outlined. We hope these mechanisms satisfy requirements of all interested individuals and organizations for data and information from this program.

Interested individuals and organizations can obtain a complimentary subscription by filling out the form on the inside pages and mailing it to TI & EP Update, EG&G Idaho, Inc., P.O. Box 88, Middletown, PA 17057.

# Participants Form Information and Examination Program; Seek Generic Data from Unit-2 Accident


Four groups, with a common interest in obtaining valuable generic information from the TMI Unit-2 accident, jointly established the TMI Unit-2 Information and Examination

Program. The Department of Energy (DOE), the Nuclear Regulatory Commission (NRC), the Electric Power Energy Research Institute (EPRI), and the General Public Utilities Company

(GPU) signed a coordination agrement on March 26, 1980, whice documents these common interests.

EG&G Idaho, Inc., has staffed the Technical Integration Office (TIO which reports to Dr. Willis W. Bixby the DOE Manager of the TMI Sin Office. The TIO is responsible for the day-to-day management of the Information and Examination Program.

The TIO staff and their respective areas of responsibility are as follows Harold M. Burton, EG&G Program Manager; Gregory R. Eidam, Radis tion and Decontamination Technica Coordinator; Robert E. Holzworth Mechanical Systems and Rad Wast Technical Coordinator; James W Mock, Instrumentation and Electrica Systems Technical Coordinator Dennis E. Owen, Fuels Technica Coordinator; Frank J. Kocsis, Con figuration and Document Contro Technical Coordinator; Joseph R Kerscher, Planning, Scheduling, and Budgets Coordinator; Donna L Morris, Material and Contracts Coor dinator; and Marilyn R. Rehbogen Secretary.



Model of TMI Unit-2 containment building shows penetration location.

# Camera, Radiation Probe Explore Containment

Since the accident, the TMI Unit-2 containment building has been dark and inaccessible except through the eye of a small video camera.

On November 10, 1979, a nine-inch diameter hole was drilled through an inner flange of an existing spare penetration (see the photograph above), and a video camera, an associated strobe light, and a radiation probe were inserted into the containment through the opening. During that day, more than two hours of video taping was done. The camera, equipped with a zoom lens and capable of scanning 360 degrees, relayed good quality video tape information, but was

limited in range and did not permit inspection of the water surface.

Radiation readings from the installed probe were taken on November 11, 1979. Gamma radiation levels were in the 3 to 5 rem per hour range, and beta radiation levels were in the range of 400 rems per hour.

At present, Metropolitan Edison Company is documenting the results and conclusions from the review of the tapes. Initial reviews do not show any structural damage. Final evaluation is forthcoming and preparations are being made for initial entry into the containment.




Published by the Technical Integration Office, Configuration Document Control Section, EG&G Idaho, Inc. under Contract DE-ACO7-7IDO1570 to the U.S. Department of Energy, P.O. Box 88, Middletown, PA 17057. Phone (717) 948-8486— FTS 590-3933.

F13 370-3733.
Coordinator F. J. Kocsis
Editor D. M. Grigg
Design L. E. Rockhold
Secretary M. R. Rehbogen
Manager H. M. Burton
Manager W. W. Bixby
DOE-TMI Site Office

# **B&W Samples Reactor Building**

Reactor coolant has been sampled regularly since the TMI Unit-2 accident and then analyzed by Babcock & Wilcox for specific radioisotope activity. Data collected from the samples will be used in the fission product transportation and deposition task, part of the Technical Information and Examination Program. The graph below shows some sample results.


Babcock & Wilcox analyzed other samples in the reactor building such as the sump on October 20, 1979 (see the table to the right), and the air on February 13, 1980. The sample from



TMI-2 reactor coolant samples reveal radioisotope concentrations.

the reactor building air documented specific radioisotope concentrations (e.g.,  $^{85}$ Kr activity of 1  $\mu$ Ci/ml,  $^{134}$ Cs activity of < 7 x 10<sup>-6</sup> $\mu$ Ci/ml,  $^{137}$ Cs activity of <3.2 x 10<sup>-5</sup> $\mu$ Ci/ml).

The owner of TMI Unit-2, the General Public Utilities Company, measured the radiation in the reactor building on December 14, 1979, as one of the many preparatory steps for entry into the reactor, and to provide basic planning information for subsequent decontamination efforts. The measurements were performed through a shaft called Penetration R-626, using various instruments (see the chart below). The calculated dose rate to the skin, based on the observed beta dose in the building, lies within a range of 100 to 350 rad/br.



Different instruments show dose rates inside the TMI-2 reactor building.

#### Reactor Building Sump Sample Analysis Results

Analysis		Result
Unsiitered:		
137 <sub>Cs</sub>	(µCi/g solution)	136
134 <sub>Cs</sub>	(t/Ci/g solution)	27
Fätrate:		
Na (ppm)		1250 ± 100
C1 (ppm)		10 ± 2
B (ppm)		$1690 \pm 40$
рH		$8.6 \pm 0.2$
90 <sub>Sr</sub>	(µCi/g solution)	4.8 ± 1.2
137 <sub>Cs</sub>	(uCi/g solution)	135
134 <sub>Cs</sub>	(uCi/g solution)	26
3 <b>H</b>	(µCi/g solution)	0.92
Gross Alpha	(ECi/g solution)	<1 X 10 <sup>-6</sup>
Gross Beta	(µCi/g solution)	149
Sr-89	(µCi/g solution)	37 ± 4
Filterable Solid (µCi/g solution):		
137 <sub>Cs</sub>		0.2
134 <sub>Cs</sub>		0.03
103 <sub>Ru</sub>		3.0 X 10 <sup>-3</sup>
140 <sub>La</sub>		8.0 X 10 <sup>-3</sup>
144 <sub>Ca</sub>		3.0 X 10 <sup>-3</sup>
95 <sub>Zr</sub>		1.0 X 10 <sup>-3</sup>
95 <sub>Nb</sub>	*	4.0 X 10 <sup>-3</sup>
54 <sub>Mn</sub>		7.0 X 10 <sup>-5</sup>

# Send for your free subscription:

Fill out the address label and mail to:

TI & EP Update EG&G Idaho, Inc. P.O. Box 88 Middletown, PA 17057

Name		
Company	· · · · · · · · · · · · · · · · · · ·	
P.O. Box	Street No.	

### Oak Ridge Analyzes "Cookie" from Containment Building

Isotope


60<sub>Co</sub>

A disc (cookie) was cut from a shaft called Penetration R-626 in the TMI Unit-2 reactor containment building. Oak Ridge National Laboratory analyzed the 9-in. Type-304 "cookie" made of stainless steel.

The test results indicated that significant amounts of surface contamination may remain following the decontamination process; however, the decontamination method described below reduced the background radiation levels due to surface contamination to about 1 to 2 mr/hr betagamma.

When Oak Ridge received the disc, the initial radiation readings were 80 mr/hr beta-gamma and 6 mr/hr gamma at 2 in. from the disc surface. See the table at the right for the analysis results.

The disc was cut into sections (refer to the photograph) for decontamination tests. The standard Bechtel Corporation Specification CP-952 decontamination series removed approximately 98% of the contamination from piece 3c. Wiping with dry cheesecloth removed approximately 38% of the activity from piece 3a. while wiping with wet cheesecloth removed 17% of the activity from piece 3b. The apparent inconsistency between the wet- and dry-cheesecloth methods may be due to nonuniform contamination levels on the disc surface.



Penetration R-626 Surface

Contamination Results

**Total Activity** 

on Disc

(in µCi)

0.019

Average Contamination

Level on Disc

(in µCi/cm<sup>2</sup>)

6.09 X 10-5

Penetration R-626 "cookie" is sectioned for decontamination tests.



EG&G Idaho, Inc. • P.O. Box 88 Middletown, PA 17057