

THIRD INTERIM REPORT ON THE  
THREE MILE ISLAND NUCLEAR STATION  
UNIT 2 (TMI-2) ACCIDENT  
JULY 16, 1979

7907280633

METROPOLITAN EDISON COMPANY

542 001

CONTENTS

- I. SEQUENCE OF EVENTS
- II. RECOVERY ORGANIZATION
- III. PLANT MODIFICATIONS
- IV. RADIOLOGICAL MONITORING

542 002



I. Sequence of Events

Included in this section is an expanded version of that contained in the May 15, 1979 report. This version has been formulated using information that was compiled subsequent to May 15 and was not available prior to this date. Since compilation and analysis is continuing, new information gathered subsequent to that contained in this report will be included in a future submittal.

542 005

APPENDIX  
ANNUATED SEQUENCE OF EVENTS  
MARCH 28, 1979

A

This report provides additional detail to the May 10, 1979 Revision 0 Issues of the Preliminary Annotated Sequence of Events of the March 28, 1979 accident at Three Mile Island Unit 2 and is a result of a detailed analysis of reactor data, plant computer data, plant recorder charts, plant logs and operator interviews. Revision 1 of the report includes additional detail on the chronology, the reference source of each entry in the chronology, and the information available to the operator regarding each event in the sequence. The "Information Available to the Operator" entries address the type of information available, the form in which the information was presented, and the timeliness of the presentation of the information to the operator relative to the time of occurrence of the event. Information for which inference or correlations were required prior to providing useful knowledge to the operator is not included in the sequence of events, only that information which provides direct indication of the event is included. The report should still be considered as preliminary since investigation and data analysis is ongoing and continues to provide new insights into the TMI-2 accident. As such, new information and/or understanding is developed this report will be updated.

Annotation included with the chronology of events. In addition to providing verbally assessments of the plant status, represent input called from interviews with the operating staff.

In cases where direct action was taken by the plant operating staff the term "the operator" is used in the sequence of events.

**POOR ORIGINAL**

542 004

ADDITIONAL SUMMARY OF EVENTS

LIST OF FIGURES

Figure No.	Title	Reference
1	Summary of Reactor Coolant System Parameters (0 to 120 seconds)	1, 3a
2	Summary of Steam Generator Parameters (0 to 120 seconds)	1
3	Reactor Coolant System Pressure, Saturation Pressure and Pressurizer Level (0 to 30 minutes)	1, 3a
4	Reactor Coolant System Pressure and Pressurizer Level (0 to 8 hours)	1, 3a
5	Reactor Coolant System Pressure and Saturation Pressure (0 to 20 hours)	1, 3a
6	Reactor Coolant System Loop A & B, Hot and Cold Leg Temperatures (0 to 10 minutes)	1
7	Reactor Coolant System Loop A & B, Hot and Cold Leg Temperatures (0 to 8 hours)	1
8	Steam Generator A & B, Level and Pressure (0 to 10 minutes)	1
9	Steam Generator A & B, Level and Pressure (0 to 8 hours)	1
10	Reactor Coolant System Pressure (0 to 120 seconds)	1
11	Reactor Coolant System Pressure (0 to 120 minutes)	1, 3a
12	Reactor Coolant System Pressure (0 to 20 hours)	1, 3a
13	Reactor Coolant System Loops A & B Flow (0 to 120 seconds)	1
14	Reactor Coolant System Loops A & B Flow (0 to 30 minutes)	1
15	Reactor Coolant System Loops A & B Flow (0 to 120 minutes)	1
16	Reactor Coolant System Loops A & B Flow (0 to 8 hours)	1
17	Reactor Coolant System Loops A & B Flow (0 to 20 hours)	1
18	Reactor Coolant System Loop A, Hot and Cold Leg Temperatures (0 to 120 seconds)	1
19	Reactor Coolant System Loop A, Hot and Cold Leg Temperatures (0 to 30 minutes)	1
20	Reactor Coolant System Loop A, Hot and Cold Leg Temperatures (0 to 120 minutes)	1
21	Reactor Coolant System Loop A, Hot and Cold Leg Temperatures (0 to 8 hours)	1
22	Reactor Coolant System Loop A, Hot and Cold Leg Temperatures (0 to 20 hours)	1

POOR ORIGINAL

542 005



ANNALS OF EQUIPMENT OF EVENTS  
 (CONTINUED)

Figure No.	Title	Reference
23	Reactor Coolant System Loop B, Hot and Cold Leg Temperatures (0 to 120 seconds)	-----
24	Reactor Coolant System Loop B, Hot and Cold Leg Temperatures (0 to 30 minutes)	-----
25	Reactor Coolant System Loop B, Hot and Cold Leg Temperatures (0 to 120 minutes)	-----
26	Reactor Coolant System Loop B, Hot and Cold Leg Temperatures (0 to 8 hours)	-----
27	Reactor Coolant System Loop B, Hot and Cold Leg Temperatures (0 to 20 hours)	-----
28	Reactor Coolant System Pressurizer Level (0 to 120 seconds)	-----
29	Reactor Coolant System Pressurizer Level (0 to 120 minutes)	-----
30	Reactor Coolant System Pressurizer Level (0 to 20 hours)	-----
31	Steam Generator A & B Steam Pressure (0 to 120 seconds)	-----
32	Steam Generator A & B Steam Pressure (0 to 120 minutes)	-----
33	Steam Generator A & B Steam Pressure (0 to 20 hours)	-----
34	Steam Generator A & B Start-Up Level (0 to 120 seconds)	-----
35	Steam Generator A & B Start-Up Level (0 to 120 minutes)	-----
36	Steam Generator A & B Start-Up Level (0 to 20 hours)	-----
37	Steam Generator A & B Operating Level (0 to 120 seconds)	-----
38	Steam Generator A & B Operating Level (0 to 120 minutes)	-----
39	Steam Generator A & B Operating Level (0 to 20 hours)	-----
40	Reactor Coolant Drain Tank Pressure (0 to 120 seconds)	-----
41	Reactor Coolant Drain Tank Pressure (0 to 10 minutes)	-----
42	Reactor Coolant Drain Tank Pressure (0 to 120 minutes)	-----

**POOL CONTROL**

442 000

ANNEXED SUBJECT OF THIS  
(CONTINUED)

Figure No.	Title	Reference
43	Reactor Coolant Drain Tank Pressure (0 to 8 hours)	F
44	Reactor Coolant Drain Tank Pressure (0 to 20 hours)	F
45	Reactor Boiling Temperature and Pressure	H
46	Intermediate Range and Source Range Monitors (0 to 4 hours)	H
47	Intermediate Range and Source Range Monitors (0 to 20 hours)	H
48	Computer Alarm Printer Log Time	Za
49	Emergency Feedwater Pumps Discharge Pressure (0 to 14 minutes)	Za
50	Pump Operating History	Za
51	Steam Generator A and B Level and Steam Pressure (60 to 120 minutes)	I
52	Reactor Coolant System Loop A, Hot and Cold Leg Temperatures (60 to 120 minutes)	I
53	Reactor Coolant System Loop B, Hot and Cold Leg Temperatures (60 to 120 minutes)	I
54	Control Room Layout	S
55	Reactor Coolant System Backup Tank Level (0 to 30 minutes)	I
56	Reactor Coolant System Backup Tank Level (0 to 8 hours)	I
57	Reactor Coolant System Backup Tank Level (0 to 20 hours)	I

**POOR ORIGINAL**

502 007

ASSOCIATED EQUIPMENT OF EVENTS

List of References

1. Reactor Data (1)
2. Plant Computer Data
  - a. Alarm Summary
  - b. Sequence of Events Review
  - c. Utility Transformer
  - d. DRI Station Log
  - e. Fuel Trip Review
3. Plant Strip Charts
  - a. Area Control Room (0P-00-1901)
  - b. Area Control Room (0P-00-1902)
  - c. Atmospheric Radiation Monitors (0P-00-2900)
  - d. Liquid Radiation Monitors (0P-00-3068)
  - e. Atmospheric Radiation Monitors (0P-00-3236)
  - f. Atmospheric Radiation Monitors (0P-00-1907)
  - g. Fuel Rod Building Air Flow (AI-00-5113 and AI-00-5206)
  - h. Fuel Rod Building Air Flow (AI-00-5109 and AI-00-5659)
  - i. Reactor Building Temperature and Pressure
  - j. Intermediate Range and Source Range Monitors
  - k. Reactor Coolant System Flow Rate
  - l. Reactor Coolant System Wide Range Pressure
  - m. Reactor Coolant System Loop A and B, Hot Leg Temperature (SC0043)
4. Plant Logs
5. Plant Drawings
6. Technical Specifications
7. PSAB
8. DRI Staff Interviews (1)
  - a. Ken Bryan by Det-Ed/GPU
  - b. Joe Bacon by Det-Ed/GPU
  - c. George Faust by Det-Ed/GPU
  - d. George Faust by T. Van Mitrebeck, et al.
  - e. John Flork by Det-Ed/GPU
  - f. G. Faust/Dr. Frederick by M. Marshall
  - g. Jim Floyd by Det-Ed/GPU
  - h. Ed Frederick by Det-Ed/GPU
  - i. Janice Klinglich by Det-Ed/GPU
  - j. Dale Undermiller by Det-Ed/GPU
  - k. B. DeGroot by M. Marshall
  - l. Brian Bohler by Det-Ed/GPU
  - m. Steve Ball by Det-Ed/GPU
  - n. Fred Schabason by Det-Ed/GPU
  - o. Bill Zeeb by Det-Ed/GPU
  - p. Bill Zeeb by CH2C Investigation Team
  - q. R. Bohler, G. Miller and J. Seelinger by Det-Ed/GPU
  - r. Sequence prepared by DRI Staff 1 and 2 Staff and Quinle BAW Personnel.
  - s. Ed Frederick by T. Van Mitrebeck, et al.
  - t. Bob DeGroot by Det-Ed/GPU
  - u. Don Miller by Det-Ed/GPU
9. T. Van Mitrebeck memorandum regarding DRI Unit 2 Operating Staff and DRI: Sequence of Events Review Meeting (1)

(1) This information is not available to the operator on March 28, 1979.

POOL ORIGINAL

542 003



ASSOCIATED EQUIPMENT OF EVENTS

LIST OF SYMBOLS

Indicates

- Electrical Status Light
- Motor
- Motor/Generator Receiver
- Alarm Indicator
- Control Room Panel
- Alarm Printer

Parameter

- T Temperature
- P Pressure
- L Level
- F Flow
- A Amperage
- V Vibration

Plant Identifiers

- RC Reactor Coolant
- FRM Freezer
- C Loop Cold Leg
- H Loop Hot Leg
- SG Steam Generator
- RS Riser Steam
- RB Reactor Building
- RCDF Reactor Coolant Drain Tank
- LB Letdown
- FF Emergency Feedwater Pump
- FSF Engineered Safety Features
- HPI High Pressure Injection
- LI Emergency Feedwater
- RI-1 Source Ringer Monitor
- RI-3 Intermediate Range Monitor
- RI-2 Reactor Coolant Pump
- RI-4 Reactor Pump
- RI-5 Feedwater Pump
- RI-6 Heavy Duty Pump

**POOR ORIGINAL**

This table in conjunction with Figure 54 "Control Room Layout", is provided as a guide to understanding the entries under the "Information Available to the Operator" column in the Associated Sequence of Events.

PRELIMINARY  
ASSOCIATED SHEPHERD 40 500425 THE 2 ACCIDENT OF MARCH 28, 1979

Information Available to the Operator Reference

For this chronology, an elapsed time clock was established with the time of the  
lockup (04:00:37, defined an elapsed time equal to zero. The elapsed time of  
each event in the sequence is given as the number of hours, minutes and seconds  
relative to 0600:37, followed in parentheses by the real time using a 24-hour  
clock. For example, 1:52:44 p.m. on March 28 would be written 9:52:06 (1352:44).  
Depending upon the accuracy of the source of data for each event, the times  
appear alone or with the notation "approximate."

PLANT STATUS

Prior to the accident Three Mile Island Unit Two was at 97% power with the  
Integrated Control System in full automatic. Rod Groups one through five were  
fully withdrawn, Rod Groups six and seven were 95% withdrawn and rod group  
eight was 2/2 withdrawn. Reactor Coolant System total flow was approximately  
130 million pounds per hour and the Reactor Coolant System pressure was 2155  
psig. Reactor Coolant Backup Pump B (RC-B) was in service supplying makeup  
and Reactor Coolant Pump seal injection flow. Normal Reactor Coolant System  
inflow was approximately 70 gallons per minute. The Reactor Coolant  
System boron concentration was approximately 1030 parts per million. The  
Pressurizer Spray Valve (RC-V1) and the Pressurizer Heaters were in manual  
control while spraying reactor coolant into the Pressurizer to equalize boron  
concentrations between the Pressurizer and the remainder of the Reactor  
Coolant System. The Pressurizer Safety Valves discharge header thermocouples  
indicated values between 190F to 210F due to leakage through one of the  
Pressurizer Safety Valves (RC-R1A or RC-R1B). An RC-R1B high temperature  
alarm had been received at -2:37 (0123) and was reset at -2:28 (0117).  
Temperatures recorded were 200F for the alarm and 192.4F for the alarm reset.

POOR ORIGINAL

542  
010

The following table lists Steam Generator parameters prior to the accident.

Table of Steam Generator Parameters<sup>1</sup>

	Steam Generator A	Steam Generator B
Design Pressure	5,745.9 MPaG	5,700 MPaG
Operating Level	5.2	57.52
Startup Level	178.8 inches	163.6 inches
Steam Pressure	910 psig	809.6 psig
Feedwater Temperature	662.7F	662.7F
Steam Temperature	595F	596F

<sup>1</sup> MPaG - Million Pounds Per Hour

<sup>2</sup> The differences between Steam Generator A and B parameters are typical of normal operation.

Steam Generator Feedwater Pumps (14-F-1A and 14-F-1B), Condensate Booster Pumps (10-F-2A and 10-F-2B) and Condensate Heats (10-F-1A and 10-F-1B) were in service. An attempt was being made to clear a clogged resin transfer line in the standby demineralizer of the Condensate Polishing System.

The Fuel Handling Building supply and exhaust fans were in service.

The Auxiliary Building exhaust fans were in service. The status of

the Auxiliary Building supply fans is not known.

572 011

**POOR ORIGINAL**



Time of event Information Available to the Operator Reference

00:00:01 (0500:16)	Condensate Pump A (C0-P-1A) tripped. The trip was a result of a breaker protection relay actuation. The cause of the relay actuation has not been determined.	Annunciator window (AN) at Panel 17 (PL17), meter (MR) indicating motor overage (A) and electrical status light (ST) at Panel 5 (PL5), alarm printer (AP) out-of-work/trip and on/off (delay time between alarm printer output and real time approximately 0 seconds)	2A, 2b
00:00:08 (0500:17)	Feedwater Pumps (FW-P-1A and FW-P-1B) tripped at essentially the same time resulting in loss of feedwater flow to both Steam Generators.	AB at PL15 and PL17, speed and throttle valve position at trip contact recorder (SC) at PL17, speed MR at PL4, pump discharge pressure (P DISCH) MR at PL5, AP alarm/trip (Delay ~ 0 seconds)	2A, 2b
00:00:09 (0500:17)	The Main Turbine and Main Generator tripped in accordance with plant design.	Turbine: AN at PL5 and PL17, various MR and ST at PL5, AP alarm/trip (Delay ~ 0 seconds) Generator: AN at PL16, various MR and ST at PL6A, AP alarm/trip (Delay ~ 0 seconds)	2A, 2b
00:00:09 (0500:17)	All three Emergency Feedwater Pumps (EF-P-1, EF-P-2A and EF-P-2B) started.	All EF-P's: ST and MR (P DISCH) at PL4 EF-P's 2A and 2B: MR(A) at PL4, AP on/off (Delay ~ 0 seconds)	2A, 2b
00:00:03 (0500:50) Approximate	The Electronic Relief Valve (ER-R2) opened at the setpoint of 2255 psig.	ST at PL4	1
00:00:08 (0500:55)	The reactor tripped on high Reactor Coolant System pressure at 2355 psig. The setpoint is 2355 psig.	AB (Red/Green/Blue/Yellow) Two out of Four Logic AT, PL 8, Red Function ST, and MR at PL14, Reversion Plus SC and MR at PL4, AP Two out of Four Logic (Delay ~ 0 seconds)	1, 2a, 2b

502 012

POOR ORIGINAL

00:00:08  
(0400:45)  
Approximate

The operator placed the Pressurizer Spray Valve (R0-V1) and Pressurizer Heaters under automatic control. Pressurizer Heater Groups 1 through 5 were de-energized as a result of this action. The de-energize setpoint is 2125 psig for Groups 1 through 3 and 2140 psig for Groups 4 and 5 under increasing pressure.

Spray Valve: ST at P14  
Heaters: ST at P14,  
AP norm/trip (Delay = 0 seconds)

Note: There are a total of 13 Pressurizer Heater Groups.

00:00:09  
(0400:46)

Steam Generator levels were approximately 120 inches (Figure 34). Steam pressure had increased to 1065 psig in Steam Generator B and 1071 psig in Steam Generator A (Figure 31). Assuming the Steam Generator Safety Valves opened at the specified setpoints, then all of the Steam Generator B Safety Valves and eight of the Steam Generator A Safety Valves opened.

SG 1: HR (Startup Range) at P14, HR (Wide Range) at P14  
SG 5: (Operate Range) at P14 and P15  
SG P: HR at P14, SG at P17

00:00:10  
(0400:47)  
Approximate

The operator verified that all control and safety rods were tripped and fully inserted into the core.

ST at P14 and P14,  
AP norm/trip and yea/no (Delay = 0 seconds)

00:00:12  
(0400:49)

The Reactor Coolant Pressurizer level reached a peak of approximately 275 inches (Figure 28).

SC at P14, HR (uncompensated) at P15

00:00:13  
(0400:50)  
Approximate

The operator attempted to start Reactor Coolant Makeup Pump A (R0-P-1A); however, he released the control switch before the required 2.5 seconds and the pump tripped. The operator opened High Pressure Injection Isolation Valve B (R0-V16B) and isolated Isolation Flow in anticipation of the expected Pressurizer level decrease which follows the initial increase in level after a loss of feedwater flow incident (Figure 28).

R0-P-1A: AM at P18, ST and HR(A) at P13,  
AP norm/trip (Delay = 0 seconds)  
R0-V16B: ST at P13, Injection flow BR at P18  
R0-V32a: ST at P13, Isolation flow BR at P13  
PZR 1: SC at P14, HR (uncompensated) at P15

542 013

POOR ORIGINAL

RR at PL5, AP low (22.5 inches)/norm/High (36 inches)  
(Delay = 0 seconds)

SI at PL4

Event

The Condenser Bottom Low level alarm was received. The level was identified to be 21.77 inches at this time.

00:00:13  
(04:00:50)

The Electromagnetic Relief Valve (RC-02) should have shut at about this time (closure setpoint of 2405 psig). The Electromagnetic Relief Valve position indication in the Control Room is a red lamp which illuminates when the Electromagnetic Relief Valve solenoid is energized. When the lamp is illuminated, i.e. solenoid energized, under normal circumstances the valve should be open. When the lamp is extinguished, i.e. solenoid de-energized, under normal circumstances the valve should be closed; however, it could be in any position as the lamp only indicates the solenoid is de-energized and not valve position. The solenoid on the Electromagnetic Relief Valve (RC-02) de-energized at approximately 00:00:13 (04:00:50) resulting in an implied "shut" indication in the Control Room. Although the plant operators did not know at the time subsequent events showed that the valve had failed to shut. The loss of reactor coolant through RC-02 was not stopped until the Electromagnetic Relief Block Valve (RC-02) was shut, approximately 2 hours and 19 minutes after the start of the transient.

00:00:14  
(05:00:50)  
Approximate

FLARE STATUS

The plant had just experienced a turbine/reactor trip. Reactor coolant system pressure and Pressurizer level were decreasing rapidly after reaching peaks of 2165 psig and 256 inches respectively. Unknown to the plant operators the Electromagnetic Relief Valve (RC-02) was not shut and was passing reactor coolant from the steam space at the top of the Pressurizer. Based on

POOR ORIGINAL



Time	Event
	control Room indications, the Reactor Coolant System pressure and Pressurizer level were trending together and decreasing as was expected after a reactor trip. The Steam Generator water levels were at about 125 inches and decreasing at about 4 inches per second. The Steam Generator atom pressure were about 1100 psig and decreasing at 32 psig per second. The Turbine Bypass Valves and a number of Main Steam Relief Valves were open and relieving steam. All Emergency Feedwater Pump had started but had not yet reached normal discharge pressure. The Steam Generator water levels had not yet reached the Integrated Control System setpoint of 30 inches for the programmed opening of the Emergency Feedwater Valves (EF-VIIA and EF-VIIB) which would admit feedwater to the Steam Generator. In addition, the Emergency Feedwater Block Valves (EF-VI2A and EF-VI2B) were shut which also prevented feedwater flow until they were opened eight minutes after the start of the transient. The reason for the block valves being shut is not known. The most likely explanation is that the valves were inadvertently left closed after performance of surveillance testing of the Emergency Feedwater System on the morning of March 26, 1979.
00:00:14 (0400:51)	The Emergency Feedwater Pumps (EF-P-1, EF-P-2A and EF-P-2B) discharge pressure normal alarms were received indicating the pumps had achieved normal discharge pressure (Figure 49).
00:00:14 (0400:51)	Pressurizer Heater Groups 1 through 5 automatically energized as a result of reactor coolant pressure decreasing below the energize setpoint of 2105 psig for groups 1 through 3 and 2120 psig for groups 4 and 5.

24

HR (P\_HISCH) at P1.4,

AP low (setpoint = 875 psig)/norm (delay = 15 seconds)

25

ST at P1.4, AP norm/trip (delay = 15 seconds)

**POOR ORIGINAL**

512 015

Information Available to the Operator

Event

Reference

00:00:14  
(0500:51)  
Approximate  
Steam generator levels were approximately 99 inches (Figure 14).  
Steam pressure was 1018 psig in Steam Generator B and 1012 psig  
in Steam Generator A (Figure 11).

SG 1: RR (Startup Range) at P14, 0% (Wide Range) at P14, 1  
SG (Operating Range) at P14 and P15  
SG 2: RR at P14, SC at P17

00:00:15  
(0500:52)  
Approximate  
"Water hammer" was noted in the Condensate Pump discharge piping  
by an auxiliary operator. The piping was displaced several feet  
according to the auxiliary operator.

Ro

00:00:20  
(0500:55)  
Approximate  
The operator announced on the Plant Page System that 300 Unit 2  
turbine and reactor had tripped.

R

00:00:20  
(0500:57)  
Approximate  
The Steam Generator Safety Valves tripped and the Turbine Bypass  
Valves (RS-V-25A, RS-V-25B, RS-V-26A and RS-V-26B) modulated steam  
flow to the Main Condenser to control steam generator pressure at  
1010 ± 10 psig (Figure 11). Subsequently the operator reduced the  
control setpoint pressure to cool down the Reactor Coolant System  
(Figure 11).

Turbine Bypass Valves: RR and ST at P15  
SG 2: RR at P14, SC at P17

# POOL ORIGINAL

00:00:28  
(0501:05)  
Approximate  
Steam generator A level reached the Integrated Control System  
setpoint of 30 inches at which the Emergency Feedwater Valve  
(EF-V11A) opens (Figure 16). Feedwater was not admitted to Steam  
Generator A because Emergency Feedwater Block Valve (EF-V12A) was  
shut. EF-V12A and EF-V12B are normally open.

SG 1: AN (24 Inches) at P17, RR (Startup Range) at P14, 1, R  
AP Low (24 Inches)/norm (Delay 2 10 seconds)  
EF-V11A and EF-V11B: RW at P14  
EF-V12A and EF-V12B: ST at P14

00:00:28  
(0501:05)  
Condensate (hotwell) level returned to normal at 26.44 inches.

RR at P15,  
AP Low (27.5 Inches)/norm/high (16 Inches)  
(Delay 2 10 seconds)

To

542 010

Information Available to the Operator Reference

SC at FI.10, AP High (2000)/norm (Delay = 10 seconds) 2a

**POOR ORIGINAL**

Time	Event	Reference
00:00:40 (05:01:07)	Pressurizer Safety Valve (RC-R1B) and Electromechanical Relief Valve (RC-R2) discharge line temperature alarms were received and values of 203.5F and 219.2F, respectively printed out. The high temperatures in the discharge lines were a result of the high temperature steam flow through the Electromechanical Relief Valve (RC-R2) during the reactor pressure transient. The Pressurizer Safety Valve (RC-R1B) did not open; the RC-R1B temperature alarm received was due to the back flow of steam in the common discharge header shared with the Electromechanical Relief Valve (RC-R2). These alarms were reported by the operator.	
00:00:42 (05:01:09) Approximate	Steam Generator B level reached the Integrated Control System setpoint of 80 inches at which the Emergency Feedwater Valve (EF-V11B) opens (Figure 36). Feedwater was not admitted to Steam Generator B because Emergency Feedwater Block Valve (EF-V12B) was shut. As noted above EF-V12A and EF-V12B should have been open.	SG 1: AH (24 inches) at FI.17, HR (Startup Range) at FI.4 1, 1b AP Low (24 inches)/normal (Delay = 10 seconds) EF-V11A and EF-V11B: HR at FI.4 EF-V12A and EF-V12B: ST at FI.4
00:00:54 (05:01:18)	The operator started Reactor Coolant Backup Pump A (RH-P-1A). With Reactor Coolant Backup Pumps A and B (RH-P-1A and RH-P-1B) operating, the Pressurizer level rate of decrease slowed (Figure 28).	RH-P-1A: AH at FI.0, ST and HR(A) at FI.3, 1, 2a AP norm/strip (Delay = 45 seconds)
00:01:00 (05:01:17) Approximate	Pressurizer level started increasing (Figure 28). Reactor Coolant System hot leg and cold leg temperatures reached approximately 52F (Figure 6). The Reactor Coolant Drain Tank pressure was 12 psig and increasing (Figure 41).	PRK 1: SC at FI.4, HR (uncompensated) at FI.5 RC T <sub>1</sub> : SC at FI.10 RC T <sub>2</sub> : SC at FI.4 and FI.10, HR at FI.4 RCBT P: HR at FI.0A



Information Available to the Operator Reference

at 1110.  
AP High (2000)/normal (delay = 50 seconds.)

Time	Event
00201200 (0020137)	The Pressurizer Safety Valve (BC-R1A) high discharge line temperature alarm was received. This alarm was expected and resulted from back flow in the common discharge header shared with the Electromechanical Relief Valve (BC-R2).

PLANT STATUS

The Reactor Coolant System was recovering from the initial loss of feedwater flow transient. The Reactor Coolant System pressure was decreasing and the Reactor Coolant Pressurizer level had begun to increase (Figures 1 and 3). The divergence of Reactor Coolant System pressure and Pressurizer level was not expected on Reactor Coolant System pressure and Pressurizer level should normally trend together during a loss of feedwater flow transient. The deviation from expected behavior was due to: (1) the failure of the Electromechanical Relief Valve (BC-R2) to recseat, which resulted in a lower Reactor Coolant System pressure, and (2) the reduction in the heat removing capability of the Steam Generator because of their low levels. Both of these conditions contributed to the expansion of the reactor coolant volume which forced reactor coolant from the Reactor Coolant System loops and Reactor Vessel into the Pressurizer via the surge line, thereby increasing the level of reactor coolant in the Pressurizer. Steam Generator A and B levels were 11 inches and 14 inches, respectively (Figure 34); however, Primary Feedwater was not admitted to the Steam Generators because the Primary Feedwater Block Valves (PF-V12A and PF-V12B) were shut. The Steam Generator pressures were being maintained by the Integrated Control System between 975 psig and 1020 psig (Figure 31). The Reactor Coolant Drain Tank pressure and temperature were increasing showing the effects of the continued discharge of reactor coolant through the Electromechanical Relief Valve (BC-R2).

POOR ORIGINAL

5A2 010

Reactor Coolant Backup Pumps (RU-F-1A and RU-F-1B) were in operation delivering water to the Reactor Coolant System at a rate in excess of 700 gallons per minute via the High Pressure Injection Valves (RU-V16A and RU-V16B) and the normal Backup Valves (RU-V17 and RU-V18). The pumps were taking suction from the Rotated Water Storage Tank.

00:01:11 (0501:50) The Condenser Baffle High level alarm was received. The level was 42.77 inches.

HR at PLS, 2a  
AP Low (22.5 inches)/notm/high (16 inches)  
(Delay = 1 minute)

00:01:26 (0502:01) A Reactor Coolant Drain Tank temperature normal alarm was received and printed out a temperature of 85.3F. This indicated the Reactor Coolant Drain Tank temperature was increasing and had reached the normal range.

HR at PLSA, 2a  
AP High (120F)/notm/low (75F) (Delay = 1 minute)

00:01:45 (0502:22) Steam Generators A and B have boiled dry at this time. This was indicated by a steadily decreasing Steam Generator pressure (Figure 8) while Reactor Coolant System hot leg and cold leg temperatures were increasing (Figures 19 and 24).

SC FI HR at PLS and SG at PLS 1  
RC TI SC at PLS and PLSB, HR at PLS

00:02:00 (0502:37) The shift supervisor noted all Condensate Pumps, Condensate Booster Pumps and Steam Generator Feedwater Pumps were stopped.

POOR ORIGINAL  
No. 9

00:02:02 (0502:39) Engineered Safety Features actuation of High Pressure Injection occurred as Reactor Coolant System pressure reached 1640 psig.

ESP HP-11 AH at PLS, SI at PLS and PLS 2a, 2b, 1  
AP notm/actuation (Delay = 2 minutes)

542 019

Time: \_\_\_\_\_ Event: \_\_\_\_\_ Information Available to the Operator: \_\_\_\_\_ Reference: \_\_\_\_\_

Reactor Coolant Backup Pump B (RB-P-1B) tripped automatically as a result of the activation of High Pressure Injection. The Engineered Safety Features design is such that Backup Pumps A and C are used for High Pressure Injection and if Backup Pump B is tripping, it is tripped prior to activation of Backup Pumps A and C.  
Reactor Coolant Backup Pump (RB-P-1A and RB-P-1B), Decay Heat Removal Cooling Water Pumps (RW-P-B and RW-P-1B) and the Emergency Pumps (DE-K-1A and DE-K-1B) also started automatically on Engineered Safety Features activation of High Pressure Injection.

RB-P-1B: AN at P1B, ST and HR(A) at P13  
AP norm/trip (Delay = 2 minutes)  
RB-P-1A, 1B: ST at P13 and P11, HR(A) at P13, HR(P152H) at P1B.  
AP norm/low and on/off (Delay = 2 minutes)

00:02:05 (0402:41) Reactor Coolant Backup Pump C (RB-P-1C) started automatically.

RB-P-1C: AN at P1B, ST and HR(A) at P13  
AP norm/trip (Delay = 2 minutes)

00:03:12 (0403:49) Approximate The Reactor Coolant Drain Tank Relief Valve (MDI-RI) lifted at 120 psig, temporarily halting the Reactor Coolant Drain Tank pressure increase (Figure 41). The pressure increase was caused by the flow of reactor coolant from the Electrostatic Relief Valve (ER-82). The MDI Relief Valve (MDI-RI) discharges to the Reactor Building Sump.

MDI P: DR at P1BA

00:03:14 (0403:51) The operator manually bypassed the High Pressure Injection portion of Engineered Safety Features to gain manual control of the Backup Pumps and the High Pressure Injection Valves. Both Reactor Coolant Backup Pumps A and C (RB-P-1A and RB-P-1C) were operating.

EXP (HPI): AP norm/bypass (Delay = 3 minutes)

00:03:26 (0403:53) The Reactor Coolant Drain Tank high temperature alarm was received at 127.2F.

RCDT T: PH at P1BA, AP high (120F)/min/low (15F) (Delay = 3 minutes)

**POOR ORIGINAL**



Information Available to the Operator

Reference

- 00-0-10: AB at F18, ST and DR(A) at F13, 1,2,3
- AP out-of-trip (Delay = 4 minutes)
- F2R 1: AB (01/01 - 315 inches, HI - 260 inches) at F18, 5C at F16, BR (uncompensated) at F15, AP low (200 inches)/alarm/high (260 inches) (Delay = 4 minutes)

HPI F1: BR at F18

**Event**

The operator stopped Reactor Coolant Makeup Pump C (RM-P-1C). The Indicated Pressurizer Level was 160 inches and increasing rapidly (Figure 29).

**Diagnosis**

In an attempt to gain control of the rapidly increasing pressurizer level the operator throttled the High Pressure Injection Isolation Valves (HI-V16A and HI-V16B).

**DIAGNOSTICS**

The Reactor Coolant System pressure was 1420 psig and steadily decreasing to the saturation pressure of the Reactor Coolant System hot leg temperature (Figure 3). The continued Reactor Coolant System depressurization was due to the failure of the Electromagnetic Relief Valve (ER-R2) to reclose and reduction in High Pressure Injection flow rate. Engineered Safety Features, which actuated High Pressure Injection when pressure reached 1640 psig, had been bypassed by the operator to permit manual control of the Makeup Pumps and the High Pressure Injection Isolation Valves. As the Pressurizer level continued to increase, the operator stopped Reactor Coolant Makeup Pump C (RM-P-1C) and throttled the High Pressure Injection Isolation Valves (HI-16A and HI-16B) in an attempt to control the Pressurizer level and not take the Pressurizer "solid" (Figures 3 and 29). The Reactor Coolant Drain Tank Relief Valve (RD-R1) had opened at 120 psig and was discharging to the Reactor Building Sump (Figure 41). A Reactor Coolant Drain Tank

**ROOM ORIGINAL**

Event

High temperature alarm had been received.

The temperature and pressure of the tank continued to increase. The Steam Generator had luffed dry as indicated by a continuously decreasing steam pressure while Reactor Coolant System hot leg and cold leg temperatures increased (Figures 19, 24 and 32). This was due to the Emergency Feedwater Block Valves (EF-V12A) and EF-V12B) being closed. The operator did not realize EF-V12A and EF-V12B were shut. The Steam Generator startup level indication remained at approximately 10 to 14 inches. A level of 8 inches or less in a Steam Generator is considered indicative of a dry Steam Generator.

00:05:52  
(05:05:29) The operator started Intermediate Closed Cooling Water Pump A (IC-P-1A) in preparation of putting a second Leddon Cooler in service.

00:05:58  
(05:05:35) The operator initiated Leddon Flow at a rate greater than 160 gallons per minute in an attempt to reduce Pressurizer level to the normal range.

00:05:06  
(05:05:53) Pressurizer level essentially stopped its sharp increase at 376 inches and began to decrease. It reached a minimum of 322 inches and again started to increase at 00:05:21 (05:05:58) (Figure 29).  
Minimum Pressurizer level indication is 400 inches.

Note: Due to the time scale, this event is difficult to identify on Figure 29.

00:05:08  
(05:05:55) In an attempt to establish condensate flow, the operator started Condensate Pump 1A (C0-P-1A).

Z4  
Z4  
Z4  
Z4  
Z4

FN at FLR, ST at FLB and FL13,  
HR(F, HR(SB)) and HR(F) at FIA,  
AP on/off (Delay = 5 minutes)

10 F1 HR at FL3  
AP (Range 0-160 gpm) (Delay = 5 minutes)

PZR 1: SC at PLA, HR (uncompensated) at PL5

**POOR ORIGINAL**

Z4  
Z4  
Z4

AR at PL17, HR(A) and SF at PL5,  
AP on/off (Delay = 5 minutes)

July 16, 1979  
Page 1

Time	Event	Information Available to the Operator	Reference
00:05:15 (0405:52)	The operator attempted to start Condensate Booster Pump B (CB-P-2B). The pump tripped twice due to low suction pressure. The pump started on the third attempt at 00:05:27 (0406:04).	AM at P1.7, IM1A) and SF at P1.5, AP note/strip (Delay = 5 minutes)	2c
00:07:50 (0406:77) Approximate	Reactor Coolant System pressure stopped its sharp decrease and began to increase. The minimum value reached was approximately 140 psig. (Figure 1). As the Reactor Coolant System pressure decreased and the Reactor Coolant System saturation temperature increased, the Reactor Coolant System hot legs reached a saturation temperature-pressure relationship at about 1350 psig which resulted in the formation of steam in the hot legs. The pressure transient is due to the existence of adequate decay heat within the Reactor Coolant System to generate steam at a rate which exceeds the loss of energy through the Electromechanical Relief Valve and other Reactor Coolant System heat sinks.	RC P1 IM and SC at P1.4 RC T1 SC at P1.4 and 10, IM at P1.4	1, 6
00:05:56 (0406:31)	Pressurizer level increased beyond the range of the instrument indication.	PZR 1.1 SC at P1.4, IM (uncompensated) at P1.5	1

POOR ORIGINAL

5A2 025



Information Available to the Operator

1, 10

Event

Time

AC F: HR and SF at P1A

BC F: SF at P1A and 10, HR at P1A

CC F: HR at P1A

The Reactor Coolant System hot leg temperature and pressure reached saturation conditions of 56°F and 135 psig as indicated by the reactor data and Control Room wide range Reactor Coolant System pressure stripchart respectively (Figure 3). The Reactor Coolant System flow rate decreased sharply, indicating a reduction in reactor coolant density (Figure 14). The increased reactor coolant volume resulting from the reactor coolant density decrease contributed to the pressurizer level and pressure behavior at 00:05:50 (0406:11) and 00:05:54 (0406:11)

Condensate Boaster Pump B (CO-P-20) tripped.

The operator started Condensate Boaster Pump B (CO-P-20).

Letdown Cooler 1A (DL-C-1A) outlet high temperature alarm was received at a value of 139F.

The operator reduced letdown flow in response to the Letdown Cooler 1A high temperature alarm and low Reactor Coolant Pressure. The letdown flow returned to normal. A flow rate of 71.5 gallons per minute was recorded.

Reactor Building Sump Pump A (RBL-P-20) started on a high Reactor Building Sump level. The increased sump level was due to the discharge from the Reactor Coolant Drain Tank Relief Valve (RDL-RV) which had been open for approximately 4 minutes. The Reactor Building

AM at P1.17, HR(A) and SF at P1.5

AP norm/trip (Delay = 5 minutes)

AM at P1.17, HR(A) and SF at P1.5

AP norm/trip (Delay = 5 minutes)

AP norm/high (135F) (Delay = 6 minutes)

HR at P1.3

AP Range 0 to 160 psig (Delay = 6 minutes)

AP on/off (Delay = 6 minutes)

00:06:24  
(0407:01)

00:06:29  
(0407:06)

00:06:54  
(0407:11)

00:06:58  
(0407:15)

00:07:11  
(0408:00)

20, 00, 00

20

POOR ORIGINAL

542 024

Title

Event

Information Available to the Incident

Reference

Sump Pumps Generally started about one psi. For this reason the pump start could not have been considered extraordinary by the operator.

Note: Each Reactor Building Sump Pump has a capacity of approximately 140 gallons per minute as measured from the Reactor Building Sump to the Miscellaneous Waste Holding Tank. Records indicate the Miscellaneous Waste Holding Tank level did not change during the incident and it is therefore believed the pump discharge was aligned to the Auxiliary Building Sump Tank. The operators however believe the pump's discharge was aligned to the Miscellaneous Waste Holding Tank.

08:00:00  
08:00:17  
Approximate

1, 2, 3, 4

The operator discovered the Emergency Feedwater Block Valves (E-FV1A and E-FV1B) were shut. E-FV1A and E-FV1B was opened admitting emergency feedwater to the Steam Generator. Indicated Steam Generator levels were approximately 10 inches just prior to feedwater addition (Figure 3). A rapid rise in Steam Generator A and B pressure was observed when feedwater was admitted to the Steam Generator (Figure 3). Addition of feedwater was also confirmed by a decrease in the Emergency Feedwater Pumps discharge pressure and by "hammering" and "rattling" heard from the Lower Port Bunkering System which was aligned to Reactor Steam Generator A (Figure 4).

08:00:15  
08:00:32

The Reactor Coolant System hot leg and cold leg temperatures began to decrease as a result of the feedwater added to the Steam Generator (Figure 6). Steam Generator pressure increased on the Steam Generator again (as indicated on a heat sink for the Reactor Coolant System (Figure 8)).

E-FV1A, B: ST at 11.4  
SG 1: HR at 11.4 (startup level), SC at 11.4 and 11.5 (operating).  
AP low (24 inches)/once (delay ~ 6 minutes)  
SG 1: HR at 11.4, SC (P<sub>HS</sub>) at 11.7  
AP low (Rd) psig)/norm/high (960 psig) (Delay ~ 6 minutes)  
PPP 1: HR (P<sub>HS</sub>) at 11.4

POOR ORIGINAL

542 025

Information Available to the Operator

Reference

Time Event

00:08:30 The Reactor Coolant System pressure began to decrease, reflecting the  
 (05/09:17) decrease in Reactor Coolant System temperature (Figures 1 and 6).  
 Reference: RC F1 DR and SC at P1.4

00:08:59 Condensate Pump 1A (C01-F-1A) tripped.  
 (05/09:36) Reference: AH at P1.7, DR1A and ST at P1.5  
 AP normal/trip and on/off (Delay = 7 minutes)

00:09:11 Condensate Booster Pump suction header pressure low alarm was  
 (05/09:50) received. A value of 14.7 psig was recorded.  
 Reference: AP normal/low (15 psig) (Delay = 7 minutes)

00:10:00 The Pressurizer Level Indication came on scale.  
 (05/10:17) Reference: PZR L1 SC at P1.6, DR (uncompensated) at P1.5

00:10:00 The operators received Reactor Coolant Pump High  
 (05/10:17) Approximate vibration alarm.  
 Reference: AH at P1.8, AN and DR at P1.10

PLANT STATUS

The Reactor Coolant System pressure was near the saturation pressure of the reactor coolant hot leg temperature (Figure 5). This was the result of the Electrically-Relief Valve (ER-RV2) remaining open, high letdown flow rate, throttled High Pressure Injection Isolation Valves and emergency feedwater addition to the Steam Generator. Emergency feedwater flow was admitted to both Steam Generators which resulted in increased steam pressures and the recovery of both Steam Generators as Reactor Coolant System heat sinks as shown by the divergence of Reactor Coolant System hot leg and cold leg temperatures (Figures 6 and 8). Steam pressures were controlled by the Integrated Control System through modulation of the Turbine Bypass Valves. As heat was removed from the Reactor Coolant System, temperature and pressure decreased. The decreasing temperature in conjunction with the letdown flow

POOR ORIGINAL



Information Available to the Operator

Event

Reference

rate and the reduced High Pressure Injection flow rate resulted in a decrease in reactor coolant volume. The Pressurizer Level Indication came on scale. Reactor Coolant Makeup Pump A (RM-P-1A) was operating providing Reactor Coolant Pump seal water and makeup flow. Reactor Coolant System level drop flow rate was approximately 70 gallons per minute.

00:10:19 (0611:56) Reactor Building Sump Pump B (RM-P-2B) started. The pump start sequence is 4-516 feet from the bottom of the Reactor Containment Building Sump. The Reactor Building Sump Pump discharge was allowed to the Auxiliary Building Sump Tank at the Miscellaneous Waste Holding Tank. AP on/off (Delay 2 H minutes) 2a, 2b



00:10:24 (0611:01) Letdown Cooler 1A (RM-C-1A) outlet temperature returned to normal. A value of 123.76 was recorded. AP norm/high (DSE) (Delay 2 H minutes) 2a

00:10:24 (0611:08) The operator stopped Reactor Coolant Makeup Pump A (RM-P-1A). AP at PLB, ST and HR(A) at PL 2a

00:10:27 (0611:06) The operator started Reactor Coolant Makeup Pump A (RM-P-1A). AP norm/trip (Delay 2 H minutes) 2a

00:10:28 (0611:05) The operator stopped Reactor Coolant Makeup Pump A (RM-P-1A). AP at PLB, ST and HR(A) at PL 2a

00:10:58 (0611:25) The Reactor Building Sump high level alarm was received. Setpoint is 4.670 feet from the bottom of the Reactor Building Sump. AP norm/high (4.65 feet) (Delay 2 H minutes) 2a

00:11:43 (0612:20) The operator started Reactor Coolant Makeup Pump A (RM-P-1A). AP norm/trip (Delay 2 H minutes) 2a

542 027

6. Initial

Information Available to the Operator

Level

Time

00:14:54  
(00:14:54)  
The operator stopped Down Fuel Exhaust Pump (00-E-1A and 00-E-1B).  
SF at 11.1 and 11.3, DR(0150) at 14.8  
DR(A) at 11.1, AP on/off and  
rate/trip (Delay = 11 minutes)

00:15:27  
(00:15:05)  
Condensate Monitor High Low pressure returned to normal. A  
value of 17.0 psig was recorded.  
AP norm/low (15 psig) (Delay = 7 minutes)

00:15:50  
(00:15:27)  
The Reactor Coolant Inlet Tank Negative Differential (00-E-2C) lost  
at about 190 psig (19 psig). Isotope lost pressure to 240  
psig. The contents of the Reactor Coolant Inlet Tank were  
relieved to the Reactor Building atmosphere.  
RCP F: All at 11.2A (12.5 psig), 11.8  
at 11.2A

00:16:51  
(00:16:50)  
Condensate Monitor High Low pressure alarm was cleared  
at 117 psig.  
AP norm/low (10 psig) (Delay = 11 minutes)

00:16:55  
(00:16:51)  
The reactor started condensate pump 1A (00-E-1A).  
MR(A) and ST at 11.5.  
AP norm/low and on/off (Delay = 11 minutes)

00:16:57  
(00:16:55)  
Condensate Monitor High Low pressure alarm was  
cleared at 16.8 psig.  
AP norm/low (15 psig) (Delay = 11 minutes)

00:19:21  
(00:19:00)  
The Reactor Building Forge Air Exhaust Inlet A Radiation Monitor  
DR and ST on 11.2

(00-E-27) recorded an increase in radioactivity level. The level  
increased from 1 x 10<sup>2</sup> counts per minute to 5 x 10<sup>2</sup> counts per  
minute on the particulate channel. Additionally, there were slight  
radioactivity level increases on:  
(a) Reactor Building Forge Air Exhaust Port B (00-E-226) -  
particulate monitor

POOL ORIGINAL



Time

Event

- (b) Reactor Boiling Purge Air Exhaust Duct B (RP-R-276) - Run monitor
- (c) Auxiliary Boiling Purge Air Exhaust Duct (before filter) (RP-R-277) - Run monitor
- (d) Auxiliary Boiling Purge Air Exhaust Duct (after filter) (RP-R-222) - particulate monitor

00:26:58  
(0:25:45)

The operator requested the computer to print the outlet temperature (RC-10-TE1, RC-10-TE2 and RC-10-TE3) of the Electromechanical Relief Valve (RC-R2) and the Pressurizer Safety Valves (RC-R1A and RC-R1B). Respective values of 285.4F, 263.9F and 275.1F were indicated. The operator attributed the temperature level to the normal condition of the discharge header following the initial opening and closing of the Electromechanical Relief Valve (RC-R2) and believed the Electromechanical Relief Valve (RC-R2) to be about.

00:25:00  
(0:25:32)  
Approximate

High radiation alarms were received at the Radiation Monitor Panel from Intermediate Cooling Letdown Coolers A and B Radiation Monitors (RC-R-1091 and RC-R-1092). This alarm is periodically received because of its low alarm setpoint and sensitivity to background radiation. The Intermediate Cooling Letdown Cooler Radiation Monitors are physically located next to the Reactor Boiling Sump. The alarms were believed to be the result of increased background radiation levels caused by the Reactor Coolant Drain Tank discharge of reactor coolant to the Reactor Boiling Sump.

PR and SC on PL12

**POOR ORIGINAL**



Time: \_\_\_\_\_ Event: \_\_\_\_\_ Information Available to the Operator: \_\_\_\_\_

Time	Event	Information Available to the Operator
00:29:23 (05:30:00) Approximate	The Reactor Building Air Sample Line monitor (RP-R-227) ran channel count rate increased from $1 \times 10^3$ counts per minute to $5 \times 10^4$ counts per minute and then decreased to $1 \times 10^3$ counts per minute.	PR and SG on FL12
00:32:23 (06:33:00) Approximate	The following radiation monitor readings increased and leveled off: (a) Gas channel of the Station Vent (RP-R-219) monitor (b) iodine channel of the Fuel Handling Building Exhaust duct (before filter) (RP-R-221A) monitor (c) Particulate channel of the Fuel Handling Building Exhaust duct (before filter) (RP-R-221A) monitor (d) iodine channel of the Fuel Handling Building Exhaust duct (after filter) (RP-R-221B) monitor (e) Particulate channel of the Fuel Handling Building Exhaust duct (after filter) (RP-R-221B) monitor (f) Gas channel of the Fuel Handling Building Exhaust duct (after filter) (RP-R-221B) monitor (g) Particulate channel of the Hydrogen Purge duct (RP-R-229) monitor (h) Iodine channel of the Hydrogen Purge duct (RP-R-229) monitor	PR and SG on FL12
00:32:36 (06:33:11)	Isotope thermometer B-10 indicated signal was out-of-range (Range = 0 to 700 F). It is believed that the Incore Thermocouple failed.	AP T (Delay $\approx$ 24 minutes)
00:36:08 (06:36:55)	Emergency Feedwater Pump 2B (EF-F-2B) was stopped after (111)g both Steam Generator to an indicated level of about 35 inches on the stoppage range (Figure 35).	ST, PR (P <sub>015R11</sub> ) and PR(A) at PL4 AP on/off and low (B75 pm1g)/norm (Delay $\approx$ 24 minutes)

POOR ORIGINAL

542 000

Time \_\_\_\_\_ Event \_\_\_\_\_ Information Available to the Operator \_\_\_\_\_ Reference \_\_\_\_\_

00:18:10  
(04:18:47)

The auxiliary operator stopped Reactor Building Sump Pump A (401-P-2A). AP on/off (delay = 31 minutes). The operator believed the pump discharge was aligned to the Waste Holdup Tank and therefore, stopped the pump to prevent the overflow of the Waste Holdup Tank.

Z-1,06

00:18:11  
(04:18:48)

The auxiliary operator stopped Reactor Building Sump Pump B (401-P-2B). The operator believed the pump discharge was aligned to the Waste Holdup Tank and therefore, stopped the pump to prevent the overflow of the Waste Holdup Tank.

NOTE: The two Reactor Building Sump Pumps had operated for 31 and 28 minutes, respectively. Based on the measured capacity of each pump, approximately 8260 gallons of water was transferred to the Auxiliary Building.

Z-1,06

00:40:00  
(04:40:37)

The operator monitored the Reactor Coolant Drain Tank parameters. The Reactor Coolant Drain Tank rupture disc had burst, therefore, the indicated temperature and pressure had reduced substantially and the plant operator did not associate the indication with leakage past the Electromechanical Relief Valve (RC-R2), but rather with the initial opening of the relief valve.

RCRDT F1 HR and AN (125 psig) at PLBA

RCRDT T1 HR at PLBA

AP normal/high (delay = 33 minutes)

R1

00:56:23  
(04:57:00)

Intermediate Cooling Section Cooler A monitor (IC-R-1092) increased from 1 x 10<sup>6</sup> counts per minute and eventually peaked at 2 x 10<sup>6</sup> counts per minute.

AN, HR and SC at PL12

R1

**POOR ORIGINAL**

542 031



Use \_\_\_\_\_ Event \_\_\_\_\_ Information Available to the Operator \_\_\_\_\_ Reference \_\_\_\_\_

01:59:21 (07:59:58)	Condensate high temperature alarm was received at 11R-3A.	AP normal/high (Delay = 48 minutes)	Zo
01:00:07 (07:00:26)	The operator stopped Circulation Water Pump (CW-P-10).	HR(A and P) and ST on FL17	Zo
01:00:49 (07:00:26)	The operator stopped Circulation Water Pump (CW-P-10).	AP on/off (Delay = 49 minutes)	Zo
01:00:50 (07:00:27)	The operator stopped Circulation Water Pump (CW-P-10).	HR(A and P) and ST on FL17	Zo
01:00:57 (07:00:29)	The operator stopped Circulation Water Pump (CW-P-10).	AP on/off (Delay = 49 minutes)	Zo
01:00:57 (07:00:29)	The operator stopped Circulation Water Pump (CW-P-10).	HR(A and P) and ST at FL17	Zo
01:00:57 (07:00:29)	The operator stopped the Circulating Water Pumps to activate a logic circuit which permits steam generator pressure control via the lower shrouded Emergency Main Steam Pump Valves (MSV-3A and MSV-3B) from the control room. Steam Generator Pressure Control was maintained by intermittent use of MSV-3A until 08:10:00 (12:02:17) when the valve was shut in response to collection reported by the State Government.	HR(A and P) and ST at FL17	Zo
01:00:56 (07:00:31)	A Reactor Building Air Cooling Valve Emergency Discharge Alarm was received.	AP on/off (Delay = 49 minutes)	Zo

FROM 518105

Both Reactor Coolant System hot leg temperatures and pressures had decreased until they stabilized at a saturation temperature-pressure relationship of 5.24 and 1050 psia. The Reactor Coolant System loop flow rates had decreased from about 49 million pounds per hour to approximately 47 million pounds per hour and continued to decrease (Figure 15). Reactor coolant

POOR ORIGINAL



00:13:42  
(0514:00)

Reactor Pump 1A (MC-P-2A) was operating. Leakage flow was in the normal range. Pressurizer level was approximately 1/2 inches. The Electricatic Relief Valve (EC-RV) was open. The Containment Baffling Temperature and Pressure had increased from 0 psig and 120 F to 2.5 psig and 130 F, as a result of releasing the contents of the Reactor Coolant Drain Tank to the Reactor containment Baffling atmosphere (Figure 63). The operator was having difficulty controlling the level of Steam Generator B. Emergency Isolation Valves (EI-V11h and EI-V12h) were shut and the operator was admitting feedwater to Steam Generator B by cycling the Emergency Isolation Isolation Valve (EI-V5h).

00:13:52  
(0514:10)

The operator stopped Reactor Coolant Pump 2h (MC-P-2h) to preclude the possibility of damage to the Reactor Coolant Pump from operation near minimum net positive suction head limits. Additional factors which contributed to the operator's decision were high pump vibration and an erratic reactor coolant flow rate.

00:14:02  
(0514:17)

The operator stopped Reactor Coolant Pump 1h (MC-P-1h) to preclude the possibility of damage to the Reactor Coolant Pump from operation near minimum net positive suction head. Additional factors which contributed to the operator's decision were high pump vibration and erratic reactor coolant flow rate.

MC-P-2h: ST, HR(A) and HR(F) at P14, AH at P1A 21, 20, 20, 20, 20

MC-P-1h: AP note/ALSP (Delay = 0 minutes) 21, 20, 20, 20, 20

MC-P-1h: AH at P1A, AH and PH at P110

MC-P-1h: OH and SC at P14

MC-P-2h: ST, HR(A) and HR(F) at P14, AH at P1A 21, 20, 20, 20, 20

MC-P-1h: AP note/ALSP (Delay = 0 minutes) 21, 20, 20, 20, 20

MC-P-1h: AH at P1A, AH and PH at P110

MC-P-1h: OH and SC at P14

See entry at time 02:47:33 (0648:00).

942 033

POOL ORIGINAL

Information Available to the Operator

Time

01:20:21  
(0724:02)

The operator requested the computer print the outlet temperature (MC-10-12, MC-10-13, and MC-10-14) of the flow-reactor heated valve (MC-12) and the reactor safety valves (MC-11A and MC-11B). The recorded values were 213.0F, 211.0F, and 218.6F, respectively. The operator continued to believe that the flow-reactor heated valve (MC-12) was shut.

MC-12 ST at P14

01:26:23  
(0727:00)

Steam generator B was isolated. Main steam isolation valve (MS-V2B and MS-V2C), emergency feedwater valve (EF-V2B, EF-V2C) and EF-V2D and Turbine bypass valve (MS-V2B and MS-V2C) were shut. The operator completed a steam generator B to reactor building leak based on the large difference in steam pressure between the two steam generators, the variation of flow and level experienced while conducting steam generator B and the increased reactor building pressure and temperature. After steam generator B was isolated the water level continued to increase which led the operator to suspect a reactor coolant leak to feedwater side leak related to steam generator B. An analysis of a water sample from the B steam generator taken at 01:24:23 (0724:00) supported this belief.

MS-V2B/MS-V2C ST at P15  
EF-V2B ST at P14  
EF-V2C HM at P14  
EF-V2D ST at P14

01:26:23  
(0727:00)  
Approximate

The reactor intermediate range channel (RI-3) indication was read from a minimum detectable indication of less than  $1.0 \times 10^{-11}$  cpm to approximately  $1.6 \times 10^{-11}$  cpm (Figure 46). Extrapolatingly, the out-of-core source range channel (OI-3) indication increased from about  $1.6 \times 10^4$  to approximately  $5.2 \times 10^4$  counts per second (Figure 46). The indicated increase was not due to reactor core neutron flux level increase but rather an increase in neutron leakage from the reactor core as a result of the isolation of steam to the reactor cooled core regions.

RI-3 HM and SC at P14  
OI-3 HM and SC at P14

**POOR ORIGINAL**

542 034

Information Available to the Operator

Level

01:16:17  
(0534:50)

Steam Generator A boiled dry (Figure 9). Data was indicated by a steadily decreasing steam generator pressure while Reactor Coolant hot leg and cold leg temperatures were increasing. In addition Reactor Coolant differential temperature across the Steam Generator approached zero, which indicated a lack of boiling in the steam generator.

SC P: HR at P14 and SC at P1.17

SC L: DR (Startup Range) at P14

AP Low (23.8 inches) /norm (delay 2.5)

01:17:00  
(0537:31)  
Approximate

The reactor out-of-core Intermediate Range Channel (RI-1) indication decreased from  $2.5 \times 10^{-11}$  amperes to a minimum detectable indication of  $1.0 \times 10^{-11}$  amperes (Figure 46). The out-of-core Source Range Channel (RI-1) indication had a step decrease from  $5.2 \times 10^4$  to  $1.5 \times 10^3$  counts per second (Figure 46). This indicated an increased moderator density as a result of liquid displacing steam in the Reactor Vessel.

RI-1: DR and SC at P14

RI-3: DR and SC at P14

01:50:00  
(0550:17)  
Approximate

The operator started raising Steam Generator A level from 8 inches on the startup range to 302 on the operating range in preparation for establishing of natural circulation (Figures 35 and 38). Reactor Coolant System Loops A and B cold leg temperatures decreased (Figures 20 and 25).

SI L: DR (Startup Range) at P14, HR (Wide Range)

at P14, SC (Nucleo Gauge) at P14 and P15

RC T<sub>1</sub> SC at P1.10

01:50:17  
(0551:15)

The operator stopped the Reactor Coolant Pump 2A (RC-P-2A) to preclude the possibility of damage to the Reactor Coolant Pump from operation near net positive suction head limits. Additional factors which contributed to the operator's decision were high pump vibration and erratic reactor coolant flow rate.

RC-P-2B: SC, Hr(A) and HR(P) at P14, AH at P1R

AP norm/crip (delay 2.5 adjust)

RCP V: AH at P1R, AH and HR at P1.10

RC P: DR and SC at P14

POOR ORIGINAL

See entry at time 02:47:31 (0648:08)

542 055



Time \_\_\_\_\_ Event \_\_\_\_\_ Information Available to the Operator \_\_\_\_\_ Reference \_\_\_\_\_

01:40:25 (05/1:22) The Operator stopped Reactor Coolant Pump 1A (RC-P-1A) to preclude the possibility of damage to the Reactor Coolant Pump from operation near minimum net positive suction head limits. Additional factors which contributed to the operator's decision were high pump vibration and erratic reactor coolant flow rate.

RC-P-2M: ST, HR(A) and HR(F) at P1A, AH at P1B  
 AP norm/trip (Delay = 0 minutes)  
 RC-P-1: AN at P1B, AH and HR at P110  
 RC-F: HR and SC at P1A

01:41:00 (05/1:17) The operator manually initiated high pressure injection to supply approximately additional cooling water to the reactor core. Backup Pump 1C (RH-P-1C) started. Backup Pumps, 1A and 1C (RH-P-1A and RH-P-1C) are operating.

HR1: AN at P113, ST at P13 and P111  
 AP norm/actuation (Delay = 0 minutes)

FLAME STATUS

The Reactor Coolant System had no forced Reactor Coolant System flow. All Reactor Coolant Pumps (RC-P-1A, RC-P-2A, RC-P-1B and RC-P-2B) had been stopped to preclude the possibility of damage from operation near net positive suction head limits. Additional factors which contributed to the operator's decision were high pump vibration and an erratic reactor coolant flow rate. (Figure 15). The Reactor Coolant System average temperature and pressure were approximately 534F and 1000 psig, respectively (Figures 11 and 25). Leakdown flow rate was in the normal range. Pressure level was 3 1/2 inches. Reactor Coolant Backup Pumps 1A and 1B (RH-P-1B) were operating in the High Pressure Injection mode. The operator was attempting to establish natural circulation flow to cool the reactor core. Steam Generator B was isolated because of a suspected Steam Generator B to Reactor Refueling Tank and a Reactor

POOR ORIGINAL

\*See entry at time 02:47:31 (01/6R100)

Event

Coolant side to feedwater side leak. Steam Generator B pressure and level were 170 psig and 9% inches respectively. Steam Generator A was steaming to the atmosphere via the power operated Emergency Bypass Steam Dump Valve (DS-VIA). Steam Generator A pressure and level were 730 psig and 10% inches respectively.

NI-1: HR and SC at FLA  
NI-2: HR and SC at FLA

01:54:00  
(0554:37)  
Approximate  
The reactor out-of-core Intermediate Range Channel (IR-3) indication increased from less than  $1.0 \times 10^{-11}$  amperes to approximately  $1.0 \times 10^{-10}$  amperes (Figure 46). A corresponding increase was recorded on the reactor out-of-core Source Range Channel (SI-1) indication (Figure 46). The indicated increase was not due to increase neutron flux level increases but rather an increase in neutron leakage from the reactor core as a result of the steam formed in the reactor vessel core region. The formation of steam was contributed to by (1) increased reactor core temperatures, (2) throttled Reactor Coolant Makeup Pump flow, (3) the absence of Reactor Coolant System flow, and (4) the decreased Reactor Coolant System pressure which resulted from the open Electromagnetic Relief Valve (ER-R2) and the increased Reactor Coolant System cold leg density caused by filling Steam Generator A.

01:54:00  
(0554:37)  
Approximate  
Reactor Coolant System Loop A hot leg temperature began to increase, reflecting steam formation in the upper reactor core region (Figure 40).  
SC at FLA and HI-10, HR at FLA

POOR ORIGINAL

July 16, 1970  
Nov. 1

Information Available to the Operator

Level

Reference

02:00:30  
(0000: 17)

Control room A level indication received 502 on the operating pump (Figure 10). This level was established by the operator in order to avoid cavitation.

SC at P1A and P1B

1,000,00

02:00:30  
(0000: 17)

Reactor coolant system loop B had low temperature alarm indicating (Figure 26).

SC at P1A and P1B, PH at P1A

02:00:30  
(0000: 17)

A telephone conference call was made between Unit 2 Technical Superintendent (Unit 2 control room) and the Station Superintendent. The President of Generation and Babcock and Wilcox President replaces which lasted approximately 20 minutes.

PH

02:10:00  
(0000: 17)

Reactor coolant system loop A had low temperature indication in excess of 100°F, greater than 6200 (Figure 21).

AN at P1A (high at 6120), SC at P1A and P1B, PH at P1A

02:14:21  
(0000: 17)

The Reactor Building Air Sample (RB-R-22) particulate channel in excess of 1000 is eventually cut off scale.

AN, PH and SC at P1B

**POOR ORIGINAL**

02:17:01  
(0000: 17)

The operator requested the computer print the outlet temperature (MC-10-11, MC-10-11/ and MC-10-12) of the directomatic inlet Valve (MC-R2) and the Pressurizer Safety Valve (MC-R1A and MC-R1B). The recorded values were 220.7°F, 180.5°F, and 196.2°F, respectively.

02:19:30  
(0000: 17)

The operator shut the Directomatic Relief Block Valve (MC-R2), which stopped reactor coolant leakage through the Directomatic Relief Valve (MC-R2). The operator noted that the Reactor Building pressure started to decrease rapidly (Figure 43).

MC-R21 SC oper/abnt at P1A

7,000,000

02:20:00  
(0000: 17)

MC-R21 RT oper/abnt resumed at P1A

PH at SC at P1B

542 058



Information Available to the Operator

Event

Time

Reference

Time	Event	Reference
02:19:00 (06:19:17) Approximate	Reactor Coolant System Pressure started to increase from 600 psig to 710 psig in the cooling 61 minutes. Reactor Coolant System Pressure was then stabilized at 710 psig.	AM (Low-2055 psig and Low/High - 1980 psig) at P18 HP and SC at P14
02:25:24 (06:25:40) Approximate	The Reactor Building Air Sample (RP-F-227) gas channel increased on(1) it eventually went off scale.	AM, HP and SC at P112
02:27:24 (06:28:40)	The alarm printer malfunctioned. The alarm printer function transferred to the utility printer. The alarm printer was 1 hour and 25 minutes behind in logging data (Figure 4B).	24, 26
02:28:24 (06:28:53)	Reactor Coolant Loop B hotleg temperature indication increased offscale, greater than 620F (Figure 2b).	AM at P18 (high at 612F), SC at P14 and P110, HP at P14
02:30:00 (06:30:17)	The operator started increasing Steam Generator B level from 30 inches on the Startup Range to 502 on the Operating Range (Figure 19).	HP (Startup Range) at P14, HP (Wide Range) at P14 SC (Operate Range) at P14 and P15
02:31:24 (06:32:00) Approximate	The Incore Instrument Panel Area Monitor (IP-R-211) reading began to increase.	AM, HP and SC at P117
02:38:24 (06:39:00) Approximate	The Letdown Cooler A monitor (IC-R-1092) level increased offscale. The levels indicated on the following radiation monitors began to increase: (a) Makeup Tank Area Monitor (IP-R-206) (b) Fuel Building Building 5. (IP-R-210) (c) Reactor Dose (IP-R-212)	AM, HP and SC at P112

542 039

**POOR ORIGINAL**

Information Available to the Operator

Event

Time

By

Reference

02:50:00  
Approximate

The shift supervisor received the results of two boron analyses which indicated the boron concentration in the Reactor Coolant System was approximately 400 parts per million. This, in conjunction with increased neutron levels indicated on the source and intermediate range channels, prompted the shift supervisor to initiate emergency boration of the Reactor Coolant System.

0011: The actual boron concentration in the Reactor Coolant System was in excess of 1000 parts per million. The samples are believed to have been diluted by distillation in the letdown system. This however was not known by the plant operators until several hours later.

- 02:55:21  
Approximate
- Incore Instrument Panel Area Monitor (IP-R-213) indication increased off scale high. The level recorded on the following monitors began to increase.
- (a) Reactor Building Purge Air Exhaust Port A (IP-R-225)-particulate
  - (b) Reactor Building Purge Air Exhaust Port B (IP-R-226)-particulate
  - (c) Auxiliary Building Purge Air Exhaust (IP-R-222)-particulate, gas, and iodine
  - (d) Auxiliary Building Heating & Ventilation monitor gas channel (indication was off scale within 30 minutes).
- The Reactor Building Air sample (IP-R-227) iodine channel indication increased off scale.

02:57:00  
0065:37  
Approximate

Several radiation alarms were received at the Control Room Radiation Monitor Panel.

AW, BR and SC at PL12

By

AW, BR and SC at PL12

By

542 040  
**POOR ORIGINAL**

Information Available to the Operator

Reference

No.

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

AP norm/trip (Delay = 4)

Event

The operator stopped Reactor Coolant Backup Pump C (RC-B-1C).

02:55:00  
(0655:00)  
Approximate

Fuel Handling Building Radiation (HF-R-21B) began to increase.

02:55:23  
(0655:23)  
Approximate

The operator attempted to start Reactor Coolant Pump 1A (RC-P-1A).

02:56:24  
(0656:24)  
Approximate

The pump would not start.

The operator initialized the alarm summary function to obtain

02:57:31  
(0657:31)  
Approximate

current alarm data. As a result the alarm summary data from

01:13:22 (0513:59) to 02:47:31 (0648:08) was deleted.

The following radiation monitor indication were increasing

02:59:23  
(0659:23)  
Approximate

steadily and by 03:20:23 (0721:00) all were off scale:

(a) Fan channel at the Station Vent (HF-R-219) monitor

(b) Fuel Handling Building Exhaust duct (HF-R-221, A & B)

(c) Hydrogen Purge duct (HF-R-229) particulate & iodine channels.

Condensate Vacuum Pump Exhaust Radiation Monitor (VA-R-74B) increased

from  $1 \times 10^2$  to  $8 \times 10^5$  counts per minute at 06:39:23 (0700:00).

Note: VA-R-74B is located in the Turbine Building at an

elevation of 201.6'.

The operator attempted to start Reactor Coolant Pump 2A (RC-P-2A).

02:51:57  
(0652:57)  
Approximate

The pump would not start.

Condensate hotwell level indication returned to normal. A level of

02:52:26  
(0653:03)  
Approximate

36.94 inches was indicated.

The operator attempted to start Reactor Coolant Pump 1B (RC-P-1B).

02:53:19  
(0653:53)  
Approximate

The pump would not start.

POOR ORIGINAL



Information Available to the Operator

Event

Time

ST, BR(A), BR(F) and ST(F) at PIA, AH at PIR, AP warn/trip (Delay = 5 minutes)

The operator started Reactor Coolant Pump 2B (RC-P-2B) and reestablished forced Reactor Coolant System flow at a rate of 10 million pounds per hour (Figure 16).

02:54:09  
(06:54:46)

ST at PIA  
AP on/off (Delay = 5 minutes)

Pressureizer heater groups 1 through 5 tripped.

02:54:19  
(06:54:56)

AP warn/trip (Delay = 5 minutes)

Waste Gas Discharge Monitor (WDG-D-16B) increased and went off scale.  
Note: This monitor is located in the Auxiliary Building at an elevation of 305.0".

02:54:24  
(06:55:01)  
Approximate

AP warn/trip (Delay = 5 minutes)

The following Incore Thermocouple temperatures were recorded in sequence on the Alarm Printer over the next seven minutes. After these values were recorded the Incore Thermocouples increased until the computer channel range upper limit of 7000 was exceeded.

02:54:33  
(06:55:10)

**POOR ORIGINAL**

- 7B = 623.7F
- 10C = 599.0F
- 10 = 596.0F
- 2G = 623.8F
- 120 = 626.9F
- 13G = 620.6F
- 16B = 653.6F
- 7R = 679.7F
- 130 = 577.1F
- 5D = 699.5F
- 11 = 305.0F
- 1F = 681.9F

AH (Low-2055 psig and Low/Low-1900 psig) at PIR

Reactor coolant system pressure rapidly increased from approximately 1250 psig to approximately 2140 psig (Figure 4).

02:54:40  
(06:55:17)  
Approximate

AH at PIR, ST at PIA and PIR  
AP warn/trip (Delay = 5 minutes)

High Pressure Injection actuation logic of the Engine Safety features reset on increasing Reactor Coolant System pressure. The set point in 1965 psig.

02:54:49  
(06:55:26)

512 042

Time	Event	Information Available to the Operator	Reference
------	-------	---------------------------------------	-----------

02:54:50 (06:55:27)	The operator started Circulating Water Pump 1B (CM-P-1B).	IR(A and F), ST at PI.17, and AP on/off (Delay $\approx$ 6 minutes)	
------------------------	---	---	--

02:55:00 (06:55:17)	A Site Emergency was declared upon receiving high level radiation status from the Condenser Vacuum Pump Exhaust Radiation Monitor (VE-R-248) and Reactor Building Monitor (RP-R-214). Notification of offsite authorities and organizations was initiated.	AR, IR and ST at PI.17	Pl. B
------------------------	--	------------------------	-------

02:55:00 (06:55:17)	The reactor out-of-core Intermediate Range Channel (RI-3) indication decreased sharply from about $8.0 \times 10^{-11}$ neutrons to less than $1.0 \times 10^{-11}$ neutrons (minimum detectable level) (Figure 46). The reactor out-of-core Source Range Channel (RI-1) indication showed a corresponding decrease which indicated the steam in the reactor core region was displaced by liquid. (Figure 46). The displacement of the steam in the reactor core region is attributed to the reestablishment of Reactor Coolant System flow.	RI-1 IR and SC at PI.4 RI-3 IR and SC at PI.4	B
------------------------	--	--	---

02:55:26 (06:56:03)	Condenser hot well low level alarm was received. The level was 21.82 inches.	IR at PI.5 AP low (22.5 inches)/norm/high (36 inches) (Delay $\approx$ 11 minutes)	2a
------------------------	--	--	----

02:55:48 (06:56:15)	The operator started Circulating Water Pump 1E (CM-P-1E).	IR (A and F) and ST on PI.17 AP on/off (Delay $\approx$ 11 minutes)	2a
------------------------	---	--	----

02:59:23 (07:00:00)	Reactor Building Torque Unit Area Monitor (RP-R-3236) and the Fuel Handling Building Area Monitor (RP-R-3240) began to increase. Fuel Handling Building Air Supply Fans were turned off.	AR, IR and SC at PI.12	Pl. B
------------------------	--	------------------------	-------

03:02:56 (07:03:13)	Condenser hotwell low level alarm was received again. The level was 9.68 inches.	IR at PI.5 AP low (22.5 inches)/norm/high (36 inches) (Delay $\approx$ 11 minutes)	2a
------------------------	--	--	----

POOR ORIGINAL

Information Available to the Operator

Event

Time	Description	Information Available to the Operator	Reference
03:03:39 (0705:16) Approximate	The operator isolated Steam Generator B for the second time. Lubrication Valves (RS-V15B, RS-V25B and RS-V26B) were shut. Emergency Feedwater Valve (EF-V5B, EF-V11B, and EF-V12B) were shut. The operator suspected a Reactor Coolant side leak. The Condenser Vacuum Pump Exhaust Radiation Monitor (VA-R-74B) increased to 5 x 10 <sup>6</sup> counts per minute.	RS-V25B/26B: ST at PL5 RS-V15B: ST at PL5 EF-V5B: ST at PL4 EF-V11B: HR at PL4 EF-V12B: ST at PL4	2a, 4b
03:05:39 (0706:16) Approximate	The reactor out-of-core Source Range Channel and Intermediate Range Channel (RI-1 and RI-3, respectively) indication increased approximately a quarter of a decade (Figure 4a).	RI-1: HR and SC at PL4 RI-3: HR and SC at PL4	B
03:06:40 (0707:17)	Condensate Storage Tank B low level alarm was received. A level of 19.96 feet was recorded.	AP low (20 (t)/norm/high (29 ft) (delay = 13 minutes)	2a
03:10:27 (0711:05)	Emergency Feedwater Pump 2A (EF-P-2A) was stopped. With Steam Generator low levels of about 50% on the Operating Range (Figure 49).	EF-P-2A: ST, HR(A) and HR(F DISCH) at PL4 SC 1: SC (Operate Range) at PL4 and PL5	1, 2a
03:11:10 (0711:47)	Condenser hotwell level returned to normal. The level was 24.07 inches.	HR at PL5 AP low (22.5 inches)/norm/high (16 inches) (delay = 15 minutes)	2a
03:12:28 (0713:05) Approximate	The operator opened the Electromechanical Relief Blank Valve (RU-V7) in an attempt to establish Free Zirc level within the normal operating range. The reactor out-of-core Intermediate Range Channel RI-3 indication decreased sharply as a result of coolant flow through the reactor core (Figure 46).	RU-V7: ST at PL4 RI-3: HR and SC at PL4	1, 11, 13, 1b

POOR ORIGINAL

042 044



Information Available to the Operator

Event

Time

Reference

03:17:51  
(0219:30)

The operator stopped Reactor Coolant Pump 2B (RC-P-2B) based on indicated zero flow and motor running current of less than 100 amperes. Normal Reactor Coolant Pump operating current is approximately 400 amperes. Later a close examination of the flow recorder trace indicated a small amount of reactor coolant flow had existed.

SI, HR(A), HR(S) and SC(S) at PLS, AI (trip) at PLS  
AI norm/trip (Delay = 16 minutes)

20.3

03:14:24  
(0215:00)  
Approximate

Intermediate Cooling Pump Area Monitor (IP-A-207) indicated an increased radiation level and at 03:20:23 (0221:00) the level stabilized at a value of 100 mR/hr.

AN, HR and SC at PLS

11

03:18:13  
(0218:00)  
Approximate

The reactor out-of-core Intermediate Range Channel (RI-3) indication increased from less than  $1.0 \times 10^{-11}$  neutrons to about  $2.7 \times 10^{-10}$  neutrons, which indicated steam was again formed in the reactor core region (Figure 46).

HR and SC at PLS

10

03:19:45  
(0220:22)

The operator manually initiated High Pressure Injection as a result of low Reactor Coolant System pressure (Figure 4). The High Pressure Injection automatic actuation setpoint is 1650 psig.

AI at PLS, SI at PLS and 11

20.9

AI bypass/vent/trip (Delay = 19 minutes)

03:20:13  
(0220:50)

Reactor Coolant Backup Pump C (RB-P-1C) started automatically. Reactor Coolant Backup Pumps A and C (RB-P-1A and RB-P-1C) were operating.

SI and HR(A) at PLS, AI at PLS

20.7

AI norm/trip (Delay = 19 minutes)

542 045

NOTE: In the an Engineered Safety Features actuation, High Pressure Injection utilizes Reactor Coolant Backup Pumps 1A and 1C (RB-P-1A and RB-P-1C).

POOR ORIGINAL

Information Available to the Operator

Event

Time

Reference

03:20:24  
(0721:00)  
Approximate

The following radiation monitors registered increased

radiation levels:

- (a) Primary Coolant Letdown 4B (HP-R-720 4B)
- (b) Primary Coolant Letdown 1a (HP-R-720 1a)
- (c) Intermediate Cooling Letdown Cooler B (IC-R-1091)
- (d) Intermediate Cooling Letdown Cooler A (IC-R-1092)
- (e) Intermediate Cooling Letdown Cooler Outlet (IC-R-1093)
- (f) Plant Effluent 11 (HP-R-1311)
- (g) Decay Heat Channel A Loop (DC-R-1399)
- (h) Decay Heat Channel B Loop (DC-R-1400)
- (i) Reactor Service Closed Cooling (RS-R-1401)
- (j) Spent Fuel Cooling (SF-R-1402)

AB, DB and SC at PL12

03:21:00  
(0721:17)  
Approximate

The reactor out-of-core Source Range Channel (RI-1) and reactor out of core Intermediate Range Channel (RI-3) indication decreased rapidly indicating flow was established thru the reactor core (Figure 56).

NI-1: RB and SC at PL4  
NI-3: RB and SC at PL4

03:21:24  
(0722:00)  
Approximate

The following radiation monitors indicated radiation levels exceeding the monitor range, and remained above range until the stripchart ended at 1400:00, 8/22/79.

- (a) Reactor Building Purge Air Exhaust Duct A (RP-R-225) - Particulate Monitor
- (b) Reactor Building Purge Air Exhaust Duct B (RP-R-226) - Particulate Monitor
- (c) Auxiliary Building Purge Air Exhaust (AP-R-222)

AN, DM and SC at PL12

POOR ORIGINAL

542 046

(0) Auxiliary Building Heating & Ventilation Radiation Monitor gas channel

The Reactor Building Purge Air Exhaust Duct Inline Monitor indicated  $1 \times 10^5$  counts per minute. The gas channel of the Reactor Building Duct A Radiation Monitor indicated  $5 \times 10^5$  counts per minute.

FLARE STATUS

The Reactor Coolant System was at minimum forced flow condition with all Reactor Coolant Pumps (RC-P-1A, RC-P-2A, RC-P-1B, and RC-P-2B) stopped. After attempts to establish natural circulation failed, the operator started Reactor Coolant Pump 2B (RC-P-2B). However, based on a no flow indication and a pump running current of less than 100 amps, Reactor Coolant Pump 2B was stopped after 19 minutes. Steam was present in the Reactor Vessel head and Reactor Coolant System hot legs. Both Reactor Coolant System hot leg temperatures were off scale high (i.e. greater than 620F). The Reactor Coolant System cold leg temperatures were 45F for loop A and 390F for loop B. Steam Generator B was isolated due to a suspected Reactor Coolant side to feedwater side leak. Steam Generator A pressure was controlled via means of the Power Operated Emergency Bypass Steam Dump Valve A (PISV-3A). An attempt was in progress to control Reactor Coolant System Pressurizer pressure and level with the Electrically Operated Relief Block Valve (RC-02). This resulted in lower Reactor Coolant System pressure which prompted the operator to manually initiate High Pressure Injection. Consequently, both Reactor Coolant Makeup Pumps 1A and 1C (MU-P-1A and MU-P-1C) were operating.

542 047

POOR ORIGINAL



Information Available to the Operator

Time

Event

Reference

03:23:46  
(02:23:53)

A High Pressure Injection activation due to low Reactor Coolant System pressure was received. High Pressure Injection had previously been placed in service by the operator.

2a

03:23:23  
(02:24:00)  
Approximate

A Crucial Emergency was declared as a result of an indicated radiation level of 8 R/hr on the Reactor Dome Radiation Monitor (RR-R-217). Notification of offsite authorities and organizations was initiated.

2a

AN, HR and SC at PL12

03:27:23  
(02:28:00)  
Approximate

The Radiation level indicated on the Auxiliary Building Access Control Corridor Radiation Monitor (RR-R-232) increased.

2b

AN, HR and SC at PL12

03:29:23  
(02:30:00)  
Approximate

The Fuel Handling Building Air Exhaust Fan(s) flow was to zero. Note: During the next 2-1/2 hours the exhaust fan(s) were turned on and off several times with run times of 30 to 60 minutes.

2b

03:30:00  
(02:30:30)  
Approximate

The operator shut the Electromechanical Relief Block valve (RR-V2). The pressurizer level was 220 inches and the Reactor Coolant System pressure was 1400 psig (Figures 4 and 12).

2c

RR-V2: ST at PL4  
RR-L1: SC at PL4, HR (uncompensated) at PL5  
RR-P1: HR and SC at PL4

03:35:08  
(02:35:43)

The operator started Emergency Feedwater Pump 2A (RR-P-2A). Steam Generator A level had been continuously falling from 682 to 442 of operating range during the previous 45 minutes (Figure 39).

2c

RR-P-2A: ST, HR (P\_his(h)) and HR(A) at PL4,  
AP on/off and P\_his(h) low/normal  
(Delay > 40 minutes)

03:37:00  
(02:37:33)

The Reactor Coolant Makeup Pump C (RR-P-C) was stopped because pressurizer level was rapidly increasing. Indicated pressurizer level was 350 inches (Figure 4).

1,2a

RR-P-C: ST and HR(A) at PL3, AH at PIR  
AP non/trip (Delay > 42 minutes)  
RR-L1: ST at PL4, HR (uncompensated) at PL5

POOL OPERATIONS

502 010

Insufficient Air Available in the Operator

Event

Time

Time	Event	Insufficient Air Available in the Operator	Notes
01:58:23 (0756:00)	Shutdown Tank Area Fanlight (TR-R-206) advanced off scale. Levels in Tank Building, Bridge 5 (TR-N-210) and Reactor Area (TR-N-216) stabilized at $1.5 \times 10^7$ R/hr.	AM, RM and ST at P12	1
01:58:50 (0756:37)	the operator opened the Electromechanical Relief Valve (EC-V2) in an attempt to decrease pressure level, which had increased to 105 inches (Figure 4).	EC-V2: ST at P16, ECR 1: ST at P16, BR (uncompensated) at P15	1, 11, 20
01:59:28 (0756:45)	the operator stopped Intermediate Cooling Pump 1B (IC-P-B).	AM, ST, HR (HSCU) and RR (F) at P18 AP on/off (delay = 46 minutes)	2
01:59:34 (0756:46)	Engineered Safety features actuated on Reactor Building high pressure of the subject of 3.58 psig (Figure 4).	AM at P13, ST at P13 and P15, AP on/off (delay = 46 minutes)	2
01:59:39 (0756:46)	The Reactor Building Isolated automatically as part of the Engineered Safety features actuation from Reactor Building high pressure. Reactor Building Isolation occurred at the nominal setpoint of 4 psig.	AM at P13, ST at P13 and P15, AP Isolation/Alarm (delay = 46 minutes)	2
01:59:46 (0756:47)	The operator stopped Intermediate Cooling Pump 1A (IC-P-1A).	AM, ST, HR (HSCU) and RR (F) at P18 AP on/off (delay = 46 minutes)	2
01:59:50 (0756:47)	Reactor Coolant Backup Pump 1: (RB-P-1C) was started automatically by the Engineered Safety features actuation.	AM at P18, ST and RR (A) at P13 AP on/off (delay = 46 minutes)	2
01:59:52 (0756:48)	Reactor Building Emergency Cooler B was shutdown.	ST at P13	2

POOR ORIGINAL

542 049

Time: \_\_\_\_\_ Event: \_\_\_\_\_ Information Available to the Operator: \_\_\_\_\_

Time	Event	Information Available to the Operator	Page
03:59:23 (0300:00) Approximate	Waste Gas Tank Discharge A (NRZ-N-1AR5) monitor began to increase from $3 \times 10^2$ counts per minute until it reached $3 \times 10^3$ counts per minute at approximately 05:00:00 (0300:17).  Note: This monitor is located in the Auxiliary Building at a elevation of 305 feet.		4
03:59:53 (0300:30)	Reactor Building Emergency Cooler B was started automatically by the Engineered Safety Features actuation.	AP T (0-200F) (Delay = 47 minutes)	2a
04:00:14 (0300:50)	The operator started Intermediate Cooling Pump 1B (IC-P-1B).	AN, ST, HR(F DISCH) and HR(F) at FLB AP on/off (Delay = 47 minutes)	2a
04:00:19 (0300:56)	The operator started Intermediate Cooling Pump 1A (IC-P-1A).	AN, ST, HR(F DISCH) and HR(F) at FLB AP on/off (Delay = 47 minutes)	2a
04:00:37 (0300:16)	The operator started Reactor Coolant Pump 1A (RC-P-1A) to re-establish Reactor Coolant System flow.  Note: During the previous run of Reactor Coolant Pump 2b (RC-P-2b), due to the flow and current indication observed, it was thought that the pump might not have started. For this reason it was decided to observe the starting current during a Reactor Coolant Pump start. Reactor Coolant Pump 1A (RC-P-1A) was started and a correct starting current was observed by the operator. As before, the indicated pump current rapidly decreased to less than 100 amperes.	ST, HR(A), HR(F) and SC(F) at FLA, AP at FLB AP norm/start (Delay = 51 minutes)	2a
04:00:14 (0300:51)	The operator stopped Reactor Coolant Pump 1A (RC-P-1A) after observing a no-flow indication and a running current less than 100 amperes.	ST, HR(A), HR(F) and SC(F) at FLA, AN at FLB AP norm/start (Delay = 51 minutes)	2a

542 050

-4- POOR ORIGINAL



Time	Event	Information Available to the Operator	Reference
05:10:10 (0811:57)	The operator stopped Intermediate Cooling Pump IB (IC-P-1B).	AH, ST, HR(P, DISCH) and HR(F) at FLB AP on/off (Delay ~ 53 minutes)	2a
05:12:17 (0812:54)	The operator stopped Reactor Coolant Makeup Pump IA (RI-P-1A).	ST and HR(A) at FL3, AH at FLB, AP norm/trip (Delay ~ 55 minutes)	2a
05:12:22 (0812:59)	The operator stopped Reactor Coolant Makeup Pump IC (RI-P-1C). No Reactor Coolant Makeup Pumps were operating.	SF and HR(A) at FL3, AH at FLB, AP norm/trip (Delay ~ 55 minutes)	2a
05:18:17 (0818:54)	The operator placed Backup Pump IA (RI-P-1A) control switch in full-to-lock position to prohibit further use of RI-P-1A due to the pump operating problems experienced.	Control switch handle position	2a, 9
05:19:02 (0819:39)	The operator started Intermediate Cooling Pump IB (IC-P-1B).	AH, ST, HR(P, DISCH) and HR(F) at FLB AP on/off (Delay ~ 55 minutes)	2a
05:21:51 (0822:39)	The operator started Reactor Coolant Makeup Pump IB (RI-P-1B). App-on/locate	ST and HR(A) at FL3, AH at FLB, AP norm/trip (Delay ~ 55 minutes)	2a
05:23:56 (0824:33)	Pressurizer heater groups 1 through 5 energized. All pressurizer heater groups were available at this time.	AH at FLB, ST at FLA, AP on/off (Delay ~ 58 minutes)	2a
05:26:59 (0827:39)	The operator started Reactor Coolant Makeup Pump IC (IC-P-1C).	SF and HR(A) at FL3, AH at FLB, AP on/off (Delay ~ 58 minutes)	2a
05:30:30 (0831:07)	Pressurizer heater group 10 tripped and remained off for the remainder of March 28.	AH at FLB, SF at FLA, AP on/off (Delay ~ 58 minutes)	2a
05:39:45 (0844:22)	The operator stopped Condenser Vacuum Pumps IA and IC (VA-P-1A and VA-P-1C) and broke Main Condenser vacuum after experiencing difficulty with the operation of the Auxiliary Roller.	Pumps: ST at FL17, AP on/off (Delay ~ 60 minutes) Vacuum: AH and SF at FL17	2a, 8a, 8b

**POOR ORIGINAL**  
 - 47 -

542 051

Information Available to the Operator

Time	Event	Reference
04:02:55 (0841:27) Approximate	The operator opened Power Operated Bypass Valve Main Steam Dump Valve A (RC-V16) to induce natural circulation in Steam Generator A. Steam Generator B was still isolated.	PIB (Valve down setpoint) at P15
04:44:23 (0845:00)	Intermediate Cooling between Cooler A and Mainline Heater (IC-1-1092) indication decreased and sent off scale. Note: Heater failure was assumed.	PIB and SC at P12
04:44:24 (0845:58)	Preheater heater groups 4 and 5 tripped and remained off for the remainder of March 28. There were 10 pressurizer heater groups available at this time.	AH at P18, ST at P14 AP on/off (Delay ~ 63 minutes)
04:49:23 (0846:00) Approximate	Condenser Vacuum Pump Exhaust radiation monitor (VA-N-748) decreased to $1 \times 10^4$ counts per minute.	PIB and SC at P12
04:59:23 (0846:00)	Intermediate Cooling Pump Area monitor (IP-N-207) and the Monitor Building Emergency Cooling Booster Pump Area monitor (IP-N-206) indications began to increase.	MI and SC at P12
05:17:38 (0848:05)	The alarm printer was returned to service and the alarm function was transferred from the utility printer to the alarm printer.	AP (Delay ~ 0 minutes)
05:18:00 (0848:17) Approximate	The operator closed the Electromechanical Relief Valve (RC-V2) in an attempt to compress the reactor coolant and condense the steam in the Reactor Coolant System.	ST at P14

PLANT STATUS

ALL Reactor Coolant Pumps (RC-P-1A, RC-P-2A, RC-P-1B and RC-P-2B) were stopped. Superheated steam/water was present in the upper Reactor Vessel

POOR ORIGINAL

and hot leg regions. Attempts to re-establish reactor coolant flow using Reactor Coolant Pump 1A (RC-P-1A) had not been successful. The Reactor Coolant hot leg temperature continued to read off-scale (i.e. greater than 600). The Reactor Coolant cold leg temperatures were 180 F for Loop A and 225 F for Loop B, and both were decreasing (Figures 21 and 26). Steam Generator A level was at 48% of the operating range (Figure 19). Steam Generator B was isolated, with a level at 66% on the operating range (Figure 19). Condenser vacuum was lost due to the auxiliary steam boiler tripping and loss of adequate main steam pressure. Steam Generator A was steaming through the Power Operated Emergency Main Steam Isolation Valve (MS-V3A). Attempts to obtain a normal operating Pressurizer level of 220 inches of water and establish pressure control using the pressurizer were not successful. The Electrically-Heated Reactor Building pressure. The first Engineered Safety Features activation on High Reactor Building pressure was received and, four minutes later, bypassed by the operator to re-establish cooling water to various plant equipment within the Reactor Building. The Reactor Building pressure continued to stay above the isolation trip setpoint for approximately 2.6 hours (Figure 45). The Station Manager made the decision to maintain continuous High Pressure Injection and Increase Reactor Coolant System pressure in an attempt to condense the superheated steam/gas in the Reactor Coolant System. This first attempt lasted for approximately 2 hours.

07:20:00 The operator increased Reactor Coolant System pressure from 1750 (0920:37)

Appropriate psig to 2100 psig during the ensuing 45 minutes. Reactor Coolant

System pressure was then maintained at 2100 psig (Figure 4).

AW (Low-2055 and Low/Low-1900) at PIA

PH and SC at PIA

AP (many clearing alarms) (Delay ~ 100 minutes)

POOR ORIGINAL



Information Available to the Operator

Event

Time

Approximate

Reference

0

SI and SR at PLS

Low Ducting Building Radiation Monitor (RP-R-215) and Control and  
Services Building Control Radiation Monitor (RP-R-216) began to  
fluctuate to between 50 and 70 counts per minute.

The radiation levels indicated by the following monitors increased  
on 11 16:59:21 (1900:00) at which time all were almost  
off scale.

- (1) Analytic Building Access Controller Radiation Monitor (RP-R-232)
- (2) Room for Building Package Unit Area Radiation Monitor (RP-R-236)
- (3) Fuel Handling Building Exhaust Unit Area Radiation Monitor (RP-R-2240)

Pressure breaker group 3 tripped leaving 9 available pressurized  
breaker groups.

AI at PLS. ST at PLS

20

AP on/off (delay = 93 minutes)

Radiation levels as indicated by the Intermediate Cooling Pump  
Area Radiation Monitor (RP-R-207) and the Reactor Building

SI and SR at PLS

30

Interpump Cooling Booster Pump Area Radiation Monitor (RP-R-204)  
started at a  $10^4$  cpm/hr. All Control Room Intake duct radiation  
monitor (particulate, iodine, gas) (RP-R-220) level increased.

The particulate channel reached  $1 \times 10^5$  counts per minute  
while the iodine and gas channels reached  $1 \times 10^3$  counts per  
minute.

POOR ORIGINAL

The operator commenced filling Steam Generator A to 95% on the  
operating pumps to induce natural circulation. Steam Generator  
A level reached 100% at 07:30:00 (1930:37) (Figure 39).

SC 1.1 IR (startup range) at PLS, SR (alar range) at PLS  
SC (operating range) at PLS and PLS

The Reactor Coolant System pressure reached a value of 2200 psig.  
The operator opened the Electrically Actuated Relief Valve (RP-V2) to  
drop the pressure, increase and reduce pressure to about 2000 psig.

RC P1 RW and SC at PLS  
RC-V2 SF at PLS  
RH P1 RC at PLS

11, 30, 60

Information Available to the Operator

Event

Time

Reference

During the period 05:57:00 (0253:32) thru 07:45:00 (1145:32), the operator attempted to condense the steam in the Reactor Coolant System by maintaining high pressure injection and controlling the Reactor Coolant System pressure at approximately 2100 psig by cycling RC-V2 (Figure 4). The Reactor Building pressure and temperature reflected the cycling of RC-V2 (Figure 45).

MR T; SC at PL25

The Auxiliary Building Air Exhaust Fans stopped.

SC and ST at PL25

Aluminum radiactivity levels in Dole 2 control room required evacuation of all but essential personnel.

4, 8a

Pressurizer heater groups 1 and 2 tripped. Seven pressurizer heater groups were available at this time.

7a

Pressurizer heater groups 1 and 2 re-energized making 9 heater groups available.

7a

The Auxiliary Building Air Exhaust Fans restarted.

SC and ST on PL25

8c

Personnel in Dole 2 control room were required to wear respirators due to increased airborne radioactivity levels.

Fans S; and ST at PL25

The operator started the Fuel Handling Building Air Exhaust Fans. Control Room Intake Port Radiation Monitor (RP-P-220) level decreased to below 100 counts per minute.

Radiation Monitor SC and MW at PL12

W, 8b

POOR ORIGINAL

542 055

Time	Event	Information Available to the Operator	Reference
07:40:00 (1140:57) Approximate	<p>The Station Manager directed the operator to open the Electric-Reset Back Valve (RC-V2) and the Pressurizer Spray Valve (RC-V1) to rapidly depressurize the Reactor Coolant System and activate the Core Flood System while High Pressure Injection was maintained (Figure 17). This was done after the operator observed no evidence of natural circulation while the Reactor Coolant System pressure was above 2000 psig. The reduction in Reactor Coolant System pressure was also done to approach conditions which would allow the Decay Heat Removal Pump 1A and 1B (DR-P-1A and DR-P-1B) to be put into service.</p>	<p>RC-V2: ST at P14 RC-V1: ST at P14</p>	1, 6, 8a
07:41:37 (1142:14)	<p>The Operator bypassed Engineered Safety Features channels A and B to prevent actuation of High Pressure Injection during the Reactor Coolant System depressurizations.</p>	<p>ESF Bypass: ST at P01. AP norm/test (Delay = 144 minutes)</p>	2a, 9
07:43:54 (1144:21)	<p>Pressurizer heater pumps 1 and 2 tripped and reenergized after 2 seconds.</p>	<p>ST at P14. AP norm/trip (Delay = 145 minutes)</p>	2a
07:44:23 (1145:00) Approximate	<p>The Auxiliary Building Air Exhaust Fans stopped.</p>		
07:50:16 (1150:53)	<p>Pressurizer heater pumps 1 and 2 tripped. Steam Pressurizer heater pumps were available at this time.</p>	<p>ST at P14 AP norm/trip (Delay = 145 minutes)</p>	2a
08:11:26 (1117:03)	<p>Core Flood Tank 1A (CF-T-1A) high level alarm was received. The level was 13.32 feet.</p>	<p>AN and MP at P18 AP norm/high (13.3 feet) (Delay = 150 minutes)</p>	2a

POOR ORIGINAL



Information Available To The Operator

Time Event Reference

08:05:00  
(12:08:17)  
The East Operated Emergency Main Steam Dump Valve (ES-VIA) was shut at the request of corporate management in response to concern expressed by the state government.

HR (valve demand setpoint) at PLS

08:11:06  
(12:14:33)  
The operator started Decay Heat Removal Cloned Cooling Pumps 1A and 1B (DR-P-1A and DR-P-1B) in preparation for eventually placing the Decay Heat System in service.

ST at PLS and PLS, HR(P) HIGH at PLS, HR(A) at PLS,  
AP norm/trip and on/off (delay = 155 minutes)

08:17:00  
(12:20:17)  
Approximate  
Reactor Coolant System pressure reached 600 psig which is the normal psi pressure maintained in the core flood tanks.

HR and SC at PLS

08:54:56  
(12:58:13)  
Core Flood Tank 1A (CF-1-1A) normal level alarm was received. The level was 13.13 feet. This indicated that the Core Flood System injected a small amount of water into the Reactor Coolant System.

AM and HR at PLS

AP norm/high (13.3 feet) (delay = 150 minutes)

09:04:10  
(1:07:55)  
The operator stopped Reactor Coolant Backup Pump C (DR-P-1C) and returned the Backup System to initial one pump operation.

AM at PLS, SC and HR(A) at PLS

AP norm/trip and norm/off (delay = 150 minutes)

09:15:00  
(1:18:37)  
Approximate  
The operator shut the Electromechanical Relief Block Valve (RC-V2).

ST at PLS

09:49:23  
(1:52:00)  
Approximate  
The Auxiliary Building Air Exhaust Fans restarted momentarily and then stopped.

SC at PLS

09:59:53  
(1:59:20)  
The operator opened the Electromechanical Relief Valve (RC-R2) and a hydrogen detonation occurred in the Reactor Building. Hydrogen gas released in the reactor coolant and hydrogen gas generated from the reaction between zirconium fuel cladding and the reactor coolant

**POOR ORIGINAL**  
ST at PLS

PL, 1, 2, 3, 4, 5, 6, 7, 8, 9

Information Available to the Operator

Event

Time

had collected in the Pressurizer. This gas had been vented through the Electrostatic Filter Valve (M-47) to the Reactor Coolant Drain Tank and returned to the Reactor Building through the Drain Tank Purge Discharge (M-42b) which had been braked. The hydrogen concentration eventually reached an explosive mixture. It is believed the detonation was a result of a set of RC-17 contacts tripping when the operator opened the valve.

Explosion Safety Evacuation activation occurred on high-high reactor building pressure. (Figure 45). The setpoint is 28 psig. This is the result of a 28 psig building pressure, spurious from the hydrogen detonation. Reactor Building Isolation and Containment Spray were activated. Reactor Coolant Makeup Pump C (RM-F-1C), started at 09:49:46 (1370:23) and Reactor Building Spray Pumps A and B (RS-F-1A and RS-F-1B) started automatically.

Reactor Building Spray Valves (RS-VIA and RS-VIB) opened. Reactor Coolant Pumps 1A and 1B (RC-F-1A and RC-F-1B) high inlet air temperature alarms annunciated and Pressurizer Safety Valves (RS-R1A and RC-R1B) high discharge line temperature alarm annunciated.

The operator stopped Reactor Coolant Makeup Pump C (RM-F-1C). Pressurizer heater Pump A tripped causing 6 heater pumps available.

09:49:46  
(1370:21)

55F: AH at P1.1, SF at P1.3 and P1.13  
AF norm/act (delay = 159 minutes)

RM-F-1C: AH at P1.8, HW(A) and SF at P1.3  
AF norm/act (delay = 159 minutes)

RS-F-1A/1B: SF at P1.13 and P1.15  
AF norm/act (delay = 159 minutes)

SF at P1.13 and P1.15

RC-F: AP norm/high (172 F) (delay = 161 minutes)

RS-R1A, B: AP norm/high (delay = 161 minutes)

**POOR ORIGINAL**

AH at P1.8, SF and HW(A) at P1.3

AF norm/act (delay = 162 minutes)

SF at P1.4

AF norm/act (delay = 160 minutes)

09:49:50  
(1370:27)

09:49:50  
(1370:27)

09:49:58  
(1370:35)

09:50:24  
(1371:01)

09:50:40  
(1371:17)

Reference

Information Available to the Operator

Event

Time

2a

HR(A), HR(F) and ST at FL3, ST at FL4, AH at FL4

The operator stopped Reactor Building Spray Pumps A and B (RS-P-1A and RS-P-1B). RS-P-1A and RS-P-1B were operated for approximately 5 minutes and 60 seconds.

09:55:40  
(1356:07)

2a

AP norm/trip (Delay = 160 minutes)

Core Flood Tank 1A (CF-T-1A) high water level alarm was received. The level recorded was 13.72 feet. One minute later, 09:57:26 (1358:03), a normal signal was received and a level of 12.05 feet recorded. This indicated a significant discharge of water from Core Flood Tank 1A to the Reactor Coolant System.

09:56:26

Note: Over the next 150 minutes similar level changes in the Core Flood Tank 1A were noted indicating periodic discharge of water from Core Flood Tank 1A into the Reactor Coolant System.

2a

ST at FL3 and FL4, HR(A) at FL3

The operator stopped Decay Heat Pumps A and B (DH-P-1A and DH-P-1B). The Reactor Coolant System pressure was never low enough to put the Decay Heat System in service.

09:56:50  
(1357:35)

11

ST at FL4

The operator opened the Electromechanical Relief Check Valve (RC-92).

10:00:00  
(1400:37)  
Approximate

ST at FL4  
AP norm/trip (Delay = 156 minutes)

Pressurizer heater groups 1 and 2 returned to an operable condition.

10:05:25  
(1406:02)

2a

ST at FL4

Pressurizer heater groups 1 and 2 tripped.

10:07:19  
(1407:56)

AP norm/trip (Delay = 156 minutes)

Reactor Coolant System Loop A hot leg temperature decreased to within the instrumentation range (Figure 22). This was the result of the alarm in Loop A hot leg condensing.

10:26:18  
(1426:55)

ST at FL4 and FL10, HR at FL4, AH at FL4

542 059



Information Available to the Operator

Time Event

10:29:13  
(14:10:00)  
Approach to

At the request of the State government, the Vice President of  
Commission traveled to the Government's office to report the  
Plant Status. He was accompanied by the Test-Operation Division  
Station Superintendent and Bill Z Technical Superintendent.  
The necessary Director's signature was directed to maintain the  
plant in a stable condition during their absence. The Station  
Superintendent carried a remote logging device to permit him to  
be alerted, if necessary.

10:31:25  
(14:12:07)

The operator started Reactor Coolant Backup Pump C (RUC-F-1C).  
Reactor coolant pressure was approximately 440 psig.

RU-F-1C: AM at PIA, HR(A) and ST at PIA

AP norm/stop (delay = 173 minutes)

RC-F: RM and SC at PIA

10:32:46  
(14:13:11)

Pressurizer heater pumps 1 and 2 returned to an operable  
condition.

ST at PIA

10:34:29  
(14:15:06)

The Reactor Coolant System Loop A hot leg temperature increased  
beyond the range of the instrumentation when High Pressure  
Injection was directed to Loop B hot leg (Figure 22 and 27).

SC at PIA and PIAO, RM at PIA, AM(HP) - 612 (1) at PIA

10:35:55  
(14:16:17)

The operator stopped Reactor Coolant Backup Pump C (RUC-F-1C).

RU-F-1C: AM at PIA, HR(A) and ST at PIA

AP norm/stop (delay = 113 minutes)

10:37:17  
(14:17:56)

Pressurizer heater pumps 1 and 2 tripped.

ST at PIA

AP norm/stop (delay = 105 minutes)

10:39:29  
(14:20:06)

Reactor Coolant System Loop A hot leg temperature decreased  
to within the instrumentation range. This was the result of the  
steam in Loop A hot leg again circulating when High Pressure

SC at PIA and PIAO, RM at PIA, AM(HP) - 612 (1) at PIA

POOR ORIGINAL

Time Event Information Available to the Operator Reference

Injection to Loop A hot leg was re-established.

10:39:51  
(1546:28)  
Process/level indicator pumps 1 and 2 returned to an operable condition.

ST at P1A

The Auxiliary Building Air Exhaust Fan started and ran for approximately 30 minutes.

SC at P12S

Temperature level started decreasing from 370 inches to 180 inches over a period of 40 minutes (Figure 10).

SC AT P1. A, AH (High/High) = 315 inches, High = 209 inches, Low = 210 inches and Low/Low = 80 inches) at P1R.

The nitrogen radioactivity level in Unit 2 Control Room had reduced to a level such that personnel were permitted to remove respirators.

11:09:21  
(1548:00)  
Approximate

The operator reset the Electromechanical Relief Stack Valve (RC-V2).

11:12:00  
(1548:37)  
Approximate

ST at P1A

Reactor Coolant System Loop A cold leg temperature started to increase from 200F to 400F indicating the occurrence of some natural circulation in Loop A (Figure 22)

11:12:00  
(1548:07)  
Approximate

SC at P1R

The Auxiliary Building Air Exhaust Fan stopped.

11:14:23  
(1548:00)  
Approximate

SC at P12S

The operator started Reactor Coolant Makeup Pump C (MU-P-10) to stop the rapid fall in the Pressurizer level.

11:18:34  
(1549:13)  
Approximate

AH at P1R, AH(A) and ST at P1A

AP norm/stop (Delay = 04 minutes)

Pressurizer level stopped decreasing at 180 inches and started increasing, setting off scale during the next hour (Figure 10).

11:24:00  
(1549:37)  
Approximate

SC at P1A

POOR ORIGINAL

542 081 |

Time	Event	Information Available to the Operator	Reference
11:28:12 (1576:49)	The operator stopped Reactor Coolant Loop Pump C (RM-P-10).	AN at 11R, RM(A) and ST at P1.1 AP norm/trip (Delay = 05 minutes) ST at P1.4 AP norm/trip (Delay = 05 minutes)	20
11:28:52 (1576:29)	Pressurizer heater pumps 1 and 2 tripped.		20
11:32:37 (1581:14)	The operator started Reactor Coolant Loop Pump C (RM-P-10) to raise the pressurizer level.	AN at 11R, RM(A) and ST at P1.1 AP norm/trip (Delay = 05 minutes)	20
11:35:40 (1586:25)	The operator stopped Reactor Coolant Loop Pump C (RM-P-10).	AN at P1R, RM(A) and ST at P1.1 AP norm/trip (Delay = 05 minutes)	20
11:36:00 (1586:37) Approximate	The operator started filling Steam Generator B to 97% on the operating pumps to induce additional cooling of the Reactor Coolant System. This level was reached at 12:00:00 (1600:37) (Figure 39).	SC operate level at P1.4 and P1.5	1
11:45:17 (1595:56)	Pressurizer heater pumps 1 and 2 returned to an operable condition.	ST at P1.4	20
12:14:23 (1617:00) Approximate	The Auxiliary Building Air Exhaust Fans restarted and remained on throughout the remainder of Shift 2A.	2A: at P1.17	20
12:36:00 (1636:37) Approximate	The operator opened the Electromechanical Bypass Block Valve (BE-V2).	ST at P1.4	11
12:48:00 (1648:00) Approximate	Pressurizer level indication rose on scale (Figure 30).	ST at P1.4	20

FOOT ORIGINAL



Information Available to the Operator

Time

Reference

11:07:21  
(170:00)

The operator started Condenser Vacuum Pump IC (VA-F-IC) in an attempt to re-establish vacuum. The auxiliary boiler had been returned to service and was supplying Kland sealing steam to the main turbine.

ST at 1117

AF on/off (Delay = 0 minutes)

11:11:40  
(171:57)

The operator started Condenser Vacuum Pump IA (VA-F-IA).

ST at 1117

A' on/off (Delay = 0 minutes)

PLANT STATUS

All Reactor Coolant Pumps (RC-F-1A, RC-F-2A, RC-F-1B and RC-F-2B) were stopped. Steam/pan existed in the vessel head and Loop B hot leg. The Loop A hot leg steam was collapsed and natural circulation flow established in this loop. Condenser vacuum was re-established after the auxiliary steam boiler was returned to service. Steam Generator A was steaming to the condenser and Steam Generator B was isolated. The Electromagnetic Relief Block Valve (RC-V2) was open, keeping the Reactor Coolant System depressurized to 650 psig. (Figure 12). Venting through the Electromagnetic Relief Valve (RC-R2) to the reactor building resulted in a hydrogen concentration increase and subsequent detonation which caused a 20 psig Reactor Building pressure pulse. Attempts to use the Core Flood System to cool the core over the last six hours had resulted in limited success. The reactor core was being cooled by (1) Steam Generator A steaming, (2) High Pressure Injection flow into the Reactor Coolant System and then to the Reactor Building floor via the Electromagnetic Relief Valve (RC-R2) and (3) Core Flood Tank A partial discharge.

POOR ORIGINAL

542 063

Information Available to the Operator

Event

Time

1, 11, 60, 6, 10

20, 10

20

20

20

20

20

20

20

20

The operator shut the thermocouple Helled Blank Valve (HT-27) in an attempt to reduce the remaining stress in the Reactor Coolant System by increasing Reactor Coolant System pressure (Figure 12).

The operator started Reactor Coolant Makeup Pump C (RC-M-10) to further increase Reactor Coolant System pressure.

Pressurizer heaters groups 1 and 2 stopped.

Pressurizer heater groups 1 and 2 return to an operable condition.

The operator stopped Reactor Coolant Makeup Pump C (RC-M-10) to allow the rapid increase in Reactor Coolant pressure.

Reactor Coolant System pressure reached 2350 psig (Figure 12).

The following radiation monitors indicated on scale and were decreasing.

- (a) Reactor Building Large Hall Area radiation monitor (RP-R-2236)
- (b) Auxiliary Building Access Corridor radiation monitor (RP-R-2332)
- (c) Waste Removal Storage Area radiation monitor (RP-R-2318)
- (d) Fuel Handling Building Exhaust Duct Area radiation monitor (RP-R-1768)

SC at P14

HM-F-10: AH at P14, BM(A) and ST at P14

HM-F: DR and SC at P14

SC at P14

AP normal/stop (delay = 0 minutes)

SC at P14

HM-F-10: AH at P14, BM(A) and ST at P14

AP normal/stop (delay = 0 minutes)

HM-F: DR and SC at P14

DR and SC at P14, AH (Low/High = 1900 psig)

Low = 2055 psig and High = 2400 psig) at P14

AH, BM and SC at P14

POOR ORIGINAL

502 004

Information Available to the Operator

Time Event

The Fuel Handling, holding radiation monitor (HR-R-215) and Control and Control Holding Control Radiation Monitor (HR-R-216) were steady about 10 counts per minute.

The operator started Reactor Coolant Makeup Pump C (RM-R-10). F

AM at FIA, HR(A) and SF at F13  
AF norm/trip (Delay = 0 minutes)

The operator started Reactor Coolant Pump IA (RC-R-1A) and after approximately 10 seconds stopped the pump. This was done to verify

RC-R-1A ST, HR(A) and HR(F) at F14.  
AU (trip) at F1R

the pump starting current was correct. Monitor Coolant System pressure dropped from 2340 psig to 1440 psig and Loop A cold leg temperature decreased from 400F to 270F (Figures 12 and 22).

AF norm/trip (Delay = 0 minutes)  
RC T, SF at F110  
RC F1 HR and SC at F1A

The operator stopped Reactor Coolant Makeup Pump B (RM-R-10)

AM at F1A, HR(A) and SF at F13  
AF norm/trip (Delay = 0 minutes)

Primary Coolant System Loop B hot leg temperature decreased to within the indication range of 572.6F (Figure 22).

AN(High = 612F), at F1R, SF at F1A and F110

The operator started Reactor Coolant Makeup Pump IC (RM-R-10).

AM at F1R, HR(A) and SF at F13  
AF norm/trip (Delay = 0 minutes)

The operator started Reactor Coolant Pump IA (RI-R-1A). Reactor Coolant pressure dropped from 2740 psig to 1380 psig and eventually stabilized at 1000 psig. The average Reactor Coolant temperature dropped to 270F and eventually stabilized at 250F (Figure 22).

RC-R-1A ST, HR(A), HR(F) and SF(A) at F1A  
AU (trip) at F1R  
AF norm/trip at F1R (Delay = 0 minutes)  
RC T, SF at F110  
RC F1 HR and SC at F1A

POOR ORIGINAL



Title: \_\_\_\_\_ Event: \_\_\_\_\_ Information Available to the Operator: \_\_\_\_\_

17:56:06  
(1956:43)

AB at 11R, 18(A) and 50 at 11)  
AR runs/stop (Delay 2.0 minutes)

17:59:21  
(7130:00)

The operator stopped Reactor Coolant Makeup Pump 1C (RM-1-1C).  
The operator started transferring the contents of the Auxiliary  
Boiling Heat Exchanger Tank (MHT-T-08) pre-incident water, to Unit 1.  
This was done to allow water in the Auxiliary Boiling Pump to be  
placed in this tank.

18:04:21  
(7215:00)

Reactor Coolant Inlet flow to Unit 1. This was due to suspected  
plugging of either the Inlet or outlet, orifices or pollution  
filters.

PLANT STATUS:

20:00:00  
(8000:17)

Reactor Coolant Pump 1A (RC-F-A) was operating with flow to the core  
re-established. The steam present in loops A and B had been condensed;  
however, a non-condensable gas space still existed in the Reactor  
Vessel head. The resistance of the gas space was not known by the  
operator. Reactor Coolant temperature and pressure were stable at  
approximately 240F and 1165 psig with the pressurizer level at 197  
inches. In any event was being removed by steaming Steam Generator A  
to the Hydro Compressor. Steam Generator B was isolated and was  
believed to have a reactor coolant side to feedwater side leak.  
Reactor Coolant Makeup Pump 1A (RM-F-1A) was operating supplying  
Reactor Coolant Pump Seal Injection Flow. Reactor Coolant Inlet  
had been lost and an attempt to repair it was in progress. The  
Reactor Boiling had been isolated except for essential services and  
practical supplies. The Auxiliary and Fuel Handling Buildings had  
at least sufficient materials present. These were being released

POOR ORIGINAL

542 06/

July 16, 1979  
Page 1

Reference

Information Available to the Operator

Event

Time


(through charcoal filters and absolute filters) to the environment through the station vent by their buildings ventilation system exhausts. To handle the water present in the Auxiliary Building Sump, pre-accident water present in the Auxiliary Building Recirculation Tank (WH-1-BB) was being transferred to Tank 1.

**POOR ORIGINAL**

- 58 -

542 067 |


Figure 1  
 TMI-2 Loss of Coolant Accident 3/28/79  
 Summary of Reactor Coolant System Parameters



512 053




Figure 2  
 TMI-2 Loss of Coolant Accident 3/28/79  
 Summary of Steam Generator Parameters



542 060

**Figure 3**  
**TMI-2 Loss of Coolant Accident 3/28/79**  
**Reactor Coolant System Pressure, Saturation Pressure and Pressurizer Level**



542 070

Figure 4  
 TMI-2 Loss of Coolant Accident 3/28/79  
 Reactor Coolant System Pressure and Pressurizer Level






Figure 5  
TMI-2 Loss of Coolant Accident 3/28/79  
Reactor Coolant System Pressure and Saturation Pressure





FIGURE 6



512-0.3

FIGURE 7







FIGURE B



SOLID LINE - STEAM GENERATOR-A LEVEL  
 DASHED LINE - STEAM GENERATOR-B LEVEL  
 DASH/DOT LINE - STEAM GENERATOR-A PRESS  
 DOTTED LINE - STEAM GENERATOR-B PRESS





FIGURE 9

542 070


FIGURE 10



542 077




Figure 11  
TMI-2 Loss of Coolant Accident 3/28/79  
Reactor Coolant System Pressure



542 078

Figure 12  
TMI-2 Loss of Coolant Accident 3/28/79  
Reactor Coolant System Pressure



542 079

FIGURE 13








FIGURE 16

SOLID LINE - REACTOR COOLANT SYSTEM LOOP A FLOW  
DOTTED LINE - REACTOR COOLANT SYSTEM LOOP B FLOW




572 031

FIGURE 15



5/12 012


FIGURE 16



542 083



FIGURE 17



542 084

FIGURE 18

THE LOSS OF COOLANT ACCIDENT 3/20/79  
RCS LOOP A HOT LEG TEMP (SOLID)  
RCS LOOP A COLD LEG TEMP (DASHED)





FIGURE 19



542 036



FIGURE 20






FIGURE 21



542 033


FIGURE 22



542 087



FIGURE 23



542 000

FIGURE 24






FIGURE 25



562 072




FIGURE 26



542 093

FIGURE 27



542 094

FIGURE 20

THI-2 LOSS OF COOLANT INCIDENT 3/26/73  
IN REACTOR COOLANT SYSTEM PRESSURIZED LEVEL RANGE 0-100 PSIG'S






FIGURE 29






FIGURE 30



542 097


FIGURE 31



542 073




FIGURE 32



542 090

FIGURE 33



542 100

FIGURE 34

UNIT-2 LOSS OF COOLANT ACCIDENT 3/20/79  
STEAM GENERATOR A SHUT UP LEVEL ISOLATION STEAM GENERATOR B SHUT UP LEVEL ISOLATION







FIGURE 35



542 102

FIGURE 36




FIGURE 37








FIGURE 30

111-2 LOSS OF CONTROL ACCIDENT 3/20/79.  
STEAM GEN OPERATING LEVEL PROFILES



542 105

FIGURE 39



542 106

FIGURE 40







FIGURE 41



542 103

FIGURE 42




FIGURE 43







FIGURE 44



542 111

Figure 45  
 TMI-2 Loss of Coolant Accident 3/28/79  
 Reactor Building Temperature and Pressure






Figure 46  
TMI-2 Loss of Coolant Accident of 3/28/79  
Intermediate and Source Range Nuclear Instrumentation



5/2 113



Figure 47  
 TMI-2 Loss of Coolant Accident of 3/28/79  
 Intermediate and Source Range Nuclear Instrumentation



51  
 52  
 11

Figure 48  
TML-2 Loss of Coolant Accident 3/28/79  
Computer Alarm Printer Lag Time






Figure 49  
TMI-2 Loss of Coolant Accident 3/28/79  
Emergency Feedwater Pump Discharge Pressures



542 115



Figure 50  
 TMI-2 Loss of Coolant Accident 3/28/79  
 TMI-2 Pump Operating History



**POOR ORIGINAL**


542 117

Note 1 Normally one pump (RCP 1A or 2A or 2B) is in combustion operation  
 the computer print out shows information only that both were  
 tripped at 0310

Note 2 Computer print out shows 1 trip for pumps WRP 1A and 1B  
 in conjunction with control room operator if not listed that  
 these pumps were started and stopped 5 to 6 times between  
 0300 and 0345

X X Would not Start  
 X X (X means for short period of time less than 15 minutes)  
 X Start X Stop

Figure 5)



542 118

FIGURE 52







FIGURE 51



542 120

Figure 54  
 TMI-2 Loss of Coolant Accident 3/28/79  
 Control Room Panel Layout






FIGURE 55



542 122




FIGURE 56



542 123

FIGURE 57



542 124

II. RECOVERY ORGANIZATION

Included in this section is updated information concerning the Waste Management Activities (WMA) Organization.

5/2 123



For the period of June 1, 1979 through June 30, 1979 the following changes have been incorporated within the TMI Unit 2 Recovery Organization.

#### THREE MILE ISLAND RECOVERY ORGANIZATION - JUNE 1979


As a result of the increased emphasis on the radioactive waste accumulation on-site, the Waste Management Activities Group has been reorganized. Three distinct functional groups are now in effect. The Decontamination Group has immediate responsibility for cleanup of surface contamination in the Auxiliary and Fuel Handling Buildings. The Processing Group consolidates the existing liquid and gas processing teams and is responsible for processing waste to the point of an acceptable product for disposal. The Disposal Group is responsible for packaging, transportation, on-site staging, off-site shipping, and disposal of all forms of radioactive waste generated on-site.

The Technical Functions Group of Waste Management remains intact, with overall responsibility for technical planning and integration of the three new groups. This group is also responsible for the collection, analysis, and dissemination of all technical data pertaining to waste activities.

Exhibit 1 is the new Waste Management Activities organizational chart.

The remainder of the Recovery Organization remains as reported last month.

542 120



LEGEND

- FUNCTIONAL DIRECTION & RESPONSIBILITY
- TASK ASSIGNMENT & COORDINATION
- TECHNICAL GUIDANCE & CONTROL
- DUAL FUNCTION & RESPONSIBILITY

WASTE MANAGEMENT ACTIVITIES ORGANIZATION CHART

542 127

### III. PLANT MODIFICATIONS

Included in this section are updated and amended subsections from the June 18, 1979 Second Interim Report. Changes from the previous report are denoted by change bars in the right hand margin and Rev. 2 on the bottom right hand corner of the page. Subsections from the June 18, Second Interim Report which have not had any changes are not included in this report.



## B. Auxiliary and Fuel Handling Building Supplementary Air Filtration Systems

### 1.0 System Function and Design Objectives

Radioactive iodine, released from the Reactor Coolant System during the TMI Unit 2 accident, was transferred into the Unit 2 Auxiliary and Fuel Handling Buildings. Immediate change out of the Auxiliary and Fuel Handling Building charcoal filter trains was not feasible because of the high radiation and contamination levels in the filter areas. As a consequence of the I-131 release rate, it was decided to construct a supplementary air filtration system to reduce off-site releases.

The function of the system is to filter radioactive particles and absorb iodine which has passed through the normal filtration system in the building ventilation system.

### 2.0 System Description

The system interfaces with the Auxiliary Building HVAC System, Fuel Handling Building HVAC System, and the Service Building HVAC System.

Discharge monitoring for the supplementary system is provided at each discharge point.

### 3.0 System Operation

A description of the system's operation is completed. Existing plant system's component functionality is being assessed. The impact of this program on the system's operation will be addressed and any changes in the system's operation will be included in a subsequent report.

### 4.0 System Status

Engineering Complete

Construction Complete

System description, flow diagrams, operating procedures, are complete. An operating and failure modes analysis has been prepared.

All four (4) trains are operable. The stack is capped. Present operation is with three (3) trains.

The operating procedure, which reflects the system operation description, is being reviewed by the NRC Site Staff.

POOR ORIGINAL

## D. Fuel Pool Waste Storage System

### 1.0 System Function and Design Objectives

This Fuel Pool Waste Storage System is to be used for temporary storage of liquid waste. These tanks will add approximately 110,000 gallons to the present storage capacity of the plant, and are located within the "A" spent fuel pool. These tanks will be filled with liquid waste from both the Reactor Building Sump and the Miscellaneous Waste Hold-Up Tank. This system enhances the capability of the plant to move and process radioactive waste.

### 2.0 System Description

The system consists basically of upper (4 at 15,000 gallons each) and lower (2 at 25,000 gallons each) tanks, forming two separate storage areas. Either storage area is capable of being filled from either the Reactor Building Sump or the Miscellaneous Waste Hold-Up Tank, and each has level indication. The tanks are protected from over-filling by automatically closing the feed valve when the storage area is nearly full. Provisions have been made to both flush the piping system after completion of the pumping operation, and to drain the piping system as required.

The vents from the tanks and the stand pipes are directed through a dryer and a charcoal filter to remove moisture and iodine before proceeding to the fuel pool ventilation system. The tanks and vent system is protected by a relief valve which vents through a parallel set of dryers and charcoal filters.

The tanks will be emptied as necessary by steam ejectors. Two ejectors are permanently installed in each stand pipe.

### 3.0 System Operation

Water is transferred from the Reactor Building Sump or the Miscellaneous Waste Storage Tank to the tank farm. After either the lower set of tanks or upper set of tanks is full the level controllers automatically close the air operated inlet valves.

Air forced from the tanks during the filling process is vented to a charcoal filter & dryer to remove moisture and iodine. This air is then piped to the Fuel Pool Ventilation System.

The steam ejectors give the capability to transfer waste water from the tank farm to the Miscellaneous Waste Storage Tank or Sump or Red Waste System, from the upper tanks to the lower tanks in the tank farm (or vice versa) or to recirculate the water in the tanks.

A high temperature alarm and interlocking switch to close the steam control valve, is installed in the tank vent line to prevent damage to the filter/dryer units during use of the ejectors.

542 130

#### 4.0 System Status

The system is essentially complete with the exception of the steam eductors. The eductors are undergoing design modifications to insure safe, reliable operation. Electrical submersible pumps are being fabricated for each stand pipe should a backup means of pumping water from the tanks be required.



## E. Upgraded Decay Heat Removal System

### 1.0 System Function and Design Objectives

Future operation of the existing decay heat removal (DHR) system may result in radiation levels possibly ranging up to 500 Rads per hour in the vicinity of the system fluid components. This condition would severely limit personnel access for routine surveillance, operation, and maintenance. The upgraded DHR system consists of a program intended to identify, evaluate, and implement modifications necessary to ensure the integrity and reliability of the system in a radiation environment, substantially exceeding the original design basis, for up to one year of operation.

### 2.0 System Description

Proposed DHR system modifications include additional decay heat vault shielding, a remote TV monitoring system, modified DHR pump and motor bearing oilers, a vibration monitoring system, and associated operating and testing procedures.

Vault shielding will be provided by lead bricks assembled in a steel support frame. This will reduce the ambient personnel radiation exposure levels to "as low as reasonably achievable" (ALARA) in the accessible area above the vault. Radiation surveys will be made during initial DHR system operation and periodically thereafter to determine shield effectiveness.

The TV monitoring system will provide remote surveillance capability for DHR system operation and maintenance. Two independent systems are provided, one for each vault. Each system includes a radiation-tolerant, closed-circuit television with remote controls. Specific operations to be monitored include pump and motor bearing oil level, pump packing leak-off, remote oil fill, and pump venting.

DHR pump and motor bearing oiler modifications will provide for increased oil storage capacity, a means for remotely reading oil levels, and to permit feeding of oil to the bearings.

Provision for remote venting of the pumps is also provided.

Provisions will be made for monitoring pump vibration and loose parts in the system. This is intended to provide early indication of pump and motor degradation, loose parts in the system (particularly at the heat exchanger tube inlet), and changes in flow patterns due to partial line blockages.

Monitoring and control for these modifications will be provided from the fan room at elevation 322 in the service building.

### 3.0 System Operation

These modifications to the DHR will not appreciably alter system operation.

#### 4.0 Status

The TV monitoring system, the bearing oil tanks and piping, and pump venting arrangement are installed and operational. The shielding bricks and support materials are on site. An operating test plan for the DFR system has been developed and is under review.

The installation of vault shielding is completed, except that the cover is not on since access is still necessary.

542 135

## F. Steam Generator "B" Closed Loop Cooling System

### 1.0 System Function and Design Objectives

In order to provide a high pressure, closed cooling loop for water-solid steam generator "B", a system utilizing new equipment must be installed. The closed loop must remove the decay heat from the core plus the added heat load from one reactor coolant pump. To minimize the possibility for contamination of the closed loop, the system must be operated at a higher pressure than the reactor coolant system. The heat transferred to the closed loop will ultimately be rejected to the river. The system is intended to provide backup decay heat removal capability should the present steaming from steam generator "A" be discontinued.

### 2.0 System Description

The system consists of a new heat exchanger, pump, surge tank, piping and valves. The hot water leaving the steam generator will pass through the tube side of the new heat exchanger and return to the steam generator via the new pump. A pressurizer surge tank will maintain the steam generator secondary side pressure above the primary coolant system pressure.

The shell side of the heat exchanger is supplied with cooling water from the secondary services closed cooling water system which, in turn, will be cooled by water from the nuclear services river water pumps piped to the turbine building via the secondary services river water piping.

The new pump discharge piping is connected to the existing feedwater piping downstream of the main feedwater pumps, and the heat exchanger inlet piping is connected to the drain pot on the main steam line between the main steam isolation valve and main turbine stop valves.

### 3.0 System Operation

A detailed description of the system's operation is given in the operating procedure for Long Term OTSG "B" Cooling System.

A procedure has been completed to fill the "B" Steam Generator using the condensate pumps. An additional procedure to flush and vent the emergency water line has been completed as part of the fill procedure for the OTSG.

### 4.0 System Status

The system is installed and the preservice testing is completed.

The flushing and venting of the feedwater line is ready to be started upon approval of procedure.

542 134



## G. Portable Disposable Demineralizer

### 1.0 System Function and Design Objectives

Steam Generator "3" is presently contaminated with radioactive (fission) products. To minimize exposure to personnel and minimize the potential for contamination of the turbine building, this fluid must be cleaned up before the closed loop cooling system is placed into long term service. This cleanup capability will be provided by a portable disposable demineralizer (PDD) sub system. After the initial cleanup is completed, water quality can also be maintained by passing the closed loop cooling system flow through portable demineralizers.

### 2.0 System Description

The PDD sub system is located along the north wall of the turbine building basement. The system includes a disposable demineralizer approximately 18 inches in diameter, 30 inches in height, and having a 1.5 cubic foot resin capacity. The demineralizer will be connected to the steam generator "3" closed loop cooling system, and receives process water from the new closed loop pump discharge while returning the effluent to the pump suction. The number of demineralizer changes that will be required will depend on the water quality and activity.

The design pressure of the available demineralizers is 30 psig. Therefore, in order to protect the vessels, the PDD sub system also includes a pressure reduction valve, a pump, and safety relief facilities necessary to process the fluid while minimizing the potential for radioactive release to the environment.

The demineralizer is housed in a portable shielded cask. All operation, maintenance, and demineralizer removal and replacement will be performed in accordance with existing health physics requirements.

### 3.0 System Operation

A detailed description of the system's operation is given in the operating procedure for Long Term OSTG "3" Cooling System.

### 4.0 Status

The demineralizers and shield casks have been fabricated and installed.

The piping system and pump have been installed and is operational.

It is currently being used for wet layup of Long Term "3" Cooling System.

## J. Steam Generator "A" Closed Loop Cooling System

### 1.0 System Function and Design Objectives

In order to provide a high pressure, closed cooling loop for water-solid steam generator "A", a cooling system utilizing new equipment has been proposed. The closed loop would remove the decay heat from the core plus the added heat load from one reactor coolant pump. To minimize the possibility for contamination of the closed loop, the system would be operated at a higher pressure than the reactor coolant system. The heat transferred to the closed loop would be rejected to the river. The system would be intended to provide primary decay heat removal capability redundant to the steam generator "3" closed loop cooling system.

### 2.0 Description

The system will consist of a new heat exchanger, pump, surge tank, and piping and valves. The hot water leaving the steam generator would be cooled in the shell side of the heat exchanger and returned to the steam generator by a new pump. A pressurized surge tank would maintain the steam generator secondary side at a minimum pressure greater than the primary coolant system pressure.

The tube side of the heat exchanger would be supplied with cooling water from the nuclear services river water pumps piped to the turbine building via installed secondary services river water piping.

The new pump discharge piping would be connected to the existing feed-water piping downstream of the main feedwater pumps. The heat exchanger inlet process piping would be connected to the main steam turbine bypass line between the isolation valve and the control valve at the condenser.

### 3.0 System Operation

A description of the system's operation is available. Should the system be constructed, the operations description will be provided in a subsequent report.

### 4.0 System Status

Design is completed. The pump and heat exchanger have been purchased and are on site. No piping, except the two tie-in pieces, have been fabricated. The procurement, fabrication, and installation have been placed on hold, and no further construction is anticipated.

## L. Alternate Decay Heat Removal System

### 1.0 System Function and Design Objectives

The proposed Alternate Decay Heat Removal (ADHR) system augments the two existing DER systems and the proposed water solid secondary/natural circulation system as backup to steam generator "A" steaming. An Integral Decay Heat Closed Cooling Water (DECCW) system is included to transport heat from the ADHR cooler and the ADHR pump seal coolers to the nuclear services river water system. Connection points are also provided outside the fuel handling building to connect other dedicated liquid waste processing systems.

The specific function of the ADHR system is to remove decay heat such that the reactor coolant system can be brought to and maintained at a cold shutdown condition. With the exception of gross core flow restrictions, this system is intended to provide sufficient core flow to maintain reactor coolant subcooled.

### 2.0 System Description

The two ADHR pumps and a new heat exchanger will be mounted on a skid located outside the west wall of the fuel handling building. Three pipe runs will be installed from the existing DER system piping within the fuel handling building and penetrate the fuel handling building west wall of a valve vault. The pipe runs will terminate in the valve vault by capping each line. Pick-up to the ADHR skid will be made later if needed. In addition, three capped taps will be provided on the ADHR piping installed outside the fuel handling building. These taps may be used later to connect other dedicated liquid waste processing systems.

Motor control centers and I&C panels for operation of all ADHR system pumps and motor operated valves will be mounted in a control trailer located near the ADHR skid.

The DECCW system provides cooling water to the ADHR system heat exchanger and pump seal coolers. It utilizes a closed loop system to provide a double barrier between the ADHR system and the river water to prevent the direct release of radioactivity to the environment. A radiation detector is provided to monitor the level of radioactivity in the DECCW system at the outlet of the DER cooler. A radiation level indicator with high radiation level alarm is located in the ADHR system remote control room. If radioactivity is detected, operation of the decay heat removal loop and its associated DECCW loop can be halted and the affected decay heat removal cooler isolated. The DECCW system is mounted on a second skid and consists of the DECCW pump, heat exchanger, and surge tank. Both skids will be located outdoors at grade level near the west wall of the fuel handling building and adjacent to each other.



### 3.0 System Operation

A detailed description of this system is not yet available; it is expected by July 30, 1979.

### 4.0 System Status

The piping for the ADHR system has been designed, fabricated, and received on site. The skid for the ADHR System with its components, two pumps, heat exchanger, valves and piping is near completion. Motor control centers are on site. The valve vault excavation is completed, shoring is in progress, and piping installation should start this week (July 9, 1979). The electrical trailer is very near completion.

Electrical power and service water connections will not be made until the system is put into service. Tie-in of the ADHR system to the existing plant DHR system is on hold until tie-in authorization.

Piping supports are being designed and fabricated on site. The control trailer wiring, air conditioning and insulation is finished. Piping construction is in progress in the Fuel Handling Building, and is 50% complete. Wall penetrations have been completed. Valve pit design, modified compatible with shoring and piping, should be done by July 13, 1979.

## M. Standby Reactor Coolant Pressure Control System

### 1.0 Systems Function and Design Objectives

High radiation levels and flooding in the reactor building have or could potentially render much of the reactor coolant (RC) system electrical equipment and instrumentation inoperable. With much of the instrumentation inoperable, the RCS should be maintained water "solid". An alternate system of pressure control is required to ensure safe and reliable cooling of the reactor core, should control of the existing system become unmanageable. The standby reactor coolant pressure control (SRCPC) system will ensure reliable core cooling by performing the following function:

- a. Maintain the RC system in a water-solid condition for natural circulation core cooling.
- b. Maintain sufficient available NPSH should RC pump operation be required
- c. Control the quality of the makeup fluid
- d. Maintain pressure within control limits while accommodating thermal and volumetric contractions in RC system inventory.

### 2.0 System Description

The SRCPC system ties into the existing High Pressure Injection lines (see FSAR Figure 9.3-6). RC system pressure is maintained by three surge tanks arranged in series with a pressurized nitrogen blanket over the last tank. A fluid inventory of approximately two thirds of the total tank capacity is sufficient to maintain RC system pressure during sudden RC system inventory reduction transients. A level control valve at the tanks' discharge will prevent nitrogen from entering the RC system.

Long term makeup will be provided by the charging pump taking suction from an atmospheric storage tank. Makeup fluid conditions are adjusted by chemical addition and heating to meet RC system water quality requirements.

The RC system pressure will normally be maintained between 100 and 750 psig during the intended cooldown process. As of April 30, the RC system pressure must be maintained at 600 psig in order to provide letdown flow equal to the RC pump seal injection flow to the system so that the RC pumps can be operable.

The SRCPC makeup system will be operated manually from a local panel during initial operations and from the control room after system automation is complete. Makeup is provided in response to decreasing pressure in the RC system. An alarm will annunciate at the control station when the pressure differential between the RC and SRCPC makeup system reaches or exceeds 50 psi.

512 139

The SRCPC makeup system will prevent gross depressurization on the RC System when operating in a water-solid mode. Over-pressurization protection can be provided by increased letdown resulting directly from RC system pressure increase, letdown with concurrent termination of RC pump seal injection or makeup, opening the pressurizer vent valve, opening the pressurizer electromechanical safety relief block valves, or lifting the pressurizer safety relief valves (the latter two methods are undesirable and will only be considered as a last resort).

### 3.0 System Operation

A preliminary description of this systems operation is now available.

TITLE: Preliminary System Description Task TS-6B Standby Reactor Coolant Pressure Control System, Revision 1, dated May 23, 1979.

### 4.0 Status

Phase I of the SRCPC makeup system is completed and has been hydrostatically tested and operated in recirculation mode. The Phase I will allow local manual operation of the system. The design work to ultimately convert the system to control room operation is being implemented.



## ii. BOP Electrical Power System

### 1.0 System Function and Design Objectives

In the event of failure of normal off-site power sources to the BOP busses, the BOP Electrical Power (BOPEP) system provides an alternate source of power to serve existing components, which previously did not require loss-of-offsite power backup protection and new components that are planned to be used or may be used for decay heat removal from the primary system.

The BOPEP system is completely independent of the existing Class IE busses.

The BOPEP busses are loaded on a 'manual only' basis in accordance with emergency operating procedures.

Modifications of power supplies associated with Steam Generator "A" cooling systems have been given priority of installation with respect to those for the Steam Generator "B" cooling systems.

The testing requirements for the BOPEP systems are to be similar to those of the Class IE systems.

The BOPEP system shall supply power to the following components and associated auxiliaries at one time or another depending upon the specific situations:

- a. Supplementary Air Compressor
- b. Circulating Water Pumps
- c. Condensate Pumps
  - Steam Generator "A" Long Term Cooling Pumps\*
  - Steam Generator "B" Long Term Cooling Pump
- d. New Decay Heat Removal Pump
- e. Secondary System Closed Cooling Water Pumps
- f. Alternate DHR System Pumps\*
  - Secondary Services River Water Strainer
- g. Pressure and Volume Control System Charging Pumps
- h. Chemical Cleaning Building Ventilation Equipment
- i. Pressurizer Heaters

\*Indicates components not currently planned to be put in service.

4. Alternate SWR System (Cooling Water Pump, Temporary Auxiliary and Fuel Handling Building SWR)
5. Fuel Handling Building SWR Fans, Filtration and Heaters
6. Auxiliary Building SWR Fans, Filtration and Heaters
7. Condenser Vacuum Pumps
8. Instrument and control power for above systems.

## 2.0 System Description

The SCFEP system includes two independent power black buses (2-6 and 2-7), each fed by a 1500 kw rated diesel generator, and two circulating water pump buses (2-8 and 2-9) fed by one 15.0 kw line. The loads associated with cooling steam generator "A" are connected to odd numbered buses. Correspondingly, loads associated with cooling steam generator "B" are connected to even numbered buses. The odd and even buses are powered by the gray and white diesel generators respectively and are, therefore, designated as the "gray" and "white" buses.

The diesel generators and associated auxiliary systems are located outdoors just south of the turbine building. Each diesel is a skid-mounted package complete with starting system, fuel injection equipment, and associated instrumentation and controls. The permanently installed fuel oil storage and supply system provides sufficient reserve for one day of rated load operation. In addition, there will be sufficient on-site fuel oil reserve to operate both diesel generators at rated load for the normal time required to obtain fuel resupply plus a secondary reserve.

Suitable fire protection will be provided for the diesel generators and auxiliary systems. This may include a fire wall separating the two fuel oil tanks and diesels of a fire suppression system.

Existing circuit breakers, previously used for condensate booster pumps 21 and 22, have been modified to connect the 2-6 (gray) and 2-7 (white) buses to their respective outboarders. Relays are provided at the buses to shed all loads on loss-of-offsite power. The existing bus transfer schemes that provide continuity of power supply by interconnecting to the other transformer, have been left intact. To accommodate this, the new under-voltage detection schemes include a 10 second delay.

\* Indicates components not currently planned to be put in service.

542 142

The 10.2 kv line supplies power to the circulating water pumps and their associated auxiliaries. This line is powered by a 10.2 kv network which is backed by combustion turbines capable of being energized independently of the 10.2 kv network. The 10.2 kv line has sufficient capacity to start a second circulating water pump while one pump is still operating. However, only one pump is normally required.

Circulating water pumps that disconnected to their breakers can be used to connect the new power supply to buses 1-3 and 2-3 respectively. Bus 2-3 serves pumps 11 and 12 which are associated with steam generator "A" cooling systems. Correspondingly, bus 1-3 serves pumps 13 and 14 which are associated with steam generator "B" cooling systems.

### 3.0 System Operation

The SCED system normally provides standby power capabilities and is not operating. On loss-of-offsite power, the offsite power supply breakers will open and the diesel generators will be started and connected to their respective buses automatically.

Loading on the diesel generators, connection of the 10.2 kv line, and starting of the circulating water pumps will be performed manually from the control room in accordance with established procedures for the various potential plant conditions. For the "gray" and "white" buses, return to normal power is accomplished manually by first opening the diesel breaker and then closing the offsite supply breaker. For the 10.2 kv line, a return to normal power will be controlled manually by closing the normal supply breaker before opening the new supply breaker (not transfer).

The primary control center for the SCED system is the control room control and monitoring capability exists locally for the diesel generators.

**POOR ORIGINAL**

542 143



Initial startup testing will verify proper system and component operability, the adequacy of operating procedures, and ensure adequate performance capabilities of the BOPEP System. Periodic testing will be performed in accordance with procedural requirements and any additional testing and maintenance requirements by the component manufacturers. Periodic testing will verify proper breaker actuation, diesel starting and synchronizing, fuel oil quality, and breaker positions.

#### 4.0 System Status

The work for the upgraded BOP electrical power system is approximately 90% complete.

The following work has not yet been completed:

The fire protection engineering and construction are approximately 50% complete.

Automatic lube oil system for "white" diesel is currently being designed.

## 3. Liquid Radioactive Waste Processing System Title "BRTCOX 21"

### 3.1 System Function and Design Criteria

The system is designed to cleanup radioactive liquids so as to produce water capable of being released from Three Mile Island. Cleanup includes removal of radioisotopes and chemical constituents to comply with Plant Technical Specifications for Water Releases to the Susquehanna River. The design is being optimized with respect to ALARA considerations.

Instrumentation and controls will be provided for monitoring of system performance. Water flows will be monitored where the values are critical to the process and or system safety. Inline monitoring and a comprehensive sampling system will be provided for thorough analysis of system water cleanup performance. Radiation and airborne monitoring equipment will be provided for analysis of activity levels.

Shielding is being provided to minimize exposure related to the operation of this system.

An HVAC subsystem is utilized to cleanup and monitor any gases that might be released from the liquid processing system. It is the goal to minimize gas releases from the system, however, should they occur, they will be cleaned to reduce any releases to the environment. Monitoring of the air exhaust will include to detect any potential radioactive gas. A slight negative pressure is projected to ensure building leakage will be established. The system is being optimized with respect to ALARA considerations.

### 3.2 System Description

#### Liquid Processing

The TMI Station Chemical Cleaning Building is being used to house the system along with the existing tankage and sump existing in that building. Piping and pumps are provided for water movement through cleanup vessels. The system is composed of a pre-filter, two demineralizers and an after filter. The pre-filter and demineralizers will be designed for ease of hookup and disconnect to allow for quick installation and remove, reliable removal.

#### Gas Processing

The primary components are a fan, an air cleaner filter train, and necessary ducting. The main HVAC components located internal to the Station Chemical Cleaning Building, but are installed in their own building.

1451  
1452  
**POOR ORIGINAL**

## 3.0 SYSTEM OPERATION

The Auxiliary Building Emergency Liquid Cleaning System consists of a Vendor supplied liquid radwaste process system which is located in the Chemical Cleaning Building. The system is designed to decontaminate by filtration and ion exchange between 100,000 and 200,000 gallons of radioactive waste water contained in the Auxiliary Building of TMI Unit 2. Contaminated water will be pumped from a connection located on the Miscellaneous Waste Holding Tank (MWHT-2-1) by a pump located in the Chemical Cleaning Building through the ground and into the process system. Yard piping will be enclosed within a ground pipe, the end of which terminates inside the Chemical Cleaning Building.

Decontaminated water will be delivered to the Clean Water Receiving Tank (CC-7-1) for sampling and analysis and pumped to the Liquid Waste Disposal System of TMI Unit 1 or Unit 2 for discharge in various areas, or transferred to the Off-Site Water Receiving Tank (CC-7-1) for recycling through the process system. Capability also exists to discharge to a tank truck.

The Chemical Cleaning Building (CCB) has been made into a low leakage confinement building and provided with an exhaust ventilation system to maintain the building at a negative pressure. HEPA and charcoal filtering is provided in the ventilation system which discharges to a local stack at the roof line of the CCB where all effluent air is monitored for radioactivity.

Normal operation of the processing system will be by remote means except for infrequent operations, such as sampling and chemical addition. All remote system operations are controlled from the TV Monitor Control Building located outside the northwest corner of the Chemical Cleaning Building.

Remote handling of spent resin containers from their position inside the Chemical Cleaning Building to the transport cask and truck are provided.

The system interfaces with the TMI Unit 2 Radwaste Disposal Miscellaneous Liquids System, the TMI Unit 1 Liquid Waste Disposal System, Demineralized Water System and the Service Air System.

## 4.0 Status

The system is essentially complete while undergoing an operability review and testing program. Operator training and qualification is proceeding.

**POOR ORIGINAL**

542 146



## 2. Staging Facilities for Devolatered Resins and Evaporator Bottoms

### A. WC-21 - Interim Solid Waste Staging Facility

#### 1.0 System Function and Design Criteria

Facilities are needed to stage devolatered radioactive resin generated by Epicor I and Epicor II until they can be shipped to a burial site. WC-21 will provide space for interim staging until WC-22, Solid Waste Staging Facility, is complete. Contact readings on the surface of the facility will be less than 1mR/hr.

#### 2.0 System Description

The facility consists of 16-7 1/2' diameter cells and 12-8 1/2' diameter cells to receive 4' x 6' and 6' x 6' resin liners. The cells are to be installed in the Unit 2 cooling tower basins, backfilled for shielding and topped with 1' thick concrete plugs.

#### 3.0 System Operation

The facility has not been constructed as of this report.

#### 4.0 System Status

Construction of the interim solid waste staging facility is nearing completion. Setting of the cell liners, backfilling, and asphalt installation is complete. Caulking of the cell seams has been accomplished, and curing of the caulking will permit application of the cell coating beginning July 2, 1979. Drip pans have been received. Concrete covers have been completed and are being held by the manufacturer until needed. It is anticipated the facility will be operational by July 6, 1979.

The Manitowac crane for handling Epicor liners is on-site and assembled. Metropolitan Edison utility operators are undergoing training on the operation of the crane.

### B. WC-22-Solid Waste Staging Facility

#### 1.0 System Function and Design Criteria

Facilities are required to stage the following radioactive wastes until they can be shipped to a burial site:

- 1.1 Devolatered radioactive resins from Epicor I.
- 1.2 Devolatered radioactive resins from Epicor II.
- 1.3 Devolatered radioactive resins or solidified evaporator bottoms from systems used to process water core radioactive resin that processed by Epicor I or Epicor II.

**POOR ORIGINAL**

## B. WG-10 - Solid Waste Staging Facility (continued)

The sump meets the seismic requirements of Reg. Guide 1.143. Contact readings on the sides of the facility will be less than 0.5 cm/hr and less than 0.5 cm/hr on the top.

### 2.0 System Description

The facility is designed as a modular one. Each module consists of 30" - 36" diameter cells fabricated in concrete and capped with 3' thick concrete plugs. Each cell has a drain line to a sump which will serve three modules. The sump is designed to collect any leakage from liners installed in the cells and meet the seismic requirements of Reg. Guide 1.143.

### 3.0 System Operation

The facility has not been constructed as of this report.

### 4.0 System Status

The design criteria for the solid waste staging facility has been approved by the waste management activity, Metropolitan Edison, and the NRC. Design is proceeding and should be completed by mid-July.

An ECM has been issued to construction for excavation. This will permit construction to start so the schedule of mid-October completion of the facility can be maintained.

All cell liners for the facility have been received. In addition, some of the drain line material has been received; the balance should be received during July. The concrete covers (23 of which will be used on the interim facility) are complete and are being held by the manufacturer until needed.

Design drawings for the transfer cask have been reviewed and approved by the technical support group. Fabrication of the cask has started. The promised delivery date for the cask is July 23, 1979.

A purchase order has been issued for the shield cask transport. The shield cask transport consists of two (2) concentric concrete sewer pipes (total concrete thickness of 15 inches) mounted on a lowboy. This transport will be used to transport liners from the Epicor 2 facility to the staging facilities. The promised delivery date for the shield cask transport is July 13, 1979.

**POOR ORIGINAL**

542 Rev. 2/40

## 5. Nuclear Sampling System

### 1.0 System Function and Design Objectives

This nuclear sampling system is to be used as a temporary liquid waste sampling facility to allow TMI Unit 2 recovery operations to continue without interfering in the normal operations of Unit 1 when that unit is returned to service. It will provide a single controlled station whereby fluid samples may be taken from tanks otherwise inaccessible for local sampling and/or from tanks that require frequent sampling for analyses of chemical and radiochemical content. Included in the sampling scope will be capability for representative samples of Unit 2 Reactor Coolant from the pressurizer steam or water space or upstream of letdown coolers, samples from the three Unit 2 Reactor Coolant Bleed Tanks, Unit 2 Miscellaneous Waste Hold-up Tank and the new Fuel Pool Waste Storage System containing liquid waste from both the Unit 2 Reactor Building Sump and Miscellaneous Waste Hold-up Tank. Provisions shall also be provided in the system for continuous monitoring of boron concentration in the reactor coolant.

### 2.0 System Description

Unit 2 Sample Lines which presently run into Unit 1 sampling area shall be rerouted to a new sample sink to be located in the Fuel Handling Building 305' elevation of Unit 2. In an adjacent room, the so-called "model room" a boronmeter shall be installed.

The system shall provide for adequate recycle, purge and return of waste liquids. Purging of radioactive piping shall be performed prior to installation of new sample lines.

Drainage from the sample sink will be routed to the Fuel Pool Waste Storage System. A shielded bottle to collect drainage will also be provided.

All piping, valves and components of the sampling system will meet the design conditions of the system with which they are associated or will meet 150 psig and 200°F. Primary coolant sampling points will have the design condition of 2500 psig and 670°F up to valve SMS-V-70.

Air exhausted from the sample hood will be filtered through charcoal and HEPA filters and discharged to the Auxiliary Building ventilation system exhaust ductwork.

### 3.0 System Operation

A detailed description of the systems operation is not yet available as design changes are still being made. This description shall be incorporated in a subsequent report.

### 4.0 System Status

The system design is essentially complete. Construction and material procurement is in progress.



#### IV. Radiological Monitoring

This section includes discussion of information compiled for the period of March 28, 1979 through May 31, 1979. The assessment for the period March 28 through April 30 is described in detail in the report submitted June 18, 1979. The results of that assessment are merely summarized and, if necessary, updated or corrected in this report. Changes from the previous report are indicated by change bars in the right hand margin and Rev. 2 on the bottom right hand corner of the page.

542 150

EXECUTIVE SUMMARY  
RADIOLOGICAL MONITORING

542 151

EXECUTIVE SUMMARY  
RADIOLOGICAL MONITORING  
MARCH 28 - May 31, 1979

The results of an assessment of radiation doses to the public due to releases from March 28 through May 31, 1979 from the Three Mile Island Unit 2 accident, based on verified release data and verified radiological environmental data are summarized in the attached table. Virtually all of this dose resulted from releases in the period March 28, 1979 through April 30, 1979. Contributions from May releases were negligible. Doses from radioactivity released in liquid effluents were extremely low. No individual received more than a fraction of a millirem, and the population dose was much less than one person-rem. Doses from airborne effluents are due to noble gas isotopes which deliver whole body doses and iodine isotopes which deliver thyroid doses. Measurements indicate that the maximum individual whole body dose from noble gases was 75 millirem, and the noble gas whole body dose to the 50 mile population was calculated to be about 3300 person-rem. (The figure of 75 millirem for the maximum individual dose differs slightly from the previously reported 83 millirem due to a refinement in the estimate of natural background radiation contribution to the measured dose.) Doses from iodine isotopes in airborne effluents result from inhalation of iodine in air and ingestion of iodine in milk. Calculations and measurements show that no individual received more than about 10 millirem to the thyroid from inhalation, and the calculations indicate the thyroid inhalation dose to the 50 mile population was about 160 person-rem. (The estimate of the maximum individual exposure based on measured air concentrations of Iodine-131 has been revised from 2.7 to 3.7 millirem.) Measurements indicate that the maximum individual thyroid dose from ingestion of Iodine-131 in cow milk was 1.5 millirem. (This dose was incorrectly reported as 2.3 millirem in the previous report.) Calculations show that the population dose from Iodine-131 in milk produced within 50 miles was about 900 person-rem. Average doses to individuals in the population from any isotope in any pathway were very low, less than 2 millirem. The maximum doses to any individual is 75 millirem which is comparable to the difference in natural background radiation dose between Harrisburg, PA and Denver, CO over the period of one year.



TABLE:

Summary of Radiation Doses Due to TMI Unit 2 Accident

March 28 - May 31, 1979

Release Mode	Pathway	Estimated Integrated Dose <sup>a</sup>		
		Maximum (micro) Individual	Population Dose (person-rem)	Organ
Liquid	Drinking Water ( <sup>131</sup> I) <sup>b</sup>	< .0%	< 1	Thyroid
	Fish Ingestion ( <sup>131</sup> I) <sup>c</sup>	.01	<< 1	Thyroid
	Swimming, Boat Inj. & Shoreline <sup>b</sup>	0	0	Thyroid
Airborne	Noble gases in plume	75	(3300)	Whole Body
	Iodine Inhalation	(6.3) 3.7	(160)	Thyroid
	Iodine uptake through cow milk ingestion	1.5	(900)	Thyroid

- a. Doses are based on TLD measurements or measured isotope concentrations in environmental samples except for those in parentheses. Doses in parentheses are based on release data and transport models.
- b. No Iodine <sup>131</sup>I activity detected in more than 95% of river water samples. Concentration in those samples are assumed to be minimum detectable. (366 water samples 3/28-4/30, 420 samples 5/1 - 5/31)
- c. No Iodine <sup>131</sup>I activity detected in any fish samples. Concentration assumed to be minimum detectable

IV. A. OFFSITE LIQUID RELEASES AND DOSES

1. Releases

The releases of radionuclides in liquid effluents to the Susquehanna River have been within expected values as a result of the refueling outage of Unit 1. From March 28, 1979 to April 30, 1979, 10.7 curies of tritium and about 0.3 curies of various activation and corrosion products have been released to the river from both units. (Table IV-A-1). From May 1, 1979 through May 31, 1979, 4.7 curies of tritium and about  $3.7 \times 10^{-2}$  curies of various activation and corrosion products have been released to the river from both units (Table IV-A-1).

The only radionuclide released in significant concentrations and quantities as a result of the accident on March 28, 1979 has been Iodine-131. The total quantity of Iodine-131 released through April 30 is approximately 0.24 curies. Detailed data and discussion regarding the release of Iodine-131 during the period March 28 through April 30 were included in the June 18, 1979 submittal. The total quantity of  $^{131}\text{I}$  released during the period May 1, 1979 through May 31, 1979 is approximately  $5.05 \times 10^{-3}$  curies. The source of most of the Iodine-131 released in May is the Industrial Waste Treatment System, the major source of earlier releases. This system is discussed in the June 18 submittal. May releases are a factor of about 47 lower than releases from March 28, 1979 through April 30, 1979 (Table IV-A-1). Detailed Iodine-131 data from each liquid release in May, 1979 are included in Table IV-A-2. Daily Iodine-131 release quantities are plotted in Figure IV-A-1. Data in this figure for the period March 28 through April 30 were presented in the June 18 report, but are plotted here in a different format. Although the release of Iodine-131 in liquid effluents did exceed normal levels, the levels did not exceed either the Technical Specification release rate limits, or concentration limits in 10 CFR 20.106, averaged over one day.

2. Environmental Measurements

The Radiological Environmental Monitoring Program conducted by Metropolitan Edison Company includes analyses of river surface water, downstream drinking water from treatment plants and aquatic biota. Except for seven samples collected on March 31, April 1 and 2, and May 12, 13, 24 and 25 at station 7G1, the Columbia Water Plant intake, which showed very low levels of Iodine-131 (0.4, 0.72, 0.66, 1.3, 0.57, 0.56, and 1.7 pCi/l) and one sample on April 27 at location 7G2, the Wrightsville Water Treatment Plant which showed 0.49 pCi/l of Iodine-131 no gamma emitting isotopes other than low levels of naturally occurring isotopes were detected. The concentrations of Iodine-131 listed above are only slightly greater than the minimum detectable concentrations. Data from the monitoring program are included in Attachment 1 to the June 18 submittal and are supplemented in Attachment 1 of this submittal.

3. Estimated Offsite Exposures

Radiation doses estimated from the measurements described above are extremely low, a few hundredths of a millirem for a person drinking water, eating fish from the river, or using the river for swimming, boating, or shore line activities. Detailed radiation doses are shown in Appendix C of Attachment 1 to this report.



TABLE IV-A-1  
SUMMARY OF RADIONUCLIDES  
RELEASED TO THE SUSQUEHANNA RIVER

<u>Radionuclide</u>	<u>3/28/79 - 4/30/79</u> Activity (Ci)	<u>5/1/79 - 5/31/79</u> Activity (Ci)
$^3\text{H}$	10.670	4.7
$^{51}\text{Cr}$	3.5E -4	1.64E -3
$^{54}\text{Mn}$	4.11E -4	1.57E -4
$^{58}\text{Co}$	0.022	1.24E -2
$^{60}\text{Co}$	6.9E -3	1.41E -3
$^{95}\text{Nb}$	1.82E -4	5.17E -4
$^{95}\text{Zr}$	4.83E -5	7.22E -5
$^{110\text{m}}\text{Ag}$	1.25E -3	9.37E -4
$^{131}\text{I}^*$	0.235	5.05E -3
$^{131\text{m}}\text{Xe}$	--	7.25E -4
$^{132}\text{I}$	3.44E -4	--
$^{133}\text{I}$	1.4E -4	1.43E -5
$^{133}\text{Xe}$	0.012	7.5E -5
$^{134}\text{Cs}$	2.11E -3	2.18E -3
$^{136}\text{Cs}$	2.7E -4	1.3E -3
$^{137}\text{Cs}$	5.61E -3	4.83E -3
$^{140}\text{Ba}$	5.99E -4	5.43E -3
$^{140}\text{La}$	1.29E -3	4.09E -3

\*  $^{131}\text{I}$  is the only radionuclide of significance released to the river from the Unit 2 accident of 3/29/79. Other isotopes result from routine releases from Unit 1.

542 156

TABLE IV-A-2

LIQUID EFFLUENT RELEASES

3/28/79 to 4/10/79  
(All data refers to I-131)

Start	Stop	Tank	<sup>1</sup> Concentration at Station Discharge ( $\mu\text{Ci}/\text{cc}$ ) (dilution calc.)	<sup>2</sup> Concentration at Station Discharge ( $\mu\text{Ci}/\text{cc}$ ) (grab samples)	$\mu\text{Ci}$ Discharged	Cumulative $\mu\text{Ci}$ Discharged
3/28 0400	3/28 0900	IWTS	$1.6 \times 10^{-7}$	$4 \times 10^{-8}$ at 1100 hrs.	6469 <sup>5</sup>	6,469
3/28 0320	3/28 0655	WECST-B	None		None <sup>3</sup>	6,469
3/29 0015	3/29 1215	WECST-B	None		None	6,469
3/29 1315	3/29 1410	IWTS	$7.5 \times 10^{-10}$		7.5	6476.5
3/29 1610	3/29 1815	IWTS	$7.5 \times 10^{-10}$	$5.4 \times 10^{-10}$ at 1700 hrs.	17.0	6493.5
3/30 0020	3/30 0753	SEC. NEUT.	None		None <sup>4</sup>	6493.5
3/30 1200	3/30 1630	IWTS	$1.2 \times 10^{-9}$		135.6 <sup>6</sup>	6629.3
3/30 0300	3/30 1600	IWTS	$6.7 \times 10^{-10}$		133	6762.3
3/30 2020	3/30 2253	SEC. NEUT.	None		None	6762.3
3/31 0140	3/31 0430	IWTS	$2.5 \times 10^{-8}$		241.3	7003.6
3/31 1600	3/31 2100	IWTS	$3.8 \times 10^{-8}$		6,961	14004.6
3/31 0001	3/31 1400	IWTS	$2.7 \times 10^{-7}$		92,112	106116.6
3/31 0240	3/31 0710	WECST-A	$3.6 \times 10^{-9}$		140	106256.6
3/31 2230	4/1 1015	SEC. NEUT.	None		None	106256.6
4/1 0630	4/1 1315	WECST-B	None		None	106256.6

**POOR ORIGINAL**

TABLE IV-A-2

GROUNDWATER RELEASES (Cont'd)

3-28-79 to 4-30-79

(All data refers to T-131)

Start	Stop	Tank	<sup>1</sup> Concentration at Station Discharge ( $\mu\text{Ci/cc}$ ) (dilution calc.)	<sup>2</sup> Concentration at Station Discharge ( $\mu\text{Ci/cc}$ ) (grab samples)	$\mu\text{Ci}$ Discharged	Cumulative $\mu\text{Ci}$ Discharged
4/1 0301	4/1 2400	INTS	$1.49 \times 10^{-7}$	$6.2 \times 10^{-8}$ * 2020 hrs.	54678	160934.6
4/1 0130	4/1 0934	INTS	$2.5 \times 10^{-8}$		346.3	161280.9
4/1 1521	4/1 1915	INTS	$2.5 \times 10^{-8}$		396	161676.9
4/2 0001	4/2 1950	INTS	$1.08 \times 10^{-7}$	$1.5 \times 10^{-8}$ * 1130 hrs.	27554	189330.9
4/2 1630	4/2 1850	SEC. NEUT.	None		None	189330.9
4/2 0513	4/2 1110	INTS	$2.5 \times 10^{-8}$		394.6	189725.5
4/3 1023	4/3 1915	SEC. NEUT.	None	$7.3 \times 10^{-10}$ * 15-0 hrs. $2 \times 10^{-10}$ 2 hrs.	None	189725.5
4/5 1813	4/6 0750	WBCST-A	$1 \times 10^{-9}$	1813 hrs. $1.0 \times 10^{-10}$ 4/5 at 1305 hrs.**	1010	190735.5
4/5 1903	4/6 0003	SEC. NEUT.	None		None	190735.5
4/6 0310	4/6 0400	INTS	$1.9 \times 10^{-7}$		450.1	191185.6
4/6 0613	4/7 2230	INTS	$7.9 \times 10^{-8}$	$3.9 \times 10^{-9}$ 4/6 at 1640 hrs.	16668	207853.6
4/6 1930	4/7 0430	INTS	$5.1 \times 10^{-8}$		930.6	208784.2
4/7 0931	4/7 1430	SEC. NEUT.	None	$< 6 \times 10^{-8}$ $0.3 \times 10^{-9}$ 4/7 at 1043 hrs.	None	208784.2

POOR ORIGINAL



TABLE IV-A-2

GROUND EFFLUENT RELEASES (cont'd)

10/28/79 to 11/1/79  
(All data refers to 1-131)

DATE	TIME	TANK	<sup>1</sup> (uCi/cc) Concentration at Station Discharge (dilution calc.)	<sup>2</sup> (uCi/cc) Concentration at Station Discharge (grab samples)	uCi Discharged	Cumulative uCi Discharged
7	4/8	WECST-B		$<4 \times 10^{-8}$	1180	210194.5
45	0150			$<3 \times 10^{-10}$ 4/8 at 1100 hrs.		
8	4/8	SEC. WST.	None	$<4 \times 10^{-8}$	None	210194.5
03	02-5					
9	4/8	WECST-B		$<4 \times 10^{-8}$	443	210637.5
55	02-5			$<2 \times 10^{-10}$ 4/8 at 1010 hrs.		
10	4/10	INTS	$5.7 \times 10^{-9}$	$<6.5 \times 10^{-8}$	80.6	210718.1
43	1010			$4.2 \times 10^{-9}$ 4/10 at 0710 hrs.		
10	4/10	WECST-A		$<5.5 \times 10^{-8}$	129.0	210847.1
25	1010					
11	4/11	SEC. WST.	None	$<1.1 \times 10^{-8}$	None	210847.1
40	1030			$1.4 \times 10^{-9}$ 4/11 at 1030 hrs.		
12	4/12	WECST-B		$<0.9 \times 10^{-8}$	200.0	211047.1
55	1130			$1.5 \times 10^{-9}$ 4/12 at 1100 hrs.		
12	4/13	WECST-A	None	$<1.6 \times 10^{-9}$	None	211047.1
03	1100					
13	4/13	SEC. WST.	None	$<0 \times 10^{-9}$	None	211047.1
55	1130					
13	4/13	WECST-B		$<5.1 \times 10^{-8}$	60.0	211107.1
18	0440					
14	4/13	INTS	$4.1 \times 10^{-8}$	$<1.3 \times 10^{-8}$	6.203	211113.1
50	0535					
14	4/14	INTS	$1.3 \times 10^{-8}$	$<1.6 \times 10^{-8}$	1.956	211271.1
40	0117			$1.2 \times 10^{-9}$ 4/14 at 0130 hrs.		
14	4/14	WECST-A	None	$<5.1 \times 10^{-8}$	None	211271.1
16	0440					
14	4/14	INTS	$1.5 \times 10^{-8}$	$<2.2 \times 10^{-8}$	1323	211394.1
5	0513			$1.9 \times 10^{-9}$ 4/14 at 1330 hrs.		
14	4/14	WECST-A		$<3.6 \times 10^{-8}$	1540.0	211336.1
5	0513			$1.3 \times 10^{-9}$ 4/14 at 1330 hrs.		
14	4/14	INTS	$1.2 \times 10^{-8}$	$<3.0 \times 10^{-8}$	102.6	211438.7
5	0513			$<1 \times 10^{-9}$ 4/14 at 1410 hrs.		

POOR ORIGINAL

TABLE IV-A-2

SEWAGE EFFLUENT RELEASES - Conold

1 28 74 to 10 79  
All data refers to 1-10-79

Start	End	Tank	Concentration at Station Discharge (Collection calc.)	Concentration at Station Discharge (grab samples)	Q Discharged	Cumulative Discharged
1-17	1-17	IWTS		$7.5 \times 10^{-8}$	21.5	222310.2
1-18	1-18		$9.5 \times 10^{-9}$	$7.8 \times 10^{-9}$ 4-17 at 1810		
4-17	4-18	WECST-A		$6.5 \times 10^{-8}$	2112	224422.2
10-3	10-3					
4-18	4-18	WECST-B	$4.6 \times 10^{-8}$	$7.75 \times 10^{-8}$	23	224445.2
1810	19-5			$4.8 \times 10^{-9}$		
4-18	4-18	IWTS	$6.1 \times 10^{-9}$	$5.1 \times 10^{-8}$	4.5	224449.7
1800	2-00			$4.9 \times 10^{-9}$ 4-18 at 1800		
4-19	4-23	IWTS		$3.5 \times 10^{-8}$	2910.88	227360.58
2-00	2-30		$3.5 \times 10^{-8}$			
4-19	4-19	WECST-B		$3.7 \times 10^{-8}$	315	227675.58
2135	2005			$3.65 \times 10^{-8}$ C1/cc 4-19 at 2135 hrs.		
4-20	4-20	IWTS	$3.1 \times 10^{-8}$	$3.1 \times 10^{-8}$	77	227752.58
1835	1125					
4-20	4-21	WECST-A		$3.75 \times 10^{-8}$ C1/cc 4-20 at 2010 hrs.		
1835	0255			$1.39 \times 10^{-8}$	582	228334.58
4-21	4-21	WECST-A		$1.65 \times 10^{-8}$ C1/cc 4-21 at 1835 hrs.		
1830	0230			$6.9 \times 10^{-10}$	1300	230134.58
4-23	4-23	SEC. NEUT. TANKS	None	$3.1 \times 10^{-8}$	None	230134.58
2310	1816			$4.2 \times 10^{-9}$		
4-23	4-24	IWTS		$3.1 \times 10^{-8}$	108	230242.58
1810	0310		$3.1 \times 10^{-8}$	$2 \times 10^{-10}$		
4-24	4-25	WECST-B		$1.7 \times 10^{-8}$	1200	231442.58
0930	0630			$3 \times 10^{-10}$		
4-24	4-25	SEC. NEUT. TANKS	None	$2 \times 10^{-8}$	None	231442.58
10-3	0755					
4-25	4-25	WECST-A		$1.3 \times 10^{-8}$	43.7	231486.28
1741	1300			$9.8 \times 10^{-10}$		
4-25	4-27	IWTS		$2.5 \times 10^{-8}$	181.87	231668.15
113	1113		$2.5 \times 10^{-8}$			
4-25	4-27	WECST-B		$1.3 \times 10^{-8}$	1450	233118.15
1030	1813			$1.8 \times 10^{-9}$		
4-27	4-28	IWTS		$3.1 \times 10^{-8}$		233118.15
1-01	0018		$3.1 \times 10^{-8}$	$1.1 \times 10^{-8}$		

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

TABLE IV-A-2

131I STATION RELEASES (Cont'd)

(1/15/79 to 4/10/79)

(All data refers to I-131)

Start	Stop	Tank	(C, Ci, cc) Concentration at Station Discharge (dilution calc.)	(MPC/cc) Concentration at Station Discharge (grab samples)	Ci Discharged	Cumulative Ci Discharged
1/15	1/15	S&S Neut Tanks	None	$3.1 \times 10^{-8}$ $1.1 \times 10^{-9}$ *	None	13335.33
1/17	1/18	WECST-A		$3.1 \times 10^{-8}$	392	13337.33
4/10	4/10	S&S Neut Tanks	None	$3.1 \times 10^{-8}$ $4.0 \times 10^{-10}$ *	None	13337.33
1/15	1/15	S&S Neut Tanks	None	$3.1 \times 10^{-8}$	None	13337.33
4/17	4/30	IKTS	$1.9 \times 10^{-6}$	$1.4 \times 10^{-6}$ $1.7 \times 10^{-9}$ *	655.6	134016.65

NOTES

1. Calculated based on average tank sample and known dilution factor (df) data during the period of time that the tank was being released. Discharges for IKTS are averaged over a 24-hour period.
2. Calculated by averaging the station discharge (SM-7) grab samples taken during the time the tank was being released. If the number appearing in this column is a "less than" (<) number, all the numbers averaged were less than MDA numbers and the MDA's were used for the purpose of averaging. This calculation is conservative in that it over-estimates the actual I-131 concentration at the station discharge. (See Attachment 7 for SM-7 grab samples)
3. WECST Tank releases are controlled by procedure HP 1621 which limits the release concentration to 0.1 MPC. The HP 1621 permit takes the specific activity of all the isotopes in the tank, assumes a dilution factor from MDCT flow and calculates a release rate so that 0.1 MPC is not exceeded while discharging. (See Attachments 4, 5 and 6)

**POOR ORIGINAL**

542 161  
REV. 2



TABLE IV-A-2

NOTES (continued)

1 The source of water into the Secondary Neutralizing Tank is from the regeneration of the Illinois Water Treatment System demineralizers. The Illinois Water Treatment System produces demin water by taking pretreated river water from upstream of the station discharge and sending it through demineralizers. The water from the regeneration of these demineralizers goes to the Secondary Neutralizing Tank. All isotopic samples on this tank after 4/2/79 showed no detectable I-131 or I-133.

Since the input to this tank is essentially river water from upstream of the station discharge, it is reasonable to assume that from 3/25 at 0400 to 4/2 at 1850, no I-131 was released from this tank.

3 See Attachment 2 for IWTB calculations/assumptions

6 See Attachment 3 for IWTB calculations/assumptions

**POOR ORIGINAL**

TABLE IV-A-2

DISCHARGE EFFLUENT RELEASES

- 10/79 to 1/31/79

(All data refers to T-101)

Start	Stop	Tank	(C1/c0) Concentration at Station Discharge (Dilution Calc.)	(C1/c0) Concentration at Station Discharge (Grab Samples)	C1 Discharged	Cumulative C1 Discharged
4/30 1810	5/1 1133	WECST-A	$3.1 \times 10^{-9}$	$3.1 \times 10^{-9}$	1960	23678.63
5/1 1800	5/2 0420	WECST-B	$1.07 \times 10^{-9}$	$3.1 \times 10^{-9}$ $2.2 \times 10^{-9}$ $2.2 \times 10^{-9}$	196	236672.63
5/1 1801	5/2 0620	U1 Sec Neut	None	$3.1 \times 10^{-9}$ $2.2 \times 10^{-9}$ $2.2 \times 10^{-9}$	None	236672.63
5/1 2119	5/2 0300	IXTS	$< 3.1 \times 10^{-9}$	$3.1 \times 10^{-9}$ $2.2 \times 10^{-9}$ $2.2 \times 10^{-9}$	None	236672.63
5/2 1700	5/2 1316	WECST-A	$2.7 \times 10^{-9}$	$2.7 \times 10^{-9}$ $2.7 \times 10^{-9}$	182	236634.63
5/3 1133	5/4 143- Neut Tank	U-1 Sec. Neut	None	$3.1 \times 10^{-9}$ $4.0 \times 10^{-10}$ $4.0 \times 10^{-10}$	None	236559.63
5/4 0801	5/4 1320	IXTS	$< 3.1 \times 10^{-9}$	$3.1 \times 10^{-9}$ $3.0 \times 10^{-10}$ $3.0 \times 10^{-10}$	-.25	236563.83
5/4 0900	5/5 0413	WECST-B	$4 \times 10^{-9}$	$4.3 \times 10^{-9}$ $1.4 \times 10^{-9}$ $1.4 \times 10^{-9}$	194	236267.63
5/5 0943	5/6 0003	WECST-A	$3.2 \times 10^{-9}$	$3.2 \times 10^{-9}$ $3.1 \times 10^{-9}$	182	237239.63
5/6 0013	5/6 0950 Neut	U-1 Sec. Neut	None	$3.1 \times 10^{-9}$ $4.0 \times 10^{-10}$ $4.0 \times 10^{-10}$	None	237239.83
5/6 1313	5/7 1130	WECST-A	$2.15 \times 10^{-9}$	$2.16 \times 10^{-9}$ $4.0 \times 10^{-10}$ $4.0 \times 10^{-10}$	422	237661.83
5/7 0323	5/7 1040 Neut	U-1 Sec. Neut	None	$2.16 \times 10^{-9}$ $3.0 \times 10^{-10}$ $3.0 \times 10^{-10}$	None	237661.83
5/7 1200	5/8 1200	IXTS	$< 4.3 \times 10^{-11}$	$3.1 \times 10^{-9}$ $3.0 \times 10^{-10}$ $3.0 \times 10^{-10}$	.0177	237661.83
5/7 1422	5/8 1803	WECST-A	$3.3 \times 10^{-9}$	$3.3 \times 10^{-9}$ $3.1 \times 10^{-9}$ $3.1 \times 10^{-9}$	188	237850.83
5/8 0020	5/8 1140	WECST-B	$3.41 \times 10^{-9}$	$3.41 \times 10^{-9}$ $3.41 \times 10^{-9}$ $3.41 \times 10^{-9}$	122	237972.83

POOR ORIGINAL  
v. 763

TABLE IV-A-2

GROUND WATER RELEASE

(1980 to 1983)

(All data refers to 1-131)

**POOL OPERATIONAL**

Start	Stop	Zone	(C1/cc) Concentration at Station Discharge (Dilution Calc.)	(C1/cc) Concentration at Station Discharge (Grab Samples) **	C1 Discharged	Cumulative C1 Discharged
3/9 1233	3/9 1240	U-1 Sec. Neut	None	$1.33 \times 10^{-8}$ $0.7 \times 10^{-10}$	None	13601.63
3/9 1233	3/11 1010	EWTS	$1.56 \times 10^{-9}$	$1.51 \times 10^{-10}$ $0.7 \times 10^{-10}$	205	13621.63
3/10 0753	3/10 1230	EWTS	$< 2.33 \times 10^{-8}$	$2.72 \times 10^{-10}$ $5.0 \times 10^{-10}$	1.6	13623.63
3/10 1230	3/10 1215	U-1 Sec. Neut.	None	$2.72 \times 10^{-10}$ $5.0 \times 10^{-10}$	None	13623.63
3/10 1923	3/11 0753	WECST-A	$3.7 \times 10^{-9}$	$2.61 \times 10^{-10}$ $5.0 \times 10^{-10}$	363	13652.63
3/11 1603	3/11 2110	U-1Sec Neut	None	$1.07 \times 10^{-10}$ $1.1 \times 10^{-10}$	None	13652.63
3/11 1713	3/13 1000	U-1 Sec Neut	None	$1.07 \times 10^{-10}$ $1.1 \times 10^{-10}$	None	13652.63
3/11 0843	3/11 1243	EWTS	$3 \times 10^{-8}$	$1.1 \times 10^{-10}$ $1.1 \times 10^{-10}$	9.16	13661.63
3/11 1423	3/11 1231	WECST-B	$4.1 \times 10^{-8}$	$3.1 \times 10^{-8}$	120	13673.81
3/13 1103	3/13 1633	EWTS	$7.3 \times 10^{-10}$	$1.92 \times 10^{-10}$ $1.1 \times 10^{-10}$	10.4	13679.21
3/13 1410	3/16 0855	U-1 Sec Neut	None	$1.59 \times 10^{-8}$ $1.1 \times 10^{-10}$	None	13679.21
3/13 0423	3/13 2130	EWTS	$1.09 \times 10^{-10}$	$3.64 \times 10^{-10}$ $1.1 \times 10^{-10}$	79.81	13687.02
3/13 0030	3/13 0725	U-1 Sec Neut	None	$1.69 \times 10^{-8}$	None	13687.02
3/13 1643	3/13 1740	EWTS	$1.4 \times 10^{-8}$	$1.44 \times 10^{-8}$	2.88	13690.90
3/13 1233	3/13 2125	U-1 Sec Neut	None	$1.1 \times 10^{-8}$ $1.1 \times 10^{-10}$	None	13690.90
3/13 0243	3/13 1610	WECST-B	$1.7 \times 10^{-8}$	$1.1 \times 10^{-8}$	19.6	13710.50

\*\*Manual 1- Sec. monitoring was started 8/17/83 for Station Discharge 1121.



TABLE IV-A-2

MEASURED EFFLUENT RELEASES

4/30/79 to 5/31/79

(All data refers to T-131)

Start	Stop	Tank	1 (μCi/cc) Concentration at Station Discharge (Dilution Calc.)	2 (μCi/cc) Concentration at Station Discharge Composit. Sample	μCi Discharged	Cumulative μCi Discharged
5/19 2110	5/20 0334	WECST-B	$3.2 \times 10^{-9}$	$< 3.0 \times 10^{-9}$	62	238956.51
5/21 0205	5/21 1335	WECST-A	$1.10 \times 10^{-9}$	$< 1.0 \times 10^{-9}$	105	239091.51
5/21 0855	5/21 1220	EWFS	$5.19 \times 10^{-11}$	$< 1.4 \times 10^{-9}$	1.15	239093.69
5/21 0845	5/23 0135	EWFS	$3 \times 10^{-10}$	$< 1.5 \times 10^{-9}$	7.05	239105.74
5/23 2145	5/23 0750	U-1 Sec Neut	None	$< 1.5 \times 10^{-9}$	None	239105.74
5/24 1755	5/25 0040	WECST-B	$3.25 \times 10^{-9}$	$< 1.5 \times 10^{-9}$	131	239236.74
5/25 0330	5/25 1610	EWFS	$1.11 \times 10^{-9}$	$< 1.5 \times 10^{-9}$	0.2	239236.94
5/25 2115	5/26 0300	WECST-B	$1.37 \times 10^{-9}$	$< 1.34 \times 10^{-9}$	110	239346.94
5/26 1200	5/27 0315	U-1 Sec Neut	None	$< 1.39 \times 10^{-9}$	None	239346.94
5/27 1700	5/28 0004	WECST-A	$1.34 \times 10^{-9}$	$< 1.34 \times 10^{-9}$	91.6	239438.54
5/28 0020	5/31 0750	EWFS	$1.16 \times 10^{-9}$	$< 2.13 \times 10^{-9}$	19	239457.54
5/28 0045	5/28 1615	WECST-B	$3.4 \times 10^{-10}$	$< 2.13 \times 10^{-9}$	24	239481.54
5/29 0246	5/29 1120	WECST-B	$1.00 \times 10^{-10}$	$< 2.13 \times 10^{-9}$	6.5	239490.0
5/29 0755	5/29 1700	EWFS	$4.18 \times 10^{-11}$	$< 2.13 \times 10^{-9}$	3.16	239493.2

\*\* Automatic compositor unit malfunctioning & 1/2 Hr. sample was started 5/24/79 for Station Discharge 1351.

542 165

POOR ORIGINAL

TABLE IV-A-2

MEASURED EFFLUENT RELEASES

(12/30/78 to 5/31/79)


(All data refers to I-131)

<u>Start</u>	<u>Stop</u>	<u>Tank</u>	<sup>1</sup> Concentration ( $\mu\text{Ci/cc}$ ) at Station Discharge (Dilution Calc.)	<sup>2</sup> Concentration ( $\mu\text{Ci/cc}$ ) at Station Discharge Composite Sample	<u>CI Discharged</u>	<u>Cumulative CI Discharged</u>
5/30 1000	5/31 0000	U-1 Sec Neut.	None	$< 3.00 \times 10^{-5}$	None	239,931.2
5/30 1000	5/30 1900	WECST-3	$1.06 \times 10^{-10}$	$< 3.00 \times 10^{-6}$ $2.1 \times 10^{-7}$	8.09	239,901
5/31 06-3	5/31 2030	WWS	$4.2 \times 10^{-11}$	$< 3.19 \times 10^{-6}$ $1.00 \times 10^{-7}$	4.03	239,905.32

NOTES

1. Calculated value based on average tank sample concentration and known dilution factor (df) data during the period of time the tank was being discharged.
2. Calculated by averaging the station discharge (RML-7) grab samples taken during the period of time that the tank was being discharged. Starting on 5/15/79 samples were being manually composited into a 24-hour sample. Starting on 5/24/79 an automatic liquid compositor was put into operation for the purpose of obtaining a more representative sample. If the number appearing in this column is a "less than" (<) number, the MCA's were taken as real number for the purpose of averaging. This calculation is conservative in that it over-estimates the actual <sup>131</sup>I concentration at the station discharge.
3. WECST releases are controlled by procedure HPI621 and RML-5 which limits the release concentration to 0.1 (MPC)<sub>w</sub>. The HPI621 permit takes into consideration the concentration (specific activity) for all the radionuclides in the tank, assumes a cf from the WOCF flow. Calculations are made to restrict the release rate so that 0.1 (MPC)<sub>w</sub> is not exceeded during discharge.
4. The source of water into the Secondary Neutralizing (Sec. Neut.) Tank is from the regeneration of the Illinois Water Treatment System demineralizers. The Illinois Water Treatment System produces demin water by taking pretreated river water from upstream of the station discharge and sending it through demineralizers. All isotopic analysis of samples on this tank showed no detectable <sup>131</sup>I and <sup>133</sup>I.

542 160



Date

**POOR ORIGINAL**

502 107



**POOR ORIGINAL**

Iodine-131 Released  
(millicuries/day)

0.1

0.01

0.001




FIGURE IV-A

Daily Liquid Releases of Iodine-131  
to the Susquehanna River

Total Amount of Iodine-131 Released  
to the Susquehanna River from  
5/1/79 to 5/31/79 is 5 Millicuries

Date in May 1979

#### IV. 3. OFFSITE NOBLE GAS RELEASES AND DOSES

##### 1. Estimated Releases

During the period March 29, 1979 through April 30, 1979, about 10 million curies of noble gases were released to the environment via the ventilation system of Units 1 and 2. This estimate is down slightly from 12 million curies reported in the June 18 submittal due to refinements in the data used with the analytical methodology described in the June 18 submittal. Revised data and results are presented in Table IV-3-1 and Figure IV-3-1 and IV-3-2. All of this release was a result of the Unit 2 accident of March 28, 1979.

During the period May 1, 1979 through May 31, 1979, approximately 1366 curies of noble gases ( $^{131}\text{Xe}$ ,  $^{133}\text{Xe}$  and  $^{135}\text{Xe}$ ) were released to the environment via the ventilation system of Unit 2. The release of noble gases was determined by obtaining daily "grab" gas samples for gamma (GeLi) spectroanalysis to determine isotopic concentrations and an evaluation of strip chart records for this period. Daily noble gas release quantities are plotted in Figure IV-3-3. Releases in May did not represent a significant increment to releases for the period March 29 through April 30, 1979.

##### 2. Environmental Measurements

The Radiological Environmental Monitoring Program (REMP) conducted by Metropolitan Edison Company is described in Attachment 1 to the June 18, 1979 submittal. Additional data are included in Attachment 1 to this submittal. The doses from noble gases released in May were not distinguishable from doses from naturally occurring background radiation. The highest measured exposure offsite for the period March 29 through April 30, reported in the June 18 submittal as 33 mR has been revised downward slightly to 75 mR based on a new assessment of the contribution of natural background radiation to the dose measured at that location, Station 4A1, 1200 meters NNE from the site.

##### 3. Estimated Offsite Whole Body Doses

The maximum offsite whole body dose to an individual, based on the revised measurement result discussed above, is 75 millirem for the period March 28 through April 30. The estimated aggregate whole body dose to the two million persons from noble gases released from March 28 through April 30 is about 3300 person-rem, as reported previously. The addition of dose contributions from releases in May do not change these values significantly.

542 169



Table IV-B-1  
 Estimated Quantities (Ci) of Each Noble Gas Isotope for  
 Release Periods Corresponding to TLD Measurements  
 3/28/79-4/30/79

Isotope	3/28 @ 0700- 3/29 @ 1600		3/29 @ 1700- 3/31 @ 1600		3/31 @ 1700- 4/3 @ 1500		4/3 @ 1600- 4/6 @ 1300		4/6 @ 1400- 4/30 @ 2400*		Total
Xe-133	4.9E6	2.1E6	1.1E6	2.7E5	1.5E4	1.5E4	8.3E6				
Xe-133m	1.2E5	3.9E4	1.5E4	1.9E3	0	0	1.7E5				
Xe-135	1.5E6	7.7E4	1.4E3	0	0	0	1.5E6				
Xe-135m	1.4E5	1.3E3	0	0	0	0	1.4E5				
Kr-88	6.1E4	0	0	0	0	0	6.1E4				
	<u>6.6E6</u>	<u>2.2E6</u>	<u>1.1E6</u>	<u>2.7E5</u>	<u>1.5E4</u>	<u>1.5E4</u>	<u>1.0E7</u>				

\*The last three weeks of the month are combined into one group since the contribution is less than 1% of the total. The estimated quantity released during this period is based on effluent measurements.




Figure IV-3-1

# TREND OF AUXILIARY AND FUEL HANDLING BUILDING AREA RADIATION MONITORS

ARROWS INDICATE HOURLY WIND DIRECTION, EACH BAR ON ARROW INDICATES 3MPH WIND SPEED

↑ INDICATES WIND TOWARD NORTH



003 ORIGINAL







FIGURE IV-D-2

Measured Noble Gas Release Rate  
5/1/79 - 5/31/79



FOON ORIGINAL



#### IV. C. OFF-SITE IODINE AND PARTICULATE RELEASES AND DOSES

##### 1. Releases

During the period March 28, 1979 through April 30, 1979 about 14.1 curies of Iodine-131 and 2.6 curies of Iodine-133 were released to the environment via the ventilation systems of Unit 1 and 2. These releases were discussed in the June 18 submittal. All of these releases resulted from the Unit 2 accident of March 28, 1979.

During the period of May, 1979 through May 31, 1979 approximately  $7.8E-2$  curies of Iodine 131 were released to the environment via the ventilation system of Unit 2. This estimate is based on periodic collection and analysis of continuous effluent samples. The Unit 2 station vent was capped on about May 20, 1979 and since that time the effluent air has been released through at least three of four newly installed filter trains which back up normal plant air cleaning systems. Table IV-C-1 and Figure IV-C-1 summarizes the release of Iodine-131 for the period May 1, 1979 through May 31, 1979. Releases in May, 1979 represent a negligible increment to Iodine-131 releases during the period March 28, 1979 through April 30, 1979.

Preliminary evaluations of measured particulate concentrations and releases indicate these isotopes are not significant in off-site dose assessments. These evaluations are continuing and results will be presented in a later report.

##### 2. Environmental Measurements

In support of routine plant operations, Metropolitan Edison Company conducts an Radiological Environmental Monitoring Program. Included are continuous air samples for iodine and particulate isotopes, vegetation samples and milk samples. This program has continued with a higher sampling frequency since the accident. Attachment 1 of the June 18 submittal includes a tabulation of these data and a brief discussion of the program. Attachment 1 to this report includes supplementary information. Results indicate that Iodine-131 was the only iodine or particulate isotope released in significant quantities. This isotope was detected in air and milk, as discussed below, and was also detected in some grass samples in the period March 28 through April 30. In early May, low concentrations of Iodine-131 were detected in some milk samples and in one air sample. By the last week of the month concentrations of Iodine-131 had fallen below detectable levels in all samples.

##### 3. Estimated Off-Site Exposures

A summary of off-site doses from radioactive iodines is given in the Executive Summary Table.

The methodology and results of the assessment of doses from atmospheric releases of iodine isotopes were included in the June 18 submittal. Estimates of maximum individual doses from inhalation of air containing Iodine-131 and ingestion of milk containing Iodine-131, based on environmental measurements, have been revised slightly from 2.7 to 3.7 millirem for inhalation and from 1.2 to 1.5 millirem for milk ingestion. Results of other dose assessments for iodine isotopes released to the atmosphere remain as reported in the June 18 submittal.


TABLE IV-C-1  
 Ci/Day from Charcoal  
<sup>131</sup>I Releases  
 5/1/79 - 5/31/79

<u>Date</u>	<u>Total</u>
5/1/79	3.50E-2
5/2/79	7.83E-3
5/3/79	6.30E-3
5/4/79	7.70E-3
5/5/79	5.81E-3
5/6/79	3.11E-3
5/7/79	7.26E-6
5/8/79	3.01E-3
5/9/79	4.08E-3
5/10/79	1.18E-5
5/11/79	1.21E-5
5/12/79	6.08E-6
5/13/79	4.92E-4
5/14/79	4.49E-5
5/15/79	1.99E-5
5/16/79	2.39E-5
5/17/79	3.37E-5
5/18/79	4.20E-5
5/19/79	2.70E-5
5/20/79	3.34E-5
5/21/79	1.25E-4
5/22/79	1.89E-5
5/23/79	1.61E-5
5/24/79	2.70E-5
5/25/79	2.56E-5
5/26/79	3.25E-5
5/27/79	1.86E-5
5/28/79	6.04E-5
5/29/79	1.46E-5
5/30/79	1.28E-5
5/31/79	1.62E-5
	<u>7.397E-2</u>

6/2 115

Figure IV-C-1  
Release of I-131 to Atmosphere from Unit 2

POOR ORIGINAL





ATTACHMENT 1

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

The information in this attachment supplements information provided in the submittal dated June 19, 1979, which also includes a description of the program and information to aid in interpreting results (maps, etc.)

542 177

## Summary

Specific radioanalytical results are found in Appendix B of this and the second Interim Report and the dosimetric applications of these findings are found in Appendix C of this report.

### Waterborne Pathways Surface & Drinking Water

All water samples were analyzed for radioiodine, tritium, and gross beta activities, as well as by gamma spectroscopy. Thirteen samples, 4 upstream and 9 downstream, had very low positive results for radioiodine (all  $<2.0$  pCi/l) while all other samples had no detectable radioiodine. Tritium and gross beta activities were at normal ambient levels for all samples and no reactor produced radionuclides were found.

### Effluent Water

Tritium levels ranged from 100 to 3690 pCi/l through April 28, 1979; iodine-131 levels ranged from 0.1 to 62 pCi/l through May 29, 1979; no gamma emitters other than iodine-131 and on 2 occasions cobalt-58 were found. The levels of radioactivity found, based on the surface and drinking water results, had no discernible effect offsite.

### Fishes - Aquatic Sediment - Aquatic Plants

Analysis of fishes found only naturally occurring potassium-40 and occasional low levels of fallout cesium-137. Analysis of sediment samples found normal levels of naturally occurring radionuclides and on occasion low levels of cobalt-58, cesium-134, and manganese-54. No aquatic plants were found.

### Airborne Pathways

Gross beta analyses of airborne particulates found typical background activities at all locations at all times. Radioiodine analyses found activities ranging from 0.02 to 23.9 pCi/m<sup>3</sup> within 3 days post incident. The distribution of these values was such that locations closest to Three Mile Island had the highest activities. No radioiodine was detected in any samples after May 3.

### Terrestrial Pathways

#### Milk

Analyses of cow's milk noted radioiodine levels ranging from 0.1 to 21 pCi/l and normal background levels of cesium-137 and potassium-40. The higher radioiodine results were immediately post incident and have been decreasing such that no radioiodine has been detected since May 20. Analysis of goat's milk found radioiodine levels ranging from  $<0.3$  to 110 pCi/l and normal background levels of cesium-137 and potassium-40. It should be noted that most to all goat's milk production in April was used to suckle newborn kids and thus there was little to no human exposure via this pathway. Radioiodine levels in goat's milk in May ranged from  $<0.3$  to 49 pCi/l; no radioiodine was detected after May 24.

#### Rainwater

Tritium, gross beta, and gamma spectrometric analyses through April 27 found normal ambient activities and naturally occurring radionuclides only. Radioiodine analyses found detectable activities (2.1 and 1.2 pCi/l) in 2 indicator samples for the period March 31 through April 5, 1979; no other samples had detectable levels of radioiodine.

Other Samples

Two of 6 grass samples had low but detectable levels of radioiodine (0.033 and 0.053 pCi/g); no radioiodine or reactor produced radionuclides were found in soil, poultry, beef, eggs, or game.



# POC ORIGINAL

TUD'S  
NET EXPANSURES  
INCLUDES BACKGROUND

Teledyne Results to m1113-coentaffens  
Net (Q) Results to m1111-Trade  
The Total Error is 1.34%cm

Map #	Page 1 of 1	4/28-5/5	5/5-5/17	5/12-5/19	5/19-5/26	5/26-6/2
1	B. Weather Station	182 0.8 ± 0.9	1.1 ± 0.4	1.0 ± 0.3	1.3 ± 0.3	0.8 ± 0.3
2	B. Weather Station	182Q 1.69±0.12	1.57 ± 0.18	1.36 ± 0.09	1.85 ± 0.15	1.40 ± 0.28
3	M. Bridge	269 0.7 ± 0.7	0.8 ± 0.3	0.0 ± 0.3	1.0 ± 0.3	0.5 ± 0.3
5	Top of Dike	482 0.5 ± 0.7	1.0 ± 0.3	1.0 ± 0.3	1.0 ± 0.2	0.7 ± 0.4
5	Top of Dike	482Q 1.69±0.20	1.49±0.14	1.44 ± 0.15	1.01 ± 0.24	1.34 ± 0.10
6	Top of Dike	532 0.6 ± 0.7	1.0 ± 0.3	0.9 ± 0.3	1.5 ± 0.4	0.9 ± 0.3
6	Top of Dike	532Q 1.46±0.11	-	1.44 ± 0.26	1.75 ± 0.22	1.24 ± 0.10
20	Falmouth-Collins Sub	801 0.3 ± 0.7	1.0 ± 0.3	0.7 ± 0.3	0.9 ± 0.2	1.1 ± 0.3
20	Falmouth-Collins Sub	801Q 0.96±0.18	1.24±0.21	1.13 ± 0.11	1.31 ± 0.09	0.90 ± 0.17
8	S. TPA	952 0.6 ± 0.7	1.1 ± 0.3	1.2 ± 0.3	1.2 ± 0.2	0.9 ± 0.3
9	RECT	1151 1.1 ± 0.7	1.4 ± 0.3	1.2 ± 0.3	1.4 ± 0.2	1.1 ± 0.3
9	H. Boat dock	1181Q 1.85±0.16	1.67±0.24	1.72 ± 0.30	2.14 ± 0.32	1.52 ± 0.11
11	M. Boat dock	1631 1.2 ± 0.7	1.5 ± 0.3	1.4 ± 0.3	1.6 ± 0.2	1.1 ± 0.3
11	M. Boat dock	1631Q 1.86±0.16	1.80±0.11	1.52 ± 0.11	2.20 ± 0.44	1.72 ± 0.22
10	Shelley	1452 0.4 ± 0.7	0.8 ± 0.3	0.7 ± 0.3	0.9 ± 0.2	1.1 ± 0.3
13	Laurel Rd	4A1 0.6 ± 0.7	1.0 ± 0.3	1.0 ± 0.3	1.2 ± 0.2	0.7 ± 0.3
14	Observ. Center	5A1 0.6 ± 0.7	1.0 ± 0.3	0.9 ± 0.3	1.2 ± 0.2	0.8 ± 0.3
14	Observ. Center	5A1Q 1.40±0.18	1.40±0.12	1.23 ± 0.16	1.61 ± 0.09	1.34 ± 0.22
17	Kohr Island	16A1 0.5 ± 0.1	1.2 ± 0.3	1.0 ± 0.3	1.0 ± 0.2	-
23	S. End Shelley	10B1 0.8 ± 0.7	1.6 ± 0.3	1.2 ± 0.3	1.4 ± 0.2	0.6 ± 0.1
24	Goldsboro Air Station	12B1 0.4 ± 0.7	1.0 ± 0.4	0.7 ± 0.3	0.9 ± 0.2	0.6 ± 0.3
26	Middletown Sub	101 0.6 ± 0.7	1.2 ± 0.9	0.8 ± 0.3	1.0 ± 0.2	0.6 ± 0.3
34	Drager Farm	7F1 1.3 ± 0.7	1.6 ± 0.3	1.6 ± 0.3	1.8 ± 0.2	1.4 ± 0.4
34	Drager Farm	7F1Q 2.06±0.08	2.07 ± 0.29	1.87 ± 0.21	2.24 ± 0.39	1.72 ± 0.35
37	RFE 2b1	401 0.7 ± 0.7	1.4 ± 0.2	1.1 ± 0.3	1.3 ± 0.2	1.5 ± 0.3
37	RFE 2b1	401Q 1.60±0.16	1.80 ± 0.14	1.71 ± 0.17	1.77 ± 0.40	1.25 ± 0.19
39	H. Fork Sub	901 0.9 ± 0.7	1.2 ± 0.3	1.2 ± 0.3	1.3 ± 0.2	1.1 ± 0.4
40	M. Fairview	1501 6.9 ± 0.7	1.2 ± 0.3	1.1 ± 0.3	1.3 ± 0.2	1.1 ± 0.3
40	M. Fairview	1501Q 1.38±0.14	1.5 ± 0.13	1.56 ± 0.29	1.71 ± 0.16	1.49 ± 0.36
38	Columbia	701 1.3 ± 0.7	1.9 ± 0.4	1.6 ± 0.3	1.8 ± 0.2	1.7 ± 0.3

16





(milli-roentgens) (0.955) = mR/hr

MAP'S  
mR/hr

Regular Stations - Results in milli-roentgens/hour  
Q Stations - Results in milli-rads/hour

INCLUDES BACKGROUND

Map #	Station Name	4/28-5/5	5/5-5/12	5/12-5/19	5/19-5/26	5/26-6/2
1	H. Weather Station	152	0.005	0.007	0.006	0.008
2	H. Weather Station	152Q	0.009	0.009	0.008	0.011
3	H. Bridge	252	0.002	0.005	0.005	0.006
5	Top of Dike	452	0.003	0.006	0.006	0.006
5	Top of Dike	452Q	0.009	0.009	0.009	0.011
6	Top of Dike	552	0.003	0.006	0.006	0.009
6	Top of Dike	552Q	0.008	0.009	0.009	0.010
28	Falmouth-Collins Sub	8C1	0.002	0.006	0.004	0.005
28	Falmouth-Collins Sub	8C1Q	0.005	0.007	0.007	0.008
8	S. TMI	952	0.003	0.007	0.007	0.007
9	MDCP	1181	0.006	0.008	0.007	0.008
9	MDCP	1181Q	0.011	0.010	0.011	0.013
11	H. Boat Dock	1681	0.007	0.009	0.009	0.008
11	H. Boat Dock	1681Q	0.011	0.011	0.009	0.013
10	Shelley	1482	0.002	0.005	0.004	0.005
13	Laurel Rd	4A1	0.004	0.006	0.006	0.007
14	Observ. Center	5A1	0.004	0.006	0.005	0.007
14	Observ. Center	5A1Q	0.008	0.009	0.007	0.010
17	Kohr Island	16A1	0.003	0.007	0.006	0.006
23	S. End Shelley	10B1	0.005	0.010	0.007	0.008
24	Goldboro Air Station	12B1	0.002	0.006	0.004	0.004
26	Middleton Sub	1C1	0.004	0.007	0.005	0.006
34	Drager Farm	7F1	0.008	0.010	0.010	0.011
34	Drager Farm	7F1Q	0.013	0.013	0.011	0.013
37	RTE 241	4G1	0.004	0.008	0.007	0.008
37	RTE 241	4G1Q	0.009	0.011	0.010	0.011
39	H. York Sub	9G1	0.005	0.007	0.007	0.008
40	W. Fairview	15G1	0.006	0.007	0.006	0.008
40	W. Fairview	15G1Q	0.008	0.009	0.009	0.010
38	Columbia	7G1	0.007	0.011	0.010	0.011



Misc. Results

Note: Blank indicates result is less than LLD

Parameter	Station	Collect Date	Wet/Dry	Item	1-131	Ca-137	K-40	Ra-226	Pb-210	Be-7	Pb-210
1	FTF	100Q	W	Chicken	<0.05		3.0				
2	SOS	100Q	W	Soil	<0.1	1.0	110	0.72	1.0		
3	VGP	100Q	W	Grass	<0.14	0.32	2.9			3.4	
4	SOL	100Q	W	Soil	<0.1	0.50	8.7	0.89	0.92		
5	VGP	100Q	W	Grass	<0.11		3.6			2.3	
6	SOL	703R	W	Soil	<0.01	0.72	110	1.0	1.1		
7	VGP	703R	W	Grass	<0.2	0.18	3.5			4.0	
8	FTF	100Q	W	Egg	<0.05		1.5				
9	FTF	600Q	W	Chicken	<0.13		6.0				
10	DEF	1003R	W	Pig	<0.09		1.9				
11	FTF	600Q	W	Pigs	<0.13						
12	FTB	501Q	W	Beef	<0.15		2.9				
13	FTF	502Q	W	Chicken	<0.06		3.4				
14	FTF	503Q	W	Eggs	<0.09						
15	FTF	1001	W	Duck	<0.05		3.09				
16	FTB	1001	W	Beef	<0.09		2.27				
17	FTF	600	W	Chicken	<0.1						
18	E	201	D	Soil	<0.2	0.456	19.9	2.49		1.59	
19	E	1001	D	Soil	<0.3	0.677	110			1.51	
20	E	1001	D	Soil	<0.1	1.48	16.3	1.95		1.36	
21	E	201	W	Grass	<0.01						
22	E	1001	W	Grass	0.33						
23	E	1001	W	Grass	0.063						
24	FTV	101	W	Spring	<0.01		2.16				

P.O. ORIGINAL

PRECIPITATION

06/17/8

Rev. 1

GROSS BETA, IODINE 131, TRITIUM

LOCATION	STATID	3/23-	3/28-3/31	4/27	4/27-4/31
W. Fairview	1561		10.0	93.0	5.2
W. Fairview	1561Q	20.9		3.3	2.35
Falmouth-CollinsSub	8C1		19.0	5.4	6.2
Falmouth-CollinsSub	8C1Q	15.5		2.0	4.37
Obs. Contr.	5A1		2.9	3.7	3.1
Drager Farm	7F1		14.0	0.1	4.1

W. Fairview	1561		<0.2	<0.2	
W. Fairview	1561Q	<0.4		<0.6	
Falmouth-CollinsSub	8C1		<0.2	2.1	
Falmouth-CollinsSub	8C1Q	<0.3		<0.7	
Obs. Contr.	5A1		<0.4	1.2	
Drager Farm	7F1		<0.4	<0.2	

W. Fairview	1561		<150	<110	
W. Fairview	1561Q	201		<307	
Falmouth-CollinsSub	8C1		160	160	
Falmouth-CollinsSub	8C1Q	<248		<307	
Obs. Contr.	5A1		160	<120	
Drager Farm	7F1		140	100	

POCC ORIGINAL

# POOR QUALITY

Nov. 1

Core	Stat.	Comp. Date	1-111	Cs-137	K-40	Th-232	Sr-90	Co-58	Cs-136	Pb-210	Hg-203	Re-7	Other
AG3	1A2	4/10	•	0.081	7.49	0.41	0.006	•	•	•	•	•	•
AG3	10B1	4/10	•	0.064	4.00	0.61	0.003	•	•	•	•	•	•
AG3	11A1	4/10	•	0.44	7.35	1.29	0.007	0.56	0.21	•	•	•	•
AG3	7A1	4/10	•	0.28	10.9	1.15	<0.002	•	•	2.25	•	•	•
AG3	9B1	4/10	•	0.18	9.47	1.00	<0.002	0.19	•	•	•	•	•
AG3	1A2	4/5	•	0.13	7.22	0.98	•	•	•	•	•	•	•
AG3	10B1	4/5	•	0.19	6.32	1.27	•	•	•	•	•	•	•
AG3	11A1	4/5	•	0.24	9.08	1.05	•	0.57	•	1.56	0.12	•	•
AG3	7A1	4/5	•	0.52	10.4	1.47	•	•	•	3.00	•	•	•
AG3	9B1	4/5	•	0.43	12.7	1.52	•	0.37	•	•	•	•	•
AG3	10B1	4/12	•	0.12	5.02	0.72	•	•	•	1.39	•	•	•
AG3	1A2	4/12	•	•	•	•	•	•	•	•	•	•	•
AG3	7A1	4/12	•	•	•	•	•	•	•	•	•	•	•
AG3	9B1	4/12	•	•	•	•	•	•	•	•	•	•	•
AG3	11A1	4/12	•	•	•	•	•	•	•	•	•	•	•
AG3	7A1	4/16	•	0.206	9.51	1.16	•	•	•	•	•	1.00	•
AG3	9B1	4/16	•	•	•	•	•	•	•	•	•	•	•
AG3	10A1	4/16	•	0.295	8.96	0.829	•	0.531	•	•	•	•	•
AG3	1A2	4/16	•	•	•	•	•	•	•	•	•	•	•
AG3	10B1	4/16	•	•	•	•	•	•	•	•	•	•	•
AG3	11A1	4/16	•	•	•	•	•	•	•	•	•	•	•
AG3	1A2	4/23	•	0.222	7.35	0.745	•	•	•	1.15	•	•	•
AG3	7A1	4/23	•	0.245	9.59	1.16	•	•	•	1.79	•	•	•
AG3	9B1	4/23	•	0.457	14.7	1.63	•	0.200	•	2.39	•	•	•
AG3	10B1	4/23	•	0.102	6.63	0.709	•	•	•	•	•	•	•
AG3	11A1	4/23	•	0.206	7.13	0.926	•	0.580	•	•	0.072	•	•
AG3	1A2	4/30	•	•	5.07	1.00	•	•	•	•	•	•	•
AG3	7A1	4/30	•	0.178	8.56	1.27	•	•	•	•	•	•	•
AG3	9B1	4/30	•	0.525	11.5	1.42	•	0.329	0.200	2.60	•	•	Co-60 = 0.185
AG3	10B1	4/30	•	•	8.67	1.43	•	•	•	2.01	•	•	•
AG3	11A1	4/30	•	0.310	11.1	1.00	•	•	•	•	•	•	•
AG3	1A2	5/7	•	0.130	7.45	0.976	•	0.305	•	1.31	0.122	•	•
AG3	7A1	5/7	•	0.525	12.8	1.10	•	•	•	1.41	•	•	•
AG3	9B1	5/7	•	0.424	12.4	•	•	0.286	•	1.47	•	•	•
AG3	10B1	5/7	•	0.095	5.52	0.606	•	•	•	•	•	•	•
AG3	11A1	5/7	•	0.324	8.97	1.43	•	0.741	•	1.44	•	•	•

540-185



Note: ■ = solid

RIVER SEDIMENT  
PCl/cm (DRY)

Locn.	Stat.	Date	1-131	Cd-13	K-10	Th-233	Si-89	Co-58	Cs-134	Mn-226	Ru-226	Pu-7	Co-60	All other
AGS	1A2	5/15	■	0.226	2.09	1.18						2.09		
AGS	1A2	5/21	■	0.222	9.87	1.29								
AGS	7A1	5/15	■	0.319	7.74	1.03				2.06				
AGS	7A1	5/21	■	0.255	9.83	1.04				1.61				
AGS	9B1	5/15	■	0.965	15.0	1.78		0.197	0.303	2.22			0.193	
AGS	9B1	5/21	■	0.746	15.2	1.64		0.324		2.97			0.160	
AGS	10B1	5/15	■	0.113	7.67	0.789								
AGS	10B1	5/21	■	0.049	5.67	0.660				1.16				
AGS	11A1	5/15	■	0.540	10.4	1.46		1.19			0.353		0.148	
AGS	11A1	5/21	■	0.252	11.7	1.40		0.540						
AGS	1A2	5/29	■	0.134	7.85	1.22				2.33		2.10		
AGS	7A1	5/29	■	0.235	12.0	1.32								
AGS	9B1	5/29	■	0.317	8.73	1.32		0.116				1.56		
AGS	10B1	5/29	■	0.145	7.95	1.13				1.74				
AGS	11A1	5/29	■	0.313	10.1	1.32		0.190						

POOL ORIGINAL

$\lambda$  = result by radiochemistry  
 ( $\lambda$ ) = result by gamma spec.

Milk  
 Iodine - 131 (pCi/L)

40 gm/gal NaI<sup>130</sup> added to each sample.

Page	1 of 4	Sample	4/22	4/23	4/24	4/25	4/26	4/27	4/28	4/29	4/30	5/1	5/2	5/3
18	Alvina Farm	14B1	<0.2	0.19	<0.2	<0.4	<0.2	<0.2	<0.4	<0.4	<0.3	<0.3	<0.2	<0.2
20	Becker Farm	74B3	0.57	0.72	<0.4	0.42	0.06	0.49	<0.5	3.6	1.7	3.6	2.9	2.7
20	Becker Farm	74B2	1.7	<0.4	<0.2	0.5	<0.5	<0.7	<0.4	4.2	5.2	5.4	2.2	1.6
36	Fisher Farm	14B1	0.31	0.40	1.0	0.77	2.1	-	0.5	<0.3	-	<0.4	<0.2	-
36	Oellie Farm	261	<0.2	<0.2	<0.2	<0.2	<0.2	<0.3	<0.5	<0.5	<0.3	<0.3	<0.2	<0.1
45	Harriison Farm	14B1	-	-	-	110.	57.	39.	22.	37.	26.	49.	46.	37.
						(97.6)	(60.0)	(46.8)	(28.9)	(50.0)	(21.6)			

2025  
 2025  
 2025

X = result by radiochemistry  
 (X) = result by gravim spec.

40 µg/µl  $\text{Ba}^{131}\text{I}_2$  added to each sample.

MILK  
 Iodine - 131 (pCi/l)

Page	of	Sample	5/4	5/5	5/6	5/7	5/8	5/9	5/10	5/11	5/12	5/13	5/14	5/15
18		Alpine Farm	<0.3	<0.2	<0.5	<0.3	<0.3	<0.3	<0.3	<0.4	<0.4	<0.4	<0.3	<0.3
20		Becker Farm	1.9	1.4	4.7	1.8	1.9	2.3	0.86	1.4	1.4	1.1	1.0	1.0
20		Becker Farm	1.7	1.6	2.3	3.7	2.3	2.3	1.5	1.5	1.8	1.4	1.8	0.65
		Fisher Farm	<0.2	<0.2	<0.2	<0.3	0.72	0.65	0.36	<0.4	0.63	<0.4	<0.3	<0.4   0.7
36		Oelliff Farm	<0.3	<0.2	<0.3	<0.5	<0.3	<0.3	<0.3	<0.5	<0.4	<0.5	<0.4	<0.4
45		Hardison Farm	35.0	-	19.0	14.0	13.0	9.7	16.0	17.0	16.0	6.9	6.4	7.1

POC ORIGINAL



Milk  
Iodine - 131 (pCi/L)

$40 \mu\text{m}/\text{m}^3$   $\text{Ba}(\text{NO}_3)_2$  added to each sample.

Page 4 of 4

	Sample	5/28	5/29	5/30	5/31
18	Alvina Farm	4B1 <0.3	<0.2	<0.3	<0.5†
20	Becker Farm	7B3 <0.2	<0.2	<0.4	<0.2
20	Becker Farm	7B3Q <3.56	<0.2	<1.2	<0.2
-	Fisher Farm	14D1 <0.2	<0.3	<0.5	<0.4
36	Oellig Farm	2G1 <0.2	<0.4	<0.2	<0.3
45	Hardison Farm	1B1 <0.5	<0.3	<0.4	<0.4

Fig. 18  
Lab.

702-121

Note: Composite samples are taken at BE1 and BE2  
 \*Indicates Finished (Treated) Water

TOPURE-131

Water  
 µCi/l

X = result by radiochemistry  
 (X) = " " Gamma Spec

Page	1 of 3	Sample	5/1	5/2	5/3	5/4	5/5	5/6	5/7	5/8	5/9	5/10	5/11	5/12
1		Savannah Creek	IC1	<0.4	<0.3	<0.4	<0.6	<0.5	<0.2	<0.4	<0.3	<0.2	<0.2	<0.4
7		Savannah Creek	IC3Q	<0.4	<0.5	0.7	0.7	0.5	0.6	<0.5	0.6	<0.2	<0.1	<0.4
8		Brunner Island	BE1	<0.3	<0.5	<0.3	<0.4	<0.3	<0.3	<0.5	<0.5	<0.2	<0.3	<0.5
8		Brunner Island	BE1*	<0.2	<0.4	<0.4	<0.4	<0.4	<0.4	<0.5	<0.5	<0.3	<0.5	<0.5
8		Columbia Water Plant	7G1	<0.4	<0.5	<0.3	<0.3	<0.3	<0.4	<0.4	<0.5	<0.4	<0.3	1.3
8		Columbia Water Plant	7G1Q	<0.3	<0.3	<0.3	<0.4	<0.3	<0.4	<0.3	<0.5	<0.3	<0.3	1.5
15		Steelton Water Works	15F1*	<0.2	<0.5	<0.4	<0.2	<0.3	<0.4	<0.4	<0.3	<0.3	<0.5	0.7
15		Steelton Water Works	15F1Q*	<0.3	<0.3	<0.2	<0.3	<0.3	<0.4	<0.5	<0.4	<0.2	<0.6	0.8
8		YRF5	BC2	<0.3	<0.4	<0.4	<0.5	<0.4	<0.4	<0.5	<0.5	<0.4	<0.5	<0.4
8		YRF5	BC2Q	<0.5	<0.3	<0.2	<0.3	<0.4	<0.3	<0.4	<0.3	<0.4	<0.6	<0.6
8		Dunbarville Fil.	1031	2.2	2.7	<0.4	<0.3	1.4	<0.3	0.43	0.67	0.5	7.2	<0.4
8		Dunbarville Fil.	1031Q	2.7	3.9	<0.4	<0.5	2.0	<0.5	<0.5	0.7	<0.7	6.2	1.4
8		York	9G2*	<0.5	<0.4	<0.4	<0.3	<0.3	<0.3	<0.3	<0.3	<0.4	<0.4	<0.4
8		York	9G2Q*	<0.3	<0.3	<0.3	<0.3	<0.3	<0.4	<0.3	<0.3	<0.4	<0.6	<0.7
8		Wrightsville	7G2	<0.5	<0.4	<0.4	<0.3	<0.3	<0.3	<0.3	<0.3	<0.4	<0.5	<0.4
8		Wrightsville	7G2*	<0.3	<0.4	<0.3	<0.3	<0.3	<0.3	<0.4	<0.2	<0.4	<0.5	<0.3



Note: Composite samples are taken at 001, 022, 701 (starting 5/17) and 1051 (starting 5/15)  
 \* Indicates Finished (Treated) Water

Water  
 µCi/L

100FPC-131

Page 2 of 3

Sample	5/13	5/14	5/15	5/16	5/17	5/18	5/19	5/20	5/21	5/22	5/23	5/24
Swatara Creek	<0.3	<0.2	<0.2	<0.4	<0.5	<0.4	<0.3	<0.5	<0.8	<0.5	<0.3	<0.5
Swatara Creek	<0.5	<0.2	<0.3	<0.3	<0.5	<0.6	<0.4	<0.3	<0.4	<0.5	<0.2	<0.4
Brunner Island	<0.3	<0.4	<0.3	<0.5	<0.4	<0.5	<0.5	<0.7	<0.4	<0.4	<0.5	<0.4
Brunner Island	0.5	<0.4	<0.3	<0.5	<0.4	<0.4	<0.4	<0.4	<0.3	<0.4	<0.5	<0.4
Columbia Water Plant	0.6	<0.3	<0.3	<0.4	<0.5	<0.5	<0.5	<0.3	<0.6	<0.5	<0.5	0.6
Columbia Water Plant	<0.7	<0.4	<0.3	<0.4	<0.5	<0.3	<0.3	<0.4	<0.4	<0.6	0.6	0.9
Steelton Water Works	0.4	<0.3	<0.4	<0.5	<0.5	<0.4	<0.5	<0.3	0.96	<0.5	<0.7	<0.6
Steelton Water Works	<0.7	<0.4	<0.4	<0.2	<0.5	<0.4	0.3	<0.5	<0.5	0.8	<0.5	<0.4
YRCS	<0.3	<0.3	<0.3	-	<0.3	<0.4	<0.4	<0.5	<0.5	<0.5	<0.5	<0.7
YRCS	<0.5	<0.3	<0.3	<0.4	<0.5	<0.5	<0.4	<0.2	<0.3	<0.8	<0.4	<0.5
Discharge Pit	14.0	2.1	0.48	<0.5	<0.4	<0.4	<0.5	<0.6	<0.4	9.7	<0.6	<0.6
Discharge Pit	16.0	2.0	<5.9	<0.7	0.5	<0.5	<0.5	2.1	<0.7	1.6	<0.4	0.7
York	<0.5	<0.5	<0.3	<0.4	<0.4	<0.4	<0.5	<0.4	<0.5	<0.5	<0.5	<0.6
York	<0.5	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.2	<0.3	<0.5
Wrightsville	<0.2	<0.5	<0.5	<0.4	<0.5	<0.5	<0.4	<0.4	<0.3	<0.6	<0.5	<0.6
Wrightsville	<0.3	<0.5	<0.5	<0.3	<0.5	<0.5	<0.5	<0.7	<0.8	<0.5	<0.5	<0.4

542 123



Page 3 of 3	Sample	5/25	5/26	5/27	5/28	5/29	5/30	5/31
77	Savanna Creek	<0.4	<0.3	<0.3	<0.2	<0.5	<0.5	<0.2
77	Savanna Creek	<0.2	<0.4	<0.3	<0.4	<0.4	<0.5	<0.4
79	Brunner Island	<0.4	<0.6	<0.5	<0.3	<0.4	<0.5	<0.5
79	Brunner Island	<0.5	<0.4	<0.4	<0.3	<0.5	<0.5	<0.5
83	Columbia Water Plant	1.7	<0.3	<0.5	<0.3	<0.4	<0.5	0.76
83	Columbia Water Plant	2.5	<0.5	0.3	<0.4	<0.3	<0.5	0.78
85	Steeleton Water Works	<0.5	<0.5	<0.6	<0.4	<0.3	<0.3	<0.5
85	Steeleton Water Works	<0.4	<0.4	<0.4	<0.3	<0.4	<0.5	<0.1
88	Y1003	<0.6	<0.8	<0.6	<0.6	<0.4	<0.4	<0.5
88	Y1003	<0.4	<0.4	<0.3	<0.2	<0.3	<0.5	<0.1
89	Discharge Pit	0.64	0.50	<0.5	<0.4	<0.5	<0.5	
89	Discharge Pit	<0.5	1.9	<0.4	<0.5	<0.4	1.41	1.08
89	York	<0.7	<0.5	<0.5	<0.5	<0.3	<0.5	
89	York	<0.5	<0.3	<0.4	<0.3	<0.3	<0.1	<0.1
89	Wrightsville	<0.8	<0.3	<0.5	<0.7	<0.7	<0.7	
89	Wrightsville	<0.5	<1.0	<0.5	<0.6	<0.6	<0.6	

542 174

Note: Composite samples are taken at SBL and RCR  
 \*Indicates Finished (Treated) Water

GROSS DATA

Water  
 TDS/L

Page 1 of 1

Sample	5/1	5/2	5/3	5/4	5/5	5/6	5/7	5/8	5/9	5/10	5/11	5/12
Sabara Creek	2.0	2.6	9.7	3.6	3.5	2.4	2.5	1.9	2.6	2.5	2.7	4.6
Sabara Creek	<3.1	<3.3	<3.3	2.2	2.2	3.4	3.4	2.1	2.9	2.7	<3.2	5.0
Brunner Island	3.0	2.9	3.1	0.6	3.6	3.0	3.1	2.2	3.2	3.1	2.4	2.1
Brunner Island	2.5	<1.0	2.3	<1.0	<1.0	<1.0	3.0	<1.0	2.2	1.9	1.6	<1.0
Columbin Water Plant	2.5	1.9	2.4	4.2	-	3.0	2.5	5.2	2.6	2.3	2.6	4.8
Columbia Water Plant	<3.3	<3.3	<3.3	2.2	2.7	3.4	4.0	<3.0	<3.0	2.5	3.1	6.7
Steelton Water Works	1.6	2.5	1.8	2.7	3.0	2.0	2.3	1.8	1.3	1.9	<1.0	2.2
Steelton Water Works	<3.1	<3.3	<3.3	<3.0	3.6	3.9	2.6	<3.0	<3.0	2.2	7.7	<2.7
YRGS	2.7	1.9	1.4	2.8	1.8	1.4	<1.0	1.3	<1.0	1.6	1.4	1.5
YRGS	<3.1	<3.3	<3.3	<3.0	2.2	4.2	2.7	<3.0	<3.0	3.3	2.2	2.1
Discharge Pit	6.5	7.7	2.3	2.2	7.7	2.2	2.1	2.7	2.0	1.9	2.0	2.2
Discharge Pit	<3.3	6.1	3.1	2.9	10.9	2.6	2.6	<3.0	<3.0	3.4	6.0	2.0
York	1.4	2.3	1.4	1.9	2.2	1.7	2.1	1.9	2.6	2.1	2.7	1.8
York	<3.3	<3.3	<3.3	<3.0	<3.0	<3.4	3.8	<3.0	<3.0	<3.2	<3.2	2.5
Wrightsville	2.9	2.0	2.9	2.5	3.3	4.1	3.4	2.1	2.8	2.8	1.9	3.8
Wrightsville	2.4	2.7	2.2	2.3	2.0	2.3	2.7	2.4	2.7	3.2	4.0	2.6



CROSS DATA

Water  
PC1/2

Note: Composite samples are taken at 061, 062, 701 (starting 5/15), and 1031 (starting 5/19).  
\* Indicates Finished (Treated) Water.

Page 2 of 3

Sample	5/13	5/14	5/15	5/16	5/17	5/18	5/19	5/20	5/21	5/22	5/23	5/24
1031 Sealara Creek	3.6	3.3	3.1	2.7	3.0	3.7	5.3	3.1	2.9	3.3	3.2	
1030 Sealara Creek	3.9	2.3	3.1	2.7	2.1	2.4	<3.3	3.7	2.9	4.0	3.7	2.4
061 Brunner Island	2.8	3.4	2.7	3.5	3.7	3.7	3.0	3.8	3.7	3.4	2.2	
062 Brunner Island	<1.0	<0.9	1.8	1.0	3.0	<0.9	1.1	6.7	<1.0	<1.0	2.0	
701 Columbia Water Plant	2.2	1.9	2.4	2.2	4.4	3.5	3.4	2.2	2.6	1.4	2.7	
701Q Columbia Water Plant	<2.7	3.2	3.4	<2.8	<2.8	<3.3		3.0	2.5	4.1	3.3	2.8
15F1 Steelton Water Works	1.7	2.2	1.6	2.7	2.1	2.3	1.7	2.7	1.9	2.1	1.5	
15F1Q Steelton Water Works	<2.7	<3.4	<3.4	2.3	<2.8	<3.3	<3.3	3.4	2.3	2.8	3.6	2.0
062 YOC	1.5	2.2	2.0	2.3	2.0	1.9	2.3	<1.0	1.7	1.1	1.6	2.0
062Q YOC	2.5	<3.4	<3.4	<2.8	<2.8	<3.3	<3.3	<3.2	<3.2	4.5	2.2	2.8
1031 Discharge P1	3.3		2.9	2.6	2.1	3.0	3.3	5.1	8.0	4.0	3.1	
1031Q Discharge P1	1.2	5.0	<3.4	<2.0	<2.8	<3.3	3.3	3.8	4.8	5.9	4.8	2.8
YORK	1.7	2.2	2.0	2.0	3.1	1.7	2.4	2.2	1.9	1.8	2.1	2.2
YORK	<2.7	<3.4	<3.4	2.1	<2.8	4.7	<3.3	<3.3	<3.2	3.7	3.7	2.0
702 Wrightsville	2.3	2.2	3.5	3.2	3.8	4.0	4.3	3.3	3.2	2.4	2.4	5.4
702Q Wrightsville	2.6	3.1	3.4	2.8	2.4	3.7	2.4	3.7	2.4	3.0	2.5	3.6

542 170



Note: Composite samples are taken at BE1, BE2, 701, 1031  
 \*Indicates Finished (Treated) Water

GROSS BETA

Water  
 pCi/l

Page 3 of 3

Sample 5/25 5/26 5/27 5/28 5/29 5/30 5/31

Sample	5/25	5/26	5/27	5/28	5/29	5/30	5/31
Swatara Creek	6.9	5.9	3.9	4.7			
Swatara Creek	3.8	2.0	4.3	2.7	2.5	4.0	
Brunner Island	BE1	8.3	7.4	7.8	4.2		
Brunner Island	BE1*	2.4	4.5	1.9	<0.9		
Columbia Water Plant	761	3.8	3.4	2.6	2.6		
Columbia Water Plant	761Q	3.3	3.1	2.6	3.9	2.3	3.4
Steelton Water Works	15F1*	2.1	3.5	1.7	1.8		
Steelton Water Works	15F1Q*	2.2	2.2	<2.6	2.9	2.2	2.3
YORK	BE2	2.1	3.6	4.2	2.6		
YORK	BE2Q	<2.6	3.0	3.2	2.6	3.5	<3.1
Discharge P1	1031	16.0	6.3	13.1	9.2		
Discharge P1	1031Q	5.8	4.1	2.2	11.0	6.7	3.6
York	902*	2.9	2.8	3.8	2.5	2.4	
York	902Q*	2.8	<3.1	2.6	2.7	3.1	<3.1
McChesville	702	8.9	7.5	7.1	5.0	3.4	
McChesville	702*	3.6	3.7	4.0	3.5	3.4	

# POOL ORIGINAL

Air Purifications - Air Iodine  
(Green Book)  
1941/42

Page	I of I	Station	5/3 -		5/9 -		5/12 -		5/15 -		5/18 -		5/21 -		5/24 -		5/27 -		5/30 -	
			5/3	5/6	5/9	5/12	5/15	5/18	5/21	5/24	5/27	5/30	5/21	5/24	5/27	5/30	5/21	5/24	5/27	5/30
2		Beeth Weather Station	0.059	0.067	0.060	0.033	0.046	0.030	0.043	0.041	0.053	0.064								
26		Falmouth Sub.	0.052	0.074	0.039	0.021	0.04	0.026	0.036	0.027	0.034									
14		Observation Contr.	0.036	0.075	0.037	0.027	0.053	0.020	0.020	0.025	0.032									
10		West Fairview	0.060	0.054	0.062	0.036	0.036	0.032	0.037	0.026	0.042									
30		Ingber Farm	0.11	0.070	0.086	0.089	0.14	0.087	0.089	0.059	0.10									
31		Ingber Farm	0.053	0.039	0.053	0.077	0.039	0.029	0.042	0.039	0.065									
6		Middleton	0.058	0.053	0.048	0.046	0.059	0.039	0.041	0.029	0.055									
20		Middleton	0.046	0.055	0.030	0.037	0.061	0.036	0.038	0.030	0.057									
3		Goldboro Air Station	0.057	0.180	0.050	0.032	0.054	0.034	0.035	0.027	0.043									
35		North York Sub.	0.051	0.080	0.045	0.049	0.045	0.028	0.039	0.026	0.040									

2		Beeth Weather Station	<0.081	<0.10	<0.09	<0.07	<0.08	<0.09	<0.07	<0.08	<0.04
26		Falmouth Sub.	<0.083	<0.077	<0.10	<0.04	<0.09	<0.05	<0.05	<0.08	<0.08
14		Observation Contr.	0.077	<0.075	<0.07	<0.05	<0.06	<0.06	<0.05	<0.06	<0.06
10		West Fairview	<0.087	<0.057	<0.06	<0.08	<0.05	<0.09	<0.07	<0.09	<0.08
30		Ingber Farm	<0.13	<0.073	<0.08	<0.10	<0.10	<0.06	<0.05	<0.10	<0.10
31		Ingber Farm	<0.057	<0.056	<0.056	<0.050	<0.056	<0.033	<0.059	<0.067	<0.079
6		Middleton	<0.062	<0.10	<0.07	<0.10	<0.08	<0.07	<0.06	<0.10	<0.10
20		Middleton	<0.057	<0.057	<0.056	<0.069	<0.061	<0.052	<0.081	<0.069	<0.080
3		Goldboro Air Station	<0.085	<0.057	<0.08	<0.08	<0.08	<0.07	<0.05	<0.09	<0.10
35		North York Sub.	<0.070	<0.057	<0.07	<0.07	<0.06	<0.06	<0.05	<0.08	<0.08



Note: Composite samples are taken at BE1 and BE2  
 \* Indicates Finished (Treated) Water

Water  
 1/31/82

Rev. 1

Page 1 of 5

Sample	4/7	4/8	4/9	4/10	4/11	4/12	4/13	4/14	4/15	4/16	4/17	4/18
Sealana Creek	<206	<292	<216	205	<273	<262	<283	<268	<256	<207		
Brunner Island	110	150	150	<120	100	320	110	100	130	280	210	160 150
Brunner Island	100	100	100	120	<110	110	<100	180	130	270	190	180 100
Columbia Water Plant	270	160	100	110	100	120	100	100	<120	200	190	160
Columbia Water Plant	<286	190	<216	<264	<273	<262	<283	<268	<309	<256	139	<305
Steelton Water Works	180	120	100	110	110	150	<100	150	160	190	140	120
Steelton Water Works	<206	<292	<216	<273	<273	<283	<283	<268	<309	<256	<207	<305
YIGS	110	110	110	140	190	210	150	160	120	260	110	<100
YIGS	<286	<292	<216	<273	<262	<283	<244	<268	<309	<256	<207	<305
Discharge Pit	<130	270	140	510	100	120	2920	220	3690	170	2770	170
Discharge Pit	<292	<264	181	506	183	<244	2880	<309	3990	<256	2440	<250
York	<130	<110	120	<110	140	160	240	150	<110	130	<110	160
York	<206	142	<216	<273	<262	<283	<283	<268	<309	<256	<207	<305

POOL  
 CLEAN  
 AREA



# POC ORIGINAL

Water Composite samples are taken at 8:31 and 8:55  
 \*Indicates Finished (Treated) Water

Water  
 1431/2

Page 2 of 2	Sample	4/19	4/20	4/21	4/22	4/23	4/24	4/25	4/26	4/27	4/28	4/29	4/30
27	Beatara Creek	270	140	280	170	230	190						
27	Beatara Creek	<205	<287	<287	<312	<270	<220	<220	<279	<226	<272	<235	<262
30	Brunner Island	300	270	<100	90	260	130				100	320	
30	Brunner Island	270	390	190	<110	160	160				220	170	
30	Columbia Water Plant	160	270	200	410	360	400	310			270		
30	Columbia Water Plant	<250	<287	<250	<312	<270	<220	<220	<279	<226	<272	210	<262
35	Steeleton Water Works	210	210	260	260	150	310	390			210	170	
35	Steeleton Water Works	<250	<287	<250	<312	100	<220	<252	<279	<226	<272	<235	<262
48	Y1022	<110	200	190	140	100	100	100					
48	Y1025	<250	<287	<250	<312	233	<220	<252	<279	<226	<272	<235	<262
48	Discharge #11	370	2240	150	240	2290	2580	<120		1570	1660		
48	Discharge #11	<250	2640	<262	235	1980	1920	<252	<279	1280	1400	<243	1130
48	York	120	180	110	299	310	240	100			160	330	
48	York	<250	<287	<220	<312	<270	<213	<252	<279	<226	<272	166	<262
48	Wrightsville				200	260	180	280					170
48	Wrightsville				260	<110	200	110			170		

Note: Composite samples are taken at B3 and B22  
 \* Indicates Finished (Treated) Water

Water TUFFLOW  
 10:1/2

Page	3 of 5	Sample	5/1	5/2	5/3	5/4	5/5	5/6	5/7	5/8	5/9	5/10	5/11	5/12
27	Seaton Creek	103R	220	<260	<262	<273	<304	<271	218	<277	<277	<256	<309	<277
28	Brunner Island	B021												
29	Brunner Island	B021*												
30	Columbia Water Plant	761												
31	Columbia Water Plant	701Q	<260	<260	160	<273	<304	<271	<300	<277	<253	<256	<309	<277
32	Glendon Water Works	15F1*												
33	Glendon Water Works	15F1Q*	<243	<260	<242	<273	<304	<271	<264	<277	<253	<256	<309	<277
34	York	B022												
35	York	B022Q	<243	<268	<242	<273	<304	<271	<264	<277	<253	<256	<309	<277
36	Discharge Pit	10S1												
37	Discharge Pit	10S1Q	2300	4110	<266	<266	1820	<300	<300	<253	<256	<309	<309	<308
38	York	902*												
39	York	902Q*	<268	<242	<266	<273	<304	<271	<264	<277	<253	213	<309	<277
40	Wrightsville	762												
41	Wrightsville	762*												

100% ORIGINAL



Note: Composite samples are taken at BE1, BE2, G61 (starting 5/17), and 10S1 (starting 5/15)  
 \*Indicates Finished (Treated) Water

Water 10000000  
 10000000

Page	4 of 5	Sample	5/13	5/14	5/15	5/16	5/17	5/18	5/19	5/20	5/21	5/22	5/23	5/24
27		Sentara Creek												
27		1030	<308	<211	<211	<197	<197	<196	<278	147	<276	<264	<211	<180
30		Bruner Island												
30		861												
38		Columbia Water Plant												
38		701												
38		Columbia Water Plant												
38		701Q	<308	<211	<274	<197	<269	<196	<278	147	<200	<264	<211	<188
39		Steelton Water Works												
39		1581*												
39		Steelton Water Works												
39		1581Q*	<308	<211	<274	<197	162	<196	<278	<194	<200	<264	<211	141
48		Y1055												
48		Y1055												
48		Y1055	<308	<211	<274	<269	<269	<196	<278	<194	<200	<264	<211	<188
48		Discharge P/L												
48		10S1												
48		Discharge P/L												
48		10S1Q	202	717	<267	<269	<269	<278	<278	161	853	<211	<211	<267
48		York												
48		962*												
48		York												
48		962Q*	<308	<211	<274	<197	<269	<196	<278	<194	<200	<264	<211	<188
48		Wrightsville												
48		762												
48		Wrightsville												
48		762*												

FOR ORIGINAL



Note: Composite samples are taken at 081, 082, 761, 762, 761, 762 Water  
 \*Indicates Finished (Treated) Water

Page 5 of 5

Sample	5/25	5/26	5/27	5/28	5/29	5/30	5/31
Southern Creek 101							
Southern Creek 101R	<188	<197	<197	<266	196	<179	<260
Brewer Island 081							
Brewer Island 081*							
Columbia Water Plant 761							
Columbia Water Plant 761Q	<267	<197	<280	<266	131	<179	<260
Steelton Water Works 151*							
Steelton Water Works 151Q*	<267	<197	<280	<266	<180	<179	<268
York 082							
York 082Q	<267	<197	<280	204	<100	<179	<260
Discharge Pit 10S1							
Discharge Pit 10S1Q	1100	381	<182	172	925	112	1043
York 962*							
York 962Q*	173	<197	<280	<266	<180	192	<260
Whiteville 762							
Whiteville 762*							

POOL ORIGINAL

Appendix C

Information On Potential Radiological Doses For The Noted Pathways And Periods

Waterborne Pathways

<u>Location</u>	<u>Period</u>	<u>Isotope and Average Concentration*</u>
TH-SW-RE1	3/29-4/29	H-3 = 164 pCi/l
	3/29-5/29	I-131 = None detected
	3/29-4/13	γ = No reactor produced radionuclides detected
TH-SW-7G1	3/29-4/29	H-3 = 194 pCi/l
	3/29-5/29	I-131 = 0.38 pCi/l
	3/29-4/13	γ = No reactor produced radionuclides detected
TH-SW-7G2	4/24-4/29	H-3 = 152 nCi/l
	4/22-5/29	I-131 = 0.44 pCi/l
	Not available	γ =
TH-SW-9G2	4/1-4/29	H-3 = 176 nCi/l
	4/1-5/29	I-131 = None detected
	4/1-4/13	γ = No reactor produced radionuclides detected
Susquehanna River South of TH	3/29-4/29	H-3 = 166 pCi/l
	3/29-5/29	I-131 = 0.35 nCi/l
	3/29-4/12	γ = No reactor produced radionuclides detected

\*For purposes of averaging values at or below the detection limit were considered to be the value of the detection limit.

Waterborne Pathways (continued)

<u>Pathway</u>	<u>Location</u>	<u>Radionuclide</u>	<u>Organ</u>	<u>Dose: mrem/period</u>		
				<u>Maximum Individual</u>	<u>Average Individual</u>	<u>Man-rem</u>
Drinking Water	TM-SW-8E1	H-3	Whole body	1.1E-3	6.4E-5	1.6E-5
	TM-SW-7G1	H-3	Whole body	1.3E-3	7.6E-4	7.6E-3
	TM-SW-7G1	I-131	Thyroid	8.9E-2	5.3E-2	-
	TM-SW-7G2	H-3	Whole body	2.0E-4	1.2E-4	3.7E-4
	TM-SW-7G2	I-131	Thyroid	6.5E-2	3.9E-2	-
	TM-SW-9G2	H-3	Whole body	1.1E-3	6.4E-4	8.0E-2
Eating Fish	River	H-3	Whole body	2.5E-5	2.9E-6	-
	River	I-131	Thyroid	3.3E-2	3.7E-3	-
Swimming	River	H-3	Whole body	0	0	-
	River	I-131	Whole body	4.1E-6	1.7 E-7	-
Boating	River	H-3	Whole body	0	0	-
	River	I-131	Whole body	2.1E-6	8.5E-8	-
Shoreline	River	H-3	Whole body	0	0	-
	River	I-131	Whole body	1.3E-5	5.5E-3	-



Milk Pathway (cow's milk only)

<u>Location</u>	<u>Radionuclide and Average Concentration</u>	<u>Period</u>	<u>Organ</u>	<u>Dose: mrem/period</u>
TM-M-783	I-131 = 1.8 pCi/l	3/29-5/29	Infant Thyroid	1.5
All locations	I-131 = 0.8 pCi/l	3/29-5/29	Infant Thyroid	0.7

Inhalation of Radioiodine

<u>Location</u>	<u>Average Concentration</u>	<u>Period</u>	<u>Organ</u>	<u>Dose: mrem/period</u>
TM-AI-5A1	1.70 pCi/m <sup>3</sup>	3/22-5/27	Adult Thyroid	3.7
TM-AI-1C1	0.76 pCi/m <sup>3</sup>	3/22-5/27	Adult Thyroid	1.7
TM-AI-12B1	1.32 pCi/m <sup>3</sup>	3/22-5/27	Adult Thyroid	2.9