



UNITED STATES
 NUCLEAR REGULATORY COMMISSION
 WASHINGTON, D. C. 20555

October 22, 1979

Docket No. 50-320



Mr. R. C. Arnold
 Senior Vice President
 Metropolitan Edison Company
 269 Cherry Hill Road
 Parsippany, New Jersey 07054

Dear Mr. Arnold:

Based on the Commission's instructions in its Memorandum and Order dated October 16, 1979, the Director, Office of Nuclear Reactor Regulation, has issued the enclosed Order for Modification of License dated October 18, 1979, and Negative Declaration dated October 18, 1979. The Order amends Facility Operating License No. DPR-73 for Three Mile Island Nuclear Station, Unit No. 2.

These documents relate to the operation of an EPICOR-II filtration and ion exchange decontamination system to decontaminate intermediate-level radioactive waste water held in tanks in the TMI-2 auxiliary building.

Copies of this Order and the Negative Declaration are being filed with the Office of the Federal Register for publication.

Sincerely,

Richard H. Vollmer, Acting Assistant Director
 for Systematic Evaluation Program
 Division of Operating Reactors

Enclosures:

1. Order for Modification of License
2. Negative Declaration

cc w/enclosures:
 See next page

1002 296

Dr. Walter H. Jordan
881 W. Outer Drive
Oak Ridge, Tennessee 37830

cc w/enclosure(s):

POOR ORIGINAL

Mr. Marvin I. Lewis
6504 Bradford Terrace
Philadelphia, Pennsylvania 19149

Dr. Linda W. Little
5000 Hermitage Drive
Raleigh, North Carolina 27612

Walter K. Cohen, Consumer Advocate
Department of Justice
Strawberry Square, 14th Floor
Harrisburg, Pennsylvania 17127

Holly S. Keck
Anti-Nuclear Group Representing
York
245 W. Philadelphia Street
York, Pennsylvania 17404

Robert L. Knupp, Esq.
Assistant Solicitor
Knupp and Andrews
P.O. Box P
407 W. Front Street
Harrisburg, Pennsylvania 17108

John Levin, Esq.
Pennsylvania Public Utilities Comm.
Box 3265
Harrisburg, Pennsylvania 17120

John E. Minnich, Chairman
Dauphin Co. Board of Commissioners
Dauphin County Courthouse
Front and Market Sts.
Harrisburg, Pennsylvania 17101

Jordan O. Cunningham, Esq.
Fox, Farr and Cunningham
2320 North 2nd Street
Harrisburg, Pennsylvania 17110

• Atomic Safety and Licensing Appeal Board
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Ms. Kathy McCaughin
Three Mile Island Alert, Inc.
23 South 21st Street
Harrisburg, Pennsylvania 17104

• Atomic Safety and Licensing Board Panel
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Ms. Marjorie M. Aamodt
R.D. #5
Coatesville, Pennsylvania 19320

• Socketing and Service Section
U.S. Nuclear Regulatory Commission
Washington, D. C. 20555

Ms. Karen Sheldon
Sheldon, Harmon, Roisman & Weiss
1725 I Street, N. W.
Suite 506
Washington, D. C. 20036

Robert C. Pollard
Chesapeake Energy Alliance
609 Montpelier Street
Baltimore, Maryland 21218



Earl B. Hoffman
Dauphin County Commissioner
Dauphin County Courthouse
Front and Market Streets
Harrisburg, Pennsylvania 17101

Chauncey Kepford
Judith H. Johnsrud
Environmental Coalition on Nuclear Power
433 Orlando Avenue
State College, Pennsylvania 16801

Ellyn Weiss, Esq.
Sheldon, Harmon, Roisman & Weiss
1725 I Street, N.W.
Suite 506
Washington, D.C. 20006

Ms. Frieda Berryhill, Chairman
Coalition for Nuclear Power Plant
Postponement
2610 Grendon Drive
Wilmington, Delaware 19808

Mr. Steven C. Sholly
304 South Market Street
Mechanicsburg, Pennsylvania 17055

Mrs. Rhoda O. Carr
1402 Marlene Drive
Harrisburg, Pennsylvania 17109

Mr. Thomas Gerusky
Bureau of Radiation Protection
Department of Environmental Resources
P.O. Box 2063
Harrisburg, Pennsylvania 17120

1002 297

Metropolitan Edison Company

-2-

cc w/enclosure(s):

G. F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
1830 H Street, N.W.
Washington, D. C. 20036

GFU Service Corporation
Richard W. Heward, Project Manager
Mr. E. G. Wallace
Licensing Manager
260 Cherry Hill Road
Persippany, New Jersey 07054

Pennsylvania Electric Company
Mr. R. W. Conrad
Vice President, Generation
1001 Broad Street
Johnstown, Pennsylvania 15907

Miss Mary V. Southard, Chairman
Citizens for a Safe Environment
Post Office Box 405
Harrisburg, Pennsylvania 17108

Government Publications Section
State of Library of Pennsylvania
Box 1501 (Education Building)
Harrisburg, Pennsylvania 17126

Dr. Edward J. Swartz
Board of Supervisors
Lancaster Township
RFD-1 - Geyers Church Road
Middletown, Pennsylvania 17057

U. S. Environmental Protection Agency
Region III Office
ATTN: EIS COORDINATOR
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, Pennsylvania 19106

Mr. J. G. Herbein
Vice President
Metropolitan Edison Company
P. O. Box 430
Middletown, Pennsylvania 17057

Ms. Jane Lee
R.D. 3; Box 3521
Etters, Pennsylvania 17319

Karin W. Carter, Esq.
505 Executive House
P. O. Box 2357
Harrisburg, Pennsylvania 17120

Honorable Mark Cohen
512 E-3 Main Capital Building
Harrisburg, Pennsylvania 17120

Dauphin County Office Emergency
Preparedness
Court House, Room 7
Front & Market Streets
Harrisburg, Pennsylvania 17101

Department of Environmental Resources
ATTN: Director, Office of Radiological
Health
Post Office Box 2063
Harrisburg, Pennsylvania 17105

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection Agency
Crystal Mall #2
Arlington, Virginia 20460

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, Maryland 20014

POOR ORIGINAL

Governor's Office of State Planning
and Development
ATTN: Coordinator, Pennsylvania
State Clearinghouse
P. O. Box 1323
Harrisburg, Pennsylvania 17120

1002 298

RELATED CORRESPONDENCE

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION

In the Matter of
METROPOLITAN EDISON COMPANY, ET AL.
(Three Mile Island Nuclear
Station, Unit 2)

Docket No. 50-320



ORDER FOR MODIFICATION OF LICENSE

I. POOR ORIGINAL

Metropolitan Edison Company, Jersey Central Power and Light Company and Pennsylvania Electric Company (the licensee) are the holders of Facility Operating License No. DPF-73, which had authorized operation of the Three Mile Island Nuclear Station, Unit 2 (TMI-2) at power levels up to 2772 megawatts thermal. The facility, which is located in Londonderry Township, Dauphin County, Pennsylvania, is a pressurized water reactor used for the commercial generation of electricity.

II.

On October 16, 1979, the Commission issued a Memorandum and Order directing the licensee to operate an EPICOR-II filtration and ion exchange decontamination system to decontaminate intermediate-level radioactive waste water now held in tanks in the TMI-2 auxiliary building. The factual bases underlying this directive are set forth fully in the Memorandum and Order and will not be restated herein. Additionally, the Commission recog-

1002 299

POOR ORIGINAL

nized that operation of EPICOR-II will add several gaseous effluent discharge paths to those previously listed in the TMI-2 operating license. The Commission further observed that its regulations in 10 C.F.R. Part 50, Appendix A, General Design Criteria for Nuclear Power Plants (GDC 64) require that the new discharge paths be monitored. Though the Commission deemed it not necessary as a legal matter to amend the TMI-2 operating license technical specifications to assure that monitoring will be conducted, it expressed the belief that the Commission's inspection and enforcement program would be simplified if the requirements for discharge path monitoring and those provisions set forth in paragraphs 1, 2 and 3 of its Order are spelled out in the operating license that can be readily referenced by the licensee and Commission inspectors. The Commission instructed the Director, Office of Nuclear Reactor Regulation (NRR) to promptly issue an order for modification of the TMI-2 operating license to (a) add EPICOR-II discharge paths to those presently listed in the Technical Specifications as requiring monitoring under GDC 64, and (b) include the provisions of paragraphs 1, 2 and 3 of its Order, and to provide that, within 20 days of the date of its Order, a hearing may be requested.

III.

Accordingly, pursuant to the Atomic Energy Act of 1954, as amended, and the Commission Memorandum and Order of October 16, 1979, IT IS ORDERED THAT:

Facility Operating License No. OPR-73 for the Three Mile Island Nuclear Station, Unit 2, be amended, in the manner hereinafter provided, to include the following conditions:

1002 300

(i) The technical specifications requiring monitoring under GDC 64 are hereby amended as reflected in the appendix hereto in order to add EPICOR-II discharge paths.

(ii) The licensee shall promptly begin the process of decontaminating the intermediate-level waste water from TMI-2 by operating EPICOR-II. Prior to operation, the licensee shall consult the Director of NRR for approval of the final operating procedures and design and construction details. In order to reduce the inherent risk from the contaminated water most expeditiously and prudently, the licensee should to the extent possible process all the water once through the EPICOR-II system.

(iii) The licensee shall maintain suitable tankage at TMI-1 that could be used to store waste water from TMI-2 at an appropriate state of readiness, should additional storage become necessary.

(iv) The licensee shall not ship spent resins offsite unless they have been solidified, and only then with the prior approval of the Director of NRR, provided however, that the licensee may ship non-solidified but dewatered spent resins offsite if it determines, and the Director of NRR concurs, that such shipment is required to assure continued operation of EPICOR-II or otherwise required to protect public health and safety. The licensee shall expeditiously construct a facility for solidification of the spent resins and shall use such facilities for resin solidification upon receiving the Director of NRR's concurrence with the design and operating procedures.

POOR ORIGINAL

IV.

The licensee or any person whose interest may be affected may, on or before November 5, 1979, request a hearing on the proposed amendment pursuant to 10 C.F.R. §2.714 to be held prior to the adoption of the formal license amendment. This amendment will become effective on the expiration of the period during which the licensee or other person may request a hearing, or in the event a hearing is requested, on the date specified in an order made following the hearing.


In the event a hearing is requested, the issues to be considered at such hearing shall be whether the actions taken under this order (a) are necessary and sufficient to protect health and safety or to minimize danger to life and property, and (b) would significantly affect the quality of the human environment.

A request for a hearing by the licensee or another person must be filed with the Office of the Secretary, U.S. Nuclear Regulatory Commission, Washington, DC 20555, Attention: Docketing and Service Section, by the above date. A copy of the request for a hearing should also be sent to the Executive Legal Director, U.S. Nuclear Regulatory Commission, Washington, DC 20555 and to Mr. George F. Trowbridge, Shaw, Pittman, Potts, and Trowbridge, 1300 M Street, NW, Washington, DC 20036, attorney for the licensee. Any questions regarding the contents of this Order should be directed to the Chief Hearing Counsel, Office of the Executive Legal Director, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

1002 302

For further details with respect to this action, see the Commission's Memorandum and Order, dated October 16, 1979, and the documentary references cited therein. This information is available for inspection at the Commission's Public Document Room, 1717 H Street, NW., Washington, DC and at the Commission's Local Public Document Room at the State Library of Pennsylvania, Government Publications Section, Education Building, Commonwealth and Walnut Streets, Harrisburg, Pennsylvania.17126.

FOR THE NUCLEAR REGULATORY COMMISSION



Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Appendix

Dated at Bethesda, Maryland
this 18th day of October, 1979.

1002 303

APPENDIX

POOR ORIGINAL

INSTRUMENTATION

RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.3.10 The radioactive gaseous effluent monitoring instrumentation channels shown in Table 3.3-13 shall be OPERABLE.

APPLICABILITY: As shown in Table 3.3-13.

ACTION:

With less than the minimum number of radioactive gaseous effluent monitoring instrumentation channels OPERABLE, take the ACTION shown in Table 3.3-13.

SURVEILLANCE REQUIREMENTS

4.3.3.10 Each radioactive gaseous effluent monitoring instrumentation channel shall be demonstrated OPERABLE by performance of the CHANNEL CHECK, SOURCE CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table 4.3-13 (per occupational exposure considerations and detector sensitivity in ambient radiation areas).

1002 304

TABLE 3.3-13

RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

<u>INSTRUMENT</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABILITY</u>	<u>ACTION</u>
10. EPICOR-II VENTILATION SYSTEM			
a. Noble Gas Activity Monitor	1	*	37
b. Iodine Sampler	1	*	41
c. Particulate Sampler	1	*	41
d. Flow Rate Monitor	1	*	36
e. Sampler Flow Rate Monitor	1	*	36

TABLE NOTATION

* At all times.

ACTION 36 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided the flow rate is estimated at least once per 4 hours.

ACTION 37 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue for up to 30 days provided grab samples are taken at least once per 8 hours and these samples are analyzed for gross activity within 24 hours.

ACTION 41 - With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via the affected pathway may continue for up to 30 days provided samples are continuously collected with auxiliary sampling equipment as required in Table 4.11-2.

1002 305

TABLE 4.3-13

RADIOACTIVE GASEOUS EFFLUENT MONITORING
INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>INSTRUMENT</u>	<u>CHANNEL CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>
10. EPICOR-II VENTILATION SYSTEM				
a. Noble Gas Activity Monitor	D	M	R(3)	Q(2)
b. Iodine Sampler	W	N.A.	N.A.	N.A.
c. Particulate Sampler	W	N.A.	N.A.	N.A.
d. Flow Rate Monitor	D	N.A.	SA	SA
e. Sampler Flow Rate Monitor	D	N.A.	SA	SA

TABLE NOTATION

POOR ORIGINAL

- (2) CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exist:
1. Instrument indicates measured levels above the alarm setpoint.
 2. Circuit failure (alarm function only).
 3. Instrument indicates a downside failure (alarm function only).
 4. Instrument controls not set in operate mode or the switch position administratively monitored and controlled.
- (3) The initial CHANNEL CALIBRATION shall be performed using one or more of the reference standards certified by the National Bureau of Standards or using standards that have been obtained from suppliers that participate in measurement assurance activities with NBS. These standards shall permit calibrating the system over its intended range of energy and measurement range. For subsequent CHANNEL CALIBRATION sources that have been related to the initial calibration shall be used.

1002 306

APPENDIX B TECHNICAL SPECIFICATIONS

GASEOUS EFFLUENTS

2.1.2.J The release rate of radioactive materials, other than noble gases, in gaseous effluents shall be determined to be within the limits calculated in accordance with this specification by obtaining representative samples and performing analyses in accordance with the sampling and analysis program, specified in Table 4.11-2.

1282 307

TABLE 2.1-1

RADIOACTIVE GASOLINE WASTE SAMPLING AND ANALYSIS PROGRAM

Gaseous Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	Lower Limit of Detection (LLD) (pCi/ml)a
C. Epicore II Ventilation	M ^e Grab Sample	M	Principal Gamma Emission H-3	1x10 ⁻⁴ 1x10 ⁻⁶

POOR ORIGINAL

1002 308

TABLE 2.1-1 (Continued)

TABLE NOTATION

- a. The LLD is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66 s_b}{E \cdot V \cdot 2.22 \cdot Y \cdot \exp(-\lambda \cdot \Delta t)}$$

POOR ORIGINAL

Where

LLD is the lower limit of detection as defined above (as picocurie per unit mass or volume),

s_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute),

E is the counting efficiency (as counts per transformation),

V is the sample size (in units of mass or volume),

2.22 is the number of transformations per minute per picocurie,

Y is the fractional radiochemical yield (when applicable),

λ is the radioactive decay constant for the particular radionuclide, and

Δt is the elapsed time between midpoint of sample collection and time of counting (for plant effluents, not environmental samples).

The value of s_b used in the calculation of the LLD for a detection system shall be based on the actual observed variance of the background counting rate or of the counting rate of the blank samples (as appropriate) rather than on an unverified theoretically predicted variance. In calculating the LLD for a radionuclide determined by gamma-ray spectrometry, the background shall include the typical contributions of other radionuclides normally present in the samples. Typical values of E, V, Y, and Δt shall be used in the calculation. The background count rate is calculated from the background counts that are determined to be within one FWHM (Full-Width-at-Half-Maximum) energy band about the energy of the gamma ray peak used for the quantitative analysis for that radionuclide.

2 309

TABLE 2.1-1 (Continued)

TABLE NOTATION

- e. Tritium grab samples shall be taken at least once per 7 days from the ventilation exhaust from the spent fuel pool area.
- g. The principal gamma emitters for which the LLD specification applies exclusively are the following radionuclides: Kr-87, Kr-98, Xe-133, Xe-133m, Xe-135, and Xe-138 for gaseous emissions and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141 and Ce-144 for particulate emissions. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses shall be reported as "less than" the nuclide's LLD and shall not be reported as being present at the LLD level for that nuclide. The "less than" values shall not be used in the required dose calculations.

POOR ORIGINAL

1002 310

BASES

3/4.3.3.10 RADIOACTIVE GASEOUS EFFLUENT INSTRUMENTATION

The radioactive gaseous effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criterion 64 of Appendix A to 10 CFR Part 50.

2.1.2 GASEOUS EFFLUENTS

This specification is provided to ensure that the dose at any time at the site boundary from gaseous effluents from all units on the site will be within the annual dose limits of 10 CFR Part 20 for unrestricted areas. The annual dose limits are the doses associated with the concentrations of 10 CFR Part 20, Appendix B, Table II, Column 1. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of an individual in an unrestricted area, either within or outside the site boundary, to annual average concentrations exceeding the limits specified in Appendix B, Table II of 10 CFR Part 20 (10 CFR Part 20.105(b)). For individuals who may at times be within the site boundary, the occupancy of the individual will be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the site boundary. The specified release rate limits restrict, at all times, the corresponding gamma and beta dose rates above background to an individual at or beyond the site boundary to less than or equal to 500 mrem/yr to the total body or to less than or equal to 3000 mrem/yr to the skin. These release rate limits also restrict, at all times, the corresponding thyroid dose rate above background to an infant via the cow-milk-infant pathway to less than or equal to 1500 mrem/yr for the nearest cow to the plant.

POOR ORIGINAL

1002 311

UNITED STATES NUCLEAR REGULATORY COMMISSION
NEGATIVE DECLARATION
REGARDING USE OF EPICOR-II SYSTEM
FOR DECONTAMINATION OF INTERMEDIATE LEVEL
RADIOACTIVE WASTE WATER AT
THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 2
DOCKET NO. 50-320

The U. S. Nuclear Regulatory Commission has been considering the use of an EPICOR-II ion exchange decontamination system to decontaminate the intermediate level radioactive waste water which has been held in tanks at Three Mile Island since the accident at the facility on March 28, 1979.

The Commission's Office of Nuclear Reactor Regulation (NRR) prepared an Environmental Assessment, "Use of EPICOR-II at Three Mile Island, Unit 2," NUREG-0591, which concluded that the use of this system will not significantly affect the quality of the human environment, and therefore an Environmental Impact Statement need not be prepared. This Assessment was issued for public comment on August 20, 1979 (44 FR 48829). Comments were received, analyzed and presented to the Commission. Based on the Commission's review of the facts and analysis in NRR's Environmental Assessment and written and oral discussion of the comments, the Commission has determined in its Memorandum and Order, dated October 16, 1979, that the operation of EPICOR-II and the attendant solidification and handling of EPICOR-II resins will not have a significant effect on the environment. Thus, in accordance with the foregoing finding of the Commission, no Environmental Impact Statement for the proposed action will be prepared.

1772 312
DUPLICATE

7911060716

POOR ORIGINAL

The Environmental Assessment (NUREG-0591) and the Commission's Memorandum and Order issued October 16, 1979, are available for public inspection at the Commission's Public Document Room, 1717 H Street, N. W., Washington, D. C., and at the Three Mile Island Unit No. 2 Local Public Document Room in the Government Publications Section, State Library of Pennsylvania, Education Building, Commonwealth and Walnut Streets, Harrisburg, Pennsylvania. Copies may be obtained upon request addressed to the U. S. Nuclear Regulatory Commission, Washington, D. C. 20555, Attention: Richard Vollmer, Director, TMI-2 Support, HRR.

FOR THE NUCLEAR REGULATORY COMMISSION



Harold R. Denton, Director
Office of Nuclear Reactor Regulation

Dated at Bethesda, Maryland
this 3th day of October, 1979

1002 313