

DISTRIBUTION
 Docket No. 50-320
 NRC PDR
 LOCAL PDR
 DCS
 TMI SITE r/f
 TMIPO HQ r/f
 BSnyder
 LBarrett JWiede
 TPointexter LChandler, ELD
 WTravers ACRS
 RWeller HRDenton
 RBellamy IE
 AFasano Service List

DEC 8 1982
 NRC/TMI-82-073-A

Docket No. 50-320

Mr. B. K. Kanga
 Director, TMI-2
 GPU Nuclear Corporation
 P.O. Box 480
 Middletown, PA 17057

Gentlemen:

Subject: Recovery Operations Plan Change Request No. 20

Reference: Letter from L. H. Barrett to B. K. Kanga, same subject, dated November 30, 1982

In the referenced letter the attachment was inadvertently left out when the letter was processed. This letter is forwarding the amended sections to the Recovery Operations Plan as approved Change No. 18.

Original signed by
 Lake H. Barrett

Lake H. Barrett
 Deputy Program Director
 TMI Program Office

Attachment:
 As Stated

cc:
 J. Barton
 L. King
 J. Larson
 J. Byrne
 J. Thiesing
 E. Wallace
 Service Distribution List

8212230056 821208
 PDR ADOCK 05000320
 P PDR

OFFICE	TMI2PS	TMI2PS	TMIPQ	TMIPQ	TMIPQ	
SURNAME	L. P. Ough / Imp.	AFasano	T. P. Oindexter	RBellamy	LBarrett	
DATE	12/6/82	12/7/82	12/6/82	12/8/82	12/8/82	

RONALD C. HAYNES
REGIONAL ADMINISTRATOR, REGION I
U.S. NUCLEAR REGULATORY COMMISSION
631 PARK AVE.
KING OF PRUSSIA, PA. 19406

JOHN F. WOLF, ESQ., CHAIRMAN,
ADMINISTRATIVE JUDGE
3409 SHEPHERD ST.
CHEVY CHASE, MD. 20815

DR. OSCAR N. PARIS
ADMINISTRATIVE JUDGE
ATOMIC SAFETY AND LICENSING
BOARD PANEL
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

DR. FREDERICK J. SHON
ADMINISTRATIVE JUDGE
ATOMIC SAFETY AND LICENSING
BOARD PANEL
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

KARIN M. CARTER
ASSISTANT ATTORNEY GENERAL
505 EXECUTIVE HOUSE
P.O. BOX 2357
HARRISBURG, PA 17120

DR. JUDITH M. JOHNSRUD
ENVIRONMENTAL COALITION ON
NUCLEAR POWER
433 ORLANDO AVE.
STATE COLLEGE, PA 16801

GEORGE F. TROWBRIDGE, ESQ.
SHAM, PITTMAN, POTTS AND
TROWBRIDGE
1800 N. ST., NW.
WASHINGTON, DC 20036

ATOMIC SAFETY AND LICENSING BOARD PANEL
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555

ATOMIC SAFETY AND LICENSING APPEAL PANEL
U.S. NUCLEAR REGULATORY COMMISSION
WASHINGTON, DC 20555

SECRETARY
U.S. NUCLEAR REGULATORY COMMISSION
ATTN: CHIEF, DOCKETING & SERVICE BRANCH
WASHINGTON, DC 20555

MR. LARRY HOCHENDORFER
DAUPHIN COUNTY COMMISSIONER
P.O. BOX 1295
HARRISBURG, PA 17108-1295

JOHN E. MINNICH, CHAIRPERSON,
DAUPHIN COUNTY BOARD OF COMMISSIONERS
DAUPHIN COUNTY COURTHOUSE
FRONT AND MARKET STREETS
HARRISBURG, PA 17101

DAUPHIN COUNTY OFFICE OF EMERGENCY
PREPAREDNESS
COURT HOUSE, ROOM 7
FRONT & MARKET STREETS
HARRISBURG, PA 17101

U.S. ENVIRONMENTAL PROTECTION AGENCY
REGION III OFFICE
ATTN: EIS COORDINATOR
CURTIS BUILDING (SIXTH FLOOR)
6TH & WALNUT STREETS
PHILADELPHIA, PA 19106

THOMAS M. GERUSKY DIRECTOR
BUREAU OF RADIATION PROTECTION
DEPARTMENT OF ENVIRONMENTAL RESOURCES
P.O. BOX 2063
HARRISBURG, PA 17120

DAVID NESS
OFFICE OF ENVIRONMENTAL PLANNING
DEPARTMENT OF ENVIRONMENTAL RESOURCES
P.O. BOX 2063

MILLIS SIXBY, SITE MANAGER
U.S. DEPARTMENT OF ENERGY
P.O. BOX 88
MIDDLETOWN, PA 17057-0311

DAVID J. MCCOFF
DIVISION OF THREE MILE ISLAND PROGRAMS
ME-23
U.S. DEPARTMENT OF ENERGY
WASHINGTON, DC 20549

MILLIAM LOCHSTET
104 DAVEY LABORATORY
PENNSYLVANIA STATE UNIVERSITY
UNIVERSITY PARK, PA 16802

RANDY MYERS, EDITORIAL
THE PATRIOT
812 MARKET ST.
HARRISBURG, PA 17105

ROBERT S. BORSUM
BARCOCK & WILCOX
NUCLEAR POWER GENERATION DIVISION
SUITE 220
7910 WOODMONT AVE.
BETHESDA, MD. 20814

JUDITH A. DORSEY
1315 WALNUT STREET
SUITE 1632
PHILADELPHIA, PA 19107

LINDA M. LITTLE
5000 HERMITAGE DR.
RALEIGH, NC 27612

MARVIN I. LEWIS
6504 BRADFORD TERRACE
PHILADELPHIA, PA 19149

JANE LEE
103 VALLEY RD.
ETTERS, PA 17319

J.B. LIBERMAN, ESQUIRE
BERLACK, ISRAELS, LIBERMAN
26 BROADWAY
NEW YORK, NY 10004

WALTER M. COHEN, CONSUMER ADVOCATE
DEPARTMENT OF JUSTICE
STRAWBERRY SQUARE, 14TH FLOOR
HARRISBURG, PA 17127

EDWARD O. SHARTZ
BOARD OF SUPERVISORS
LONDONDERRY TOWNSHIP
RFD 01 GEYERS CHURCH RD.
MIDDLETOWN, PA 17057

ROBERT L. KNUPP, ESQUIRE
ASSISTANT SOLICITOR
KNUPP AND ANDREWS
P.O. BOX P
407 N. FRONT ST.
HARRISBURG, PA 17108

JOHN LEVIN, ESQUIRE
PENNSYLVANIA PUBLIC UTILITIES COMM.
P.O. BOX 3265
HARRISBURG, PA 17120

HONORABLE MARK COHEN
512 E-E MAIN CAPITOL BUILDING
HARRISBURG, PA 17120

SURVEILLANCE REQUIREMENTS

4.3 INSTRUMENTATION

4.3.1 NEUTRON MONITORING INSTRUMENTATION

4.3.1.1 Each neutron monitoring channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION, and CHANNEL FUNCTIONAL TEST operations during RECOVERY MODE and at the frequency shown in Table 4.3-1.

4.3.2 ENGINEERING SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION

4.3.2.1 Each ESF AS instrumentation channel shall be demonstrated OPERABLE (per occupational exposure considerations) by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST operations during RECOVERY MODE and at the frequencies shown in Table 4.3-2.

4.3.3 MONITORING INSTRUMENTATION

RADIATION MONITORING INSTRUMENTATION

4.3.3.1 Each fuel storage pool area radiation monitoring instrumentation channel shall be demonstrated OPERABLE (per occupational exposure considerations) by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION, and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table 4.3-3 and by verifying the alarm/trip setpoints are adjusted in accordance with procedures approved pursuant to Technical Specification 6.8.2 for the gaseous activity monitor, radioactive iodine monitor, and particulate activity monitor.

4.3.3.2 Each AMS-3 particulate monitor used for the EPICOR II Prefilter purging and inerting operation shall be demonstrated operable by the performance of the channel checks, calibrations, and functional tests at the frequencies shown in Table 4.3-3 and by verifying alarm/trip setpoints are adjusted in accordance with procedures approved pursuant to Technical Specification 6.8.2.

Particulate air samples collected by the effluent monitor shall be analyzed for gamma emitting isotopes. Upon detection of any gamma emitter, the sample shall be analyzed for Sr-90 contents. The analytical methods used shall provide for LLD of at least 1×10^{-12} uCi/cc for both gamma emitters and Sr-90.

4.3.3.3 The Reactor Building AMS-3 purge monitor shall be demonstrated operable by performance of the channel checks, calibrations, and functional tests at the frequencies shown in Table 4.3-3 and by verifying alarm setpoints are set in accordance with procedures approved pursuant to Technical Specification 6.8.2.

SEISMIC INSTRUMENTATION

4.3.3.3.1 Each of the accessible (per occupational exposure considerations) seismic monitoring instruments shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL CALIBRATION and CHANNEL FUNCTIONAL TEST operations at the frequencies shown in Table 4.3-4.

8212230061 821208
PDR ADOCK 05000320
P PDR

4.3.3.3.2 Each of the accessible (per occupational exposure considerations) seismic monitoring instruments actuated during a seismic event shall be restored to OPERABLE status within 24 hours and a CHANNEL CALIBRATION performed within 5 days following the seismic event. Data shall be retrieved from actuated instruments and analyzed to determine the magnitude of the vibratory ground motion. A Special Report shall be prepared and submitted to the Commission pursuant to Specification 6.9.2 within 10 days describing the magnitude, frequency spectrum, and resultant effect upon facility features Important to Safety.

TABLE 4.3-3

RADIATION MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS

<u>FUNCTIONAL UNIT</u>	<u>CHANNEL CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>CHANNEL FUNCTIONAL TEST</u>
1. PROCESS MONITORS			
a. Fuel Storage Pool Area			
i. Gaseous Activity	S	R	M
ii. Particulate Activity	S	R	M
iii. Radioactive Iodine	S	R	M
2. EPICOR II Purge Monitors (AMS-3)	D	SA	W
3. Reactor Building Purge Monitor (AMS-3)	D	SA	W