

**DISTRIBUTION:**

DN 50-320  
 NRC PDR  
 Local PDR  
 DCS  
 TMI HQ r/f  
 TMI Site r/f  
 BJSnyder  
 WDTravers  
 MTMasnik  
 RAWeller  
 PGrant  
 RCook  
 CCowgill  
 LChandler  
 IE (3)  
 ACRS  
 M-Town Office  
 Service List

September 12, 1985  
 NRC/TMI 85-071

Docket No. 50-320

GPU Nuclear Corporation  
 ATTN: Mr. F. R. Standerfer  
 Vice President/Director, TMI-2  
 P. O. Box 480  
 Middletown, PA 17057

Dear Sir:

Subject: General Project Design Criteria (GPDC)

Reference: Letter from F. R. Standerfer to B. J. Snyder, 4410-85-L-0159,  
 dated August 2, 1985

The referenced letter with attached GPDC addresses NRC comments in our letter of December 11, 1984. We believe that the clarification in the current revision (revision 6) of the GPDC has essentially resolved the NRC comments in our previous letter.

We find your definition in section 2.5 acceptable for identifying safety related systems. We agree that safety related systems should be designed to remain functional through the events listed in sections 3.2.4 and 3.2.5. It is currently implied but should be explicitly stated that they are also required to remain functional through environmental conditions generated by or occurring during an accident.

Sincerely,

ORIGINAL SIGNED BY:  
 William D. Travers

William D. Travers  
 Deputy Program Director  
 TMI Program Office

cc: T. F. Demmitt  
 R. E. Rogan  
 S. Levin  
 W. H. Linton  
 J. J. Byrne  
 A. W. Miller  
 Service Distribution List  
 (see attached)

8509180500 850912  
 PDR ADOCK 05000320  
 P PDR

OFFICE	TMIPD	<i>RB</i>	TMIPD				
SURNAME	LHThonus:wa	PJGrant	WDTravers				
DATE	9/11/85	9/12/85	9/12/85				