1 of 4

Strictly Private

13 Apr11 1979

L-ACH SIEAT =1

To:

D. C. Ditmore

From:

P. W. Marriott

Subject: MECHANICAL CONDITION OF THREE MILE ISLAND CORE

On April 12 the Industry Advisory Group (IAG) requested an independent judgment of the mechanical condition of the Three Mile Island (TMI) core, assuming a sequence of events regarding core cooling postulated by experts in the IAG. A summary of that information, as I understood it from you in our telecon, is presented in Attachment A. This memo conveys our judgment for your use in comparison to others'. It has not been subjected to independent, internal review: I leave it to you to handle it accordingly and to put it in proper perspective.

Core Heatup. With the limited and speculative nature of the sequence of events postulated in Attachment A, we have simply assumed adequate cooling (clad temperature at saturation) through 116 minutes, followed by convective cooling to superheated steam until quenching. Thermal radiation of peripheral rods to the core berrel would be significant for those rods, but insignificant to the central region of the core except insofar as it would abet natural circulation of steam within the core. Our judgment; unsupported by detailed calculations for this exact sequence, is that the cladding temperature would increase to at least 2600F under the flow conditions postulated by IAG, possibly higher. Assuming a limited amount of natural circulation of steam inside the vessel, the lower powered regions would be heated to similar temperatures.

For simplicity, our core mechanical considerations postulated a peak cladding temperature increasing linearly from 600F to 2600F from t = 116 minutes to t = 126 minutes, then holding constant at 2600F until quenching, with increasing amounts of cladding reaching 2600F through the transient. Quenching at t = 176 minutes would reduce cladding temperatures to saturation (~600F) in seconds. The five-minute, heatup at t = 195 minutes is probably of secondary importance.

This postulation has the following limitations which may be important to the IAS's judgment of the machanical condition of the core:

- (1) It omits the possibility of early (t = 100 to 116 minutes) heatup, and perhaps cladding perforations, high in the core while good cooling is still taking place at lower elevations. An estimate of this could be made, if IA6's thermal-hydraulic advisers could speculate on -vessel inventory and (even better) void distribution, during the first twenty minutes or so.
- (2) It does not consider at what time the entire core would become essentially adiabatic and heat to higher temperatures. However, IAG's postulated event sequence, the heatup sequence we postulated, and IAG's estimate of 30-45% of the core's zircalcy reacted, all corroborate each other approximately.

252 099

7906260469

Roisman 79-98

Strictly Private

Fuel Rod Perforation. Assuming a rod internal pressure of 400 psi at 20°C,—
whe calculated rod internal pressure at ~2600°F is ~2320 psi. This yields a
clad hoop stress of ~16,100 psi. Based on zircaloy rupture data the rods
would be expected to balloon and perforate at cladding temperatures of ~1500°F.

Based on General Electric full-scale single-bundle ECCS heat transfer test data, the location of rod ballooning and perforation would be expected to be within + 6 inches of the peak temperature region of the rod; the location on any given rod would be rendom within this range.

Assuming clad heatup from 600°F to ~2600°F in ten minutes and constant temperature thereafter, and using the Baker-Just rate equation, the clad wall could be expected to be about 47% oxidized in one-half hour, about 67% oxidized in one hour, and fully oxidized in about two hours. This calculation considers only external oxidation; the extent of oxidation can be expected to nearly double over a short length in areas where the rods have ballooned and perforated, exposing inner clad surfaces to an oxidizing environment.

Fuel Rod Ballooning. As noted above, for the rods experiencing the assumed elevated temperature and pressures imposed by the transfent, rod ballooning would be expected. The maximum magnitude of the expected ballooning would be ~100%, i.e., the rod initial diameter would be expected to double. (This estimate is based on AKL 76-121 LMR Safety Research Program, Quarterly Progress Report July-September 1976). Based on full bundle tests conducted by GE and others, coplanar ballooning leading to extensive flow blockage would not be expected; however, as stated above, the ballooning would be expected to be preferentially located within roughly a one-foot section of the axial location of peak cladding temperature.

Fuel Rod Distortion. We cannot comment on the possibility of rod distortion or bowing during the core heatup because of our unfamiliarity with the core mechanical design. In GE full-scale ECCS heat transfer tests, some bowing of rods did occur at temperatures several hundred degrees lower than postulated here. It should be noted that the fuel rods in these tests had larger outside diameter and cladding thickness than TMI's. The possibility of rod distortion should be considered.

Clad Embrittlement and Effect of Quenching. Due to the clad heatup, significant exidation would be expected. The brittle behavior of stabilized alpha-phase zirconium exide would be expected to result in fragmentation under quench conditions. The 10CFR 50.46 exidation limit to preclude this condition is 17% for LOCA application. AML* has suggested a limit of 28% under slow quench conditions. It should be noted that in the experiments discussed by AML, many of the rods which were intact following quenching failed during post-test handling. Post-test handling failure has also been experienced in fuel rods subjected to similar temperatures in tests performed by EG&G Idaho, Inc.

The posutlated amount of cladding exidation and embrittlement, if present together with severe red distortion, could have resulted in mechanical failure of affected reds during the heatup, quenching, or subsequent pressure or flow transferts.

* Argone National Laboratory, "Mechanical Properties of Zircaloy Containing Oxygen," USMRC Zircaloy Cladding Program Review Meeting, April 25-26, 1978.



Strictly Private

Conclusions. Based on these scoping evaluations the following core mechanical condition is postulated:

- Rod ballooming lending to rupture expected in the highest-power areas of many or all fuel reds. Sallooming not expected to be coplanar.
- (2) Clad perforation in many or all fuel rods resulting from operation post the rupture capability of Zr.
- (3) Clad oxidation sufficient to cause fregmentation under quench conditions, particularly if aggrevated by rod boring.

ይያ ቀላት መጀመራት የመ^ቀዋቂያ ምምነት ምምነት የሚያስፈ የሚያስፈ የሚያስፈ ነገር ነው ነው የሚያስፈ የሚያስፈርር ነገር ነው ነው

fllequide



Strictly Private

THREE MILE ISLAND-2 CORE HEATUP: POSTULATED SEQUENCE OF EVENTS

(Reference Telecon DC Ditmore to PM Marriott, 4/12/79, 1326 PST)

Time After Event, Min.	<u>Event</u>								
100	"A" primary coolant pumps tripped ("B" pumps had been tripped previously)								
100-116	Cooling by boiling in subcooled liquid and high-density froth								
116	Density of fluid in core begins to decrease rapidly. Hot leg coolant temperature begins to show superheat.								
116-146	Cooling by low density froth and (not much later) steam								
146	Unexplained spike in core fluid density								
146-176	No net inflow or outflow of steam in vessel (cooling by natural circulation of steam inside vessel)								
176	Rapid quenching								
176-195	Cooling by boiling in subcooled liquid and high-density froth								
195-200	Brief second heatup								
200	Rapid quenching								

THREE MILE ISLAND-2 CORE HEATUP: CORE PRESSURE/TIME HISTORY

(Reference Telecon DC Ditmore to PW Marriott, 4/12/79, 1420 PST)

Time After Event, Min.	Core Pressure psig
60	1100
75	1045
90	1110
105	1000
120	800
135	670 (1amest)
160	600
165	1050
180	2200

4-12-79 J.W. Thiesing Estimate of lower bound for Zr-Hz0 reaction Basis: Inventory as of 4-1-79, 46,000 lbm 1) Hz burn - Now estimated to have released 2.5 - 4.0 ×106 Btu Equivalent to 2.5 - 4.0% Zr-H20 VXA 1 2 1/0 Hz in Containment 4-1-79 equivalent to 11.5 % 2r-H20 rxn (3) 1000 ft. 3 bubble, in RCS 4-1-79 equivalent to 13% zr-420 rxn (4) Saturated &CS at 1000 psig /280% on 4-1-79 equivalent to 2.5% Zr-H20. (5) Unknown degassing from 3-28 to 4-1 thru letdown system - could be equivalent to reduction in bubble From measured 1800 ft 1 1000 ft 3 on 4-1-79 equivalent to 10.5%. tr-HLO rxa 1) There Lower Bound = 29.5% Median = 41.5% (1) + (2) + (4)

CORE EXIT TEMPERATURE

						T	T			1				
					+		}			-	1	7		
		_	+	-		286	287						7	
					289			295	286			259		
				288					286				286	
			289			287		302		285				
		294				252	205				205	282		
	288			352	308		<u>i .</u>	302		NG		250		
,				378			399	288				284		
	- 1			29,						305	285			
	288	N.G.			314					276		N.G		
	•	288				290		338	302				209	
			291				300	293						
				293	296				289		281			
					295									
						294			185		3			

Care Decay Heat NSMN

252 104 -

ATTACHMENT #4

CORE FLOW BLOCKAGE ASSESSMENT FROM CORE HEAT BALANCE

D. C. Ditmore 4/13/79

April 10, 1979 Reactor Conditions:

t_{core} in = ~ 280°F

tcore out = ~ 285 to 399°F (with two TC's reading below the core inlet and thus likely erroneous.)

core exit ~ 288.5°F (a € 2.7 8.5°F)

in annular region outside very center of core

Qcore ~ SMW

Normal operation - 4 pump core flow 137.9x10⁶ 1b/hr

Single loop - one pump core flow 1/8 - 1/4 x full core flow* (next page)

Unblocked Core Heat Balance - Single Loop/Single Pump

a) 1/8 of full core flow

 $Q_{core} = N_{core}C_{p} \Delta t_{core}$ $\Delta t_{core} = \frac{Q_{core}}{C_{p} W_{core}} \frac{(5MW) (3.415x10^{6} \frac{BTU}{Hr.Min.})}{(137.9x10^{6} \frac{1b/hr}{lb} (~.9 \frac{BTU}{lb^{0}F})} = ~1.1^{\circ}F$

b) 1/4 of full core flow Δ tcore \sim 2.20F

Blocked Core (Current Condition) Heat Balance - Single Loop/Single Pump

(Mcore Cp Atcore) unblocked = (Mcore Cp Atcore) blocked

 $\frac{\text{W}_{core}}{\text{N}_{core}} = \frac{(\Delta^{t} \text{core}) \text{unblocked}}{\Delta^{t} \text{core}) \text{blocked}} = \frac{A \text{ blocked}}{A \text{ unblocked}}$

(A tcore) blocked ~8.50F

(\D tcore)unblocked -1-20F

A blocked $\sim \frac{1-2^{\circ}F}{8.5^{\circ}F}$ Range .11 - .24 ~ 89 - 76% flow blockage

89 - 76% core blockage in peripheral region .

Because of high expectation that normal single pump operation core flow is closer to 1/8 of normal four pump operation core flow, the expected_result

252 101

ATTACHMENT #4 - Continued

is closer to 89%.

*Analyses by T. Mott and B&W indicate ~ 1/8 of the normal four pump flow through the core under one pump operation, most of the flow by-passing the core and flowing in reverse mode in non-operational loops.