



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

May 19, 1979

R. Vollmer
file
Emergency - in accordance

Mr. R. C. Arnold
General Operations Manager
GPU Services Corporation
260 Cherryhill Road
Parsippany, New Jersey 07054

Subject: EXTRA PRECAUTIONARY MEASURES FOR AREA TRANSMISSION SYSTEMS
FOR TMI

Dear Mr. Arnold:

In response to your letter dated May 15, 1979, and the attached memorandum, we have reviewed the sources of power that would be available in the event the extra precautionary measures previously instituted were rescinded. We conclude that the completion of the "gray and white" emergency diesel generators and the completion of the additional 13.8 kV feed to the circulating water pump house assure adequate sources of power for safe operation of TMI-2. I concur with the relaxation of the extra precautionary measures as described in your May 18 letter and attachment.

Sincerely,

Richard H. Vollmer
Assistant Director for Systems
and Projects
Division of Operating Reactors

Revised 7-78

7906280204. P