

Central File



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

December 18, 1979

Docket No. 50-320

Metropolitan Edison Company
Att: Mr. R. F. Wilson, Director
TMI-2
P.O. Box 480
Middletown, Pennsylvania 17057

REGULATORY DOCKET FILE COPY

Dear Mr. Wilson:

We have reviewed your letter of December 13, 1979 (GQL 1506) which recommended reducing the water level in the Unit 2 BWST to a minimum of 100,000 gallons and subsequently refilling BWST with EPICOR II processed water which has been borated. We concur with your recommendations and we will revise the draft Technical Specifications accordingly. It should be noted that while the BWST water volume Technical Specification limit will be 100,000 gallons, your implementing procedures should include provisions to account for instrumentation errors and other uncertainties. These provisions should be sufficient to assure that an actual volume of 100,000 gallons will be contained within the BWST at all times.

John T. Collins
John T. Collins
Deputy Director
TMI Support

- cc: R. C. Arnold, Senior Vice President
- J. J. Barton, Manager Site Operations
- B. Elam, Manager Plant Engineering (TMI-2)
- L. W. Harding, Supervisor of Licensing
- E. G. Wallace, Licensing Manager
- J. G. Herbein, Vice President Nuclear Operations
- G. P. Miller, Manager Support Services and Logistics
- J. B. Logan, Superintendent Unit 2
- G. A. Kunder, Unit 2 Superintendent - Technical Support
- J. J. Colitz, Manager Plant Engineering
- I. R. Finfrock, Jr.
- R. W. Conrad
- G. F. Trowbridge, Esquire
- J. B. Lieberman, Esquire
- Ms. Mary V. Southard, Chairperson, Citizens for a Safe Environment

8001160 435