



Metropolitan Edison Company
Post Office Box 480
Middletown, Pennsylvania 17057
717 944-4041

Writer's Direct Dial Number

May 29 1980
TLL 247

Office of Inspection and Enforcement
Attn: B. H. Grier, Director
Region I
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pa. 19406

Dear Sir:

Three Mile Island Nuclear Station, Unit II (TMI-2)
Operating License No. DPR-73
Docket No. 50-320
IE Bulletins

In response to your letter of April 17, 1980 concerning IE Bulletins for TMI-II, we are transmitting to you herein our guidelines for establishing action on past and future bulletins. Also, enclosed is an identification of each bulletin which we have determined to be not applicable to TMI-II or to be of a long term nature. The remainder of the bulletins are undergoing further investigation and a determination of their classification will be provided by June 30, 1980. The guidelines by which we determine bulletin classifications are as follows:

- 1) Long Term Action -- IE Bulletins or portions thereof that are not applicable to systems that relate to the maintenance of a safe shutdown condition in the recovery mode.
- 2) Short Term Action -- IE Bulletins or portions thereof that are applicable to systems that relate to the maintenance of a safe shutdown condition in the recovery mode.

NOTE: Portions of IE Bulletins requiring actions performed in or addressing the Reactor Containment Building or in areas access to which is restricted for ALARA considerations will not be performed with the remainder of the short term bulletin actions.

No action will be taken at this time on long term bulletins. They will be reevaluated for applicability in June of 1983. Short term bulletins will be responded to in accordance with a schedule to be provided in our submittal of June 30, 1980. Any short term bulletins after Bulletin 80-09 will

Asst
5/1

8006030359

Metropolitan Edison Company is a Member of the General Public Utilities System

be responded to in an appropriate manner within the time frame specified within the bulletin. All long term bulletins after Bulletin 80-09 will be identified as such within the action period in the bulletin.

Sincerely,

/s/ G. K. Hovey

G. K. Hovey
Director
TMI-II

GKH:SDC:hah

Enclosure

cc: J. T. Collins


<u>BULLETIN NO.</u>	<u>SUBJECT</u>	<u>CLASSIFICATION</u>
79-18	Audibility Problem in High Noise Areas	To Be Determined
79-19	Packaging of Low Level Radwaste for Transport and Burial	Response Sent October 8, 1979 (GQL 1229)
79-20	Packaging of Low Level Radwaste for Transport and Burial	Not applicable to TMI-II
79-21	Temperature Effects on Level Measurement	To Be Determined
79-22	Possible Leakage of Tubes of Tritium Gas Used in Timepieces for Luminosity	Not Applicable to TMI-II .
79-23	Diesel Generator Field Exciter Transformer	To Be Determined
79-24	Frozen Lines	To Be Determined
79-25	Westinghouse BFD Relays in Safety Related Systems	To Be Determined
79-26	Boron Loss From BWR Control Blades	Not Applicable to TMI-II
79-27	Loss of Non Class IE I & C Power System During Operation	Long Term Action
79-28	NAMCO Model EA 180 Limit Switches at Elevated Temperatures	To Be Determined
<hr/>		
80-01	Operability of ADS Valve Pneumatic Supply	Not Applicable to TMI-II
80-02	Inadequate Quality Assurance for Nuclear Supplied Equipment	Not Applicable to TMI-II
80-03	Loss of Charcoal from Standard Type II 2 inch Tray Adsorber Cells	Long Term Action
80-04	PWR Main Steam Line Break With Continued Feedwater Addition	Long Term Action
80-05	Vacuum Condition in CVCS Hold Up Tank	To Be Determined
80-06	ESF Reset Controls	To Be Determined

<u>BULLETIN NO.</u>	<u>SUBJECT</u>	<u>CLASSIFICATION</u>
80-07	BWR Jet Pump Assembly Failure	Not Applicable to TMI-II
80-08	Examination of Containment Penetration Welds	Long Term Action
80-09	Hydramotor Actuator Deficiencies	To Be Determined

CLASSIFICATION OF IE BULLETINS FOR TMI-2

Enclosure 1

TLL 247

<u>IE BULLETIN NO.</u>	<u>SUBJECT</u>	<u>CLASSIFICATION</u>
79-01 Series	Environmental Qualification of Class 1E Equipment. ASCO Solenoid Valves HELB In and Out	See Inspection 50-320 79-01 Item 3 Long Term Action
79-02 Series	Base Plates and Anchor Bolts Seismic/Design Load	Long Term Action
79-03 Series	Longitudinal Weld Defects ASME-SA-312 Type 304 SS YW&E/ARMCO/SWEYCO	To Be Determined
79-04	Velan Swing Check Valves	Long Term Action
79-05 Series	Nuclear Incident at Three Mile Island	Long Term Action
79-06 Series	Operational Errors and System Misalignment	Not applicable to TMI-II
79-07	Seismic Stress Analysis of Safety Related Piping	Long Term Action
79-08	BWR's and TMI Incident	Not applicable to TMI-II
79-09	GE AK-2 Circuit Breaker	To Be Determined
79-10	Requalification Training Program Statistics	To Be Determined
79-11	Faulty Overcurrent Trip Device in Circuit Breaker	To Be Determined
79-12	Short Period Scrams at BWR Facilities	Not applicable to TMI-II
79-13 Series	Cracking in Feedwater System Piping	Long Term Action
79-14 Series	Seismic Analysis For As Built Safety Related Piping Systems	Long Term Action
79-15	Deep Draft Pump Deficiencies	To Be Determined
79-16	Vital Area Access	See TMI-Security Plan Addendum 1/10/80 and 2/19/80 No Further Action Is Planned
79-17	Pipe Cracks in Stagnant Borated Water Systems in PWR's	Long Term Action