



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 11, 1981
NRC/TMI-81-009

Docket No. 50-320

Mr. Gale K. Hovey, Vice President
and Director of TMI-2
Metropolitan Edison Company
P.O. Box 480
Middletown, PA 17057

Dear Mr. Hovey:

Subject: Design Criteria for Modification of Reactor Building Penetration #401

Reference: Your letter of December 23, 1980, TLL 684

The referenced letter contained your original submittal of "Design Criteria for Closure of Reactor Building Penetration 401". We have reviewed these criteria and requested several changes, additions and clarifications. They were discussed with your engineering and licensing staff and were incorporated into a revised submittal of the design criteria.

We have reviewed the revised design criteria and conclude that the criteria are acceptable for Modification of Reactor Building Penetration No. 401. A copy of the revised criteria as approved is attached to prevent any possibility of confusion as to the approved version.

Lake H. Barrett
Acting Deputy Program Director
TMI Program Office

Enclosure: As Stated

cc: See Service Distribution List



810226 0734

P

Mr. Gale Hovey
Metropolitan Edison Company

FEB 11 1981

Mr. J. J. Barton
Manager, Site Operations, TMI-2
Metropolitan Edison Company
P. O. Box 480
Middletown, PA 17057

Mr. E. D. Fuller
TMI-2 Licensing Supervisor
Metropolitan Edison Company
P. O. Box 480
Middletown, PA 17057

Mr. E. G. Wallace
PWR Licensing Manager
GPU Service Corporation
100 Interpace Parkway
Parsippany, NJ 07054

Mr. J. B. Liberman, Esquire
Berlack, Israels, Liberman
26 Broadway
New York, NY 10004

Mr. G. F. Trowbridge, Esquire
Shaw, Pittman, Potts & Trowbridge
1800 M Street, N.W.
Washington, DC 20036

Dr. Walter H. Jordan
881 W. Outer Drive
Oak Ridge, TN 37830

Dr. Linda W. Little
5000 Hermitage Drive
Raleigh, NC 27612

Karin W. Carter, Esquire
505 Executive House
P. O. Box 2357
Harrisburg, PA 17120

Honorable Mark Conen
512 E-3 Main Capital Building
Harrisburg, PA 17120

Ellyn Weiss, Esquire
Sheldon, Harmon, Roisman & Weiss
1725 I Street, N.W., Suite 506
Washington, DC 20006

Mr. Steven C. Sholly
304 S. Market Street
Mechanicsburg, PA 17055

Mr. Thomas Gerusky
Bureau of Radiation Protection
P. O. Box 2063
Harrisburg, PA 17120

Mr. Marvin I. Lewis
6504 Bradford Terrace
Philadelphia, PA 19149

Ms. Jane Lee
R. D. 3, Box 3521
Etters, PA 17319 ..

Walter W. Cohen, Consumer Advocate
Department of Justice
Strawberry Square, 14th Floor
Harrisburg, PA 17127

Robert L. Knupp, Esquire
Assistant Solicitor
Knupp and Andrews
P. O. Box P
407 N. Front Street
Harrisburg, PA 17108

John E. Minnich, Chairperson
Dauphin Co. Board of Commissioners
Dauphin County Courthouse
Front and Market Streets
Harrisburg, PA 17101

Robert Q. Pollard
Chesapeake Energy Alliance
609 Montpelier Street
Baltimore, MD 21218

Chauncey Kepford
Judith H. Johnsrud
Environmental Coalition on Nuclear Power
433 Orlando Avenue
State College, PA 16801

Mr. Gale Hovey
Metropolitan Edison Company

FEB 11 1981

Ms. Frieda Berryhill, Chairperson
Coalition for Nuclear Power Plant
Postponement
2610 Grendon Drive
Wilmington, DE 19808

Holly S. Keck
Anti-Nuclear Group Representing York
245 W. Philadelphia Street
York, PA 17404

John Levin, Esquire
Pennsylvania Public Utilities Commission
P. O. Box 3265
Harrisburg, PA 17120

Jordon D. Cunningham, Esquire
Fox, Farr and Cunningham
2320 N. Second Street
Harrisburg, PA 17110

Ms. Kathy McCaughin
Three Mile Island Alert, Inc.
23 South 21st Street
Harrisburg, PA 17104

Ms. Marjorie M. Aamodt
R. D. #5
Coatesville, PA 19320

Ms. Karen Sheldon
Sheldon, Harmon, Roisman & Weiss
1725 I Street, N.W., Suite 506
Washington, DC 20006

Earl B. Hoffman
Dauphin County Commissioner
Dauphin County Courthouse
Front and Market Street
Harrisburg, PA 17101

Government Publications Section
State of Library of Pennsylvania
Box 1601 Education Building
Harrisburg, PA 17127

Dr. Edward O. Swartz
Board of Supervisors
Londonderry Township
RFD #1 Geyers Church Road
Middletown, PA 17057

U. S. Environmental Protection Agency
Region III Office
ATTN: EIS Coordinator
Curtis Building (Sixth Floor)
6th and Walnut Streets
Philadelphia, PA 19106

Dauphin County Office Emergency
Preparedness
Court House, Room 7
Front and Market Streets
Harrisburg, PA 17101

Department of Environmental Resources
ATTN: Director, Office of
Radiological Health
P. O. Box 2063
Harrisburg, PA 17105

Governor's Office of State
Planning and Development
ATTN: Coordinator, Pennsylvania
Clearinghouse
P. O. Box 1323
Harrisburg, PA 17120

Mrs. Rhoda D. Carr
1402 Marene Drive
Harrisburg, PA 17109

Mr. Richard Roberts
The Patriot
812 Market Street
Harrisburg, PA 17105

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
Suite 420, 7735 Old Georgetown Road
Bethesda, MD 20014

Ivan W. Smith, Esquire
Atomic Safety and Licensing Board
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Atomic Safety and Licensing Board Panel
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Gale Hovey
Metropolitan Edison Company

FEB 11 1981

Atomic Safety and Licensing Appeal Panel
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Docketing and Service Section
U. S. Nuclear Regulatory Commission
Washington, DC 20555

THREE MILE ISLAND UNIT #2

DESIGN CRITERIA

MODIFICATION FOR CLOSURE OF REACTOR BUILDING PENETRATION 401

APPROVED: B. Clam

DATE: _____

THREE MILE ISLAND UNIT 2

DESIGN CRITERIA

MODIFICATION FOR CLOSURE OF REACTOR BUILDING PENETRATION 401

1.0 SCOPE

This document provides criteria for design modification to Reactor Building penetration number 401 to provide a more permanent closure of the penetration, in consideration of future potential increase of building water level to the extent of flooding the penetration.

2.0 INTRODUCTION

Penetration 401 was modified in late Summer 1979 to allow access to obtain samples of the building sump water. Following successful completion of the sampling program, further design changes were made to use the penetration for building water level measurement, by addition of a manometer system to the sampling tubing. The penetration has remained in this basic configuration to date, to allow daily water level measurements. The present configuration is described by Reference 1 and Reference 2. The intended modification will remove the 12-inch gate valve and the special cover assembly outboard of the valve. A welded closure assembly will then be added. Provisions shall be made to obtain valid water level measurements at least once every 48 hours during installation of the modification. This modification is not intended to return the penetration design to the pre-accident condition nor to qualify the penetration for plant restart.

3.0 DESIGN REQUIREMENTS

3.1 Codes and Standards

- 3.1.1 Design and fabrication shall be in accordance with applicable portions of ANSI B 31.7, ~~as indicated herein~~

3.1.2 Welding shall be in accordance with ASME Section IX.

3.2 Design Pressure and Temperature

The penetration shall be designed for the positive pressure corresponding to the maximum allowable water level in the Reactor Building, as well as 2.5 psi vacuum condition. Design temperature range shall be 50°F to 100°F.

3.3 Design Loads

Design shall consider dead weight and pressure loads, and accelerations applicable to the plant safe shutdown earthquake, without loss of function.

4.0 MATERIALS

New pressure boundary ferrous materials shall be in accordance with the requirements of ANSI B31.7, including identification, traceability, and certification of test results. Tubing, fittings, and valves associated with the level measuring instrumentation shall be of commercial grade with certificates of conformance provided.

5.0 TESTING

All new welds shall receive visual plus liquid penetration inspection. Radiography of welds will not be performed.

6.0 QUALITY ASSURANCE

Design, procurement, fabrication, and testing are within QA scope, as defined in applicable sections of "TMI-2 Recovery QA Plan".

7.0 REFERENCES

- 7.1 Drawing JS061780, Revision 0 - Three Mile Island Unit #2, Containment Penetration No. 401, M20 area.
- 7.2 Three Mile Island Unit #2 procedure 2104-4.47, Instrument Hookup, Measurement and Removal for Reactor Building Sump Level Determinations.