

EMERGENCY Procedure # EP-19

TITLE: RC-V2 stuck shut

APPROVALS:	PORC	<u>J. A. B...</u>	DATE	<u>4/5/79</u>
	UNIT Supt.	<u>REP J. J. ...</u>	DATE	<u>4/5/79</u>
	BSW	<u>...</u>	DATE	<u>4/5/79</u>
	NRC	<u>J. ...</u>	DATE	<u>4/5/79</u>
	AMRA	<u>...</u>	DATE	<u>4/5/79</u> 005-B

NRC

EMERGENCY PROCEDURE EP #19

RC V2 STUCK SHUT

1.0 SYMPTOMS

1.1 WHEN ATTEMPTING TO OPEN

a) NO STATUS LIGHT CHANGE

b) NO PRESSURIZER PRESSURE DROP

1.2 LOSS OF BUS 2-32B INDICATED BY

LOSS OF WHITE POWER LIGHT FOR BUS 2-32.

2.0 IMMEDIATE ACTIONS

2.1 AUTOMATIC ACTIONS

NONE

2.2 MANUAL ACTIONS

2.2.1 MANUALLY CONTROL PRESSURIZER ^{RCS}

PRESSURE BY:

a) CYCLE SPRAY VALVES AND PRESSURIZER
HEATERS TO MAINTAIN PRESSURE

~~b)~~

2.2.2 IF NECESSARY, USE RC-V-137

TO RELIEVE PRESSURE

3.0 FOLLOW UP ACTIONS

23.

155 017

3.1 IF POWER HAS BEEN LOST ENERGIZE

ALTERNATE POWER SUPPLY PER SOP 2-45
IF APPLICABLE