

P
IAG

TASK CLOSE OUT DOCUMENT

Task Scope

Instrument Diagnostics

To: M. Levenson
S. Levy
E. Zebroski

Task No.

11

Date Complete

4/30/79

Reason felt task is complete:

Reported

Members of Committee

N.C. Kreyter

C. J. Hale

J. J. Bell

J. L. Ziegler

J. J. Adelmann

Signed
Committee Leader

TO: SIG Distribution

Attached is a summary report on the noise analysis study of thermocouple signals for natural circulation performed by ORNL/SAI personnel.

cc: R. C. Kryter, ORNL

2004 288

ORNL-SAI SUMMARY REPORT

4/30/79
R.C. Kryfor
W.H. Sledge
S.J. Ball
G.L. Ziegler

① T/C noise following RCP shutdown is:

(a) very small in magnitude ($0.1 - 0.5^{\circ}\text{F}$).

(b) Not different in major characteristics relative to one-pump flow conditions examined previously, except that hottest T/C's no longer have greatest noise.

(c) With few exceptions, shows essentially zero correlation (coherence) amongst the T/C's.

(d) Shows no evidence of core boiling, as characterized through THF tests at ORNL.

(e) Regarding (d) above, one T/C pair [$12\text{F} \pm 9\text{H}$] was found to be strongly correlated (coherence ~ 0.9) with phase $= 180^{\circ}$ at a frequency of $\sim 0.5\text{Hz}$. Also, one T/C [09H] was found to respond to system oscillations associated with makeup water turnoff.

Erratic T/C readings (low values) can be explained in terms of T/C shunting to ground thru various leakage resistances:

Correct (no shunt) reading = 180°F

Low-side of T/C connected to ground = 40°F

High-side of T/C " " " = 140°F

High-side of T/C to ground thru $10K\Omega$ = 176°F

" " " " thru $2K\Omega$ = 164°F

So if leakage resistance varies with time (water in cables?), almost any reading is possible.

(3) Observation: With no RCS major forcing functions present, the system behaves ~~like~~ⁱⁿ a very lightly damped manner, and should be treated "gently", i.e., step changes should be minimized.

2004 290

(4) In correlation with other plant parameters, we requested B&W to put on the strip chart recorders Mill tank level and pressurizer level. Suggest also pri. pressure noise signals from A & B loops on same recorder.