

This is an informal report intended for use as a preliminary or working document



ŕ

1

General Public Utilities • Electric Power Research Institute • U.S. Nuclear Regulatory Commission • U.S. Department of Energy

QUICK LOOK REPORT ENTRY 7 THREE MILE ISLAND UNIT 2

Bechtel Northern Corporation/ General Public Utilities Nuclear Corporation

Prepared for the U.S. Department of Energy Three Mile Island Operations Office Under Contract No. DE-AC07-76ID01570

TO BEL SHIVEN AND DREAMANNERS IN CONTRACTORS

ABSTRACT

This report summarizes tasks performed during Entry 7 at Three Mile Island Unit 2. During the entry into containment, which was made on March 17, 19, and 20, 1981, samples of sump water were collected, water was processed via the resin column test equipment, the LPR-3B contactor was jumpered for additional floor lighting on Elevation 347, large purge valves were surveyed, the in-core tunnel area was surveyed and photographed, the CRDM service structure was surveyed, CCTV cables between cameras were rerouted, and a high volume air sample was taken on E¹evation 305.

This report provides raw data from the entry, and no attempt is made to provide interpretations or conclusions from the data.

ii

CONTENTS

ABSTRACT	ii
ENTRY SUMMARY	1
UBSERVATIONS AND RECOMMENDATIONS	19

FIGURES

1.	Elevation 305, reactor building in-core instrumentation cable chasestructural design	9
2.	Reactor building sumpwater resin column experimentsystem flow diagram	10
3.	Reactor vessel service structure control rod drive mechanism	12
4.	Reactor vessel service structure inside of barrel	13

TABLES

1.	Entry 7 task summary sheet	2
2.	Entry 7, Elevation 305 radiation survey	8
3.	Entry 7, Elevation 347 radiation survey	n
4.	Entry 7 surface contamination	14
5.	Entry 7 preliminary TLD readings	16
6.	Entry 7 equipment list	17

QUICK LOOK REPORT ENTRY 7 THREE MILE ISLAND UNIT 2 MARCH 17, 19, AND 20, 1981

ENTRY SUMMARY

The major accomplishments of Entry 7 into containment at Three Mile Island Unit 2 are as follows:

- 1. Three 1-liter and one 150-ml samples of sump water were taken
- Five gallons of water were processed via the resin column test equipment
- The LPR-3B contactor was jumpered to provide additional floor lights on Elevation 347
- 4. Large purge valves were surveyed
- 5. In-core tunnel area was surveyed and photographed
- 6. CRDM service structure was photographed
- 7. Cables between CCTV cameras and their control boxes were rerouted as needed, and CCTV camera connections were verified
- 8. A high volume air sample was taken on Elevation 305.

Table 1 shows the Entry 7 Task Summary Sheet. Table 2 is the Entry 7, Elevation 305 Radiation Survey; and Table 3 is the Radiation Survey for Elevation 347. The Entry 7 Surface Contamination is listed in Table 4. Table 5 shows the Preliminary TLD Readings for the entry. The Equipment List for Entry 7 is shown in Table 6.

Data Acquisition Task Number	Task Description	Task Accomplished	Problems Encountered	Comments/ Significant Findings
20B	Sump water samples	Samples taken	None	Sample cart and pump were left in containment. During operation the 3/8-in. ID tubing was less than 2 rem/hr γ on contact. Once filled, the sample bombs had the following contact readings:
			·	No. 1 - 1 liter - 2 rem/hr y contact
				No. 2 - 1 liter - 1 rem/hr y contact
				No. 3 - 1 liter - 1 rem/hr γ contact
				No. 4 - 150 ml - 1.5 rem/hr y contact
				All readings were taken with a teletector. All of the sample bomb were wrapped with lead.
23, 27	Survey and smears of CRDM service structure	Survey and smears complete	Tools to implement back- up method for taking head readings were the wrong size.	None
45	Survey and pic- tures of incore tunnel area	Survey and pic- tures were taken	Lack of light in area made task very difficult.	None

TABLE 1. ENTRY 7 TASK SUMMARY SHEET

 \sim

Data Acquisition Task Number	Task Description	Task Accomplished	Problems Encountered	Comments/ Significant Findings
			Nikonas camera was inadver- tently set with too high a shutter speed causing pictures to be 1/2 frame; pictures slightly fogged.	
42B	Decontamination test control smears and acetate pads	Completed	None	Control smears were taken by removing the smear and acetate pads from their protective bags and rebagging them without being used.
25, 26	Survey and smears inside inside A D-rirg	Not performed	Due to heat stress problems encountered on March 17, 1981, this task was not performed.	None
20	Resin column test	5 gallons of pro- cessed water were obtained	On March 17, 1981, attempts sump pump into sump failed;	Radiation measurements follow- ing test are given in Figure 2.

TABLE 1. (continued)

ω

quisition Task Number	Task Description	Task Accomplished	Problems Encountered	Comments/ Significant Findings
			additional attempts on	
			March 19, 1981, were successful.	
			Loss of video on camera No. 1 caused	
			an additional entry to be made on March 19, 1981,	
			to reconnect video on camera No. 1 and verify opera- tion of column test.	
			On March 20, 1981, an entry was made to re- trieve the 10	
			gallon carboy which con- tained the 5 gallons of processed	

TABLE I. (continued)

' •

4

Sector Contraction

Task Number	Task Description	Task Accomplished	Problems Encountered	Comments/ Significant Findings
Maintenance	Jumper LPR-3B	Jumpering com- pleted	None	None
Uperations	Plant surveil- lance purge valves AHV-2A, 2B, 3A, 3B	All valves oiled	Some difficulty in performing oiling; first attempt on March 17, 1981, partially com- pleted task; task was com- pleted on March 19, 1981, by shutting down the purge to allow the oiling to pro- ceed; once complete the purge valves cannot be oiled while in the open position.	NORE

•

TABLE 1. (continued)

والمراجع والمراجع والمراجع والمنافع والمنافع والمنافع والمراجع والمراجع والمراجع والمراجع والمراجع والمراجع

5

;

-

TABLE 1. (continued)

Uata Acquisition Task Number	Task Description	Task Accomplished	Problems Encountered	Comments/ Significant Findings
Uperations	Plant surveil- lance of chemical addi- tion valves CA-1 CA-2, CA-3.	Valves were lo- cated, but not serviced.	Once location of valves was made, it was determined that physical access was not possible due to restricting clothing required for radiological hazards.	If these valves are to be serviced, an alternate route for access will be required.
1	Verify cabling on CCTV and reroute as needed		None	Connectors on CCTV units do not always make proper contact; use of duct tape to secure several connectors was made
N/A	High volume air sample	Sample taken	Results are suspect as actual on-off times may be in error when retrieved air sampler was off and and unit was cool	Airborne concentrations were as follows: Sr/Y 90: 2.65 ⁻¹¹ µCi/cm ³ Cs 134 : 7.9 ⁻¹¹ µCi/cm ³ Cs 137 : 7.19 ⁻¹⁰ µCi/cm ³

TABLE 1.	(continued)

7

and the second second second second

Data Acquisition Task Number	Task Description	Task Accomplishea	Problems Encountered	Comments/ Significant Findings
			indicating premature shutdown had occurred.	

:

Note: Containment temperature, 62°F; containment pressure, 0.2 in. Hg; relative humidity, <100%; airborne activity, <MPC.

TABLE 2. ENTRY 7, ELEVATION 305 RADIATION SURVEY

Data Acquisition Task_Number	Location Figure 1 Instrument	Gamma Beta Dose Rate Dose Rate	<u>Location</u>
45	As Noted on Figure 1	As Noted on Figure 1	
20	As Noted on Figure 2	As Noted on Figure 2	

÷





Figure 1. Elevation 305, reactor building in-core instrumentation cable cnase--structural design.




ι.

Figure 2. Reactor building sumpwater resin column experiment--system flow diagram.

TABLE 3. ENTRY 7, ELEVATION 347 RADIATION SURVEY

Data Acquisition Task Number	Location Figure 2	Instrument	Gamma Dose Rate	Beta Dose <u>Rate</u>	Neutron Keading	Location
23, 27	As noted or	ı Figure 3 and	Figure 4	As No Figur	ted on Figu e 4	ire 3 and



a. Numbers correspond to those shown in Table 4. All readings were taken with an RO2A on contact.

INEL-A-19 019

¢ :

Figure 3. Reactor vessel service structure control rod drive mechanism.

12

Salana (Chini Sha




Figure 4. Reactor vessel service structure inside of barrel.

Data Acquisition Task Number	Specimen	Sample Number	Location ^b	Cs-134 (µCi)	Cs-137 (µCi)
27	smear ^a	58731	1	2.3-1	1.80
27	smear	58732	2	3.8-1	3.00
27	smear	58733	3	6.1 ⁻¹	4.9 ⁰
27	smear	58734	4	5.8-1	4.30
27	smear	58735	5	7.7-1	5.9 ⁰
27	smear	58736	δ	6.1-1	4.7 ⁰
27	smear	5873 7	7	2.7-1	2.20
27	smear	58738	8	5.5-1	4. 2 ⁰
27	smear	58739	Position indicating cables on access bridge to service structure	4.9-1	3.70
The following	are control	smears in	area of CRDM service	structure ^c	
27	smear	58727		1.6-3	1.1-2
27	smear	58728		2.0-3	1.5-2
27	smear	58729		2.1-3	1.8-2
27	smear	58730		<lld< td=""><td>3.8-4</td></lld<>	3.8-4
The following Elevation 347	are control as noted ^a	smears ar	nd acetate pads on Elevo	ation 305	and
42B	smear	58741	Elevation 305	2.3-4	2.4-3
42B	pad ^d	58744	Elevation 305		≃ 7-4

TABLE 4. ENTRY 7 SURFACE CONTAMINATION

42B

42B

14

Elevation 347

Elevation 347

58742

58745

smear

pad

2.4-3

1.6-2

≃1-3

¢

.

TABLE 4.	(continued)
----------	-------------

Data Acquisition					
Task Number	Specimen	Sample Number	Location ^b	Cs-134 (µCi)	Cs-137 (µCi)
42B	smear	58743	Elevation 347	7.7-4	7.9-3
42B	pad	58746	Elevation 347		1 - 3

a. Smear data is total activity on the smear; smeared area was approximately 100 \mbox{cm}^2 .

b. Numbers correspond to those shown in Figure 3.

c. Control smears and acetate pads were removed from their protective bags and rebagged without being used.

d. Acetate pad data is total activity on the pad, pad area is approximately 10 cm^2 .

	Whole Body (mrem)	Skin (mrem)	Maximum (mre	Extremity em)	Approved Dose	
Team Member	Gamma	<u>Beta</u>	Gamma	<u>Beta</u>	Limit (mrem)	
Team 1						
Eng #1	590	0	730	0	1000	
HP #1	510	0	570	0	1000	
Ops #1	150	0	160	U	1000	
Team 2						
Ëng #2	580	0	670	0	1000	
Tech #1	5 7 0	0	580	0	1000	
HP #2	560	0	640	0	1000	
Team 3						
Elec #1	290	0	450	0	1000	
Ops #2	410	0	470	0	1000	
HP #3	600	0	710	0	1000	
Eng #3	350	0	420	0	1000	
Team 4						
Eng #4	150	0	120	0	1000	
Eng #5	100	0	120	0	1000	
HP #4	55	0	60	0	1000	

TABLE 5. ENTRY 7 PRELIMINARY TLD READINGS

「「「「「「「」」」

Survey Equipment		Protective Clothing		Tools and Other Equipment	
Туре	Quantity	Туре	Quantity	Description	Quantity
R0-2A	3	PC's w/hoods, gloves	2	Column test equipment	1
Teletector	2	Fireman's bools, pair	1	Grease gun	l
E530	I	Wet suits (7 men only)	1	Üiler	1
PNC-4	1	MSA purifer or parti- culate respirator	1	Clipboards	6
				High volumn air sampler	1
		BZA samplers	1	Gallon bottles filled with 25 lb of lead	14
				Nikonos III camera w/flash (35 mm)	1
				Airlock ramp	2
				CCTV connector tester	١
			Sump sampler equipment	1	
				Lead lined powdex buckets	4
				Simpson volt meter	1
				Set of jumpers for LPR-3B	1
				Spotlight	1

.

 \sim

~

e. 16

TABLE 6. ENTRY 7 EQUIPMENT LIST

2

 \sim

The second se

Survey E	quipment	Protective C	lothing	Tools and Other Equipmen	t
Туре	Quantity	Туре	Quantity	Description	Quantity
				Two way racios/minimum per team	1
				Small lights/individual	١
				Pencil dosimeter/individual	1
				Digital dosimeter/individual	1

-

1

الأو المتعدية

OBSERVATIONS AND RECOMMENDATIONS

The following are the results of the debriefing session. Response action has been assigned as noted.

3

1

1

)

7

Response Action	Item
Safety	More training concerning heat stress and how to avoid it.
CAG	Physical effort level to be better simulated during mock-up training in full dress.
CAG	Reading of digital dosimeters to be attempted during mock- ups to determine best location for each individual.
CAG	Turn on of small back-up lights to be done during mock-up training.
CAG	Waist belts are to be secured in a manner to preclude slipping.
CAG	Those who are to wear radios should do so during mock-up training.
CAG	Smaller clipboards secured around the neck may be easier to use.
CAG	Use of scenarios which provide each individual with his specific tasks to be performed with the time frame indicated in a very brief form. Detailed and integrated scenarios to be utilized in the command center.
CAG	All equipment should be staged on a table in the entry room prior to start of entry. If more than one team is to make an entry, equipment should be grouped and designated as to which team it belongs to.
CAG	Ante-room support personnel should have a team by team air- lock loading schedule for all equipment.
CAG	All team members should have extra booties in order to accommodate unforeseen transits into the airlock.
CAG	Wet suits if used should be two piece with bib type pants.
CAG	Need to include a signal during training which signifies to the undressers that there is an urgent need for rapid undressing.

19

a strategical second

OBSERVATIONS AND RECOMMENDATIONS (continued)

Response Action	Item
CAG	Wet suit should be sliced open immediately in order to allow cooling.
CAG	Department that is to perform task should provide required tools.
CAG	Some type of handling bracket should be provided for aircraft light.
CAG	Area in ante-room should be designated for survey clipboards.
CAG	Alternate methods for attaching equipment (clipboards, survey instruments, etc.) should be developed.
None	Minimum floor surface clearance on Elevation 305 between open stairwell and containment seismic gap is fourteen inches.
Plant Maintenance	LPR-3A is extremely noisy.
CAG	Notify maintenance that scaffolding on Elevation 305 between open stairwell and containment seismic gap is fourteen inches.
Plant Maintenance	No tags were installed on LPR-3B jumpers.
CAG	Additional means should be provided to ensure that radio earphones are secured properly.

Ĺ

Ċ