

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

GEND- INF-078

GEND- INF--078

DE88 007710

ICBC VERSION 3.1
TMI-2 INITIAL AND BOUNDARY CONDITIONS
DATA BASE

Ronne W. Brower
Larry J. Fackrell
Daniel W. Golden
Mary L. Harris
Carol L. Olaveson

MASTER

January 1988

EG&G Idaho, Inc.
Idaho Falls, Idaho 83415

Prepared for the
U. S. Department of Energy
Idaho Operations Office
Under DOE Contract No. DE-AC07-76ID01570

Abstract

The TMI-2 initial and boundary conditions data base is a micro computer data base which provides the required initial and boundary conditions to simulate the TMI-2 accident. Additionally, other time series plant measurements related to the accident are included in the data base. Major features of the data base are the ability to plot, manipulate and list data as well as to enter user supplied data (e.g. results of simulations). The user guide provides the instructions for installation and operation of the data base.

CONTENTS

1.0	INTRODUCTION	1
2.0	ICBC INSTALLATION	4
2.1	Data Base Acquisition	4
2.2	Personal Computer Hardware Requirements	4
2.3	Data Base Installation	5
3.0	ICBC STRUCTURE	9
4.0	USER INTERACTIONS	11
4.1	Entry Form	12
4.2	ICBC Main Menu	13
4.3	Edit Menu	13
4.4	Plant Conditions Report Form	15
4.5	Custom User Reports	18
4.6	Plotting Capabilities	19
4.7	User Entry of Time Series	25
4.8	Manipulation of Time Series Functions	29
5.0	DATA QUALITY	31
6.0	SUMMARY	34
	REFERENCES	35
	APPENDIX A	A-1
	APPENDIX B	B-1
	APPENDIX C	C-1
	APPENDIX D	D-1
	APPENDIX E	E-1

FIGURES

1.	Instructions to Generate the PCSYS.CFG File	6
2.	Identification of PC Hardware	6
3.	Form Configuration for TMI-2 Data Bases.....	10
4.	ICBC Entry Form	12
5.	Main ICBC Option Menu	13
6.	ICBC Edit Menu	14
7.	Display of Plant Conditions Record for Editing.....	14
8.	ICBC Fixed Report Generation Menu (Screen 1).....	15
9.	ICBC Fixed Report Generation Menu (Screen 2).....	17
10.	User Selected Conditions Report Menu.....	18
11.	ICBC Plot Selection Menu	20
12.	Option 4 Plot Setup Menu	21
13.	Find Time Series Function Menu.....	22
14.	Plot of Composite Primary Pressure with Uncertainty Function	24
15.	Two Plot Selection with List Screen Overlay	24
16.	Listings of Steam Generator Level Functions.....	25
17.	Model ICBC Time Series Entry File.....	26
18.	ICBC Disk Entry Form	27
19.	Description of User Functions	28
20.	ICBC Time Series Function Manipulations	29
21.	Form for Identification of USER Functions.....	30

ICBC VERSION 3.1
TMI-2 INITIAL AND BOUNDARY CONDITIONS
DATA BASE

1.0 INTRODUCTION

The Initial and Boundary Conditions data base (ICBC) has been developed by EG&G Idaho's Three Mile Island (TMI) Accident Evaluation Program (AEP) to support the Department of Energy (DOE) sponsored TMI-2 Standard Problem¹. The ICBC contains the best available data of those initial and boundary conditions that affected the progression of the accident in the TMI Unit 2 (TMI-2) reactor coolant systems for the first 16 hours following the initiating turbine trip event at 04:00:37 hours on March 28, 1979.

Initial conditions consist of plant operational parameters, status of operating systems and burnup condition of the nuclear fuel at accident initiation. Conditions that occurred in the pressurizer, mass transfers within the primary system, reactor coolant pump operations, and steam generator conditions constitute the reported boundary conditions data. All data in the ICBC have been reviewed by AEP's Data Integrity Review Committee (DIRC), which assigned qualification categories and has approved uncertainty estimates developed through analyses of plant data. The procedures followed by DIRC have been written into a methodology (to be published) based largely on methods proposed by Abernathy¹. Published analyses of plant ICBC data are contained in other referenced reports. By convention, all data within ICBC are stored in units commonly used in the TMI-2 plant and existing literature (predominately English). SI units are available to users.

This data base has been developed to operate on an IBM personal computer system (PC, XT, AT or PS/2) or on a 100% compatible system. An EG&G Idaho scientific data base product, SAGE, has been chosen as the data base management system. Applications routines are written (using overlay segmentation) in the Modula-2 structured programming language.

This report emphasizes user interaction with the data base. Section 2.0 addresses the acquisition of the ICBC and how to install it, including hardware requirements. Section 3.0 is a brief description of the data base structure. User interaction with the data base to produce outputs of the contained data are discussed in Section 4.0.

Version 3.1 of the ICBC includes all features of the previously distributed Version 3.0 with improvements or additions in the following areas:

addition of a PC configuration table (also in Version 3.0);

inclusion of more TMI-2 data functions reviewed by DIRC (compare listing in Appendix B with that from Version 3.0);

revised decimation of 14 reactimeter data channels to preserve frequency structure lost in previous ICBC versions where every 10th point was recorded (see Appendix D);

extension of the data manipulation capability to include integration and differentiation plus ability to exercise a <F>ind option from the manipulation form and to execute manipulations (including delete) from the form produced;

addition of power peaking factor data at 0 and 100 minutes (ORIGEN calculation in the same format as the core burnup data) and the Los Alamos Scientific Laboratory (LASL) decay heat curve;

further improvements in the procedures which permit users to enter time series functions; and

addition of a capability to rebuild user data files plus ability to load

--
1. Standard Problem - A formal exercise in which participants will apply their analytic methods to the TMI-2 accident using common data (i.e., initial and boundary conditions, plant configuration, etc.) to benchmark accident analyses techniques to estimate the source term from low-probability severe accidents.

ICBC Version 3.1 files from diskettes and merge existing user data files already within the \ICBC subdirectory of the hard disk.

A discussion of these new features is presented in the appropriate sections of this user manual. In several cases, forms have been altered to provide improved ICBC capabilities.

2.0 ICBC INSTALLATION

2.1 Data Base Acquisition

The TMI-2 Initial and Boundary Conditions data base may be acquired free of charge to agencies connected with DOE sponsored TMI-2 research by written request to:

J. M. Broughton
Manager, DOE Severe Accident Research Programs
EG&G Idaho, Inc.
P. O. Box 1625
Idaho Falls, Idaho, 83415

2.2 Personal Computer Hardware Requirements

The personal computer system on which ICBC Version 3.1 is to be installed must be an IBM system (PC, XT, AT or PS/2) or a 100% IBM compatible system. The host PC system must be operated under IBM Disk Operating System Version 2.1 (DOS 2.1) or newer software. In addition, the following hardware features are necessary:

a diskette drive, double sided (320/360KB) or high capacity (1.2MB);
Note: ICBC is not available 3.5" diskettes

a display with graphics adapter (color preferred). Note that use of an IBM enhanced graphics adapter also requires that the system have a 16 color IBM memory expansion card (P/N 1501201)

a 20MB internal fixed (hard) disk unit

640KB memory

a math co-processor (8087 for PC, XT; 80287 for AT, PS/2)

dependent. The data bases support those devices that are in common use at EG&G Idaho. In particular, plotted hardcopy output of ICBC data requires:

- a. an EPSON FX series plotter (or 100% compatible unit), and/or
- b. a Hewlett-Packard plotter (Model HP7450, HP7470, HP7475, or HP7550).

The data base software routines for output generation require that PC system hardware be defined in a file (PCSYS.CFG) located within the \DOS directory of the system on which they operate. When a user attempts to perform any output option, this file is interrogated to determine if the user's PC system has an acceptable output device. Appropriate error indications are issued if the operation is not permitted.

The user is required to generate the configuration file using two configuration forms prior to their initial attempt to use a TMI-2 SAGE data base product. The two forms are shown in Figures 1 and 2. Once the file exists, it need not be regenerated for installation of additional TMI-2 data bases. Should the hardware configuration change, the user may select an option from the main menu that will permit a change to the PCSYS.CFG file.

Note that ICBC 3.1 plotting requires considerable memory (approximately 570KB) and will not, for example, operate on a system with 640KB of memory and the IBM network program, version 1.0 running at the same time.

2.3 Data Base Installation

ICBC 3.1 is transported on ten, double sided (320/360KB) diskettes or on three, high capacity (1.2MB) diskettes. The descriptions of each diskette content are included in Appendix E.

If you already have ICBC, Version 3.0 resident on your PC system, do not remove files from the \ICBC subdirectory before proceeding with the installation. Observe the special instructions below to retain your user data files within the UDATA.BLK, UDATA.DAT and UDATA.IDX files.

SAGE PC SYSTEM HARDWARE CONFIGURATION
<C>ontinue / Generate <R>eport / <E>xit [C]

The TMI-2 data base products developed by EG&G Idaho, Inc. have outputs (e.g., plots, reports,) which are device dependent. The data base software routines require that PC system hardware be defined in a file (PCSYS.CFG) located within the \DOS directory of the system on which they operate. Users must generate this file prior to their initial attempt to use a TMI-2 SAGE data base product but not thereafter unless their hardware changes.

The file is created through interaction with a form produced by entering "C" in the field at the top of this form. The main menu of each data base includes an option to edit hardware information in PCSYS.CFG. An "R" entry in the above option field generates a copy of the form in a file named SCREEN.CPY .

Use the ALT-H key combination to get general help or the ESC key to obtain specific field help while completing this procedure.

Figure 1. Instructions to Generate the PCSYS.CFG File

SAGE PC SYSTEM HARDWARE CONFIGURATION
<C>ontinue / Generate <R>eport / <E>xit [C]

- 1. PRINTER
 - 0 Other
 - 1 Other w/IBM font
 - 2 EPSON printer
 - 3 EPSON w/IBM fontDefinition [3]

- 2. DISPLAY
(for plotting purposes)
 - 0 No graphics adapter
 - 1 Low resolution
 - 2 Enhanced graphics
 - 3 Professional graphicsDefinition [2]

- 3. PLOTTER
(Hewlett Packard only)
 - 0 None
 - 1 HP7450 3 HP7475
 - 2 HP7470 4 HP7550Definition [0]
Serial Port [1]

To obtain help, place the cursor in a field and depress the ESC key; use ENTER to return.

Figure 2. Identification of PC Hardware

The file named INSTALL.BAT on diskette 1 is used to install ICBC on the user's fixed disk system. To perform this installation, insert diskette 1 into the diskette drive (hereafter termed drive A:) and type the command 'A:INSTALL'. The installation batch file, INSTALL, will create a \ICBC directory on the fixed drive (hereafter termed drive C:) and will copy all files from diskette 1 onto drive C:. Following the transfer from diskette 1, the user will be instructed to remove it and insert the second diskette for transfer of its contents to C:. A second subdirectory, \HALO, will be created to contain all of the ICBC plotting routines. This directory is necessary for plotting; other TMI-2 SAGE data bases will use this same area for plotting.

If you previously have created user time series data files which you wish to retain, you must take the following actions:

Enter the ICBC data base environment by typing "ICBC" and proceed to the main menu.

Choose option 5, 'Enter Data From Disk'.

Select data entry option 3, 'Put New Descriptions in Meas Relation'. This action will properly rebuild access to your user time series functions stored in the UDATA files.

Total storage requirement for ICBC Version 3.1 is 2.7 MB. The '.DAT' files contain the Initial and Boundary Conditions data; the '.IDX' files are associated indices; the '.BLK' files are storage structures for time series functions or large textual records. The ICBC.DFL file contains the forms (screens), including online help messages, through which the data base is operated. M2.EXE is the Modula-2 executable driver and the '.LOD' files are overlay routines that contain the applications software to operate the data base. Those files with 'HALO' in the filename are for plotting of time series data.

The ICBC data base operates from ICBC.BAT in the PC batch area and can be executed by typing 'ICBC' from any directory. All files (default RPT.RPT or user defined) produced by ICBC will be located on disk in the \ICBC

subdirectory. Since the normal return from ICBC will invoke the batch menu function, the user will be required to change directories (CD\ICBC) to direct output of ICBC created files. It is recommended that 'ICBC - Initial and Boundary Conditions data base' be added to the bootup software menu of the user's PC system.

3.0 ICBC STRUCTURE

The ICBC data base uses three major software systems; SAGE, Modula-2 and MPG. SAGE, an EG&G Idaho product, is a scientific oriented development utility with versatile relational data base tools, including a convenient schema and form development package (THOR). Modula-2, an applications language used in connection with the SAGE software, is a state-of-the-art, structured language developed to overcome the shortcomings of PASCAL. MPG is an in-house plotting package built expressly for SAGE personal computer applications.

The ICBC data base has four principal data areas as follows:

- COND - Contains plant conditions data by type, value, associated time, description, uncertainty, physical unit code, and applicable note reference(s). This area contains time series boundary conditions stored in block form within the data base. These functions have attributes that include measurement identification descriptions, uncertainty estimates, data qualification categories, and statements.
- TIMSER - Contains time series functions that have been reviewed by DIRC.
- USER - An area provided for data base users to enter functions into ICBC. This area is also used to contain functions which have been transformed using the data manipulation capabilities within the data base.
- FUEL BURNUP - Contains original enrichment and location of all fuel assemblies within the TMI-2 core, the total burnup and peaking factors in each assembly at each of seven axial elevations within the core and reference(s) to applicable notes.

User interface with ICBC is through a hierarchical system of menus and forms. A typical system structure based on forms is contained in Figure 3. User interaction is accomplished via fill-in-the-blank selections which determine data base operation. The forms and operations are discussed in detail in the next section.




Figure 3. Form Configuration for TMI-2 Data Bases

4.0 USER INTERACTIONS

This section discusses the main ICBC forms (Figure 3), explaining the options available to the user and the actions that result from execution of each. The fields in which the user is expected to input his operational commands are shown in reverse video on a monochrome display and in a different color on a color monitor. A cursor (blinking dash) is used to identify position within the form.

Movement between input fields is accomplished by: (1) completely filling in a field or by depressing the <TAB> key; that causes a sequential transfer to the next field; (2) by using the backtab keys <Shift/TAB> to move to the previous field; (3) by use of the four arrow keys in the numeric pad section of the keyboard; or, (4) by selecting the <HOME> key to transfer to the primary form field. A carriage return <CR> entry causes the user supplied information to be interpreted by the data base software and requested operations to be performed. In one instance (custom reports form) multiple <CR> operations are required, first to transfer the cursor to the form entry field and then to execute user requests.

User entries are processed for legitimate response. When an error is detected (such as an incorrect format, an entry out of range, or <CR> when cursor is not in an entry field), a bell is sounded and a brief error statement displayed at the bottom of the display screen.

On-line help is available from the various fields of the forms by striking the <ESC> key. This causes a brief message to be printed that describes the options available/information to be entered for the field in which the cursor is currently located. Should the cursor not be located within an input field, the form entry position message is displayed. A <CR> is used to return from help messages to the original position within the form (note that when multiple <ESC> key operations are required to complete a user help request, an equivalent number of <CR> operations are required to return to the form). In most instances, the help forms will also contain

the same entry fields as the area of the form from which help is requested; information may be entered from the help screens. Some general form options provided by SAGE are available in ICBC; these options can be reviewed at any time by depressing the <ALT> and <H> keys simultaneously.

4.1 Entry Form

The entry form (Figure 4) provides fields for the user to enter a set of initials and a password for entry into the data base environment. The data base logs the number of times each user/password entry pair is exercised. Users are divided into two classes: 'M'aster users who have permission to edit data base relations and must enter a legitimate user-ID/password combination to alter the data base or 'R'egular users who cannot edit data and are not required to fill in the user-ID and password fields if they so desire. Master user status is reserved to only those individuals responsible for the update and maintenance of the ICBC in accordance with established policy.

TMI-2 ICBC 3.1
Three Mile Island
Initial and Boundary Conditions Data Base

Welcome to the TMI-2 data base system. Please enter your initials and your password for entry permission to be granted. If you have not yet entered the system, your initials and selected password will be recorded.

Use ALT-H for SAGE (general) help	Initials [ANY] Password [USER]	Use ESC for ICBC (specific) help
--------------------------------------	------------------------------------	-------------------------------------

Figure 4. ICBC Entry Form

4.2 ICBC Main Menu

The main menu (Figure 5) gives the user options to edit data base records, to generate data outputs, to enter data from a disk file, to manipulate time series data with simple mathematical operators, or to change the PC system configuration table. All users are permitted to select the edit option and to inspect, but not modify, record contents (see below). Regular user entry of data is restricted to the USER area.

```

      I C B C 3.1
      TMI-2 INITIAL AND BOUNDARY
      CONDITION DATA BASE

```

```

Enter option ... [0]

0)  Exit
1)  Edit data base records
2)  Produce defined tables
3)  Generate custom conditions reports
4)  Plot conditions or time series data
5)  Enter data from disk
6)  Change PC system configuration table
7)  Manipulation of data (USER relation)

```

```

Use ALT-H for SAGE (general) help; Use ESC
for ICBC (specific form field) help.

```

Figure 5. Main ICBC Option Menu

4.3 Edit Menu

Edit selections (Figure 6) allow all users to browse through data records and master users to change data records. Options available in the edit menus are described in boxes at the top of the edit forms. The <A>dd, <M>odify and <D>elete options require master status; others are available to all users. The options are described in help messages associated with the forms. An example of an ICBC editing form (plant boundary conditions, option 1) is shown in Figure 7.

**I C B C 3.1
TMI-2 INITIAL AND BOUNDARY
CONDITION EDITING**

- 0) Exit
- 1) Edit initial condition and boundary condition
- 2) Edit descriptive notes
- 3) Edit time series data
- 4) Edit core burnup data
- 5) Edit group summary data
- 6) Edit peaking factor data
- 7) Edit user

Edit option ... [0]

Use ALT-H for SAGE (general) help;
use ESC for ICBC (form field) help.

Figure 6. ICBC Edit Menu

PLANT BOUNDARY CONDITIONS

<L>ocate / <N>ext / <P>revious / <A>dd / <M>odify / <D>elete
<E>xit [L]

Condition name	[COLD LEG TEMP1A]	
Condition description	[COLD LEG TEMPERATURE 1A, RC-5A-TE2]
Time	[04:00:37]	
Data physical unit code	[1] F	
Low value	[5.506E+002]	
Qualification Status	[QUALIFIED]	
Low uncertainty	[1.910E+000]	
High uncertainty	[1.910E+000]	
Notes	[32] [34] [--] [--] [--]	

Figure 7. Display of Plant Conditions Record for Editing

4.4 Plant Conditions Report Form

ICBC has provision for generation of nine conditions reports (plus explanatory notes), a time series summary report and six reports which describe the conditions of the fuel at the time of the accident. These reports are accessed through option 2 from the main menu (figure 5). Selection of the 'produce defined reports' option produces the screen shown in Figure 8. From it, the user can generate the following reports:

Plant conditions reports (Figure 8) - tabulations of important plant conditions at accident initiation, at 100 and at 174 minutes (key times in the accident scenario, available as report options 3, 4, or 5); history of the pressurizer block and spray valve operations (report options 7 and 8); the pressurizer heater operations (option 11); the primary coolant pumps operations (option 9) and makeup and HPI injection rates (option 11). In addition, ICBC makes available to the user a set of notes relative to the last conditions report generated (report from option 1) or a complete set of conditions notes (option 2).




Figure 8. ICBC Fixed Report Generation Menu (Screen 1)

ICBC Time Series Function Summary (Figure 8) - The user can also generate a report of the time series data within ICBC by selecting report number 12. This will produce a tabulation containing the function identification, type, the reactor system to which the measurement pertains, the measurement description, its qualification category, uncertainty and comments needed to interpret the function. As an example: Measurement RC-58-TE2-R is a temperature measurement within the Reactor Coolant B loop; it is stored in ICBC in the COND relation; its associated description is 'Cold Leg Temperature - Loop 18'; it has been reviewed by the AEP DIRC and assigned a category of 'QUALIFIED' with an uncertainty of 1.91 Deg F.; and it is 'QUALIFIED UP TO 100 AND AT 174 MIN.'

When the user strikes the <PgDn> key while the report generation menu in Figure 8 is on his PC screen, a second report screen is displayed as shown in Figure 9. From this screen, he has option to select any of six reports which pertain to TMI-2 fuel conditions at the start of the accident.

ICBC Fuel Conditions Reports (Figure 9) - Fuel condition calculations have been generated using the isotopic generation and depletion code ORIGEN2 and a generic PWR cross section library. These calculations were performed by dividing the core into 12 fuel groups and calculating core inventory data at 7 axial levels in the core for each of the 177 fuel elements. Information in ICBC includes a group summary report (option 12), an element location and fuel enrichment table (option 13), initial conditions fuel burnup data in tabular (option 14) or diagram (option 16) format and core peaking factor data in tabular (option 17) or diagram (option 18) format. Fuel diagram outputs are provided in two forms; one uses the IBM extended character set to generate square rectangle corners.

The user may direct report output to the <S>creen, to an attached <P>rinter or to <D>isk. While reports are being generated, the message "Generating Report" is output at the bottom of the monitor screen. The ICBC system default is the screen. The user is given the ability to page up and down through a report sent to the screen using the <PgUp>, <PgDn> plus the up and down arrow keys. Information sent to the screen is buffered; a

Select the plant conditions or fuel burnup report format you desire by highlighting it in the rectangle below and pressing <Enter>

Use PgDn to
select fuel
burnup
reports

```
0 Exit
13 Group summary report
14 Initial conditions core burnup
15 Element location and enrichment tab
16 Axial level diagrams
17 Peaking factor table
18 Axial peaking factor diagrams
```

Use PgUp to
select plant
conditions
reports

```
[ 0 ] ... report selection
[E] <E>nglish or <M>etric units
[S] <S>creen, <P>rinter or <D>isk  Filename [      ]
```

Figure 9. ICBC Fixed Report Generation Menu (Screen 2)

<Ctrl><Z> command is used to control the buffers. When an end to the current buffer is reached, the <Ctrl><Z> command produces a message inquiring whether the user desires to move <F>orward or ackward through additional buffers or <E>nd the screen report display. A <Ctrl><Z> command is required to return control to the ICBC screen menus when the last buffer of a report is displayed. All reports sent to the screen are also written in the ICBC subdirectory on the default disk device under a scratch filename 'RPT.RPT'.

When a report is sent to a system printer, a pause is executed to ask user if the printer is ready to receive a print file. When the user responds 'Y'es, the report is printed.

If the <D>isk option is selected, the user may specify any system disk desired for report generation and may select any filename desired by typing <DEV:FILENAME> in the appropriate field (example - A:MYREPORT entry creates a file MYREPORT.RPT on diskette device A:).

As a convenience, all reports which can be generated from the report forms (figures 8 and 9) are included in this user's document within Appendix B.

4.5 Custom User Reports

User defined reports can be generated containing selected combinations of conditions data at 0, 100 or 174 minutes through use of the report generation form shown in Figure 10.

```
<E>xit \ <D>one ..... [ ]
Report Title [ ]
Time Selection 0 min. [ ] 100 min. [ ] 174 min. [ ]
min. relative to Zero, place an X in fields desired
<E>nglish or <M>etric [E]
<P>rinter <S>creen or <D>isk [S]
Disk Filename [ ]
Mark Cond Type All [ ]
[ A LOOP LEVEL [ A LOOP MASS [ B LOOP LEVEL
[ COLD LEG TEMP1A [ COLD LEG TEMP1B [ COLD LEG TEMP2A
[ COLD LEG TEMP2B [ FEEDWATER FLOWA [ FEEDWATER FLOWB
[ FEEDWATER TEMP [ FLOW RATE [ HG01
[ HG02 [ HG03 [ HG04
[ HG05 [ HG06 [ HG07
[ HG08 [ HG09 [ HG10
[ HG11 [ HG12 [ HG13
[ HOT LEG TEMP-A [ HOT LEG TEMP-B [ HPI/MAKEUP
[ LETDOWN FLOW [ MASS FLOW RATEA [ MASS FLOW RATEB
[ NSAC MAKEUP [ PCP1A [ PCP1B
[ PCP2A [ PCP2B [ PCRV FLOW RATE
[ PRESSURE PRI [ PRESSURE SG-A [ PRESSURE SG-B
```

Figure 10. User Selected Conditions Report Menu

This menu permits the user to specify a report title, select data output at 0, and/or 100 and/or 174 minutes, and to choose <E>nglish (default) or <M>etric units. As in the fixed report generation operations described above, he can direct his output to the <P>rinter, <S>creen or <D>isk. He may select output of any of the listed data by placing the cursor in the fields at the left of the desired conditions and striking the <Enter> key which places an 'X' to mark the condition for report output.

Marking the 'All' field with a character will list all of the conditions data on his report. The <Home> key will transfer cursor control to the Exit/Done field, an <E> exits the option 3 form to the main ICBC menu without any report generation action, a <D>one entry generates a report as defined by user entered criteria. Warning - The <D> option leaves the user in the option 3 menu where he can generate other reports. When the <S>screen output is exercised each report is sent to the default scratch file RPT.RPT which is continuously written over. If you wish to save the reports please use the <P>rinter or <D>isk file output options.

The data listed on the form depicted in Figure 10 comes from discontinuous functions (i.e., binary ON/OFF primary coolant pumps, etc.) single or tabular data sources (i.e., initial reactor power) or from time series functions ('A' hot leg temperature). Values of these functions at these three key accident times have been placed in an ICBC conditions relation. The discontinuous and time series functions may be plotted or listed using ICBC capabilities discussed in the following user interaction subsections.

4.6 Plotting Capabilities

Within the ICBC data base, users may plot:

1. COND data- Certain plant operations data (piecewise discontinuous - such as HPI flow or primary coolant pump operation) or time series data containing boundary conditions defining accident parameters;
2. TIMSER data- Functions that have been reviewed by the AEP DIRC;
3. USER data - Time series data functions entered by regular data base users.

Plot generation is started by selecting Option 4 from the main menu (Figure 5). This action will produce a plot format selection menu as shown in Figure 11.

Four plot formats are selectable from the plot menu: single variable time series plots with linear or semi-log ordinates; multiple (up to five) plots of time series functions of the same physical type on a common set of X, Y axes; and, two time series functions with individual ordinates on a common time axis. On the plot selection screen, the user may set flags which will produce outputs in <M>etric units (default is <E>nglish), <G>rids at major divisions on the plots (default is <N>one), or <R>etain user time and ordinate axes scaling between successive plotted functions (default is to <N>ot retain scaling).




Figure 11. ICBC Plot Selection Menu

ICBC plot operations will be illustrated using Option 4 and plotting the composite primary pressure function together with its associated uncertainty. Exercising Option 4 brings up another menu on which the user specifies the data identifications, time and amplitude window, and labelling desired on a plot (Figure 12). If the user does not elect to specify ranges for the axes, the program defaults to the entire data set (note that ordinate ranges and a time range were specified). Default labels are also supplied for the time and ordinate axes if not specified (note that no ordinate label was specified in the example).

At the top of the plot setup menus are some options available to the user in determining what time series functions are available in the data base. The first (the <F>ind option) produces another form on which the user is able to locate functions. When the form is initially entered, the identification and description fields are blank and an 'F' appears in the lower right field. The user moves to the double lined box at the top

```

TIME SERIES TWO PLOT SETUP

<F>ind ID / <R>etrieve characteristics / <S>creen / <H>P Plotter
<P>rinter (EPSONFX) / <L>ist / <N>ext / <E>xit ..... [R]

1. Time Series IDs: 1 - [PRESS.-PRIMARY ] 2 - [PRESSURE UNC ]
2. Time Axis      Start [-----E----] Stop [-----E----]
   Time Units      [MN] (sc,mm,hr,dy)
3. Ordinate:     Min 1 - [-----E----] 2 - [-----E----]
   Max 1 - [-----E----] 2 - [-----E----]
4. Labels:      Main Title [ ]
   Time Label   [ ]
   Y1 Title     [ ]
   Y2 Title     [ ]

```

Pts	Plot 1 - 1411	Plot 2 - 32
Start	-1.000E+001	-1.000E+001
Stop	9.999E+002	1.000E+003
Ymin	4.237E+002	1.090E+001
Ymax	2.361E+003	3.970E+001
Unit	10	10

Figure 12. Option 4 Plot Setup Menu

(using the 'Home', tab or arrow keys) and specifies the data functions to be listed by entering information in the fields for:

1. Function type
2. System
3. Leading parameter name characters (example = RC-15A*, where * is a wild card character)
4. <C>OND, <T>IMSER, <U>SER, or <A>LL (the default condition) for data base area selection.

These four fields are logically .AND.ed together for retrieval of data base functions. **NOTE:** Refer to the help messages for these fields by striking <Esc> for legitimate search criteria when the cursor is within one of these fields. Identifications and descriptions are then retrieved and displayed (seven at a time) on the form. The retrieved information is sent to the scratch RPT.RPT file in the \ICBC\ subdirectory of the PC system (note that RPT.RPT is used in many data base output situations and is written over frequently).

The user may page through the screen list using <N>ext and <P>revious options. The user may also select data to be plotted by marking the select boxes to the left of the function IDs. Up to 10 functions may be selected at one time; they must be numbered 1 - 10 if <F>ind is executed from the single plot menus, from 1 - 5 in pairs if <F>ind is selected from the two plot menu (example case), or in two groups, 1 or 2 for the multiple selection form. In Figure 13, we have requested time series functions from COND that have the type attribute = 'PRESSURE' and have marked them with a '1' which, upon return to a two plot format menu, would produce a screen like Figure 12 with the pair 1 identifications and data characteristics filled in.

IDENTIFICATION OF TIME SERIES DATA RECORDS			
List data base time series parameters with descriptions by: Type - [PRESSURE] .AND. System - [] First characters of ID - [] <C>ond,<U>ser,<T>imser,or<A>11 - []			
Check	Identification	Description	
[--]	BS-PR-4388-S	Reactor Building Pressure - Composite	Timser2
[1]	PRESS.-PRIMARY	Reactor Coolant Composite Pressure	Timser3
[1]	PRESSURE UNC	Primary System Pressure Uncertainty, Discontinuous Function	Cond
[--]	SP-10A-PT1-R	Turbine Header Pressure - Loop A	Timser3
[2]	SP-6A-PT-ABS	Steam Generator A - Secondary Absolute Pressure	Timser3
[--]	SP-6A-PT1-R	Steam Generator A - Steam Pressure	Timser3
[2]	SP-6B-PT-ABS	Reactor bldg. - Steam Line A1 or A2	Timser3
		Steam Generator B - Secondary Absolute Pressure	Timser3
<N>ext / <P>revious / <E>xit ... [F]			

Figure 13. Find Time Series Function Menu

The <R>retrieve characteristics option (default when entering a plot generation form) causes the named function(s) to be accessed on disk to determine the time and amplitude ranges, number of points, and the unit code. These data are placed in the box at the bottom of the screen (see figure 12).

The <S>screen, <H>P Plotter and <P>rinter selections direct a defined plot file to a desired output device. Error messages are displayed at the bottom of the screen if the user attempts to send a plot file to a device not specified in the PCSYS.CFG file. Messages, presented at the bottom of the plot setup screen when a plot is sent to a specified device, remind the user of actions to be performed (for example, if the output selected was <P>rinter, the message "Is printer ready (Y/N)?" is shown and the program pauses waiting for the appropriate response). The plot specified in Figure 13 was output to an HP 7475 plotter and reproduced as Figure 14. Data are decimated with a minimum/maximum algorithm in ICBC when plotting is requested for functions (or portion thereof) exceed 1000 points in length. Each function to be displayed on a single or two plot format is decimated to <1000 points prior to display; each function displayed in a multiple plot format is decimated to <750 points. These reduced numbers are placed in the attribute boxes when the setup forms are redisplayed following a plot operation.

The <L>ist data option produces an overlay screen on the plot selection forms as shown in Figure 15. On the two plot selection menu, functions SG-A-LEVEL and SG-B-LEVEL have been retrieved (their identifications are hidden under the overlay list menu but their characteristics can be seen in the display only fields at the bottom of the figure). The user is given the option to select a list format and a decimation algorithm.

In the Figure 15 example, we have selected format 1 and a decimation of every 99th point. Format 2 listings are useful when the user wishes to extract time series data from ICBC and process it in some other software package. Note that an entry in the single heading field will produce only an initial list heading and data rather than a paginated output with a heading on each page. The 'P' decimation algorithm uses an iterative min/max file compaction routine in which the least and greatest of each consecutive three points are chosen until the number of points in the file




Figure 14. Plot of Composite Primary Pressure with Uncertainty Function

TIME SERIES TWO PLOT SETUP

<F>ind ID / <R>retrieve ch
 <P>printer (EPSONFX) / <L>

SELECT LIST OPTIONS [L]

1. Time Series IDs: 1	Format:
2. Time Axis Start	1 = 3 time/value pairs per line (reports)
Time Units	2 = 1 time/value pair per line
3. Ordinate: Min 1	[] ... Select Format
Max 1	[] ... Single Heading
4. Labels: Main Title	Decimation:
Time Label	[--] Enter n to list every nth point
Y1 Title	[] Enter P to obtain plot min/max
Y2 Title	[---] decimation (below 1000 pts)

Pts	P1	
Start	-1.000E+001	-1.000E+001
Stop	9.313E+002	9.313E+002
Ymin	1.078E+001	1.468E+002
Ymax	1.089E+003	1.067E+003
Unit	10	10

Figure 15. Two Plot Selection Form with List Screen Overlay

is less than a default of 1000 (further compaction is provided by entering an integer in the range 1-999 in the decimation field). The listings of time series functions are sent to file RPT.RPT in the /ICBC subdirectory. Figure 16 is a reproduction of the list generated by executing the options selected in Figure 15 (16 points/function are produced since there were 1550 points per function and every 99th value was selected).

Data Listing for SG-B-LEVEL

Time Period -1.000E+001 to 2.990E+002 MM
Decimation: Every 99th point; - Plot min/max

Time	Value	Time	Value	Time	Value
-1.00E+01	5.30E+02	9.00E+00	0.00E+00	2.96E+01	1.04E+02
4.94E+01	9.43E+01	6.92E+01	1.07E+02	0.90E+01	2.32E+02
1.09E+02	2.74E+02	1.29E+02	2.76E+02	1.48E+02	2.77E+02
1.68E+02	5.08E+02	1.08E+02	7.10E+02	2.08E+02	7.29E+02
2.28E+02	7.38E+02	2.47E+02	7.42E+02	2.67E+02	7.45E+02
2.87E+02	7.48E+02				

Data Listing for SG-B-LEVEL

Time Period -1.000E+001 to 2.990E+002 MM
Decimation: Every 99th point; - Plot min/max

Time	Value	Time	Value	Time	Value
-1.00E+01	5.30E+02	9.00E+00	0.00E+00	2.96E+01	1.04E+02
4.94E+01	9.43E+01	6.92E+01	1.07E+02	0.90E+01	2.32E+02
1.09E+02	2.74E+02	1.29E+02	2.76E+02	1.48E+02	2.77E+02
1.68E+02	5.08E+02	1.08E+02	7.10E+02	2.08E+02	7.29E+02
2.28E+02	7.38E+02	2.47E+02	7.42E+02	2.67E+02	7.45E+02
2.87E+02	7.48E+02				


Figure 16. Listings of Steam Generator Level Functions

4.7 User Entry of Time Series Functions

The ICBC data base provides an area (USER) in which a user can enter his own time series functions (such as the results of calculations) for comparison with similar functions contained within the data base. To enter time series functions into the data base, the user must:

1. Prepare a formatted disk file containing the time, value pairs.

less 13-character fields per card. The data may be in fixed point or exponential format. A data frame may consist of multiple channels with an associated common time channel (refer to the diagram in Figure 17).



•
•
•

Figure 17. Model ICBC Time Series Entry File

If input data are multiplexed in this manner the following rules must be observed -

- a. Each new frame of data must begin on a new card, and
- b. If some time series functions have more values than others, the shorter channels must contain blank filled fields within the data frames to preserve position for correct interpretation.

The Figure 17 diagram depicts five frames from a model entry file in which there is one time channel (third position) and seven time series functions per frame.

2. Enter the formatted data (from a PC system disk) through selection of option 5 from the main menu (Figure 5). This action produces a disk entry menu (Figure 18) on which the user enters the time series data one channel at a time. The user must enter -

```

      ICBC 3.1
TMI-2 INITIAL AND BOUNDARY CONDITIONS DATA BASE
DISK ENTRY OF DATA

File Name for disk entry      [          ]

For time series data include:
Channel Name                   [          ]
Channel Position in file      [---]
Total Channels on file        [---]
Relation Name to contain data [Data  ]
Time Channel Position         [---]
Time Channel Name             [          ]

0) Exit
1) Disk entry of time series meas.
2) Deletion of time series measurement
3) Put new Descriptions in Meas Relation
[0] ... Enter option [N] ... Find functions

```

Figure 18. ICBC Disk Entry Form

- a. The disk filename (DEV:FILENAME.EXT), 'A:MODEL.DAT' in the example,
- b. Channel identification must be unique among the COND, TIMSER and USER areas, 'CHANNEL 6' assumed unique,
- c. Channel position in the file data frame (the data function being entered is in the 2nd position of the 2nd card in each frame, so the proper entry for channel 6 is '7'),

- d. Total channels in the frame (there are 7 functions in our hypothesized file plus the time channel so the correct entry is '8'),
 - e. Relation name in which the data is to be deposited (NOTE: This name must be 'Data' as other time series data areas in ICBC are password protected); and,
 - f. The associated time channel position in the frame, '3', and its name, 'TIMECH6', which also must be unique in ICBC.
3. Describe the entered function by completing the form in Figure 19 that is automatically displayed upon successful completion of the disk entry process. Help messages are available that list the function types, unit codes, systems, and locations associated with functions in the COND and TIMSER data base areas. Wherever possible, it is recommended that user functions be given these same attributes.

DESCRIBE USER FUNCTION

1. MEASUREMENT DESCRIPTION:

Measurement ID	[LETDOWN FLOW]		
Description	[]
Meas Type	[Unit Code [--]]
System	[]
Location	[]

Figure 19. Description of User Functions

Maintenance of the user defined data base functions becomes the data base owners responsibility. A well conceived plan for the identification, usage and maintenance of these data is essential. In the following section of the report information is presented to delete user functions; Appendix C describes a utility to rebuild user data files.

4.8 Manipulation of Time Series Functions

The ICBC contains a capability for manipulation of time series data functions from the COND, TIMSER and USER areas. It can be used by anyone and is accessed by entering Option 7 from the main menu. A menu of mathematical operators is presented on the manipulation screen shown in Figure 20.

0 Exit			
Math operations with pairs of functions or function and constant:		Logarithms:	
1 ADD		7 LOG Common log	
2 SUBTRACT		8 LN Natural log	
3 MULTIPLY		Other:	
4 DIVIDE		9 ABSOLUTE value of function	
NOTE - When used with <F>ind, user must select operation number.		10 SHIFT add const. to x-coordinate	
Exponentiation:		11 SQRT square root of function	
5 EXPN raise function to power		12 INTEGRATE function	
6 EXP raise function to power, keep arithmetic sign		13 DIFFERENTIATE function	
		14 DELETE functions	
		[0] . . . Select Operation desired	
		[] . . . <F>ind functions	
Original Function	[]	Relation	Data
Second Function	[]	Relation	
or constant	[-----E-----]		
New Function	[]		USER

Figure 20. ICBC Time Series Function Manipulations

The simple mathematical operators (add, subtract, multiply, or divide) may transform a selected function using a specified constant or another selected function. Functions may be raised to a power; the common or natural logarithm of functions may be obtained. Other manipulations include (1) taking the absolute value of a function, (2) shifting the function time base by specification of a value (remember that the ICBC time values are assumed to be in minutes), (3) taking the square root of a function, or (4)

integration or differentiation of a function. The results of these data manipulations are written into the USER relation. They must be identified in the ICBC with a unique identification in the new function field.

For convenience, a <F>ind option is provided which will produce a form (Figure 21, much like the one in Figure 12) that identifies data functions in the USER area of ICBC. All manipulations may be exercised from the form through identification of the functions involved. To perform manipulations involving two functions, choose the number of the operation on the

IDENTIFICATION OF TIME SERIES DATA RECORDS		
List data base time series functions with descriptions by:		
Type - []	.AND. System - []
First characters of ID - []	<C>ond,<U>ser,<T>imser,or<A>ll - []
Check	Identification	Description
[--]		
[--]		
[--]		
[--]		
[--]		
[--]		
[--]		
[--]		
Entry in check field varies by application, see Help		<N>ext / <P>revious / <E>xit ... []

Figure 21. Form for Identification of USER Functions

manipulation form (Figure 20) and mark the check box to the left of the desired functions on Figure 21 with a '1' and a '2'; the '2' function will be the subtrahend, multiplier or divisor. To perform other operations, choose the operation and check the functions to be manipulated with the numbers 1 - 10 in the check fields. Upon exit from the <F>ind form, each marked function will be presented on the manipulation form in the 'original function' field and the user is required to enter any constants involved and the 'new function' name to execute the manipulation. The user delete option

5.0 DATA QUALITY

The quality of the data provided as initial and boundary conditions has been established. The review process involves a thorough review of the measurement system, its operation and calibration. Computational models, methods and assumptions were also evaluated. From this review and analyses of the measurement systems, uncertainties in the data are determined. Based on the review process the measurements were then categorized on the basis of data quality.

The sources of data for the accident are the reactimeter, alarm printer, utility printer, analog strip charts, multipoint recorders, plant manuals and procedures, other analyses and reports on the accident, and operator interviews. The reactimeter was an online digital data acquisition system and is the most reliable source of information about the accident. However, only a small number (24 of the more than 3000 data channels) were recorded on this system at a sampling rate of 20 per minute. The utility printer provides the hourly logs; specific digital measurement groupings requested by the operators at various times and other automatic data printouts. The alarm printer provides a printed record of plant alarms as they occurred. These data were lost from 73.3 to 159.5 minutes since the printer was running behind and the operators flushed the buffer so they could get more current information. The alarm and utility printer are also considered to be reliable sources of information.

Analog strip charts and multipoint recorders are quite useful, but the uncertainties in these data sources are in general larger than the digital data recorded on the reactimeter, alarm printer, or utility printer. The remaining sources of information provide a background for understanding the context in which the data were recorded and a basis to test the consistency of the data.

The formal review process started with an analyst reviewing the data for consistency with other available data sources and performing any required calculations. The analyst's work was then presented to and reviewed by an internal peer review committee (the Data Integrity Review Committee). Based on the analyst's recommendation and the committee review, the quality level of the data was established.

Qualified data are that which have valid magnitudes and whose uncertainties are sufficiently small to represent data from a typical experimental facility. TMI-2 data that typically fit this category are the reactimeter data, except when specific measurements were out of range.

Trend data are those for which the validity of the data magnitudes can not be assured due to unacceptably high uncertainties or inability to determine the uncertainties. Lack of a recent calibration for a measurement is one reason for data to be categorized as trend data. Inability to accurately read the recorded data (e.g., poorly printed multipoint strip charts) is another. Enigmas in the data represent a common reason for categorizing data as trend.

Composite data are assembled using data from more than one measurement channel. TMI-2 composite data may be composed from reactimeter, strip chart and/or utility printer sources. As an example, the primary system pressure during the accident has been constructed from three measurement channels depending on the time during the accident. The reactimeter recorded the primary system pressure from a narrow range transmitter (RC-3B-PT1-R). Up to about 2 minutes after the turbine trip, the reactimeter data were used. At this time, the pressure fell below the range for this instrument. Transmitter RC-3A-PT3 being recorded on the utility printer (-15 to +15 minutes) and on a strip chart was then used for the primary pressure. During this period of time, the system pressure rose high enough several times so that the narrow range instrument could be used. Composite data may contain both qualified and trend data depending on the source for any specific time period.

Computed parameters are the result of post accident manipulation of a measurement or set of measurements. Computed parameters are based on computational models for which the output is clearly related to the data. The best estimate steam generator levels, for example, are computed parameters based on the level measurements. The start-up, operating and full range level measurements were put on a common basis using a computational model. The results from the computational model provide a better level estimate than do the values from any one measurement. Computed parameters may be categorized as either qualified or trend depending on the quality of the data and the computational model.

Estimates are based on calculations that rely on assumptions about the plant operation and behavior; they may require considerable manipulation of data or use of plant modeling techniques.

6.0 SUMMARY

The Initial and Boundary Conditions data base has been developed by the EG&G TMI-2 Accident Evaluations Branch using information from many sources. Those that have (at the time of this report) received report status are included in the references to this document.

The data base product may be acquired by any agency connected with TMI-2 research programs sponsored by DOE. Corrections to the data base or comments on its content or operation are welcomed. Please contact the EG&G TMI-2 Accident Evaluations Programs manager at the address given in Section 2.

1. R. B. Abernathy, R. P. Benedict, Measurement Uncertainty: A Standard Methodology, ISA Transactions, Volume 24, Number 1, 1985.
2. Stephen R. Behling, Computer Code Calculations of the TMI-2 Accident: Initial and Boundary Conditions, EG&G Idaho Inc., Informal Report EGG-TMI-6859, May 1985.
3. B. G. Schnitzler and J. B. Briggs, TMI-2 Isotopic Inventory Calculations, EG&G Idaho Inc., Informal Report EGG-PBS-6798.
4. J. L. Anderson, Analysis of TMI-2 Pressurizer Level Indications, EG&G Idaho Inc., Informal Report EGG-TMI-7100, January 1986.
5. R. B. McCormick, Determination of Void Fraction from Source Range Monitor and Mass Flow Rate Data, EG&G Idaho Inc., EGG-TMI-7324, September 1986.
6. J. L. Anderson, TMI-2 Once Through Steam Generator Secondary Level Analysis, EG&G Idaho Inc., Informal Report EGG-TMI-7359, January 1987.
7. J. L. Anderson, TMI-2 Once Through Steam Generator Auxiliary Feedwater Injection Rates, EG&G Idaho Inc., Informal Report EGG-TMI-7481, January 1987.
8. J. L. Anderson, Steam Generator Secondary Side Effects Upon Primary Side Thermal-Hydraulics During the TMI-2 Accident, EG&G Idaho Inc., Informal Report EGG-TMI-7482, January 1987.
9. R. D. McCormick, TMI-2 Primary Coolant Mass Flowrate Data Report, EG&G Idaho Inc., Informal Report EGG-TMI-7485, December 1986.
10. R. D. McCormick, TMI-2 Radiation Monitor Data Report, EG&G Idaho Inc., Informal Report EGG-TMI-7376, 1986.

APPENDIX A

SAMPLE REPORT OUTPUTS FROM ICBC REPORTS

APPENDIX A

CONTENTS

TABLE A-1	TMI-2 Plant Conditions: Initial.....	A-1
TABLE A-2	TMI-2 Plant Conditions: 100 min.....	A-5
TABLE A-3	TMI-2 Plant Conditions: 174 min.....	A-9
TABLE A-4	Pressurizer Block Valve Operation	A-13
TABLE A-5	Spray Valve Position	A-16
TABLE A-6	Primary Coolant Pump Operation	A-19
TABLE A-7	Heater Operation	A-25
TABLE A-8	TMI-2 Fuel Group Summary	A-29
TABLE A-9	Core Burnup Data at Start of Accident	A-30
TABLE A-10	Element Location and Enrichment Map	A-43
TABLE A-11	Burnup for Axial Level n of 7	A-44
TABLE A-12	Peaking Factor Data for TMI-2 Core	A-51
TABLE A-13	Peaking Factors for Axial Level n of 7	A-60

TABLE A-1

TMI-2 PLANT CONDITIONS: INITIAL

CONDITION	VALUE		NOTES
AUX FEEDWATER INJECTION SG-A, AFW-SG-A Uncertainty estimates: Low:	0.00E+00 none	1bm/s High:	33 none
AUX FEEDWATER INJECTION SG-B, AFW-SG-B Uncertainty estimates: Low:	0.00E+00 none	1bm/s High:	33 none
CALCULATED PARAMETER PORV FLOW RATE Uncertainty estimates: Low:	5.70E+00 1.14E+00	1bm/s High:	32 1.14E+00
COLD LEG TEMPERATURE 1A, RC-5A-TE2 Uncertainty estimates: Low:	5.51E+02 1.91E+00	F High:	32 34 1.91E+00
COLD LEG TEMPERATURE 1B, RC-5B-TE2 Uncertainty estimates: Low:	5.57E+02 1.91E+00	F High:	32 34 1.91E+00
COLD LEG TEMPERATURE 2A, RC-15A-TE3 Uncertainty estimates: Low:	5.26E+02 none	F High:	33 35 none
COLD LEG TEMPERATURE 2B, RC-15B-TE3 Uncertainty estimates: Low:	5.57E+02 none	F High:	33 35 none
HOT LEG TEMPERATURE A-LOOP, TE-HL-A Uncertainty estimates: Low:	6.06E+02 1.14E+00	F High:	32 50 1.14E+00
HOT LEG TEMPERATURE B-LOOP, TE-HL-B Uncertainty estimates: Low:	6.06E+02 1.14E+00	F High:	32 50 1.14E+00
HPI/MakeUp Baseds on expected results Uncertainty estimates: Low:	1.20E+01 none	1bm/s High:	 none
LETDOWN FLOW Uncertainty estimates: Low:	9.22E+00 1.84E+00	1bm/s High:	4 32 1.84E+00
MAIN STEAM TEMPERATURE A, SP-4A-TE-P Uncertainty estimates: Low:	5.95E+02 2.10E+00	F High:	32 2.10E+00
MAIN STEAM TEMPERATURE B, SP-4B-TE-P Uncertainty estimates: Low:	5.94E+02 2.10E+00	F High:	32 2.10E+00
PRESSURE-PRIMARY, PRESS.-PRIMARY Uncertainty estimates: Low:	2.21E+03 1.09E+01	psia High:	32 34 38 1.09E+01
PRESSURIZER LEVEL, RC-1-LT1-L-R Uncertainty estimates: Low:	2.27E+02 2.40E+01	in High:	32 34 2.40E+01

TMI-2 PLANT CONDITIONS: INITIAL

CONDITION	VALUE	NOTES
PRIMARY COOLANT PUMP OPERATION 1A Uncertainty estimates: Low:	ON none	14 none
PRIMARY COOLANT PUMP OPERATION 1B Uncertainty estimates: Low:	ON none	14 none
PRIMARY COOLANT PUMP OPERATION 2A Uncertainty estimates: Low:	ON none	14 none
PRIMARY COOLANT PUMP OPERATION 2B Uncertainty estimates: Low:	ON none	14 none
RC FLOW RATE LOOP A RC-14A-FT-CALC Uncertainty estimates: Low:	6.57E+01 1.41E+00	MPPH 32 High: 1.41E+00
RC FLOW RATE LOOP B RC-14B-FT-CALC Uncertainty estimates: Low:	6.79E+01 1.46E+00	MPPH 32 High: 1.46E+00
REACTOR POWER Uncertainty estimates: Low:	2.70E+03 3.90E+01	MW 32 High: 3.90E+01
STEAM GEN. A FEEDWATER FLOW, SP-8A-FT-R Uncertainty estimates: Low:	5.74E+00 1.06E-01	MPPH 32 34 High: 1.06E-01
STEAM GEN. B FEEDWATER FLOW, SP-8B-FT-R Uncertainty estimates: Low:	5.69E+00 1.06E-01	MPPH 32 34 High: 1.06E-01
STEAM GEN. FEEDWATER TEMP, SP-5A-TE1/2-R Uncertainty estimates: Low:	4.64E+02 1.78E+00	F 32 34 High: 1.78E+00
STEAM GENERATOR A PRESSURE, SP-6A-PT-ABS Uncertainty estimates: Low:	1.06E+03 1.62E+01	psia 32 50 49 High: 1.62E+01
STEAM GENERATOR B PRESSURE, SP-6B-PT-ABS Uncertainty estimates: Low:	1.05E+03 1.62E+01	psia 32 50 49 High: 1.62E+01
TOTAL PRESSURIZER HEATER GROUP POWER Uncertainty estimates: Low:	1.39E+03 none	kw 33 High: none

TABLE A-1

TMI-2 PLANT CONDITIONS: INITIAL NOTES

NOTE NUMBER	TEXT
4	System leakage was 6 gpm liquid equivalent prior to the accident; when the PORV failed open, this leakage can be ignored.
14	Only events which resulted in fluid being pumped are included in pump operation table. Operators started pumps at other times, but because they were steam filled, they developed no head, used very little current, and were quickly turned off.
32	QUALIFIED DATA: These data (a) have had all calibration corrections applied; (b) agree with independent redundant data to within specified uncertainty limits; (c) have been verified to represent the physical parameter being measured; (d) have engineering unit conversions applied; and (e) have uncertainties established for the 95% confidence level.
33	TREND DATA: These data (a) have been verified to represent the relative changes in the physical phenomenon they represent but not the absolute level because of one or more of the following: (a) calibrations do not adequately represent the environment; (b) uncertainty limits cannot be adequately quantified; (c) there are some anomalies in the data; or (d) environmental effects cannot be adequately compensated. TREND data are considered to contain some useful information.
34	Measurement recorded on plant reactimeter - The TMI-2 plant reactimeter contained 24 channels of digital measurement information recorded at one sample/three seconds.
35	Measurement recorded on strip chart recorder - Data were recorded as an analog signal in one of two forms: (a) continuous trace or (b) pen points at specified intervals. Digitized data from the strip charts were converted to engineering units based on recorded measurement ranges. Time base for strip chart measurements were checked against known digital events and adjusted as necessary to preserve time redundancy.

TABLE A-1

TMI-2 PLANT CONDITIONS: INITIAL NOTES

NOTE NUMBER	TEXT
38	PRESSURE-PRIMARY is a composite of measurements (a) RC-3B-PT1-R (reactimeter) -10 - 2.15, 174.35 - 203.6, 225.35 - 233.3, 336 - 463.55, 870.85 - 932.75, 934.75 - 950.2 min; (b) RC-3A-PT3-P (utility printer) 2.4 - 5.65, 570.3 - 869.6, 933.55, 950.75 - 1000 min; (c) RC-4A-TE1-R (reactimeter sat press) 6.0 - 100 min.; and (d) RC-3A-PT3-S (strip chart) 100.6 - 172.5, 207 - 223.5, 240 - 326.6, 464 - 568 min.
49	Qualification Statement for SP-6A-PT-ABS, SP-6B-PT-ABS - These functions composited from secondary pressures SP-6A-PT1-R, SP-6B-PT1-R, reactor building pressure BS-PR-4388-S and atmospheric pressure (14.7 psia assumed). Times between the secondary gage pressures (reactimeter) and the R.B. pressure (strip chart) were normalized at H2 burn time (589.9 min); an artificial spike remains. Elsewhere, timing of small pressure changes (<5 psia) may be affected by large strip chart uncertainty (1.2 min.).
50	Data in this time series function has been composited from multiple TMI-2 measurements after DIRC review to provide a best representation.

TABLE A-2

TMI-2 PLANT CONDITIONS: 100 MIN

CONDITION	VALUE		NOTES
A LOOP WATER LEVEL FROM BOTTOM OF FUEL Uncertainty estimates: Low:	1.81E+01 none	ft High:	33 none
AUX FEEDWATER INJECTION SG-A, AFW-SG-A Uncertainty estimates: Low:	4.37E+01 none	lbm/s High:	33 none
AUX FEEDWATER INJECTION SG-B, AFW-SG-B Uncertainty estimates: Low:	0.00E+00 none	lbm/s High:	33 none
B LOOP WATER LEVEL FROM BOTTOM OF FUEL Uncertainty estimates: Low:	1.90E+01 none	ft High:	33 none
CALCULATED PARAMETER PORV FLOW RATE Uncertainty estimates: Low:	1.95E+01 3.88E+00	lbm/s High:	32 3.88E+00
COLD LEG TEMPERATURE 1A, RC-5A-TE2 Uncertainty estimates: Low:	5.35E+02 1.91E+00	F High:	32 34 1.91E+00
COLD LEG TEMPERATURE 1B, RC-5B-TE2 Uncertainty estimates: Low:	5.36E+02 1.91E+00	F High:	32 34 1.91E+00
COLD LEG TEMPERATURE 2A, RC-15A-TE3 Uncertainty estimates: Low:	5.40E+02 none	F High:	33 35 none
COLD LEG TEMPERATURE 2B, RC-15B-TE3 Uncertainty estimates: Low:	5.43E+02 none	F High:	33 35 none
HOT LEG TEMPERATURE A-LOOP, TE-HL-A Uncertainty estimates: Low:	5.35E+02 1.10E+00	F High:	32 50 1.10E+00
HOT LEG TEMPERATURE B-LOOP, TE-HL-A Uncertainty estimates: Low:	5.37E+02 1.14E+00	F High:	32 50 1.14E+00
HPI/MakeUp Based on expected results Uncertainty estimates: Low:	8.79E+00 none	lbm/s High:	33 none
LETDOWN FLOW Uncertainty estimates: Low:	1.94E+01 3.88E+00	lbm/s High:	32 3.88E+00
NSAC MAAP V2.0 CALCULATION OF HPI/MAKEUP Uncertainty estimates: Low:	1.76E+01 none	lbm/s High:	 none
PRESSURE-PRIMARY, PRESS.-PRIMARY Uncertainty estimates: Low:	9.25E+02 1.60E+01	psia High:	32 34 38 1.60E+01

TABLE A-2

TMI-2 PLANT CONDITIONS: 100 MIN

CONDITION	VALUE	NOTES
PRESSURIZER BLOCK VALVE POSITION Uncertainty estimates:	OPEN Low: 31 3none High:	1 2 29 none
PRESSURIZER COOLANT MASS @100 MIN. Uncertainty estimates:	6.02E+04 Low: none High:	1bm 33 none
PRESSURIZER HEATER RESPONSE Uncertainty estimates:	ON Low: none High:	none
PRESSURIZER LEVEL, RC-1-LT1-L-R Uncertainty estimates:	3.64E+02 Low: 2.40E+01 High:	in 32 34 2.40E+01
PRIMARY COOLANT PUMP OPERATION 1A Uncertainty estimates:	ON Low: none High:	none
PRIMARY COOLANT PUMP OPERATION 1B Uncertainty estimates:	OFF Low: none High:	40 none
PRIMARY COOLANT PUMP OPERATION 2A Uncertainty estimates:	ON Low: none High:	40 none
PRIMARY COOLANT PUMP OPERATION 2B Uncertainty estimates:	OFF Low: none High:	40 none
RC FLOW RATE LOOP A RC-14A-FT-CALC Uncertainty estimates:	1.50E+01 Low: 4.60E+00 High:	MPPH 32 3.00E+00
REACTOR COOLANT FLOW RATE Uncertainty estimates:	2.70E+01 Low: none High:	MPPH 33 none
REACTOR VESSEL COOLANT MASS @100 MIN. Uncertainty estimates:	9.15E+04 Low: none High:	1bm 33 none
RV A LOOP COOLANT MASS @100 MIN. Uncertainty estimates:	5.86E+04 Low: none High:	1bm 33 none
SPRAY VALVE POSITION Uncertainty estimates:	CLOSED Low: .none High:	29 none
STEAM GENERATOR A PRESSURE, SP-6A-PT-ABS Uncertainty estimates:	8.62E+02 Low: 1.62E+01 High:	psia 32 50 49 1.62E+01
STEAM GENERATOR B PRESSURE, SP-6B-PT-ABS Uncertainty estimates:	1.90E+02 Low: 1.62E+01 High:	psia 32 50 49 1.62E+01

TMI-2 PLANT CONDITIONS: 100 MIN NOTES

NOTE
NUMBER

TEXT

- 1 At the time of the turbine trip, the pressurizer was being operated in manual mode; all other major systems were in automatic mode.
- 2 It should be assumed that the PORV failed open on its first challenge when the pressure exceeded 2270 psia (16.65 MPa) and remained open throughout the accident.
- 29 Operation time uncertainty is plus or minus 0.05 min. (3 sec.).
- 31 Reference: Anderson, J. L., Informal Report EGG-TMI-7100, "Analysis of TMI-2 Pressurizer Level Indications", EG&G Idaho, Inc., Jan 1986.
- 32 QUALIFIED DATA: These data (a) have had all calibration corrections applied; (b) agree with independent redundant data to within specified uncertainty limits; (c) have been verified to represent the physical parameter being measured; (d) have engineering unit conversions applied; and (e) have uncertainties established for the 95% confidence level.
- 33 TREND DATA: These data (a) have been verified to represent the relative changes in the physical phenomenon they represent but not the absolute level because of one or more of the following: (a) calibrations do not adequately represent the environment; (b) uncertainty limits cannot be adequately quantified; (c) there are some anomalies in the data; or (d) environmental effects cannot be adequately compensated. TREND data are considered to contain some useful information.
- 34 Measurement recorded on plant reactimeter - The TMI-2 plant reactimeter contained 24 channels of digital measurement information recorded at one sample/three seconds.
- 35 Measurement recorded on strip chart recorder - Data were recorded as an analog signal in one of two forms: (a)

TMI-2 PLANT CONDITIONS: 100 MIN NOTES

NOTE NUMBER	TEXT
	<p>continuous trace or (b) pen points at specified intervals. Digitized data from the strip charts were converted to engineering units based on recorded measurement ranges. Time base for strip chart measurements were checked against known digital events and adjusted as necessary to preserve time redundancy.</p>
38	<p>PRESSURE-PRIMARY is a composite of measurements (a) RC-3B-PT1-R (reactimeter) -10 - 2.15, 174.35 - 203.6, 225.35 - 233.3, 336 - 463.55, 870.85 - 932.75, 934.75 - 950.2 min; (b) RC-3A-PT3-P (utility printer) 2.4 - 5.65, 570.3 - 869.6, 933.55, 950.75 - 1000 min; (c) RC-4A-TE1-R (reactimeter sat press) 6.0 - 100 min.; and (d) RC-3A-PT3-S (strip chart) 100.6 - 172.5, 207 - 223.5, 240 - 326.6, 464 - 568 min.</p>
40	<p>Surmised from hot leg mass flow.</p>
49	<p>Qualification Statement for SP-6A-PT-ABS, SP-6B-PT-ABS - These functions composited from secondary pressures SP-6A-PT1-R, SP-6B-PT1-R, reactor building pressure BS-PR-4388-S and atmospheric pressure (14.7 psia assumed). Times between the secondary gage pressures (reactimeter) and the R.B. pressure (strip chart) were normalized at H2 burn time (589.9 min); an artificial spike remains. Elsewhere, timing of small pressure changes (<5 psia) may be affected by large strip chart uncertainty (1.2 min.).</p>
50	<p>Data in this time series function has been composited from multiple TMI-2 measurements after DIRC review to provide a best representation.</p>

TABLE A-3

TMI-2 PLANT CONDITIONS: 174 MIN

CONDITION	VALUE	NOTES
AUX FEEDWATER INJECTION SG-A, AFW-SG-A Uncertainty estimates: Low:	1.45E+01 none	lbm/s 33 High: none
AUX FEEDWATER INJECTION SG-B, AFW-SG-B Uncertainty estimates: Low:	0.00E+00 none	lbm/s 33 High: none
CALCULATED PARAMETER PORV FLOW RATE Uncertainty estimates: Low:	0.00E+00 none	lbm/s 32 High: none
COLD LEG TEMPERATURE 1A, RC-5A-TE2 Uncertainty estimates: Low:	4.06E+02 1.91E+00	F 32 34 High: 1.91E+00
COLD LEG TEMPERATURE 1B, RC-5B-TE2 Uncertainty estimates: Low:	4.47E+02 1.91E+00	F 32 34 High: 1.91E+00
COLD LEG TEMPERATURE 2A, RC-15A-TE3 Uncertainty estimates: Low:	4.53E+02 none	F 33 35 High: none
COLD LEG TEMPERATURE 2B, RC-15B-TE3 Uncertainty estimates: Low:	4.45E+02 none	F 33 35 High: none
HOT LEG TEMPERATURE A-LOOP, TE-HL-A Uncertainty estimates: Low:	7.88E+02 none	F 33 50 High: none
HOT LEG TEMPERATURE B-LOOP, TE-HL-B Uncertainty estimates: Low:	7.66E+02 none	F 33 50 High: none
HPI/MakeUp Based on expected results Uncertainty estimates: Low:	8.79E+00 none	lbm/s 33 High: none
LETDOWN FLOW Uncertainty estimates: Low:	2.30E+01 4.60E+00	lbm/s 32 High: 4.60E+00
PRESSURE-PRIMARY, PRESS.-PRIMARY Uncertainty estimates: Low:	1.98E+03 3.97E+01	psia 32 34 38 High: 3.97E+01
PRESSURIZER BLOCK VALVE POSITION Uncertainty estimates: Low:	CLOSED none	30 High: none
PRESSURIZER LEVEL, RC-1-LT1-L-R Uncertainty estimates: Low:	3.57E+02 2.40E+01	in 32 34 High: 2.40E+01
SPRAY VALVE POSITION Uncertainty estimates: Low:	CLOSED none	29 High: none

TABLE A-3

TMI-2 PLANT CONDITIONS: 174 MIN

CONDITION	VALUE	NOTES
STEAM GENERATOR A PRESSURE, SP-6A-PT1-R	3.70E+02 psia	32 50 49
Uncertainty estimates:	Low: 1.62E+01 High: 1.62E+01	
STEAM GENERATOR 8 PRESSURE, SP-68-PT-ABS	6.23E+02 psia	32 50 49
Uncertainty estimates:	Low: 1.62E+01 High: 1.62E+01	

TABLE A-3

TMI-2 PLANT CONDITIONS: 174 MIN NOTES

NOTE NUMBER	TEXT
29	Operation time uncertainty is plus or minus 0.05 min. (3 sec.).
30	Operation time uncertainty is plus or minus 0.5 min (30 sec).
32	QUALIFIED DATA: These data (a) have had all calibration corrections applied; (b) agree with independent redundant data to within specified uncertainty limits; (c) have been verified to represent the physical parameter being measured; (d) have engineering unit conversions applied; and (e) have uncertainties established for the 95% confidence level.
33	TREND DATA: These data (a) have been verified to represent the relative changes in the physical phenomenon they represent but not the absolute level because of one or more of the following: (a) calibrations do not adequately represent the environment; (b) uncertainty limits cannot be adequately quantified; (c) there are some anomalies in the data; or (d) environmental effects cannot be adequately compensated. TREND data are considered to contain some useful information.
34	Measurement recorded on plant reactimeter - The TMI-2 plant reactimeter contained 24 channels of digital measurement information recorded at one sample/three seconds.
35	Measurement recorded on strip chart recorder - Data were recorded as an analog signal in one of two forms: (a) continuous trace or (b) pen points at specified intervals. Digitized data from the strip charts were converted to engineering units based on recorded measurement ranges. Time base for strip chart measurements were checked against known digital events and adjusted as necessary to preserve time redundancy.
38	PRESSURE-PRIMARY is a composite of measurements (a) RC-3B-PT1-R (reactimeter) -10 - 2.15, 174.35 - 203.6,

TABLE A-3

TMI-2 PLANT CONDITIONS: 174 MIN NOTES

NOTE
NUMBER

TEXT

225.35 - 233.3, 336 - 463.55, 870.85 - 932.75, 934.75 - 950.2 min; (b) RC-3A-PT3-P (utility printer) 2.4 - 5.65, 570.3 - 869.6, 933.55, 950.75 - 1000 min; (c) RC-4A-TE1-R (reactimeter sat press) 6.0 - 100 min.; and (d) RC-3A-PT3-S (strip chart) 100.6 - 172.5, 207 - 223.5, 240 - 326.6, 464 - 568 min.

- 49 Qualification Statement for SP-6A-PT-ABS, SP-6B-PT-ABS - These functions composited from secondary pressures SP-6A-PT1-R, SP-6B-PT1-R, reactor building pressure BS-PR-4388-S and atmospheric pressure (14.7 psia assumed). Times between the secondary gage pressures (reactimeter) and the R.B. pressure (strip chart) were normalized at H2 burn time (589.9 min); an artificial spike remains. Elsewhere, timing of small pressure changes (<5 psia) may be affected by large strip chart uncertainty (1.2 min.).
- 50 Data in this time series function has been composited from multiple TMI-2 measurements after DIRC review to provide a best representation.

TABLE A-4
PRESSURIZER BLOCK VALVE OPERATION

TIME (rel. to turbine trip) HH:MM:SS	MINUTES	VALVE OPERATION	NOTES
04:00:40	0.0	OPEN	1 2 29 31
06:19:37	139.0	CLOSED	30
07:12:13	191.6	OPEN	29
07:15:25	194.8	CLOSED	29
07:18:31	197.9	OPEN	29
07:19:01	198.4	CLOSED	29
07:40:37	220.0	OPEN	30
08:20:37	260.0	CLOSED	30
08:36:37	276.0	OPEN	30
09:18:37	318.0	CLOSED	30
09:43:37	343.0	OPEN	18 30
11:38:37	458.0	OPEN	30
13:14:37	554.0	CLOSED	30
13:20:37	560.0	OPEN	30
13:30:37	570.0	CLOSED	30
14:01:37	601.0	OPEN	30
15:12:37	672.0	CLOSED	30
16:34:37	754.0	OPEN	30
16:43:37	763.0	CLOSED	30
16:52:37	772.0	OPEN	30
17:15:37	795.0	CLOSED	30




TABLE A-4

PRESSURIZER BLOCK VALVE OPERATION NOTES

NOTE NUMBER	TEXT
1	At the time of the turbine trip, the pressurizer was being operated in manual mode; all other major systems were in automatic mode.
2	It should be assumed that the PORV failed open on its first challenge when the pressure exceeded 2270 psia (16.65 MPa) and remained open throughout the accident.
18	Cycled open and closed to maintain pressure between 1915 and 2165 psia (13.2 and 14.9 MPa) from 05:40 and 07:38.
29	Operation time uncertainty is plus or minus 0.05 min. (3 sec.).
30	Operation time uncertainty is plus or minus 0.5 min (30 sec).
31	Reference: Anderson, J. L., Informal Report EGG-TMI-7100, "Analysis of TMI-2 Pressurizer Level Indications", EG&G Idaho, Inc., Jan 1986.

TABLE A-5
SPRAY VALVE POSITION

TIME (rel. to turbine trip) HH:MM:SS	MINUTES	VALVE OPERATION	NOTES
04:00:38	0.0	OPEN	1 12 13 28
04:00:49	0.2	CLOSED	29
06:55:37	175.0	OPEN	39 43
07:14:01	193.4	CLOSED	39 43
07:45:49	225.2	OPEN	39 43
08:22:01	261.4	CLOSED	39 43
11:58:49	478.2	OPEN	39 43
13:07:37	547.0	CLOSED	39 43
14:05:13	604.6	OPEN	39 43
16:06:01	725.4	CLOSED	39 43
22:30:49	1110.2	OPEN	39 43
22:31:37	1111.0	CLOSED	39 43
22:51:37	1131.0	OPEN	39 43
22:53:13	1132.6	CLOSED	39 43
23:13:13	1152.6	OPEN	39 43
23:14:01	1153.4	CLOSED	39 43
23:56:25	1195.8	OPEN	39 43
23:57:13	1196.6	CLOSED	39 43





TABLE A-5


SPRAY VALVE POSITION NOTES


NOTE NUMBER	TEXT
1	At the time of the turbine trip, the pressurizer was being operated in manual mode; all other major systems were in automatic mode.
12	Pressurizer spray is effective only when the 2A pump is running.
13	Pressurizer spray valve setpoints - Opens when hot leg pressure greater than 2205 psig (2220 psia or 15.31 MPa); closes whenever pressure decreases below 2155 psig (2170 psia or 14.96 MPa).
28	From 8 s to 11 min, reactimeter data indicates that the spray valve is opening and closing. These indications are felt to be false and are attributed to spurious noise somewhere in the measurement systems.
29	Operation time uncertainty is plus or minus 0.05 min. (3 sec.).
39	Operation time uncertainty is plus or minus 0.4 min. (24 seconds).
43	Manual mode.

TABLE A-6
PRIMARY COOLANT PUMP OPERATION

TIME		PUMP DESIGNATION				NOTES
HH:MM:SS	MIN	PCP1A	PCP1B	PCP2A	PCP2B	
04:00:37	0.0	ON	ON	ON	ON	14
05:14:07	73.5	ON	ON	ON	OFF	40 14
05:14:19	73.7	ON	OFF	ON	OFF	40
05:41:13	100.6	ON	OFF	OFF	OFF	
05:41:25	100.8	OFF	OFF	OFF	OFF	
06:54:43	174.1	OFF	OFF	OFF	ON	
07:13:31	192.9	OFF	OFF	OFF	OFF	14
08:09:14	248.6	ON	OFF	OFF	OFF	41
08:09:49	249.2	OFF	OFF	OFF	OFF	41
19:33:13	932.6	ON	OFF	OFF	OFF	
19:33:23	932.7	OFF	OFF	OFF	OFF	
20:00:37	960.0	ON	OFF	OFF	OFF	
20:40:37	1000.0	ON	OFF	OFF	OFF	










TABLE A-6

PRIMARY COOLANT PUMP OPERATION NOTES

NOTE NUMBER	TEXT
14	Only events which resulted in fluid being pumped are included in pump operation table. Operators started pumps at other times, but because they were steam filled, they developed no head, used very little current, and were quickly turned off.
40	Surmised from hot leg mass flow.
41	The only significant result of this pump restart was an approximate 25 deg F increase in the 1A cold leg pump suction temperature. From alarm printer.

TABLE A-7
HEATER OPERATION

TIME HH:MM:SS	MIN	OPERATION OF HEATER GROUP														
		1	8	2	9	3	10	4	11	5	12	6	13	7		
04:00:38	0.0	ON		ON		ON		ON		ON		ON		OFF		OFF
Notes:	21 42		ON		ON		ON		ON		ON		ON		ON	
04:00:45	0.1	OFF		OFF		OFF		OFF		OFF		OFF		OFF		OFF
Notes:			OFF		OFF		OFF		OFF		OFF		OFF		OFF	
04:00:51	0.2	ON		ON		ON		ON		ON		ON		OFF		OFF
Notes:			ON		ON		ON		ON		ON		ON		ON	
06:54:56	174.3	OFF		OFF		OFF		OFF		OFF		OFF		OFF		OFF
Notes:	23		OFF		OFF		OFF		OFF		OFF		OFF		OFF	
08:24:31	263.9	ON		ON		ON		ON		ON		ON		OFF		OFF
Notes:	26 27		ON		ON		ON		ON		ON		ON		ON	
08:31:07	270.5	ON		ON		ON		ON		ON		ON		OFF		OFF
Notes:	24		ON		ON		OFF		ON		ON		ON		ON	
08:46:55	286.3	ON		ON		ON		OFF		ON		OFF		OFF		OFF
Notes:	25		ON		ON		OFF		ON		ON		ON		ON	
09:31:13	330.6	ON		ON		OFF		OFF		ON		OFF		OFF		OFF
Notes:	26		ON		ON		OFF		ON		ON		ON		ON	
10:14:19	373.7	OFF		OFF		OFF		OFF		ON		OFF		OFF		OFF
Notes:			ON		ON		OFF		ON		ON		ON		ON	
10:14:43	374.1	ON		ON		OFF		OFF		ON		OFF		OFF		OFF
Notes:			ON		ON		OFF		ON		ON		ON		ON	

HEATER OPERATION

TIME		OPERATION OF HEATER GROUP												
HH:MM:SS	MIN	1	2	3	4	5	6	7	8	9	10	11	12	13
17:26:49	806.2	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	ON	OFF	ON	ON	ON
Notes:			OFF	ON		OFF		ON		ON		ON		ON
18:26:05	865.4	ON	ON	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF
Notes:			OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF	OFF

TABLE A-7
HEATER OPERATION NOTES

NOTE NUMBER	TEXT
21	All heaters (groups 1 - 13) operated in automatic; groups 6 and 7 were inoperational throughout the accident.
23	Groups 1 - 7 (heater banks 4 and 5) are in the upper elevation heater bundles.
24	Group 10 off; remains off hereafter, assumed to be failed.
25	Groups 4 and 5 off; remain off hereafter, assumed to be failed.
26	Group 3 off; remains off hereafter, assumed to be failed.
27	Group 8 off; remains off hereafter, assumed to be failed.
42	Timing uncertainty is -1. second to +0. seconds.

TABLE A-8
TMI-2 FUEL GROUP SUMMARY

Fuel Group	Number of Fuel Nodes	Initial Enrichment (wt %)	Initial Uranium (tonnes)	Average Burnup (MWd/MTU)	Minimum Burnup (MWd/MTU)	Maximum Burnup (MWd/MTU)
1	72	1.9	4.768	1863	1436	2240
2	68	1.9	4.503	2746	2488	3158
3	152	1.9	10.067	3637	3190	4021
4	100	1.9	6.622	4391	4087	4905
5	105	2.6	6.954	2239	1647	2741
6	76	2.6	5.033	3552	2810	3890
7	230	2.6	15.233	4315	3907	4952
8	16	2.6	1.057	5465	5227	6213
9	136	2.9	9.007	1548	910	2020
10	164	2.9	10.861	2644	2100	3143
11	76	2.9	5.033	3554	3261	4192
12	44	2.9	2.914	4878	4453	5572

TABLE A-9

CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Level	Fuel Burnup Data (MWd/M.TU)						
			1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
1	A-06	2.9%	966 9	2186 10	2632 10	2617 10	2522 10	2290 10	1416 9
2	A-07	2.9%	1031 9	2260 10	3053 10	3380 11	3321 11	2970 10	1984 9
3	A-08	2.9%	1334 9	3050 10	3738 11	3794 11	3717 11	3410 11	2134 10
4	A-09	2.9%	1032 9	2260 10	3054 10	3381 11	3321 11	2971 10	1984 9
5	A-10	2.9%	967 9	2186 10	2632 10	2618 10	2523 10	2290 10	1416 9
6	B-04	2.9%	912 9	1807 9	2107 10	2101 10	2020 9	1845 9	1205 9
7	B-05	2.9%	1456 9	2975 10	3401 11	3347 11	3295 11	3075 10	1936 9
8	B-06	2.9%	1724 9	3854 11	4603 12	4567 12	4455 12	4163 11	2681 10
9	B-07	2.6%	1650 5	3649 6	4387 7	4384 7	4264 7	3966 7	2582 5
10	B-08	2.9%	1832 9	4507 10	5551 12	5572 12	5500 12	5163 12	3263 11
11	B-09	2.6%	1650 5	3649 6	4387 7	4385 7	4264 7	3966 7	2582 5
12	B-10	2.9%	1724 9	3854 11	4603 12	4568 12	4456 12	4163 11	2682 10
13	B-11	2.9%	1457 9	2975 10	3402 11	3348 11	3296 11	3075 10	1936 9
14	B-12	2.9%	912 9	1807 9	2108 10	2102 10	2021 9	1845 9	1205 9

Note - 2nd line of element entry is nodal fuel group assignment

TABLE A-9
CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWD/MTU)							
		Fuel	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
15	C-03	2.9%	1003 9	1973 9	2220 10	2170 10	2131 10	1996 9	1279 9
16	C-04	2.9%	1416 9	2741 10	3142 10	3122 10	3040 10	2837 10	1895 9
17	C-05	1.9%	1589 1	3219 3	3630 3	3478 3	3361 3	3194 3	2125 1
18	C-06	2.6%	1848 5	3928 7	4342 7	4016 7	3906 7	3856 6	2591 5
19	C-07	1.9%	1872 1	3801 3	4370 4	4264 4	4106 4	3840 3	2548 2
20	C-08	2.6%	1974 5	4101 7	4832 7	4794 7	4811 7	4261 7	2811 6
21	C-09	1.9%	1872 1	3601 3	4371 4	4264 4	4106 4	3840 3	2548 2
22	C-10	2.6%	1914 5	3864 6	4303 7	4063 7	3926 7	3811 6	2612 5
23	C-11	1.9%	1590 1	3220 3	3630 3	3479 3	3362 3	3194 3	2125 1
24	C-12	2.9%	1417 9	2742 10	3143 10	3124 10	3041 10	2838 10	1895 9
25	C-13	2.9%	1003 9	1973 9	2220 10	2171 10	2131 10	1997 9	1279 9
26	D-02	2.9%	912 9	1807 9	2108 10	2102 10	2020 9	1845 9	1205 9
27	D-03	2.9%	1417 9	2741 10	3142 10	3123 10	3040 10	2837 10	1895 9
28	D-04	1.9%	1580 1	3158 2	3560 3	3413 3	3265 3	3064 2	2039 1

Note - 2nd line of element entry is nodal fuel group assignment

TABLE A-9
CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
29	D-05	2.6%	1804 5	3806 6	4188 7	3818 6	3645 6	3615 5	2514 5
30	D-06	1.9%	1781 1	3964 3	3862 3	2925 2	2855 2	3419 3	2582 2
31	D-07	2.6%	2072 5	4060 7	4480 7	4224 7	4067 7	3939 7	2726 5
32	D-08	1.9%	1708 1	3347 3	3920 3	3790 3	3401 3	3061 2	2240 1
33	D-09	2.6%	2072 5	4060 7	4480 7	4225 7	4067 7	3940 7	2726 5
34	D-10	1.9%	1781 1	3964 3	3862 3	2925 2	2855 2	3419 3	2582 2
35	D-11	2.6%	1804 5	3807 6	4189 7	3819 6	3646 6	3615 6	2515 5
36	D-12	1.9%	1581 1	3158 2	3560 3	3413 3	3266 3	3065 2	2039 1
37	D-13	2.9%	1417 9	2742 10	3143 10	3124 10	3041 10	2838 10	1895 9
38	D-14	2.9%	912 9	1807 9	2108 10	2102 10	2021 9	1845 9	1205 9
39	E-02	2.9%	1457 9	2975 10	3402 11	3347 11	3295 11	3075 10	1936 9
40	E-03	1.9%	1597 1	3251 3	3604 3	3401 3	3310 3	3192 3	2107 1
41	E-04	2.6%	1908 5	3879 6	4127 7	3712 6	3612 6	3625 6	2454 5
42	E-05	1.9%	1438 1	3644 3	4197 4	3805 3	3635 3	3646 3	2489 2

Note - 2nd line of element entry is nodal fuel group assignment

TABLE A-9
CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (Mwd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
43	E-06	2.6%	1885 5	4121 7	4589 7	4207 7	4049 7	4014 7	2741 5
44	E-07	1.9%	2020 1	3929 3	4421 4	4301 4	4167 4	3891 3	2547 2
45	E-08	2.6%	2153 5	4161 7	4774 7	4723 7	4529 7	4147 7	2735 5
46	E-09	1.9%	1931 1	3925 3	4485 4	4350 4	4186 4	3909 3	2569 2
47	E-10	2.6%	1885 5	4121 7	4589 7	4208 7	4050 7	4014 7	2741 5
48	E-11	1.9%	1439 1	3644 3	4198 4	3806 3	3636 3	3646 3	2489 2
49	E-12	2.6%	1909 5	3880 6	4128 7	3713 6	3612 6	3625 6	2454 5
50	E-13	1.9%	1597 1	3251 3	3604 3	3401 3	3311 3	3192 3	2108 1
51	E-14	2.9%	1457 9	2975 10	3402 11	3348 11	3295 11	3075 10	1936 9
52	F-01	2.9%	967 9	2186 10	2632 10	2618 10	2523 10	2290 10	1416 9
53	F-02	2.9%	1727 9	3917 11	4666 12	4598 12	4479 12	4192 11	2633 10
54	F-03	2.6%	1850 5	3845 6	4301 7	4035 7	3890 6	3790 6	2593 5
55	F-04	1.9%	1736 1	3902 3	3794 3	2867 2	2829 2	3416 3	2569 2
56	F-05	2.6%	2025 5	4036 7	4470 7	4195 7	4024 7	3921 7	2740 5

Note - 2nd line of element entry is nodal fuel group assignment

TABLE A-9
CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
57	F-06	1.9%	2042 1	4021 3	4559 4	4435 4	4263 4	3950 3	2586 2
58	F-07	2.6%	2141 5	4212 7	4933 7	4936 7	4714 7	4274 7	2819 6
59	F-08	1.9%	1802 1	3845 3	4675 4	4748 4	4572 4	4148 4	2689 2
60	F-09	2.6%	2141 5	4212 7	4933 7	4936 7	4714 7	4274 7	2819 6
61	F-10	1.9%	2042 1	4021 3	4559 4	4436 4	4263 4	3950 3	2586 2
62	F-11	2.6%	2026 5	4036 7	4470 7	4195 7	4025 7	3921 7	2740 5
63	F-12	1.9%	1737 1	3902 3	3794 3	2867 2	2830 2	3416 3	2569 2
64	F-13	2.6%	1872 5	3883 6	4267 7	3984 7	3920 7	3854 6	2548 5
65	F-14	2.9%	1727 9	3917 11	4667 12	4598 12	4479 12	4192 11	2683 10
66	F-15	2.9%	967 9	2186 10	2633 10	2618 10	2523 10	2290 10	1416 9
67	G-01	2.9%	1032 9	2260 10	3053 10	3380 11	3321 11	2970 10	1984 9
68	G-02	2.6%	1699 5	3587 6	4276 7	4324 7	4252 7	3949 7	2552 5
69	G-03	1.9%	1868 1	3838 3	4395 4	4265 4	4133 4	3907 3	2594 2
70	G-04	2.6%	2060 5	4078 7	4494 7	4208 7	4036 7	3925 7	2728 5

Note - 2nd line of element entry is nodal fuel group assignment

TABLE A-9

CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
71	G-05	1.9%	2076 1	3915 3	4393 4	4294 4	4147 4	3878 3	2606 2
72	G-06	2.6%	2184 5	4237 7	4921 7	4952 7	4804 7	4384 7	2847 6
73	G-07	1.9%	2053 1	4089 4	4836 4	4904 4	4739 4	4270 4	2735 2
74	G-08	2.6%	2105 5	4284 7	5236 8	5421 8	5228 8	4678 7	3042 6
75	G-09	1.9%	2053 1	4089 4	4836 4	4904 4	4739 4	4270 4	2734 2
76	G-10	2.6%	2184 5	4237 7	4921 7	4952 7	4805 7	4385 7	2847 6
77	G-11	1.9%	1939 1	3888 3	4439 4	4314 4	4145 4	3875 3	2578 2
78	G-12	2.6%	2060 5	4077 7	4494 7	4208 7	4036 7	3925 7	2728 5
79	G-13	1.9%	1868 1	3838 3	4395 4	4265 4	4133 4	3907 3	2593 2
80	G-14	2.6%	1699 5	3587 6	4276 7	4324 7	4252 7	3949 7	2552 5
81	G-15	2.9%	1032 9	2260 10	3053 10	3381 11	3321 11	2970 10	1984 9
82	H-01	2.9%	1334 9	3050 10	3738 11	3794 11	3717 11	3409 11	2134 10
83	H-02	2.9%	1832 9	4507 12	5550 12	5572 12	5500 12	5163 12	3262 11
84	H-03	2.6%	1974 5	4100 7	4831 7	4793 7	4611 7	4260 7	2811 6

Note - 2nd line of element entry is nodal fuel group assignment

TABLE A-9

CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
85	H-04	1.9%	1708 1	3346 3	3919 3	3789 3	3400 3	3060 2	2240 1
86	H-05	2.6%	2152 5	4160 7	4773 7	4722 7	4528 7	4146 7	2735 5
87	H-06	1.9%	1801 1	3844 3	4674 4	4747 4	4572 4	4147 4	2688 2
88	H-07	2.6%	2104 5	4283 7	5235 8	5421 8	5228 8	4678 7	3042 6
89	H-08	2.6%	2057 5	4799 7	6009 8	6213 8	6117 8	5571 8	3464 6
90	H-09	2.6%	2104 5	4283 7	5235 8	5421 8	5228 8	4678 7	3042 6
91	H-10	1.9%	1801 1	3844 3	4674 4	4747 4	4572 4	4147 4	2688 2
92	H-11	2.6%	2152 5	4160 7	4773 7	4722 7	4528 7	4146 7	2735 5
93	H-12	1.9%	1707 1	3346 3	3919 3	3789 3	3400 3	3060 2	2240 1
94	H-13	2.6%	1973 5	4100 7	4831 7	4793 7	4611 7	4260 7	2811 6
95	H-14	2.9%	1832 9	4507 12	5550 12	5572 12	5500 12	5163 12	3262 11
96	H-15	2.9%	1334 9	3050 10	3737 11	3794 11	3717 11	3409 11	2134 10
97	K-01	2.9%	1032 9	2260 10	3053 10	3380 11	3321 11	2970 10	1984 9
98	K-02	2.6%	1699 5	3587 6	4276 7	4324 7	4252 7	3949 7	2552 5

Note - 2nd line of element entry is nodal fuel group assignment

CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
99	K-03	1.9%	1868 1	3838 3	4394 4	4265 4	4132 4	3907 3	2593 2
100	K-04	2.6%	2059 5	4077 7	4494 7	4208 7	4036 7	3925 7	2728 5
101	K-05	1.9%	2002 1	3911 3	4418 4	4315 4	4185 4	3904 3	2553 2
102	K-06	2.6%	2183 5	4236 7	4920 7	4951 7	4804 7	4384 7	2847 6
103	K-07	1.9%	2053 1	4088 4	4835 4	4904 4	4738 4	4270 4	2734 2
104	K-08	2.6%	2104 5	4283 7	5234 8	5421 8	5227 8	4677 7	3041 6
105	K-09	1.9%	2052 1	4088 4	4834 4	4904 4	4738 4	4270 4	2734 2
106	K-10	2.6%	2183 5	4236 7	4920 7	4951 7	4804 7	4384 7	2846 6
107	K-11	1.9%	1977 1	3952 3	4487 4	4320 4	4121 4	3865 3	2603 2
108	K-12	2.6%	2059 5	4076 7	4493 7	4207 7	4035 7	3924 7	2728 5
109	K-13	1.9%	1867 1	3837 3	4394 4	4265 4	4132 4	3907 3	2593 2
110	K-14	2.6%	1698 5	3586 6	4275 7	4324 7	4252 7	3949 7	2552 5
111	K-15	2.9%	1031 9	2259 10	3053 10	3380 11	3321 11	2970 10	1984 9
112	L-01	2.9%	987 9	2186 10	2632 10	2618 10	2523 10	2290 10	1416 9

Note - 2nd line of element entry is nodal fuel group assignment

CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
113	L-02	2.9%	1726 9	3916 11	4666 12	4597 12	4478 12	4191 11	2683 10
114	L-03	2.6%	1789 5	3792 6	4212 7	3927 7	3839 6	3796 6	2565 5
115	L-04	1.9%	1735 1	3901 3	3792 3	2866 2	2828 2	3416 3	2568 2
116	L-05	2.6%	2025 5	4034 7	4468 7	4193 7	4023 7	3920 7	2739 5
117	L-06	1.9%	2040 1	4019 3	4557 4	4434 4	4261 4	3949 3	2585 2
118	L-07	2.6%	2139 5	4210 7	4931 7	4934 7	4713 7	4273 7	2819 6
119	L-08	1.9%	1800 1	3843 3	4673 4	4746 4	4571 4	4147 4	2688 2
120	L-09	2.6%	2139 5	4209 7	4931 7	4934 7	4713 7	4273 7	2819 6
121	L-10	1.9%	2040 1	4019 3	4557 4	4433 4	4261 4	3949 3	2585 2
122	L-11	2.6%	2024 5	4033 7	4468 7	4193 7	4023 7	3919 7	2739 5
123	L-12	1.9%	1734 1	3899 3	3792 3	2865 2	2828 2	3415 3	2568 2
124	L-13	2.6%	1862 5	3775 6	4245 7	4046 7	3917 7	3784 6	2583 5
125	L-14	2.9%	1725 9	3915 11	4665 12	4597 12	4478 12	4191 11	2683 10
126	L-15	2.9%	966 9	2186 10	2632 10	2618 10	2523 10	2290 10	1416 9

Note - 2nd line of element entry is nodal fuel group assignment

CORE BURNUP DATA AT START OF ACCIDENT

		Fuel Burnup Data (Mwd/MTU)							
Element Number	Grid Loc.	1 Fuel Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level	
127	M-02	2.9% 9	1456 10	2974 11	3401 11	3347 11	3295 11	3075 10	1936 9
128	M-03	1.9% 1	1596 3	3249 3	3602 3	3400 3	3309 3	3191 3	2107 1
129	M-04	2.6% 5	1907 6	3878 7	4126 7	3711 6	3611 6	3624 6	2453 5
130	M-05	1.9% 1	1437 3	3642 4	4195 3	3804 3	3634 3	3645 3	2488 2
131	M-06	2.6% 5	1883 7	4118 7	4586 7	4205 7	4047 7	4012 7	2740 5
132	M-07	1.9% 1	1992 3	3943 4	4452 4	4295 4	4124 4	3870 3	2580 2
133	M-08	2.6% 5	2151 7	4157 7	4771 7	4720 7	4527 7	4145 7	2734 5
134	M-09	1.9% 1	1970 3	3986 4	4473 4	4286 4	4157 4	3932 3	2567 2
135	M-10	2.6% 5	1882 7	4117 7	4585 7	4205 7	4047 7	4012 7	2740 5
136	M-11	1.9% 1	1436 3	3641 4	4195 3	3804 3	3634 3	3645 3	2488 2
137	M-12	2.6% 5	1906 6	3877 7	4125 7	3710 6	3610 6	3623 6	2453 5
138	M-13	1.9% 1	1595 3	3249 3	3602 3	3400 3	3309 3	3191 3	2107 1
139	M-14	2.9% 9	1455 10	2973 11	3400 11	3346 11	3294 11	3074 10	1936 9
140	N-02	2.9% 9	911 9	1806 10	2107 10	2101 10	2020 9	1844 9	1204 9

Note - 2nd line of element entry is nodal fuel group assignment

CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
141	N-03	2.9%	1416 9	2740 10	3141 10	3122 10	3039 10	2837 10	1894 9
142	N-04	1.9%	1579 1	3155 2	3558 3	3411 3	3264 3	3064 2	2038 1
143	N-05	2.6%	1802 5	3803 6	4186 7	3816 6	3644 6	3613 6	2514 5
144	N-06	1.9%	1779 1	3960 3	3859 3	2922 2	2853 2	3417 3	2581 2
145	N-07	2.6%	2069 5	4056 7	4476 7	4222 7	4064 7	3937 7	2725 5
146	N-08	1.9%	1705 1	3342 3	3916 3	3787 3	3398 3	3058 2	2240 1
147	N-09	2.6%	2069 5	4055 7	4476 7	4221 7	4064 7	3937 7	2725 5
148	N-10	1.9%	1779 1	3960 3	3858 3	2922 2	2852 2	3417 3	2581 2
149	N-11	2.6%	1801 5	3802 6	4185 7	3815 6	3643 6	3612 6	2513 5
150	N-12	1.9%	1578 1	3154 2	3557 3	3411 3	3264 3	3063 2	2039 1
151	N-13	2.9%	1415 9	2738 10	3140 10	3121 10	3038 10	2836 10	1895 9
152	N-14	2.9%	911 9	1805 9	2106 10	2101 10	2020 9	1844 9	1204 9
153	O-03	2.9%	1002 9	1971 9	2218 10	2170 10	2130 10	1996 9	1278 9
154	O-04	2.9%	1415 9	2739 10	3141 10	3121 10	3039 10	2836 10	1894 9

Note - 2nd line of element entry is nodal fuel group assignment

TABLE A-9

CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWD/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
155	O-05	1.9%	1587 1	3216 3	3627 3	3476 3	3359 3	3192 3	2124 1
156	O-06	2.6%	1787 5	3805 6	4279 7	4010 7	3872 6	3788 6	2589 5
157	O-07	1.9%	1869 1	3797 3	4367 4	4261 4	4103 4	3838 3	2547 2
158	O-08	2.6%	1971 5	4096 7	4828 7	4790 7	4609 7	4258 7	2810 6
159	O-09	1.9%	1869 1	3796 3	4367 4	4261 4	4103 4	3838 3	2547 2
160	O-10	2.6%	1752 5	3756 6	4237 7	3982 7	3864 6	3796 6	2593 5
161	O-11	1.9%	1587 1	3216 3	3626 3	3476 3	3359 3	3192 3	2124 1
162	O-12	2.9%	1414 9	2738 10	3139 10	3120 10	3038 10	2836 10	1894 9
163	O-13	2.9%	1002 9	1971 9	2218 10	2169 10	2130 10	1995 9	1278 9
164	P-04	2.9%	911 9	1805 9	2106 10	2100 10	2109 9	1844 9	1204 9
165	P-05	2.9%	1455 9	2972 10	3399 11	3545 11	3293 11	3074 10	1935 9
166	P-06	2.9%	1722 9	3850 11	4599 12	4565 12	4453 12	4161 11	2680 10
167	P-07	2.6%	1648 5	3645 6	4383 7	4382 7	4262 7	3964 7	2581 5
168	P-08	2.9%	1829 9	4503 12	5547 12	5569 12	5498 12	5161 12	3261 11

Note - 2nd line of element entry is nodal fuel group assignment

TABLE A-9
CORE BURNUP DATA AT START OF ACCIDENT

Element Number	Grid Loc.	Fuel Burnup Data (MWd/MTU)							
		Fuel Level	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
169	P-09	2.6%	1647 5	3645 6	4383 7	4381 7	4261 7	3964 7	2581 5
170	P-10	2.9%	1721 9	3850 11	4599 12	4565 12	4453 12	4161 11	2680 10
171	P-11	2.9%	1454 9	2971 10	3398 11	3344 11	3293 11	3073 10	1935 9
172	P-12	2.9%	910 9	1804 9	2105 10	2100 10	2019 9	1843 9	1204 9
173	R-06	2.9%	965 9	2183 10	2630 10	2616 10	2521 10	2288 10	1416 9
174	R-07	2.9%	1029 9	2256 10	3050 10	3379 11	3319 11	2969 10	1983 9
175	R-08	2.9%	1332 9	3046 10	3734 11	3791 11	3715 11	3408 11	2133 10
176	R-09	2.9%	1029 9	2256 10	3050 10	3379 11	3319 11	2969 10	1983 9
177	R-10	2.9%	964 9	2183 10	2629 10	2615 10	2521 10	2288 10	1415 9

Note - 2nd line of element entry is nodal fuel group assignment

				1	2	3	4	5						
				9	9	9	9	9						
				966	1031	1334	1032	967						
		6	7	8	9	10	11	12	13	14				
		9	9	9	5	9	5	9	9	9				
		912	1456	1724	1650	1832	1650	1724	1457	912				
	15	16	17	18	19	20	21	22	23	24	25			
	9	9	1	5	1	5	1	5	1	9	9			
	1003	1416	1589	1848	1872	1974	1872	1914	1590	1417	1003			
26	27	28	29	30	31	32	33	34	35	36	37	38		
9	9	1	5	1	5	1	5	1	5	1	9	9		
912	1417	1580	1804	1781	2072	1708	2072	1781	1804	1581	1417	912		
39	40	41	42	43	44	45	46	47	48	49	50	51		
9	1	5	1	5	1	5	1	5	1	5	1	9		
1457	1597	1908	1438	1885	2020	2153	1931	1885	1439	1909	1597	1457		
52	53	54	55	56	57	58	59	60	61	62	63	64	65	66
9	9	5	1	5	1	5	1	5	1	5	1	5	9	9
967	1727	1850	1736	2025	2042	2141	1802	2141	2042	2026	1737	1872	1727	967
67	68	69	70	71	72	73	74	75	76	77	78	79	80	81
9	5	1	5	1	5	1	5	1	5	1	5	1	5	9
1032	1699	1868	2060	2076	2184	2053	2105	2053	2184	1939	2060	1868	1699	1032
82	83	84	85	86	87	88	89	90	91	92	93	94	95	96
9	9	5	1	5	1	5	5	5	1	5	1	5	9	9
1334	1832	1974	1708	2152	1801	2104	2057	2104	1801	2152	1707	1973	1832	1334
97	98	99	100	101	102	103	104	105	106	107	108	109	110	111
9	5	1	5	1	5	1	5	1	5	1	5	1	5	9
1032	1699	1868	2060	2002	2183	2053	2104	2052	2183	1977	2059	1867	1698	1031
112	113	114	115	116	117	118	119	120	121	122	123	124	125	126
9	9	5	1	5	1	5	1	5	1	5	1	5	9	9
987	1726	1789	1735	2025	2040	2139	1800	2139	2040	2024	1734	1862	1725	966
127	128	129	130	131	132	133	134	135	136	137	138	139		
9	1	5	1	5	1	5	1	5	1	5	1	9		
1456	1596	1907	1437	1883	1992	2151	1970	1882	1436	1906	1595	1455		
140	141	142	143	144	145	146	147	148	149	150	151	152		
9	9	1	5	1	5	1	5	1	5	1	9	9		
911	1416	1579	1802	1779	2069	1705	2069	1779	1801	1578	1415	911		
153	154	155	156	157	158	159	160	161	162	163				
9	9	1	5	1	5	1	5	1	9	9				
1002	1415	1587	1787	1869	1971	1869	1752	1587	1414	1002				
164	165	166	167	168	169	170	171	172						
9	9	9	5	9	5	9	9	9						
911	1455	1722	1648	1829	1647	1721	1454	910						
173	174	175	176	177										
9	9	9	9	9										
965	1029	1332	1029	964										

Element No
Fuel Group
MWd/MTU

				1	2	3	4	5								
				10	10	10	10	10								
				2186	2260	3050	2260	2186								
		6	7	8	9	10	11	12	13	14						
		9	10	11	6	10	6	11	10	9						
		1807	2975	3854	3649	4507	3649	3854	2975	1807						
	15	16	17	18	19	20	21	22	23	24	25					
	9	10	3	7	3	7	3	6	3	10	9					
	1973	2741	3219	3928	3801	4101	3601	3864	3220	2742	1973					
26	27	28	29	30	31	32	33	34	35	36	37	38				
9	10	2	6	3	7	3	7	3	6	2	10	9				
1807	2741	3158	3806	3964	4060	3347	4060	3964	3807	3158	2742	1807				
39	40	41	42	43	44	45	46	47	48	49	50	51				
10	3	6	3	7	3	7	3	7	3	6	3	10				
2975	3251	3879	3644	4121	3929	4161	3925	4121	3644	3880	3251	2975				
52	53	54	55	56	57	58	59	60	61	62	63	64	65	66		
10	11	6	3	7	3	7	3	7	3	7	3	6	11	10		
2186	3917	3845	3902	4036	4021	4212	3845	4212	4021	4036	3902	3883	3917	2186		
67	68	69	70	71	72	73	74	75	76	77	78	79	80	81		
10	6	3	7	3	7	4	7	4	7	3	7	3	6	10		
2260	3587	3838	4078	3915	4237	4089	4284	4089	4237	3888	4077	3838	3587	2260		
82	83	84	85	86	87	88	89	90	91	92	93	94	95	96		
10	12	7	3	7	3	7	7	7	3	7	3	7	12	10		
3050	4507	4100	3346	4160	3844	4283	4799	4283	3844	4160	3346	4100	4507	3050		
97	98	99	100	101	102	103	104	105	106	107	108	109	110	111		
10	6	3	7	3	7	4	7	4	7	3	7	3	6	10		
2260	3587	3838	4077	3911	4236	4088	4283	4088	4236	3952	4076	3837	3586	2259		
112	113	114	115	116	117	118	119	120	121	122	123	124	125	126		
10	11	6	3	7	3	7	3	7	3	7	3	6	11	10		
2186	3916	3792	3901	4034	4019	4210	3843	4209	4019	4033	3899	3775	3915	2186		
127	128	129	130	131	132	133	134	135	136	137	138	139				
10	3	6	3	7	3	7	3	7	3	6	3	10				
2974	3249	3878	3642	4118	3943	4157	3986	4117	3641	3877	3249	2973				
140	141	142	143	144	145	146	147	148	149	150	151	152				
9	10	2	6	3	7	3	7	3	6	2	10	9				
1806	2740	3155	3803	3960	4056	3342	4055	3960	3802	3154	2738	1805				
153	154	155	156	157	158	159	160	161	162	163						
9	10	3	6	3	7	3	6	3	10	9						
1971	2739	3216	3805	3797	4096	3796	3736	3216	2738	1971						
	164	165	166	167	168	169	170	171	172							
	9	10	11	6	12	6	11	10	9							
	1805	2972	3850	3645	4503	3645	3850	2971	1804							
			173	174	175	176	177									
			10	10	10	10	10									
			2183	2256	3046	2256	2183									

Element No
Fuel Group
MWD/MTU

					1 10 2632	2 10 3053	3 11 3738	4 10 3054	5 10 2632					
		6 10 2107	7 11 3401	8 12 4603	9 7 4387	10 12 5551	11 7 4387	12 12 4603	13 11 3402	14 10 2108				
	15 10 2220	16 10 3142	17 3 3630	18 7 4342	19 4 4370	20 7 4832	21 4 4371	22 7 4303	23 3 3630	24 10 3143	25 10 2220			
26 10 2108	27 10 3142	28 3 3560	29 7 4188	30 3 3862	31 7 4480	32 3 3920	33 7 4480	34 3 3862	35 7 4189	36 3 3560	37 10 3143	38 10 2108		
39 11 3402	40 3 3604	41 7 4127	42 4 4197	43 7 4589	44 4 4421	45 7 4774	46 4 4485	47 7 4589	48 4 4198	49 7 4128	50 3 3604	51 11 3402		
52 10 2632	53 12 4666	54 7 4301	55 3 3794	56 7 4470	57 4 4559	58 7 4933	59 4 4675	60 7 4933	61 4 4559	62 7 4470	63 3 3794	64 7 4267	65 12 4667	66 10 2633
67 10 3053	68 7 4276	69 4 4395	70 7 4494	71 4 4393	72 7 4921	73 4 4836	74 8 5236	75 4 4836	76 7 4921	77 4 4439	78 7 4494	79 4 4395	80 7 4276	81 10 3053
82 11 3738	83 12 5550	84 7 4831	85 3 3919	86 7 4773	87 4 4674	88 8 5235	89 8 6009	90 8 5235	91 4 4674	92 7 4773	93 3 3919	94 7 4831	95 12 5550	96 11 3738
97 10 3053	98 7 4276	99 4 4394	100 7 4494	101 4 4418	102 7 4920	103 4 4835	104 8 5234	105 4 4834	106 7 4920	107 4 4487	108 7 4493	109 4 4394	110 7 4275	111 10 3053
112 10 2632	113 12 4666	114 7 4212	115 3 3792	116 7 4468	117 4 4557	118 7 4931	119 4 4673	120 7 4931	121 4 4557	122 7 4468	123 3 3792	124 7 4245	125 12 4665	126 10 2632
	127 11 3401	128 3 3602	129 7 4126	130 4 4195	131 7 4586	132 4 4452	133 7 4771	134 4 4473	135 7 4585	136 4 4195	137 7 4125	138 3 3602	139 11 3400	
	140 10 2107	141 10 3141	142 3 3558	143 7 4186	144 3 3859	145 7 4476	146 3 3916	147 7 4476	148 3 3858	149 7 4185	150 3 3557	151 10 3140	152 10 2106	
	153 10 2218	154 10 3141	155 3 3627	156 7 4279	157 4 4367	158 7 4828	159 4 4367	160 7 4237	161 3 3626	162 10 3139	163 10 2218			
	164 10 2106	165 11 3399	166 12 4599	167 7 4383	168 12 5547	169 7 4383	170 12 4599	171 11 3398	172 10 2105					
				173 10 2630	174 10 3050	175 11 3734	176 10 3050	177 10 2629						

Element No
Fuel Group
MWd/MTU

					1 10 2617	2 11 3380	3 11 3794	4 11 3381	5 10 2618							
			6 10 2101	7 11 3347	8 12 4567	9 7 4384	10 12 5572	11 7 4385	12 12 4568	13 11 3348	14 10 2102					
		15 10 2170	16 10 3122	17 3 3478	18 7 4016	19 4 4264	20 7 4794	21 4 4264	22 7 4063	23 3 3479	24 10 3124	25 10 2171				
	26 10 2102	27 10 3123	28 3 3413	29 6 3818	30 2 2925	31 7 4224	32 3 3790	33 7 4225	34 2 2925	35 6 3819	36 3 3413	37 10 3124	38 10 2102			
		39 11 3347	40 3 3401	41 6 3712	42 3 3805	43 7 4207	44 4 4301	45 7 4723	46 4 4350	47 7 4208	48 3 3806	49 6 3713	50 3 3401	51 11 3348		
52 10 2618	53 12 4598	54 7 4035	55 2 2867	56 7 4195	57 4 4435	58 7 4936	59 4 4748	60 7 4936	61 4 4436	62 7 4195	63 2 2867	64 7 3984	65 12 4598	66 10 2618		
	67 11 3380	68 7 4324	69 4 4265	70 7 4208	71 4 4294	72 7 4952	73 4 4904	74 8 5421	75 4 4904	76 7 4952	77 4 4314	78 7 4208	79 4 4265	80 7 4324	81 11 3381	
		82 11 3794	83 12 5572	84 7 4793	85 3 3789	86 7 4722	87 4 4747	88 8 5421	89 8 6213	90 8 5421	91 4 4747	92 7 4722	93 3 3789	94 7 4793	95 12 5572	96 11 3794
		97 11 3380	98 7 4324	99 4 4265	100 7 4208	101 4 4315	102 7 4951	103 4 4904	104 8 5421	105 4 4904	106 7 4951	107 4 4320	108 7 4207	109 4 4265	110 7 4324	111 11 3380
		112 10 2618	113 12 4597	114 7 3927	115 2 2866	116 7 4193	117 4 4434	118 7 4934	119 4 4746	120 7 4934	121 4 4433	122 7 4193	123 2 2865	124 7 4046	125 12 4597	126 10 2618
			127 11 3347	128 3 3400	129 6 3711	130 3 3804	131 7 4205	132 4 4295	133 7 4720	134 4 4286	135 7 4205	136 3 3804	137 6 3710	138 3 3400	139 11 3346	
			140 10 2101	141 10 3122	142 3 3411	143 6 3816	144 2 2922	145 7 4222	146 3 3787	147 7 4221	148 2 2922	149 6 3815	150 3 3411	151 10 3121	152 10 2101	
				153 10 2170	154 10 3121	155 3 3476	156 7 4010	157 4 4261	158 7 4790	159 4 4261	160 7 3982	161 3 3476	162 10 3120	163 10 2169		
					164 10 2100	165 11 3345	166 12 4565	167 7 4382	168 12 5569	169 7 4381	170 12 4565	171 11 3344	172 10 2100			
							173 10 2616	174 11 3379	175 11 3791	176 11 3379	177 10 2615					

Element No
Fuel Group
MWd/MTU

				1	2	3	4	5						
				10	11	11	11	10						
				2522	3321	3717	3321	2523						
		6	7	8	9	10	11	12	13	14				
		9	11	12	7	12	7	12	11	9				
		2020	3295	4455	4264	5500	4264	4456	3296	2021				
	15	16	17	18	19	20	21	22	23	24	25			
	10	10	3	7	4	7	4	7	3	10	10			
	2131	3040	3361	3906	4106	4811	4106	3926	3362	3041	2131			
26	27	28	29	30	31	32	33	34	35	36	37	38		
9	10	3	6	2	7	3	7	2	6	3	10	9		
2020	3040	3265	3645	2855	4067	3401	4067	2855	3646	3266	3041	2021		
39	40	41	42	43	44	45	46	47	48	49	50	51		
11	3	6	3	7	4	7	4	7	3	6	3	11		
3295	3310	3612	3635	4049	4167	4529	4186	4050	3636	3612	3311	3295		
52	53	54	55	56	57	58	59	60	61	62	63	64	65	66
10	12	6	2	7	4	7	4	7	4	7	2	7	12	10
2523	4479	3890	2829	4024	4263	4714	4572	4714	4263	4025	2830	3920	4479	2523
67	68	69	70	71	72	73	74	75	76	77	78	79	80	81
11	7	4	7	4	7	4	8	4	7	4	7	4	7	11
3321	4252	4133	4036	4147	4804	4739	5228	4739	4805	4145	4036	4133	4252	3321
82	83	84	85	86	87	88	89	90	91	92	93	94	95	96
11	12	7	3	7	4	8	8	8	4	7	3	7	12	11
3717	5500	4611	3400	4528	4572	5228	6117	5228	4572	4528	3400	4611	5500	3717
97	98	99	100	101	102	103	104	105	106	107	108	109	110	111
11	7	4	7	4	7	4	8	4	7	4	7	4	7	11
3321	4252	4132	4036	4185	4804	4738	5227	4738	4804	4121	4035	4132	4252	3321
112	113	114	115	116	117	118	119	120	121	122	123	124	125	126
10	12	6	2	7	4	7	4	7	4	7	2	7	12	10
2523	4478	3839	2828	4023	4261	4713	4571	4713	4261	4023	2828	3917	4478	2523
127	128	129	130	131	132	133	134	135	136	137	138	139		
11	3	6	3	7	4	7	4	7	3	6	3	11		
3295	3309	3611	3634	4047	4124	4527	4157	4047	3634	3610	3309	3294		
140	141	142	143	144	145	146	147	148	149	150	151	152		
9	10	3	6	2	7	3	7	2	6	3	10	9		
2020	3039	3264	3644	2853	4064	3398	4064	2852	3643	3264	3038	2020		
153	154	155	156	157	158	159	160	161	162	163				
10	10	3	6	4	7	4	6	3	10	10				
2130	3039	3359	3872	4103	4609	4103	3864	3359	3038	2130				
164	165	166	167	168	169	170	171	172						
9	11	12	7	12	7	12	11	9						
2109	3293	4453	4262	5498	4261	4453	3293	2019						
173	174	175	176	177										
10	11	11	11	10										
2521	3319	3715	3319	2521										

Element No
Fuel Group
Mwd/MTU

	1	2	3	4	5
	9	9	10	9	9
	1416	1984	2134	1984	1416

	6	7	8	9	10	11	12	13	14
	9	9	10	5	11	5	10	9	9
	1205	1936	2681	2582	3263	2582	2682	1936	1205

	15	16	17	18	19	20	21	22	23	24	25
	9	9	1	5	2	6	2	5	1	9	9
	1279	1895	2125	2591	2548	2811	2548	2612	2125	1895	1279

	26	27	28	29	30	31	32	33	34	35	36	37	38
	9	9	1	5	2	5	1	5	2	5	1	9	9
	1205	1895	2039	2514	2582	2726	2240	2726	2582	2515	2039	1895	1205

	39	40	41	42	43	44	45	46	47	48	49	50	51
	9	1	5	2	5	2	5	2	5	2	5	1	9
	1936	2107	2454	2489	2741	2547	2735	2569	2741	2489	2454	2108	1936

	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66
	9	10	5	2	5	2	6	2	6	2	5	2	5	10	9
	1416	2683	2593	2569	2740	2586	2819	2689	2819	2586	2740	2569	2548	2683	1416

	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81
	9	5	2	5	2	6	2	6	2	6	2	5	2	5	9
	1984	2552	2594	2728	2636	2847	2735	3042	2734	2847	2578	2728	2593	2552	1984

	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96
	10	11	6	1	5	2	6	6	6	2	5	1	6	11	10
	2134	3262	2811	2240	2735	2688	3042	3464	3042	2688	2735	2240	2811	3262	2134

	97	98	99	100	101	102	103	104	105	106	107	108	109	110	111
	9	5	2	5	2	6	2	6	2	6	2	5	2	5	9
	1984	2552	2593	2728	2553	2847	2734	3041	2734	2846	2603	2728	2593	2552	1984

	112	113	114	115	116	117	118	119	120	121	122	123	124	125	126
	9	10	5	2	5	2	6	2	6	2	5	2	5	10	9
	1416	2683	2565	2568	2739	2585	2819	2688	2819	2585	2739	2568	2583	2683	1416

	127	128	129	130	131	132	133	134	135	136	137	138	139
	9	1	5	2	5	2	5	2	5	2	5	1	9
	1936	2107	2453	2488	2740	2580	2734	2567	2740	2488	2453	2107	1936

	140	141	142	143	144	145	146	147	148	149	150	151	152
	9	9	1	5	2	5	1	5	2	5	1	9	9
	1204	1894	2038	2514	2581	2725	2240	2725	2581	2513	2039	1895	1204

	153	154	155	156	157	158	159	160	161	162	163
	9	9	1	5	2	6	2	5	1	9	9
	1279	1894	2124	2589	2547	2810	2547	2593	2124	1894	1278

	164	165	166	167	168	169	170	171	172
	9	9	10	5	11	5	10	9	9
	1204	1935	2680	2581	3261	2581	2680	1935	1204

	173	174	175	176	177
	9	9	10	9	9
	1416	1983	2133	1983	1415

Element No
Fuel Group
MWd/MTU

TABLE A-12

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
1	A-06	2.96%	.303	.679	.815	.811	.782	.711	.442
2	A-07	2.96%	.323	.701	.944	1.041	1.024	.918	.619
3	A-08	2.96%	.419	.942	1.149	1.166	1.142	1.050	.665
4	A-09	2.96%	.323	.703	.944	1.041	1.024	.918	.619
5	A-10	2.96%	.303	.679	.815	.811	.782	.712	.442
6	B-04	2.96%	.286	.564	.655	.654	.630	.575	.378
7	B-05	2.96%	.455	.920	1.048	1.032	1.015	.949	.604
8	B-06	2.96%	.538	1.184	1.408	1.397	1.364	1.276	.830
9	B-07	2.64%	.516	1.122	1.342	1.342	1.305	1.217	.800
10	B-08	2.96%	.571	1.379	1.689	1.695	1.674	1.573	1.006
11	B-09	2.64%	.518	1.122	1.342	1.342	1.305	1.217	.800
12	B-10	2.96%	.538	1.184	1.408	1.397	1.364	1.276	.830
13	B-11	2.96%	.455	.920	1.048	1.032	1.017	.949	.604
14	B-12	2.96%	.286	.564	.655	.654	.630	.575	.378
15	C-03	2.96%	.316	.615	.690	.676	.663	.622	.400
16	C-04	2.96%	.442	.848	.969	.964	.938	.878	.591
17	C-05	1.98%	.501	.993	1.114	1.070	1.035	.986	.665
18	C-06	2.64%	.578	1.206	1.329	1.232	1.199	1.184	.804
19	C-07	1.98%	.588	1.166	1.333	1.302	1.256	1.177	.793
20	C-08	2.64%	.617	1.258	1.474	1.463	1.408	1.305	.870
21	C-09	1.98%	.588	1.166	1.333	1.302	1.256	1.177	.793

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
22	C-10	2.64%	.599	1.186	1.316	1.247	1.204	1.171	.810
23	C-11	1.98%	.501	.993	1.114	1.070	1.035	.986	.665
24	C-12	2.96%	.444	.848	.971	.964	.940	.878	.591
25	C-13	2.96%	.316	.615	.690	.676	.663	.622	.400
26	D-02	2.96%	.286	.564	.655	.654	.630	.575	.378
27	D-03	2.96%	.442	.848	.969	.964	.940	.878	.591
28	D-04	1.98%	.498	.975	1.094	1.050	1.006	.947	.639
29	D-05	2.64%	.564	1.170	1.283	1.173	1.122	1.113	.780
30	D-06	1.98%	.560	1.214	1.184	.905	.885	1.052	.802
31	D-07	2.64%	.646	1.245	1.370	1.294	1.247	1.210	.845
32	D-08	1.98%	.538	1.032	1.201	1.162	1.046	.946	.699
33	D-09	2.64%	.646	1.245	1.370	1.294	1.247	1.210	.845
34	D-10	1.98%	.560	1.214	1.184	.905	.885	1.052	.802
35	D-11	2.64%	.564	1.170	1.283	1.173	1.122	1.113	.780
36	D-12	1.98%	.498	.975	1.094	1.050	1.006	.947	.639
37	D-13	2.96%	.444	.848	.971	.964	.940	.878	.591
38	D-14	2.96%	.286	.564	.655	.654	.630	.575	.378
39	E-02	2.96%	.455	.920	1.048	1.032	1.015	.949	.604
40	E-03	1.98%	.503	1.002	1.107	1.046	1.021	.986	.659
41	E-04	2.64%	.597	1.192	1.265	1.142	1.111	1.114	.762
42	E-05	1.98%	.453	1.120	1.281	1.166	1.116	1.120	.775

TABLE A-12

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
43	E-06	2.64%	.589	1.263	1.403	1.289	1.241	1.232	.850
44	E-07	1.98%	.632	1.203	1.348	1.313	1.272	1.192	.791
45	E-08	2.64%	.670	1.276	1.458	1.441	1.384	1.270	.848
46	E-09	1.98%	.606	1.203	1.366	1.327	1.278	1.197	.799
47	E-10	2.64%	.589	1.263	1.403	1.289	1.241	1.228	.850
48	E-11	1.98%	.453	1.120	1.281	1.168	1.116	1.120	.775
49	E-12	2.64%	.597	1.192	1.265	1.142	1.111	1.114	.762
50	E-13	1.98%	.503	1.002	1.107	1.046	1.021	.986	.659
51	E-14	2.96%	.455	.920	1.048	1.032	1.017	.949	.604
52	F-01	2.96%	.303	.675	.815	.811	.782	.712	.442
53	F-02	2.96%	.540	1.203	1.427	1.406	1.370	1.285	.832
54	F-03	2.64%	.578	1.181	1.316	1.237	1.193	1.164	.804
55	F-04	1.98%	.545	1.195	1.164	.889	.876	1.052	.799
56	F-05	2.64%	.632	1.237	1.368	1.285	1.234	1.204	.848
57	F-06	1.98%	.639	1.230	1.388	1.351	1.302	1.210	.804
58	F-07	2.64%	.666	1.291	1.504	1.505	1.439	1.309	.874
59	F-08	1.98%	.565	1.179	1.423	1.443	1.392	1.267	.835
60	F-09	2.64%	.666	1.291	1.504	1.505	1.439	1.309	.874
61	F-10	1.98%	.639	1.230	1.388	1.351	1.302	1.210	.804
62	F-11	2.64%	.632	1.237	1.368	1.285	1.234	1.204	.848
63	F-12	1.98%	.545	1.195	1.164	.889	.878	1.052	.799

TABLE A-12

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
64	F-13	2.64%	.586	1.192	1.307	1.223	1.203	1.184	.791
65	F-14	2.96%	.540	1.203	1.427	1.406	1.371	1.285	.832
66	F-15	2.96%	.303	.679	.815	.811	.782	.712	.442
67	G-01	2.96%	.323	.703	.944	1.041	1.024	.918	.619
68	G-02	2.64%	.532	1.103	1.309	1.324	1.302	1.212	.793
69	G-03	1.98%	.586	1.177	1.340	1.302	1.263	1.197	.806
70	G-04	2.64%	.643	1.250	1.373	1.289	1.237	1.204	.846
71	G-05	1.98%	.650	1.199	1.340	1.311	1.267	1.188	.810
72	G-06	2.64%	.679	1.298	1.500	1.509	1.467	1.342	.881
73	G-07	1.98%	.643	1.250	1.469	1.489	1.441	1.304	.848
74	G-08	2.64%	.655	1.311	1.594	1.649	1.592	1.428	.940
75	G-09	1.98%	.643	1.250	1.469	1.489	1.441	1.304	.848
76	G-10	2.64%	.679	1.298	1.500	1.509	1.467	1.342	.881
77	G-11	1.98%	.608	1.192	1.353	1.316	1.267	1.188	.800
78	G-12	2.64%	.643	1.250	1.375	1.289	1.237	1.204	.846
79	G-13	1.98%	.586	1.177	1.340	1.302	1.263	1.197	.806
80	G-14	2.64%	.532	1.103	1.309	1.324	1.302	1.212	.793
81	G-15	2.96%	.323	.701	.944	1.041	1.024	.918	.619
82	H-01	2.96%	.419	.942	1.149	1.166	1.142	1.050	.665
83	H-02	2.96%	.571	1.379	1.689	1.695	1.674	1.573	1.006
84	H-03	2.64%	.617	1.258	1.474	1.463	1.408	1.305	.870

TABLE A-12

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
85	H-04	1.98%	.538	1.030	1.201	1.162	1.046	.946	.699
86	H-05	2.64%	.670	1.274	1.456	1.441	1.384	1.270	.848
87	H-06	1.98%	.565	1.179	1.423	1.443	1.392	1.267	.835
88	H-07	2.64%	.655	1.311	1.594	1.649	1.592	1.428	.940
89	H-08	2.64%	.641	1.465	1.821	1.873	1.854	1.693	1.067
90	H-09	2.64%	.655	1.311	1.594	1.649	1.592	1.428	.940
91	H-10	1.98%	.565	1.179	1.423	1.443	1.392	1.267	.835
92	H-11	2.64%	.670	1.274	1.456	1.441	1.384	1.270	.848
93	H-12	1.98%	.536	1.030	1.201	1.162	1.046	.946	.699
94	H-13	2.64%	.615	1.258	1.474	1.463	1.408	1.305	.870
95	H-14	2.96%	.571	1.379	1.689	1.695	1.674	1.573	1.006
96	H-15	2.96%	.419	.942	1.149	1.166	1.142	1.050	.665
97	K-01	2.96%	.323	.701	.944	1.041	1.024	.918	.619
98	K-02	2.64%	.532	1.103	1.309	1.324	1.302	1.212	.793
99	K-03	1.98%	.586	1.177	1.340	1.302	1.263	1.197	.806
100	K-04	2.64%	.643	1.250	1.373	1.289	1.237	1.204	.845
101	K-05	1.98%	.628	1.197	1.348	1.316	1.278	1.195	.793
102	K-06	2.64%	.679	1.298	1.500	1.509	1.465	1.342	.881
103	K-07	1.98%	.643	1.250	1.469	1.489	1.441	1.304	.848
104	K-08	2.64%	.655	1.311	1.594	1.649	1.592	1.428	.940
105	K-09	1.98%	.643	1.250	1.469	1.489	1.441	1.304	.848

TABLE A-12

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
106	K-10	2.64%	.679	1.298	1.500	1.509	1.465	1.342	.881
107	K-11	1.98%	.619	1.210	1.368	1.318	1.259	1.184	.810
108	K-12	2.64%	.643	1.250	1.373	1.289	1.237	1.204	.845
109	K-13	1.98%	.586	1.177	1.340	1.302	1.263	1.197	.806
110	K-14	2.64%	.532	1.103	1.309	1.324	1.302	1.212	.791
111	K-15	2.96%	.323	.701	.944	1.041	1.024	.918	.619
112	L-01	2.96%	.303	.679	.815	.811	.782	.711	.442
113	L-02	2.96%	.538	1.203	1.427	1.406	1.370	1.285	.832
114	L-03	2.64%	.560	1.166	1.291	1.204	1.179	1.166	.797
115	L-04	1.98%	.545	1.195	1.162	.889	.876	1.052	.799
116	L-05	2.64%	.632	1.237	1.366	1.285	1.234	1.203	.848
117	L-06	1.98%	.639	1.230	1.388	1.351	1.302	1.210	.804
118	L-07	2.64%	.666	1.289	1.504	1.504	1.439	1.309	.872
119	L-08	1.98%	.565	1.177	1.421	1.443	1.392	1.267	.834
120	L-09	2.64%	.666	1.289	1.504	1.504	1.439	1.309	.872
121	L-10	1.98%	.639	1.230	1.388	1.351	1.302	1.208	.804
122	L-11	2.64%	.632	1.237	1.366	1.285	1.234	1.203	.848
123	L-12	1.98%	.545	1.195	1.162	.887	.876	1.052	.799
124	L-13	2.64%	.582	1.160	1.300	1.241	1.203	1.162	.802
125	L-14	2.96%	.538	1.203	1.427	1.406	1.370	1.285	.832
126	L-15	2.96%	.303	.679	.815	.811	.782	.711	.442

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
127	M-02	2.96%	.455	.920	1.048	1.032	1.015	.949	.604
128	M-03	1.98%	.503	1.002	1.107	1.046	1.021	.984	.659
129	M-04	2.64%	.597	1.192	1.265	1.140	1.111	1.114	.762
130	M-05	1.98%	.453	1.118	1.281	1.166	1.116	1.120	.775
131	M-06	2.64%	.588	1.263	1.401	1.289	1.241	1.230	.850
132	M-07	1.98%	.624	1.208	1.357	1.311	1.261	1.186	.802
133	M-08	2.64%	.670	1.274	1.456	1.441	1.384	1.270	.848
134	M-09	1.98%	.617	1.221	1.364	1.309	1.270	1.204	.799
135	M-10	2.64%	.588	1.261	1.401	1.289	1.241	1.230	.848
136	M-11	1.98%	.453	1.118	1.281	1.166	1.116	1.120	.775
137	M-12	2.64%	.595	1.190	1.265	1.140	1.111	1.114	.762
138	M-13	1.98%	.503	1.002	1.107	1.046	1.019	.984	.659
139	M-14	2.96%	.455	.920	1.048	1.032	1.015	.949	.604
140	N-02	2.96%	.286	.564	.655	.654	.630	.575	.378
141	N-03	2.96%	.442	.848	.969	.964	.938	.878	.591
142	N-04	1.98%	.498	.975	1.094	1.050	1.006	.947	.639
143	N-05	2.64%	.564	1.168	1.283	1.171	1.120	1.111	.780
144	N-06	1.98%	.558	1.212	1.182	.905	.883	1.052	.802
145	N-07	2.64%	.644	1.243	1.370	1.293	1.247	1.208	.845
146	N-08	1.98%	.536	1.030	1.199	1.160	1.046	.946	.699
147	N-09	2.64%	.644	1.243	1.368	1.293	1.247	1.208	.845

TABLE A-12

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
148	N-10	1.98%	.558	1.212	1.182	.905	.883	1.052	.802
149	N-11	2.64%	.564	1.168	1.281	1.171	1.120	1.111	.780
150	N-12	1.98%	.498	.973	1.094	1.050	1.006	.947	.639
151	N-13	2.96%	.442	.848	.969	.964	.938	.878	.591
152	N-14	2.96%	.286	.564	.655	.654	.630	.575	.378
153	O-03	2.96%	.314	.613	.690	.676	.663	.622	.400
154	O-04	2.96%	.442	.848	.969	.964	.938	.878	.591
155	O-05	1.98%	.499	.991	1.114	1.069	1.035	.986	.665
156	O-06	2.64%	.560	1.170	1.311	1.230	1.190	1.164	.804
157	O-07	1.98%	.586	1.164	1.331	1.302	1.254	1.177	.791
158	O-08	2.64%	.615	1.256	1.472	1.461	1.408	1.304	.870
159	O-09	1.98%	.586	1.164	1.331	1.302	1.254	1.177	.791
160	O-10	2.64%	.549	1.155	1.298	1.221	1.186	1.166	.804
161	O-11	1.98%	.499	.991	1.114	1.069	1.035	.986	.665
162	O-12	2.96%	.442	.848	.969	.964	.938	.878	.591
163	O-13	2.96%	.314	.613	.690	.674	.663	.621	.400
164	P-04	2.96%	.286	.564	.655	.654	.628	.575	.378
165	P-05	2.96%	.455	.918	1.048	1.032	1.015	.949	.602
166	P-06	2.96%	.538	1.182	1.406	1.395	1.362	1.276	.830
167	P-07	2.64%	.516	1.122	1.342	1.340	1.305	1.217	.800
168	P-08	2.96%	.571	1.377	1.687	1.695	1.673	1.573	1.006

TABLE A-12

PEAKING FACTOR DATA FOR TMI-2 CORE

Element Number	Grid Loc.	Enrich wt.	1 Level	2 Level	3 Level	4 Level	5 Level	6 Level	7 Level
169	P-09	2.64%	.516	1.122	1.342	1.340	1.305	1.217	.800
170	P-10	2.96%	.538	1.182	1.406	1.395	1.362	1.276	.830
171	P-11	2.96%	.455	.918	1.046	1.032	1.015	.949	.602
172	P-12	2.96%	.286	.564	.655	.654	.628	.575	.378
173	R-06	2.96%	.303	.679	.815	.811	.782	.711	.442
174	R-07	2.96%	.323	.701	.942	1.041	1.023	.918	.617
175	R-08	2.96%	.417	.942	1.147	1.166	1.142	1.050	.663
176	R-09	2.96%	.323	.701	.942	1.041	1.023	.918	.617
177	R-10	2.96%	.303	.679	.815	.810	.782	.711	.442

				1	2	3	4	5							
				.303	.323	.419	.323	.303							
		6	7	8	9	10	11	12	13	14					
		.286	.455	.538	.516	.571	.518	.538	.455	.286					
	15	16	17	18	19	20	21	22	23	24	25				
	.316	.442	.501	.578	.588	.617	.588	.599	.581	.444	.316				
26	27	28	29	30	31	32	33	34	35	36	37	38			
.286	.442	.498	.564	.568	.646	.538	.646	.568	.564	.498	.444	.286			
39	40	41	42	43	44	45	46	47	48	49	50	51			
.455	.503	.597	.453	.589	.632	.678	.686	.589	.453	.597	.583	.455			
52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	
.303	.548	.578	.545	.632	.639	.666	.565	.666	.639	.632	.545	.586	.548	.303	
67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	
.323	.532	.586	.643	.658	.679	.643	.655	.643	.679	.688	.643	.586	.532	.323	
82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	
.419	.571	.617	.538	.678	.565	.655	.641	.655	.565	.678	.536	.615	.571	.419	
97	98	99	100	101	102	103	104	105	106	107	108	109	110	111	
.323	.532	.586	.643	.628	.679	.643	.655	.643	.679	.619	.643	.586	.532	.323	
112	113	114	115	116	117	118	119	120	121	122	123	124	125	126	
.303	.538	.568	.545	.632	.639	.666	.565	.666	.639	.632	.545	.582	.538	.303	
127	128	129	130	131	132	133	134	135	136	137	138	139			
.455	.583	.597	.453	.588	.624	.678	.617	.588	.453	.595	.583	.455			
140	141	142	143	144	145	146	147	148	149	150	151	152			
.286	.442	.498	.564	.558	.644	.536	.644	.558	.564	.498	.442	.286			
153	154	155	156	157	158	159	160	161	162	163					
.314	.442	.499	.568	.586	.615	.586	.549	.499	.442	.314					
164	165	166	167	168	169	170	171	172							
.286	.455	.538	.516	.571	.516	.538	.455	.286							
173	174	175	176	177											
.303	.323	.417	.323	.303											

Element No
Peaking
Factor

PEAKING FACTORS FOR AXIAL LEVEL 2 OF 7

				1	2	3	4	5						
				.679	.701	.942	.703	.679						
		6	7	8	9	10	11	12	13	14				
		.564	.920	1.18	1.12	1.37	1.12	1.18	.920	.564				
	15	16	17	18	19	20	21	22	23	24	25			
	.615	.848	.993	1.20	1.16	1.25	1.16	1.18	.993	.848	.615			
26	27	28	29	30	31	32	33	34	35	36	37	38		
.564	.848	.975	1.17	1.21	1.24	1.03	1.24	1.21	1.17	.975	.848	.564		
39	40	41	42	43	44	45	46	47	48	49	50	51		
.920	1.00	1.19	1.12	1.26	1.20	1.27	1.20	1.26	1.12	1.19	1.00	.920		
52	53	54	55	56	57	58	59	60	61	62	63	64	65	66
.679	1.20	1.18	1.19	1.23	1.23	1.29	1.17	1.29	1.23	1.23	1.19	1.19	1.20	.679
67	68	69	70	71	72	73	74	75	76	77	78	79	80	81
.703	1.10	1.17	1.25	1.19	1.29	1.25	1.31	1.25	1.29	1.19	1.25	1.17	1.10	.701
82	83	84	85	86	87	88	89	90	91	92	93	94	95	96
.942	1.37	1.25	1.03	1.27	1.17	1.31	1.46	1.31	1.17	1.27	1.03	1.25	1.37	.942
97	98	99	100	101	102	103	104	105	106	107	108	109	110	111
.701	1.10	1.17	1.25	1.19	1.29	1.25	1.31	1.25	1.29	1.21	1.25	1.17	1.10	.701
112	113	114	115	116	117	118	119	120	121	122	123	124	125	126
.679	1.20	1.16	1.19	1.23	1.23	1.20	1.17	1.20	1.23	1.23	1.19	1.16	1.20	.679
127	128	129	130	131	132	133	134	135	136	137	138	139		
.920	1.00	1.19	1.11	1.26	1.20	1.27	1.22	1.26	1.11	1.19	1.00	.920		
140	141	142	143	144	145	146	147	148	149	150	151	152		
.564	.848	.975	1.16	1.21	1.24	1.03	1.24	1.21	1.16	.975	.848	.564		
153	154	155	156	157	158	159	160	161	162	163				
.613	.848	.991	1.17	1.16	1.25	1.16	1.15	.991	.848	.613				
164	165	166	167	168	169	170	171	172						
.564	.918	1.18	1.12	1.37	1.12	1.18	.918	.564						
173	174	175	176	177										
.679	.701	.942	.701	.679										

Element No
Peaking
Factor

TABLE A-15
PEAKING FACTORS FOR AXIAL LEVEL 3 OF 7

					1	2	3	4	5										
					.815	.944	1.14	.944	.815										
					6	7	8	9	10	11	12	13	14						
					.655	1.04	1.40	1.34	1.68	1.34	1.40	1.04	.655						
					15	16	17	18	19	20	21	22	23	24	25				
					.698	.969	1.11	1.32	1.33	1.47	1.33	1.31	1.11	.971	.698				
					26	27	28	29	30	31	32	33	34	35	36	37	38		
					.655	.969	1.09	1.28	1.18	1.37	1.28	1.37	1.18	1.28	1.09	.971	.655		
					39	40	41	42	43	44	45	46	47	48	49	50	51		
					1.04	1.18	1.26	1.28	1.40	1.34	1.45	1.36	1.40	1.28	1.26	1.18	1.04		
					52	53	54	55	56	57	58	59	60	61	62	63	64	65	66
					.815	1.42	1.31	1.16	1.36	1.38	1.58	1.42	1.58	1.38	1.36	1.16	1.38	1.42	.815
					67	68	69	70	71	72	73	74	75	76	77	78	79	80	81
					.944	1.38	1.34	1.37	1.34	1.58	1.46	1.59	1.46	1.58	1.35	1.37	1.34	1.38	.944
					82	83	84	85	86	87	88	89	90	91	92	93	94	95	96
					1.14	1.68	1.47	1.28	1.45	1.42	1.59	1.82	1.59	1.42	1.45	1.28	1.47	1.68	1.14
					97	98	99	100	101	102	103	104	105	106	107	108	109	110	111
					.944	1.38	1.34	1.37	1.34	1.58	1.46	1.59	1.46	1.58	1.36	1.37	1.34	1.38	.944
					112	113	114	115	116	117	118	119	120	121	122	123	124	125	126
					.815	1.42	1.29	1.16	1.36	1.38	1.58	1.42	1.58	1.38	1.36	1.16	1.38	1.42	.815
					127	128	129	130	131	132	133	134	135	136	137	138	139		
					1.04	1.18	1.26	1.28	1.40	1.35	1.45	1.36	1.40	1.28	1.26	1.18	1.04		
					140	141	142	143	144	145	146	147	148	149	150	151	152		
					.655	.969	1.09	1.28	1.18	1.37	1.19	1.36	1.18	1.28	1.09	.969	.655		
					153	154	155	156	157	158	159	160	161	162	163				
					.698	.969	1.11	1.31	1.33	1.47	1.33	1.29	1.11	.969	.698				
					164	165	166	167	168	169	170	171	172						
					.655	1.04	1.40	1.34	1.68	1.34	1.40	1.04	.655						
					173	174	175	176	177										
					.815	.942	1.14	.942	.815										

Element No
Peaking
Factor

PEAKING FACTORS FOR AXIAL LEVEL 4 OF 7

					1	2	3	4	5																					
					.811	1.04	1.16	1.04	.811																					
						6	7	8	9	10	11	12	13	14																
						.654	1.03	1.39	1.34	1.69	1.34	1.39	1.03	.654																
							15	16	17	18	19	20	21	22	23	24	25													
							.676	.964	1.07	1.23	1.38	1.46	1.38	1.24	1.07	.964	.676													
								26	27	28	29	30	31	32	33	34	35	36	37	38										
								.654	.964	1.05	1.17	.985	1.29	1.16	1.29	.985	1.17	1.05	.964	.654										
									39	40	41	42	43	44	45	46	47	48	49	50	51									
									1.03	1.04	1.14	1.16	1.28	1.31	1.44	1.32	1.28	1.16	1.14	1.04	1.03									
										52	53	54	55	56	57	58	59	60	61	62	63	64	65	66						
										.811	1.48	1.23	.889	1.28	1.35	1.58	1.44	1.58	1.35	1.28	.889	1.22	1.48	.811						
											67	68	69	70	71	72	73	74	75	76	77	78	79	80	81					
											1.04	1.32	1.38	1.28	1.31	1.58	1.48	1.64	1.48	1.58	1.31	1.28	1.38	1.32	1.04					
												82	83	84	85	86	87	88	89	90	91	92	93	94	95	96				
												1.16	1.69	1.46	1.16	1.44	1.44	1.64	1.87	1.64	1.44	1.44	1.16	1.46	1.69	1.16				
													97	98	99	100	101	102	103	104	105	106	107	108	109	110	111			
													1.04	1.32	1.38	1.28	1.31	1.58	1.48	1.64	1.48	1.58	1.31	1.28	1.38	1.32	1.04			
														112	113	114	115	116	117	118	119	120	121	122	123	124	125	126		
														.811	1.48	1.28	.889	1.28	1.35	1.58	1.44	1.58	1.35	1.28	.887	1.24	1.48	.811		
															127	128	129	130	131	132	133	134	135	136	137	138	139			
															1.03	1.04	1.14	1.16	1.28	1.31	1.44	1.38	1.28	1.16	1.14	1.04	1.03			
																140	141	142	143	144	145	146	147	148	149	150	151	152		
																.654	.964	1.05	1.17	.985	1.29	1.16	1.29	.985	1.17	1.05	.964	.654		
																	153	154	155	156	157	158	159	160	161	162	163			
																	.676	.964	1.06	1.23	1.38	1.46	1.38	1.22	1.06	.964	.674			
																		164	165	166	167	168	169	170	171	172				
																		.654	1.03	1.39	1.34	1.69	1.34	1.39	1.03	.654				
																			173	174	175	176	177							
																			.811	1.04	1.16	1.04	.810							

Element No
Peaking
Factor

LOADING FACTORS FOR AXIAL LEVEL 3 OF 7

				1	2	3	4	5										
				.782	1.02	1.14	1.02	.782										
				6	7	8	9	10	11	12	13	14						
				.630	1.01	1.36	1.30	1.67	1.30	1.36	1.01	.630						
				15	16	17	18	19	20	21	22	23	24	25				
				.663	.938	1.03	1.19	1.25	1.40	1.25	1.20	1.03	.940	.663				
				26	27	28	29	30	31	32	33	34	35	36	37	38		
				.630	.940	1.00	1.12	.885	1.24	1.04	1.24	.885	1.12	1.00	.940	.630		
				39	40	41	42	43	44	45	46	47	48	49	50	51		
				1.01	1.02	1.11	1.11	1.24	1.27	1.38	1.27	1.24	1.11	1.11	1.02	1.01		
				52	53	54	55	56	57	58	59	60	61	62	63	64	65	66
				.782	1.37	1.19	.876	1.23	1.38	1.43	1.39	1.43	1.38	1.23	.876	1.20	1.37	.782
				67	68	69	70	71	72	73	74	75	76	77	78	79	80	81
				1.02	1.30	1.26	1.23	1.26	1.46	1.44	1.59	1.44	1.46	1.26	1.23	1.26	1.30	1.02
				82	83	84	85	86	87	88	89	90	91	92	93	94	95	96
				1.14	1.67	1.40	1.04	1.38	1.39	1.59	1.85	1.59	1.39	1.38	1.04	1.40	1.67	1.14
				97	98	99	100	101	102	103	104	105	106	107	108	109	110	111
				1.02	1.30	1.26	1.23	1.27	1.46	1.44	1.59	1.44	1.46	1.25	1.23	1.26	1.30	1.02
				112	113	114	115	116	117	118	119	120	121	122	123	124	125	126
				.782	1.37	1.17	.876	1.23	1.38	1.43	1.39	1.43	1.38	1.23	.876	1.20	1.37	.782
				127	128	129	130	131	132	133	134	135	136	137	138	139		
				1.01	1.02	1.11	1.11	1.24	1.26	1.38	1.27	1.24	1.11	1.11	1.01	1.01		
				140	141	142	143	144	145	146	147	148	149	150	151	152		
				.630	.938	1.00	1.12	.883	1.24	1.04	1.24	.883	1.12	1.00	.938	.630		
				153	154	155	156	157	158	159	160	161	162	163				
				.663	.938	1.03	1.19	1.25	1.40	1.25	1.18	1.03	.938	.663				
				164	165	166	167	168	169	170	171	172						
				.628	1.01	1.36	1.30	1.67	1.30	1.36	1.01	.628						
				173	174	175	176	177										
				.782	1.02	1.14	1.02	.782										

Element No
Peaking
Factor

1	2	3	4	5
.711	.918	1.05	.918	.712

6	7	8	9	10	11	12	13	14
.575	.949	1.27	1.21	1.57	1.21	1.27	.949	.575

15	16	17	18	19	20	21	22	23	24	25
.622	.878	.986	1.18	1.17	1.38	1.17	1.17	.986	.878	.622

26	27	28	29	30	31	32	33	34	35	36	37	38
.575	.878	.947	1.11	1.05	1.21	.946	1.21	1.05	1.11	.947	.878	.575

39	40	41	42	43	44	45	46	47	48	49	50	51
.949	.986	1.11	1.12	1.23	1.19	1.27	1.19	1.22	1.12	1.11	.986	.949

52	53	54	55	56	57	58	59	60	61	62	63	64	65	66
.712	1.28	1.16	1.05	1.28	1.21	1.38	1.26	1.38	1.21	1.28	1.05	1.18	1.28	.712

67	68	69	70	71	72	73	74	75	76	77	78	79	80	81
.918	1.21	1.19	1.28	1.18	1.34	1.38	1.42	1.38	1.34	1.18	1.28	1.19	1.21	.918

82	83	84	85	86	87	88	89	90	91	92	93	94	95	96
1.05	1.57	1.38	.946	1.27	1.26	1.42	1.69	1.42	1.26	1.27	.946	1.38	1.57	1.05

97	98	99	100	101	102	103	104	105	106	107	108	109	110	111
.918	1.21	1.19	1.28	1.19	1.34	1.38	1.42	1.38	1.34	1.18	1.28	1.19	1.21	.918

112	113	114	115	116	117	118	119	120	121	122	123	124	125	126
.711	1.28	1.16	1.05	1.28	1.21	1.38	1.26	1.38	1.28	1.28	1.05	1.16	1.28	.711

127	128	129	130	131	132	133	134	135	136	137	138	139
.949	.986	1.11	1.12	1.23	1.19	1.27	1.28	1.23	1.12	1.11	.986	.949

140	141	142	143	144	145	146	147	148	149	150	151	152
.575	.878	.947	1.11	1.05	1.28	.946	1.28	1.05	1.11	.947	.878	.575

153	154	155	156	157	158	159	160	161	162	163
.622	.878	.986	1.16	1.17	1.38	1.17	1.16	.986	.878	.621

164	165	166	167	168	169	170	171	172
.575	.949	1.27	1.21	1.57	1.21	1.27	.949	.575

173	174	175	176	177
.711	.918	1.05	.918	.711

Element No
Peaking
Factor

TABLE A-13
PEAKING FACTORS FOR AXIAL LEVEL 7 OF 7

				1	2	3	4	5						
				.442	.619	.665	.619	.442						
		6	7	8	9	10	11	12	13	14				
		.378	.684	.838	.888	1.00	.888	.838	.684	.378				
	15	16	17	18	19	20	21	22	23	24	25			
	.488	.591	.665	.884	.793	.878	.793	.818	.665	.591	.488			
26	27	28	29	30	31	32	33	34	35	36	37	38		
.378	.591	.639	.788	.882	.845	.699	.845	.882	.788	.639	.591	.378		
39	40	41	42	43	44	45	46	47	48	49	50	51		
.684	.659	.762	.775	.858	.791	.848	.799	.858	.775	.762	.659	.684		
52	53	54	55	56	57	58	59	60	61	62	63	64	65	66
.442	.832	.884	.799	.848	.884	.874	.835	.874	.884	.848	.799	.791	.832	.442
67	68	69	70	71	72	73	74	75	76	77	78	79	80	81
.619	.793	.886	.846	.818	.881	.848	.948	.848	.881	.888	.846	.886	.793	.619
82	83	84	85	86	87	88	89	90	91	92	93	94	95	96
.665	1.00	.878	.699	.848	.835	.948	1.06	.948	.835	.848	.699	.878	1.00	.665
97	98	99	100	101	102	103	104	105	106	107	108	109	110	111
.619	.793	.886	.845	.793	.881	.848	.948	.848	.881	.818	.845	.886	.791	.619
112	113	114	115	116	117	118	119	120	121	122	123	124	125	126
.442	.832	.797	.799	.848	.884	.872	.834	.872	.884	.848	.799	.882	.832	.442
127	128	129	130	131	132	133	134	135	136	137	138	139		
.684	.659	.762	.775	.858	.882	.848	.799	.848	.775	.762	.659	.684		
140	141	142	143	144	145	146	147	148	149	150	151	152		
.378	.591	.639	.788	.882	.845	.699	.845	.882	.788	.639	.591	.378		
153	154	155	156	157	158	159	160	161	162	163				
.488	.591	.665	.884	.791	.878	.791	.884	.665	.591	.488				
164	165	166	167	168	169	170	171	172						
.378	.682	.838	.888	1.00	.888	.838	.682	.378						
		173	174	175	176	177								
		.442	.617	.663	.617	.442								

Element No
Peaking
Factor

APPENDIX B

SUMMARY OF ICBC TIME SERIES FUNCTIONS

APPENDIX 8

CONTENTS

TABLE B-1 Summary of ICBC Time Series Functions 8-1

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
AFW-SG-A	FLOW	STEAM GENERATOR A	TIMSER
Description:	Aux Feedwater Secondary Injection Rate based upon secondary mass inventory - SG-A Timser		
Qualification category:	EST TREND	Uncertainty:	
Comments:			
AFW-SG-B	FLOW	STEAM GENERATOR B	TIMSER
Description:	Aux Feedwater Secondary Injection Rate based upon secondary mass inventory - SG-B Timser		
Qualification category:	EST TREND	Uncertainty:	
Comments:			
AH-TE-5011-M	TEMPERATURE	REACTOR BUILDING	TIMSER
Description:	Ambient Temperature, Letdown Cooler Area Timser2		
Qualification category:	QUAL/TREND	Uncertainty: 2.7 OR 3.3 F	
Comments:	DATA ARE TREND AT TEMP. PEAK 586 MIN.		
AH-TE-5012-M	TEMPERATURE	REACTOR BUILDING	TIMSER
Description:	Ambient Temperature, Drain Tank Area Timser2		
Qualification category:	QUAL/TREND	Uncertainty: 2.7 OR 3.3 F	
Comments:	DATA ARE TREND AT TEMP. PEAK 47-53 & 587-593 MIN.		

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
BS-PR-4388-S	PRESSURE	REACTOR BUILDING	TIMSER
Description:	Reactor Building Pressure - Composite		Timser2
Qualification category:	QUALIFIED	Uncertainty:	.32&2.15PSIA
Comments:	COMPOSITE DATA		
DC-R-3399-M	RADIATION	DECAY HEAT	TIMSER
Description:	Decay Heat Closed A Loop Radiation Monitor		Timser2
Qualification category:	TREND	Uncertainty:	TIME +-5 MIN
Comments:			
DC-R-3400-M	RADIATION	DECAY HEAT	TIMSER
Description:	Decay Heat Closed B Loop Radiation Monitor		Timser2
Qualification category:	TREND	Uncertainty:	TIME +-5 MIN
Comments:			
FW-TE-1131-P	TEMPERATURE	FEEDWATER B	TIMSER
Description:	Feedwater Heater B Outlet Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	2.2 DEG F
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
FW-TE-1134-P	TEMPERATURE	FEEDWATER A	TIMSER
Description:	Feedwater Heater A Outlet Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	2.2 DEG F
Comments:			
HG01	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 1 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			
HG02	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 2 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			
HG03	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 3 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			

TABLE 8-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
-------------------------	---------------	-----------------	-----------

HG04	POWER	PRESSURIZER	COND
------	-------	-------------	------

Description: Pressurizer Heater Group 4 Operation		Cond	
---------------------------------------------------	--	------	--

Qualification category: TREND	Uncertainty:		
-------------------------------	--------------	--	--

Comments:

HG05	POWER	PRESSURIZER	COND
------	-------	-------------	------

Description: Pressurizer Heater Group 5 Operation		Cond	
---------------------------------------------------	--	------	--

Qualification category: TREND	Uncertainty:		
-------------------------------	--------------	--	--

Comments:

HG06	POWER	PRESSURIZER	COND
------	-------	-------------	------

Description: Pressurizer Heater Group 6 Operation		Cond	
---------------------------------------------------	--	------	--

Qualification category: TREND	Uncertainty:		
-------------------------------	--------------	--	--

Comments:

HG07	POWER	PRESSURIZER	COND
------	-------	-------------	------

Description: Pressurizer Heater Group 7 Operation		Cond	
---------------------------------------------------	--	------	--

Qualification category: TREND	Uncertainty:		
-------------------------------	--------------	--	--

Comments:

TABLE 8-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
HG08	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 8 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			
HG09	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 9 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			
HG10	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 10 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			
HG11	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 11 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
HG12	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 12 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			
HG13	POWER	PRESSURIZER	COND
Description:	Pressurizer Heater Group 13 Operation		Cond
Qualification category:	TREND	Uncertainty:	
Comments:			
HP-R-207-M	RADIATION-GM	AUX BUILDING	TIMSER
Description:	Intermediate Cooling Pump Area Radiation Monitor - in the Auxiliary Building		Timser2
Qualification category:	TREND	Uncertainty:	TIME +-10MIN
Comments:			
HP-R-219-G-M	RADIATION - GAS	AUX BUILDING	TIMSER
Description:	Station Vent Radiation Monitor - Gas		Timser2
Qualification category:	TREND	Uncertainty:	TIME +-2 MIN
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
-------------------------	---------------	-----------------	-----------

HP-R-222-G-M	RADIATION - GAS	AUX BUILDING	TIMSER
--------------	-----------------	--------------	--------

Description: Auxiliary Building Purge Air Exhaust Radiation
Monitor, Upstream of Filter - Gas Timser2

Qualification category: TREND Uncertainty: TIME +-2 MIN

Comments:

HP-R-222-I-M	RADIATION - IODINE	AUX BUILDING	TIMSER
--------------	--------------------	--------------	--------

Description: Auxiliary Building Purge Air Exhaust Radiation
Monitor, Upstream of Filter - Iodine Timser2

Qualification category: TREND Uncertainty: TIME +-2 MIN

Comments:

HP-R-222-P-M	RADIATION - PART.	AUX BUILDING	TIMSER
--------------	-------------------	--------------	--------

Description: Auxiliary Building Purge Air Exhaust Radiation
Mon., Upstream of Filter - Particulate Timser2

Qualification category: TREND Uncertainty: TIME +-2 MIN

Comments:

HP-R-225-G-M	RADIATION - GAS	REACTOR BUILDING	TIMSER
--------------	-----------------	------------------	--------

Description: Reactor Building Purge Air Exhaust, Duct A,
Radiation Monitor - Gas Timser2

Qualification category: TREND Uncertainty: TIME +-2 MIN

Comments:

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
HP-R-225-I-M	RADIATION - IODINE	REACTOR BUILDING	TIMSER
Description: Reactor Building Purge Air Exhaust, Duct A, Radiation Monitor - Iodine Timser2			
Qualification category: TREND		Uncertainty: TIME +-2 MIN	
Comments:			
HP-R-225-P-M	RADIATION - PART.	REACTOR BUILDING	TIMSER
Description: Reactor Building Purge Air Exhaust, Duct A, Radiation Monitor - Particulate Timser2			
Qualification category: TREND		Uncertainty: TIME +-2 MIN	
Comments:			
HP-R-226-G-M	RADIATION - GAS	REACTOR BUILDING	TIMSER
Description: Reactor Building Purge Air Exhaust, Duct B, Radiation Monitor - Gas Timser2			
Qualification category: TREND		Uncertainty: TIME +-2 MIN	
Comments:			
HP-R-226-I-M	RADIATION - IODINE	REACTOR BUILDING	TIMSER
Description: Reactor Building Purge Air Exhaust, Duct B, Radiation Monitor - Iodine Timser2			
Qualification category: TREND		Uncertainty: TIME +-2 MIN	
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
-------------------------	---------------	-----------------	-----------

HP-R-226-P-M	RADIATION - PART.	REACTOR BUILDING	TIMSER
--------------	-------------------	------------------	--------

Description: Reactor Building Purge Air Exhaust, Duct B,
Radiation Monitor - Particulate Timser2

Qualification category: TREND Uncertainty: TIME +/-2 MIN

Comments:

HP-R-228-G-M	RADIATION - GAS	AUX BUILDING	TIMSER
--------------	-----------------	--------------	--------

Description: Auxiliary Building Purge Air Exhaust Radiation
Monitor, Downstream of Filter - Gas Timser2

Qualification category: TREND Uncertainty: TIME +/-2 MIN

Comments:

HP-R-228-I-M	RADIATION - IODINE	AUX BUILDING	TIMSER
--------------	--------------------	--------------	--------

Description: Auxiliary Building Purge Air Exhaust Radiation
Monitor, Downstream of Filter - Iodine Timser2

Qualification category: TREND Uncertainty: TIME +/-2 MIN

Comments:

HP-R-228-P-M	RADIATION - PART.	AUX BUILDING	TIMSER
--------------	-------------------	--------------	--------

Description: Auxiliary Building Purge Air Exhaust Radiation
Mon., Downstream of Filter - Particulate Timser2

Qualification category: TREND Uncertainty: TIME +/-2 MIN

Comments:

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
HP-R-229-G-M	RADIATION - GAS	REACTOR BUILDING	TIMSER
Description:	Hydrogen Purge Radiation Monitor - Gas Timser		
Qualification category:	TREND	Uncertainty:	TIME +-2 MIN
Comments:			
HP-R-3236-M	RADIATION - GM	REACTOR BUILDING	TIMSER
Description:	Reactor Building Purge Unit Area Radiation Monitor Timser2		
Qualification category:	TREND	Uncertainty:	TIME +-15MIN
Comments:			
HP-R-3238-M	RADIATION - GM	AUX BUILDING	TIMSER
Description:	Auxiliary Building Exhaust Unit Area Radiation Monitor Timser2		
Qualification category:	TREND	Uncertainty:	TIME +-15MIN
Comments:			
HP-R-3240-M	RADIATION - GM	FUEL HANDLING BUILDING	TIMSER
Description:	Fuel Handling Exhaust Unit Area Radiation Monitor Timser2		
Qualification category:	TREND	Uncertainty:	TIME +-15MIN
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
HPI/MAKEUP	FLOW	MAKEUP/LETDOWN	COND
Description:	HPI/Makeup Est. Based on Expected Results, from a mass balance analysis of the Pri. Sys. Cond		
Qualification category:	EST TREND	Uncertainty:	
Comments:			
IC-R-1091-M	RADIATION	REACTOR COOLANT	TIMSER
Description:	Intermediate Coolant Letdown, Cooler B Radiation Monitor Timser2		
Qualification category:	TREND	Uncertainty:	TIME +-5 MIN
Comments:			
IC-R-1092-M	RADIATION - SCINT.	REACTOR COOLANT	TIMSER
Description:	Intermediate Coolant Letdown, Cooler A Radiation Monitor Timser2		
Qualification category:	TREND	Uncertainty:	TIME +-5 MIN
Comments:			
IC-R-1093-M	RADIATION	REACTOR COOLANT	TIMSER
Description:	Intermediate Coolant Letdown, Inlet Radiation Monitor Timser2		
Qualification category:	TREND	Uncertainty:	TIME +-5 MIN
Comments:			

TABLE 8-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
LASL DECAY HEAT	DECAY HEAT	REACTOR CORE	TIMSER
Description: Decay Heat			Timser
Qualification category: QUALIFIED		Uncertainty: 20% READ.	
Comments:			
LETDOWN FLOW	FLOW	MAKEUP/LETDOWN	COND
Description: Letdown Cooler Mass Flowrate			Cond
Qualification category: QUALIFIED		Uncertainty: 24.6% READ.	
Comments: CALCULATED PARAMETER			
MU-R-720H-M	RADIATION	MAKEUP/LETDOWN	TIMSER
Description: Primary Coolant Letdown HI Radiation Monitor			Timser2
Qualification category: TREND		Uncertainty: TIME +-5 MIN	
Comments:			
MU-R-720L-M	RADIATION	MAKEUP/LETDOWN	TIMSER
Description: Primary Coolant Letdown LO Radiation Monitor			Timser
Qualification category: TREND		Uncertainty: TIME +-5 MIN	
Comments:			

TABLE 8-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
MU-TE-739-M	TEMPERATURE	MAKEUP/LETDOWN	TIMSER
Description:	Letdown Cooler 1A Outlet Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	10% READING
Comments:			
MU-TE-740-M	TEMPERATURE	MAKEUP/LETDOWN	TIMSER
Description:	Letdown Cooler 1B Outlet Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	10% READING
Comments:			
NI-ND-1-P	NUCLEAR - BF3	REACTOR VESSEL	TIMSER
Description:	Source Range Power Level		Timser
Qualification category:	QUALIFIED	Uncertainty:	TIME+0S-30S
Comments:			
NI-ND-1-S	NUCLEAR - BF3	REACTOR VESSEL	TIMSER
Description:	Source Range Power Level		Timser
Qualification category:	QUALIFIED	Uncertainty:	TIME+10S-45S
Comments:			

TABLE 8-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
NI-ND-2-P	NUCLEAR - BF3	REACTOR VESSEL	TIMSER
Description:	Source Range Power Level		Timser
Qualification category:	QUALIFIED	Uncertainty:	TIME+0S-30S
Comments:			
NI-ND-3-S	NUCLEAR - ION	REACTOR VESSEL	TIMSER
Description:	Intermediate Range Power Level		Timser
Qualification category:	TREND	Uncertainty:	TIME+10S-45S
Comments:			
NI-ND-4-S	NUCLEAR - ION	REACTOR VESSEL	TIMSER
Description:	Intermediate Range Power Level		Timser
Qualification category:	TREND	Uncertainty:	TIME+10S-45S
Comments:			
NSAC MAKEUP	FLOW	MAKEUP/LETDOWN	COND
Description:	NSAC MAAP V2.0 Calculation of HPI/Makeups		Cond
Qualification category:	ESTIMATE	Uncertainty:	
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
PCP1A	BINARY	REACTOR COOLANT-A	COND
Description:	Primary Coolant Pump 1A (Start/Stop Times), Binary Function Cond		
Qualification category:	TREND	Uncertainty:	
Comments:			
PCP1B	BINARY	REACTOR COOLANT-B	COND
Description:	Primary Coolant Pump 1B (Start/Stop Times), Binary Function Cond		
Qualification category:	TREND	Uncertainty:	
Comments:			
PCP2A	BINARY	REACTOR COOLANT-A	COND
Description:	Primary Coolant Pump 2A (Start/Stop Times), Binary Function Cond		
Qualification category:	TREND	Uncertainty:	
Comments:			
PCP2B	BINARY	REACTOR COOLANT-B	COND
Description:	Primary Coolant Pump 2B (Start/Stop Times), Binary Function Cond		
Qualification category:	TREND	Uncertainty:	
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
-------------------------	---------------	-----------------	-----------

PORV FLOW RATE	FLOW	PRESSURIZER	TIMSER
----------------	------	-------------	--------

Description: Discharge Flow Rate Through the Pressurizer PORV -
Calculated Parameter Timser

Qualification category: QUALIFIED Uncertainty: 20% READING

Comments: CALCULATED PARAMETER, FROM 220 - 318 MIN. UNCERT.
IS +50%, - 20%

PRESS.-PRIMARY	PRESSURE	REACTOR COOLANT	TIMSER
----------------	----------	-----------------	--------

Description: Reactor Coolant Composite Pressure
Timser3

Qualification category: QUALIFIED Uncertainty: 40 PSI (MAX)

Comments: COMPOSITE DATA

PRESSURE UNC	PRESSURE	REACTOR COOLANT	COND
--------------	----------	-----------------	------

Description: Primary System Pressure Uncertainty, Discontinuous
Function Cond

Qualification category: QUALIFIED Uncertainty:

Comments:

PZR HEAT POWER	POWER	PRESSURIZER	COND
----------------	-------	-------------	------

Description: Total Pressurizer Heater Group Power

Qualification category: TREND Uncertainty:

Comments:

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
RC-1-LT1-L-R	LEVEL	PRESSURIZER	TIMSER
Description: Pressurizer Level			Timser3
Qualification category: QUALIFIED		Uncertainty: 24 IN	
Comments:			
RC-14A-FT-CALC	FLOW	REACTOR COOLANT - LOOP A	TIMSER
Description: Calculated Loop A Mass Flow Rate			Timser
Qualification category: QUALIFIED		Uncertainty: SEE UNC. CH.	
Comments: SEE RC-14A-FT-UNC-U & -L			
RC-14A-FT-UNC-L	FLOW	REACTOR COOLANT - LOOP A	TIMSER
Description: Lower Uncertainty of Function RC-14A-FT-CALC			Timser
Qualification category:		Uncertainty:	
Comments: LOWER UNCERTAINTY FUNCTION FOR RC-14A-FT-CALC			
RC-14A-FT-UNC-U	FLOW	REACTOR COOLANT - LOOP A	TIMSER
Description: Upper Uncertainty of Function RC-14A-FT-CALC			Timser
Qualification category:		Uncertainty:	
Comments: UPPER UNCERTAINTY FUNCTION FOR RC-14A-FT-CALC			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
RC-14B-FT-CALC	FLOW	REACTOR COOLANT - LOOP B	TIMSER
Description:	Calculated Loop B Mass Flow Rate		Timser
Qualification category:	QUALIFIED	Uncertainty:	SEE UNC. CH.
Comments:	SEE RC-14B-UNC-U & -L		
RC-14B-FT-UNC-L	FLOW	REACTOR COOLANT - LOOP B	TIMSER
Description:	Lower Uncertainty of Function RC-14A-FT-CALC		Timser
Qualification category:		Uncertainty:	
Comments:	LOWER UNCERTAINTY FUNCTION FOR RC-14B-FT-CALC		
RC-14B-FT-UNC-U	FLOW	REACTOR COOLANT - LOOP B	TIMSER
Description:	Upper Uncertainty Function of RC-14B-FT-CALC		Timser
Qualification category:		Uncertainty:	SEE UNC. CH.
Comments:	UPPER UNCERTAINTY FUNCTION FOR RC-14B-FT-CALC		
RC-15A-TE3-M	TEMPERATURE	REACTOR COOLANT-A	TIMSER
Description:	Cold Leg Temperature - Pump 2A Inlet : Wide Range (Elev. 310'2")		Timser
Qualification category:	TREIND	Uncertainty:	TIME +/-5 MIN
Comments:	USE AS INITIAL CONDITION, CONDITION AT 100 AND 174 MIN.		

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
RC-15B-TE2-M	TEMPERATURE	REACTOR COOLANT-B	TIMSER
Description:	Cold Leg Temperature - Pump 1B Inlet : Wide Range Timer		
Qualification category:	TREND	Uncertainty:	TIME+-2.5MIN
Comments:	DATA ARE TREND		
RC-15B-TE3-M	TEMPERATURE	REACTOR COOLANT-B	TIMSER
Description:	Cold Leg Temperature - Pump 2B Inlet : Wide Range (Elev. 310'2") Timer		
Qualification category:	TREND	Uncertainty:	TIME+-2.5MIN
Comments:	USE AS INITIAL CONDITION, CONDITION AT 100 AND 174 MIN.		
RC-2-TE1/2-P	TEMPERATURE	PRESSURIZER	TIMSER
Description:	Pressurizer Temperature Timer		
Qualification category:	QUALIFIED	Uncertainty:	2.5 DEG F
Comments:			
RC-5A-TE2-R	TEMPERATURE	REACTOR COOLANT - LOOP A	TIMSER
Description:	Cold Leg Temperature - Loop 1A Inlet: Wide Range Timer ⁴		
Qualification category:	QUALIFIED	Uncertainty:	1.91 DEG F
Comments:	QUALIFIED FOR FIRST 1000 MIN.		

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
RC-5B-TE2-R	TEMPERATURE	REACTOR COOLANT - LOOP B	TIMSER
Description:	Cold Leg Temperature - Pump 1B Inlet : Wide Range Timser4		
Qualification category:	QUALIFIED	Uncertainty:	1.91 DEG F
Comments:	QUALIFIED FOR FIRST 1000 MIN.		
RC-9-TE-P	TEMPERATURE	PRESSURIZER	TIMSER
Description:	Pressurizer Surge Line Temperature Timser		
Qualification category:	TREND	Uncertainty:	TIME +-1 MIN
Comments:			
RC-V1	BINARY	PRESSURIZER	COND
Description:	Pressurizer Spray Valve Position (Open/Closed), Binary Function Cond		
Qualification category:	QUALIFIED	Uncertainty:	N. A.
Comments:			
RC-V2	BINARY	REACTOR COOLANT	TIMSER
Description:	Pressurizer Block Valve Position (Open/Closed), Binary Function Timser		
Qualification category:	QUALIFIED	Uncertainty:	TIME+-0.5MIN
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
SF-R-3402-M	RADIATION	SPENT FUEL	TIMSER
Description: Spent Fuel Cooling Area Radiation Monitor Timser2			
Qualification category: TREND		Uncertainty: TIME +/-5 MIN	
Comments:			
SG-A-LEVEL	LEVEL	STEAM GENERATOR A	TIMSER
Description: Steam Generator A - Composite Level Timser3			
Qualification category: QUALIFIED		Uncertainty: 9 IN	
Comments: COMPOSITE DATA			
SG-B-LEVEL	LEVEL	STEAM GENERATOR B	TIMSER
Description: Steam Generator B - Composite Level Timser3			
Qualification category: QUALIFIED		Uncertainty: 9 IN	
Comments: COMPOSITE DATA			
SP-10A-PT1-R	PRESSURE	STEAM GENERATOR A	TIMSER
Description: Turbine Header Pressure - Loop A Timser3			
Qualification category: QUALIFIED		Uncertainty: 8.2 PSI	
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
SP-12A-TE1-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description:	Steam Generator A - Upper Downcomer Temperature Elevation 320'1"		Timser
Qualification category:	QUALIFIED	Uncertainty:	2.2 DEG F
Comments:			
SP-12A-TE2-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description:	Steam Generator A - Upper Downcomer Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	2.2 DEG F
Comments:			
SP-12B-TE1-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
Description:	Steam Generator B - Upper Downcomer Temperature Elevation 320'1"		Timser
Qualification category:	QUALIFIED	Uncertainty:	2.2 DEG F
Comments:			
SP-12B-TE2-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
Description:	Steam Generator B - Upper Downcomer Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	2.2 DEG F
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
SP-2A-TE1-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description: Steam Generator A - Shell Temperature Elevation 303'2" Timser			
Qualification category: QUALIFIED		Uncertainty: 8.1 DEG F	
Comments:			
SP-2A-TE2-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description: Steam Generator A - Shell Temperature Timser			
Qualification category: QUALIFIED		Uncertainty: 8.1 DEG F	
Comments:			
SP-2A-TE3-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description: Steam Generator A - Shell Temperature Timser			
Qualification category: QUALIFIED		Uncertainty: 8.1 DEG F	
Comments:			
SP-2A-TE4-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description: Steam Generator A - Shell Temperature Timser			
Qualification category: QUALIFIED		Uncertainty: 8.1 DEG F	
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
SP-2A-TE5-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description:	Steam Generator A - Shell Temperature Elevation 338'3" Steam Outlet		Timser
Qualification category:	QUALIFIED	Uncertainty:	8.1 DEG F
Comments:			
SP-2B-TE1-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
Description:	Steam Generator - B - Shell Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	8.1 DEG F
Comments:			
SP-2B-TE2-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
Description:	Steam Generator B - Shell Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	8.1 DEG F
Comments:			
SP-2B-TE3-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
Description:	Steam Generator B - Shell Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	8.1 DEG F
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
-------------------------	---------------	-----------------	-----------

SP-2B-TE4-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
-------------	-------------	-------------------	--------

Description: Steam Generator B - Shell Temperature
Timser

Qualification category: QUALIFIED Uncertainty: 8.1 DEG F

Comments:

SP-2B-TE5-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
-------------	-------------	-------------------	--------

Description: Steam Generator B - Shell Temperature
Elevation 338'3" Steam Outlet Timser

Qualification category: QUALIFIED Uncertainty: 8.1 DEG F

Comments:

SP-3A-TE1/2-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
---------------	-------------	-------------------	--------

Description: Steam Generator A - Downcomer Temperature
Timser

Qualification category: QUALIFIED Uncertainty: 2.2 DEG F

Comments:

SP-3B-TE1/2-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
---------------	-------------	-------------------	--------

Description: Steam Generator B - Downcomer Temperature
Timser

Qualification category: QUALIFIED Uncertainty: 2.2 DEG F

Comments:

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
SP-4A-TE-P	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description:	Steam Generator A - Main Steam Temperature Turbine Bldg. - Steam Line A1		Timser
Qualification category:	QUALIFIED	Uncertainty:	2.1 DEG F
Comments:	QUALIFIED FOR INITIAL CONDITIONS ONLY		
SP-4B-TE-P	TEMPERATURE	STEAM GENERATOR B	TIMSER
Description:	Steam Generator B - Main Steam Temperature Turbine Bldg.		Timser
Qualification category:	QUALIFIED	Uncertainty:	2.1 DEG F
Comments:	QUALIFIED FOR INITIAL CONDITIONS ONLY		
SP-5A-TE1/2-R	TEMPERATURE	FEEDWATER	TIMSER
Description:	Feedwater Temperature		Timser
Qualification category:	QUALIFIED	Uncertainty:	1.78 DEG F
Comments:	QUALIFIED FOR INITIAL CONDITIONS ONLY		
SP-6A-PT-ABS	PRESSURE	STEAM GENERATOR A	TIMSER
Description:	Steam Generator A - Secondary Absolute Pressure		Timser3
Qualification category:	QUALIFIED	Uncertainty:	16.2 PSI
Comments:	FAILED AFTER 932 MIN. (SEE NOTE 49)		

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
SP-6A-PT1-R	PRESSURE	STEAM GENERATOR A	TIMSER
Description:	Steam Generator A - Steam Pressure Reactor bldg. - Steam Line A1 or A2		Timser3
Qualification category:	QUALIFIED	Uncertainty:	16.1 PSI
Comments:	FAILED AFTER 932 MIN. (SEE NOTE 48)		
SP-6B-PT-ABS	PRESSURE	STEAM GENERATOR B	TIMSER
Description:	Steam Generator B - Secondary Absolute Pressure		Timser3
Qualification category:	QUALIFIED	Uncertainty:	16.2 PSI
Comments:	FAILED AFTER 932 MIN. (SEE NOTE 49)		
SP-6B-PT1-R	PRESSURE	STEAM GENERATOR B	TIMSER
Description:	Steam Generator B - Steam Pressure Reactor Bldg. - Steam Line A1 or A2		Timser3
Qualification category:	QUALIFIED	Uncertainty:	16.1 PSI
Comments:	FAILED AFTER 932 MIN. (SEE NOTE 48)		
SP-8A-FT-R	FLOW	FEEDWATER A	TIMSER
Description:	Main Feedwater Flow Rate - Loop A Steam Generator		Timser
Qualification category:	QUALIFIED	Uncertainty:	.106 MLB/HR
Comments:	QUALIFIED FOR INITIAL CONDITIONS ONLY		

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
-------------------------	---------------	-----------------	-----------

SP-8B-FT-R	FLOW	FEEDWATER B	TIMSER
------------	------	-------------	--------

Description: Main Feedwater Flow Rate - Loop B Steam Generator
Timser

Qualification category: QUALIFIED Uncertainty: .106 MLB/HR

Comments: QUALIFIED FOR INITIAL CONDITIONS ONLY

TE-HL-A	TEMPERATURE	REACTOR COOLANT LOOP A	TIMSER
---------	-------------	------------------------	--------

Description: Reactor Coolant Composite Hot Leg Temperature -
Loop A Timser4

Qualification category: QUAL/TREND Uncertainty: 1.14 DEG F

Comments: COMPOSITE DATA

TE-HL-B	TEMPERATURE	REACTOR COOLANT LOOP B	TIMSER
---------	-------------	------------------------	--------

Description: Reactor Coolant Composite Hot Leg Temperature -
Loop B Timser4

Qualification category: QUAL/TREND Uncertainty: 1.14 DEG F

Comments: COMPOSITE DATA

TSAT-PRIMARY	TEMPERATURE	REACTOR COOLANT	TIMSER
--------------	-------------	-----------------	--------

Description: Reactor Coolant Saturation Temperature - Calcul.
from Composite Pri. Press. PRESS.-PRI. Timser4

Qualification category: QUALIFIED Uncertainty: 4.8 DEG F

Comments: COMPUTED PARAMETER

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
TSAT-SG-A	TEMPERATURE	STEAM GENERATOR A	TIMSER
Description:	Saturation Temperature Calculated from Secondary Pressure (SP-6A-PT1-R), Steam Gen. A Timser4		
Qualification category:	QUALIFIED	Uncertainty:	5.5 DEG F
Comments:	COMPUTED PARAMETER		
TSAT-SG-B	TEMPERATURE	STEAM GENERATOR B	TIMSER
Description:	Saturation Temperature Calculated from Secondary Pressure (SP-6B-PT1-R), Steam Gen. B Timser4		
Qualification category:	QUALIFIED	Uncertainty:	5.5 DEG F
Comments:	COMPUTED PARAMETER		
WDL-PT-1202-R	PRESSURE	PRESSURIZER	TIMSER
Description:	Reactor Coolant Drain Tank (RCDT) Pressure Timser3		
Qualification category:	QUALIFIED	Uncertainty:	3.9 PSI
Comments:	QUALIFIED UP TO 932 MINUTES - FAILED THEREAFTER		
WDL-R-1311-M	RADIATION	DISCHARGE	TIMSER
Description:	Plant Effluent Radiation Monitor, Unit 2 Timser2		
Qualification category:	TREND	Uncertainty:	TIME +/- 5 MIN
Comments:			

TABLE B-1 SUMMARY OF ICBC TIME SERIES FUNCTIONS

Function Identification	Function Type	Function System	ICBC Area
WDL-TE-1200-P	TEMPERATURE	PRESSURIZER	TIMSER
Description: Reactor Coolant Drain Tank (RCDT) Temperature Timser2			
Qualification category: QUALIFIED		Uncertainty: 1.7 DEG F	
Comments:			
WGD-R-1480-G-M	RADIATION - GAS	WASTE GAS	TIMSER
Description: Waste Gas Discharge Duct Radiation Monitor - Gas Timser2			
Qualification category: TREND		Uncertainty: TIME +-2 MIN	
Comments:			

APPENDIX C

INSTRUCTIONS TO REBUILD USER INDEX FILE

APPENDIX C

CONTENTS

PROCEDURE TO REBUILD USER DATA AREA C-1

FIGURES

C-1. REBUILD Definition Form C-1

APPENDIX C - PROCEDURE TO REBUILD USER DATA AREA

ICBC Version 3.1 contains provision for users to enter their own time series functions. These data are stored in block files within the \ICBC subdirectory of the PC system; associated with this block file are a data and an index file (UDATA.BLK, UDATA.DAT and UDATA.IDX). The user should periodically back these files up on some disk media to insure that his information will not be lost.

A SAGE utility, named REBUILD, has been provided in the \ICBC area and can be used (1) to restore a damaged index file to operation or (2) to remove unused space within the UDATA.BLK file caused by deletion of user functions.

The utility is accessed by entering the ICBC subdirectory (cd\icbc) and typing the command 'rebuild' followed by a carriage return (Enter). A form shown in Figure C-1 is produced on which the user enters 'Data' as the name of the relation to rebuild and 'ICBC.DFL' as the current definition file (if compacting a data file, case 2 above, 'ICBC.DFL' is also required as the old definition file). Processing messages are displayed at the bottom of the form during the rebuild operation; should errors occur, SAGE error message notation will be displayed.

Restructure / Rebuild Process	
This process restructures a relation's data records and/or rebuilds its index.	
Name of relation to rebuild	Data
Name of current DFL file	ICBC.DFL
Fill in the Name of the old DFL file if a restructure of the requested relation is required. If only an index rebuild is required, leave the old DFL file name blank.	
Name of old DFL file	ICBC.DFL

Figure C-1. REBUILD Definition Form

Any ICBC data file or index may be processed using REBUILD, however, since the user is unable to change data in any file other than UDATA, it is preferred that errors in other files which may occur be corrected by recopying them from the Version 3.1 diskettes to area \ICBC.

APPENDIX D

IMPROVED DECIMATION OF REACTIMETER DATA CHANNELS

APPENDIX D

CONTENTS

IMPROVED DECIMATION OF REACTIMETER DATA CHANNELS	D-1
--------------------------------------------------------	-----

TABLES

D-1. TMI-2 Reactimeter Data Channel Decimation	D-2
------------------------------------------------------	-----

FIGURES

D-1. Steam Generator A Pressure - 0 to 100 min (SP-6A-PT1-R)	D-3
D-2. Decimated Steam Generator Pressure - 0 to 100 Minutes	D-3
D-3. Steam Generator A Pressure - 100 to 200 min (SP-6A-PT1-R)	D-4
D-4. Decimated Steam Generator Pressure - 100 to 200 Minutes	D-4
D-5. Steam Generator A Pressure - 400 to 500 min (SP-6A-PT1-R)	D-5
D-6. Decimated Steam Generator Pressure - 400 to 500 Minutes	D-5

APPENDIX D - IMPROVED DECIMATION OF REACTIMETER DATA CHANNELS

A typical reactimeter channel contains in excess of 20,000 samples for the first 1,000 minutes of the TMI-2 accident. The data base becomes inefficient both in speed of performance and required disk storage space for channels in excess of about 2,500 samples. The objective in decimating the TMI-2 data is to provide less than 2,500 samples that represent the original data with regard to magnitude, event timing, frequency content, and measurement range. Simple methods such as keeping every tenth point, although simple and easy to implement, reduces the frequency content by the same magnitude. A method utilizing the first derivative, absolute magnitude changes, and relative minima and maxima of the data was developed to accomplish data decimation while meeting the stated criteria. The computer code which accomplished the decimation in effect simulated hand selection of the data to be retained.

Table 1 provides a summary of the decimated data. Only 14 of the measurements required decimation. The decimation ratio ranged from approximately 3:1 up to approximately 17:1. The number of samples retained for a specific measurement and time period is highly dependent on the character of the data. For example a comparison of the original to decimated data for the measured steam pressure of steam generator A (SP-6A-PT1-R) for three 100 minute time periods is shown in figures D-1 through D-6. These figures show that the character of the data is retained with regard to frequency content (except for noise), magnitudes (variations are within data uncertainty) and event timing. No known essential features have been deleted from the data.

TABLE O-1
TMI-2 REACTIMETER DATA CHANNEL DECIMATION

Identification	Description	Range (sec)	Nr Samples	
			Original	Decimated
PRESS.-PRIMARY	Reactor Coolant Composite Pressure	-10 - 1000	7229	1411
RC-1-LT1-L-R	Pressurizer Level	-10 - 1000	20115	2347
RC-5A-TE2-R	Cold Leg Temperature - Loop 1A Inlet: Wide Range	-10 - 1000	20116	1948
RC-5B-TE2-R	Cold Leg Temperature - Pump 1B Inlet: Wide Range	-10 - 1000	20116	1829
SG-A-LEVEL	Steam Generator A - Composite Level	-10 - 1000	20195	1864
SG-B-LEVEL	Steam Generator B - Composite Level	-10 - 1000	20115	1704
SP-10A-PT1-R	Turbine Header Pressure - Loop A	-10 - 132	20115	1216
SP-6A-PT1-R	Steam Generator A - Steam Pressure	-10 - 933	18745	1583
SP-6A-PT1-ABS	Steam Generator A - Absolute Pressure	-10 - 933	18745	2164
SP-6B-PT1-R	Steam Generator B - Steam Pressure	-10 - 933	18745	2197
SP-6B-PT1-ABS	Steam Generator B - Absolute Pressure	-10 - 933	18745	2405
TE-HL-A	Reactor Coolant Composite Temperature - Loop A	-10 - 938	9099	1618
TE-HL-B	Reactor Coolant Composite Temperature - Loop B	-10 - 979	3495	1336
WDL-PT-1202-R	Reactor Coolant Drain Tank (RCDT) Pressure	-10 - 933	18765	1974




Figure D-1. Steam Generator A Pressure 0 to 100 Minutes (SP-6A-PT1-R)




Figure D-2. Decimated Steam Generator Pressure 0 to 100 minutes




Figure D-3. Steam Generator A Pressure 100 to 200 Minutes (SP-6A-PT1-R)




Figure D-4. Decimated Steam Generator Pressure 100 to 200 Minutes




Figure D-5. Steam Generator A Pressure 400 to 500 Minutes (SP-6A-PT1-R)




Figure D-6. Decimated Steam Generator Pressure 400 to 500 Minutes

APPENDIX E

CONTENTS OF ICBC DISKETTES

APPENDIX E

CONTENTS

CONTENTS OF LOW DENSITY ICBC DISKETTES	E-1
CONTENTS OF HIGH DENSITY ICBC DISKETTES	E-3

CONTENTS OF ICBC LOW DENSITY DISKETTES

Diskette 1:

INSTALL	BAT	INSTALLX	BAT	ICBC	BAT	BURNUP	DAT
DBUSER	DAT	GPSUM	DAT	GROUPS	DAT	NOTES	DAT
TSDAT	DAT	TIMSER	DAT	BURNUP	IDX	DBUSER	IDX
GROUPS	IDX	NOTES	IDX	TIMSER	IDX	TSDAT	IDX
M2	EXE	REBUILD	EXE	ICBC	DFL		

Diskette 2:

COND	DAT	COND	IDX	ICBCPD	LOD	ICBCW02	LOD
ICBCW03	LOD	ICBCW05	LOD	ICBCW07	LOD	ICBCW08	LOD
ICBCW11	LOD	ICBCW12	LOD	ICBCW13	LOD	ICBCW14	LOD

Diskette 3:

APPEND	DAT	PKFAC	DAT	APPEND	IDX	PKFAC	IDX
ICBC	LOD						

Diskette 4:

DISKITS	LOD	ICBCPM	LOD	MANIPTS	LOD		
---------	-----	--------	-----	---------	-----	--	--

Diskette 5:

TIMSER	BLK	HALOKBDI	COM	MARK	COM	RELEASE	COM
ICBCW04	LOD	HALOMSMI	LOC	REBUILD	DFL		

Diskette 6:

TSDAT	BLK	HALOMSMI	COM	HALOSDTI	COM	HALORLM	EXE
THALO	EXE	EDITI	LOD	HPLOT	LOD	HALOIBME	DEV
HALO106	FNT	HALOEPSN	PRN				

Diskette 7:

HP7550	EXE	ICBCP	LOD	ICBCW	LOD	ICBCW09	LOD
ICBCW10	LOD	ICBCW15	LOD	ICBCW16	LOD		

Diskette 8:

TIMSER3	BLK	TIMSER3	DAT	TIMSER3	IDX		
---------	-----	---------	-----	---------	-----	--	--

Diskette 9:

TIMSER4	BLK	TIMSER4	DAT	HP7475	EXE	TIMSER4	IDX
---------	-----	---------	-----	--------	-----	---------	-----

Diskette 10:

TIMSER2	BLK	TIMSER2	DAT	TIMSER2	IDX		
---------	-----	---------	-----	---------	-----	--	--

CONTENTS OF ICBC HIGH DENSITY DISKETTES

Diskette 1:

INSTALL	BAT	INSTALLX	BAT	ICBC	BAT	ICBC	DFL
M2	EXE	DISKITS	LOD	EDITI	LOD	HPPLOT	LOD
ICBC	LOD	ICBCP	LOD	ICBCPD	LOD	ICBCPM	LOD
ICBCW	LOD	ICBCW02	LOD	ICBCW03	LOD	ICBCW04	LOD
ICBCW05	LOD	ICBCW07	LOD	ICBCW08	LOD	ICBCW09	LOD
ICBCW10	LOD	ICBCW11	LOD	ICBCW12	LOD	ICBCW13	LOD
ICBCW14	LOD	ICBCW15	LOD	ICBCW16	LOD	MANIPTS	LOD

Diskette 2:

TIMSER3	BLK	TIMSER4	BLK	APPEND	DAT	BURNUP	DAT
COND	DAT	DBUSER	DAT	GPSUM	DAT	GROUPS	DAT
HPI	DAT	NOTES	DAT	PKFAC	DAT	TIMSER	DAT
TIMSER2	DAT	TIMSER3	DAT	TIMSER4	DAT	TSDAT	DAT
REBUILD	DFL	HP7475	EXE	HP7550	EXE	REBUILD	EXE
APPEND	IDX	BURNUP	IDX	COND	IDX	DBUSER	IDX
GROUPS	IDX	NOTES	IDX	PKFAC	IDX	TIMSER	IDX
TIMSER2	IDX	TIMSER3	IDX	TIMSER4	IDX	TSDAT	IDX

Diskette 3:

TIMSER	BLK	TIMSER2	BLK	TSDAT	BLK	HALOKBDI	COM
HALOMSMI	COM	HALOSDTI	COM	MARK	COM	RELEASE	COM
HALOIBM	DEV	HALOIBME	DEV	HALOIBMG	DEV	HALOPLHP	EXE
HALORLM	EXE	HALO106	FNT	HALOKBDI	LOC	HALOMSMI	LOC
HALOSDTI	LOC	HALOEPSN	PRN	HALOLJTP	PRN		