March 15, 1985

Docket No. 50-320

Mr. F. R. Standerfer Vice President/Director Three Mile Island Unit 2 GPU Nuclear Corporation P.O. Box 480 Hiddletown, PA 17057

Dear Hr. Standerfer:

Distribution: Docket No. 50-320 HRDenton NRC PDR Local PDR M-town Office DCS TMI HO R/F TMI Site R/F BJSnyder **WDTravers TPoindexter** MTMasnik RWeller PGrant RCook CCowgill. LChandler, ELD IE (3) ACRS (16)

By letter (4410-84-L-0199) dated November 8, 1984, you forwarded the "Reactor Coolant System Criticality Report." This report provides the criteria and rationale used for the selection of a boron concentration for the reactor coolant system (RCS) which will ensure that the fuel in the RCS will remain subcritical with a shutdown margin of at least one percent (K ≤ 0.99) for any conceivable core configuration. The report concludes that an RCS boron concentration of 4350 ppm will provide the stated shutdown margin (i.e., at least one percent) throughout all reactor disassembly and defueling activities.

The "Criticality Report" was reviewed by the NRC Core Performance Branch (CPB) and the CPB evaluation is enclosed. As discussed in the enclosure, the staff concludes that an RCS horon concentration of 4350 ppm will assure at least one percent shutdown margin for the hypothetical conservative fuel model assumed in your analysis. We note that your maintenance of an "operating" RCS boron concentration of approximately 5000 ppm will provide a significantly larger real shutdown margin, and a corresponding degree of enhanced safety, as you conduct reactor disassembly and defueling operations.

Sincerely,

Original signed by B. J. Strutter

> Bernard J. Snyder, Program Director Three Mile Island Program Office Office of Nuclear Reactor Regulation

Enclosure: As stated

cc: T. F. Demnit R. E. Rogan S. Levin R. L. Freeme J. J. Byrne	t Preda 85032201 PDR ADO P	45 850315 CK 05000320 PDR		
OFFICED SCRVICE Dist SURNAMED (see attac	ribution List	TMIPO:NRR RAWeller:bg 3//4/85	PD: 119 PD: NRR BJSnyder 3/14/85	
NRC FORM 318 (10-80) NRCM 0240	OFFICIAL	RECORD C	OPY	USGPO: 1981335-960

TMI-2 SERVICE LIST

Dr. Thomas Hurley Regional Administrator, Region 3 U.S. Nuclear Adgulatory Commission 831 Part Avenue King of Prussia, PA 19405

John F. Wolfe, Esc., Chairman, Administrative Judge Ja09 Shepherd St. Chevy Chase, HD, 20015

Dr. Oscar H. Paris Administrative Judge Atomic Safety and Licensing Board Panel U.S. Muclear Regulatory Commission Washington, D.C. 20555

Dr. Frederict H. Shon Administrative Judge Atomic Safety and Licensing Board Panel U.S. Nuclear Regulatory Commission Meshington, D.C. 20555

Karin W. Carter Assistant Attorney General 505 Executive House P.O. Box 2357 Herrisburg, PA 17120

Dr. Judith H. Johnsrud Environmental Coalition on Nuclear Power 433 Drlando Ave. State College. PA 16801

George F. Trowbridge, Eso. Shaw, PittMan, Potts and Trowbridge 1800 M. St., NM. Washington, O.C. 20036

Atomic Safety and Licensing Board Panel U.S. Ruclear Regulatory Commission Mashington, D.C. 20555

Atomic Safety and Licensing Appeal Panel U.S. Nuclear Regulatory Commission Mashington, D.C. 20555

Secretary U.S. Muclear Regulatory Commission ATTN: Chief, Docketing & Service Branch Weshington, D.C. 20555

Mr. Larry Hochendoner Deuphin Cornty Commissioner P.O. Boz 1295 Herrisburg, PA 17108-1295

John C. Winnich, Chairperson, Dauphin County Board of Commissioners Dauphin County Courthouse Front end Market Streets Marrisburg, PA 17101

Dauphin County Office of Emergency Preparedness Court Nouse, Room 7 Front & Market Streets Nerrisburg, PA 17101

U.S. Environmental Protection Agency Region 111 Office ATTA: Elis Coordinator Curtis Building (Sixth Floor) 6th 8 Walnut Streets Philacelphia, PA 19106

Thomas N. Gerusky, Director Buresu of Rediation Protection Department of Environmental Resources P.O. Box 2063 Nuerisburg, PA 17120

Den Kannedy Office of Environmental Planning Oeguroment of Environmental Resources P.O. Box 2003 Narrisburg, PA 17120 Willis Bizby, Site Kenager U.S. Depertment of Energy P.O. Boz 88 Middletown, PA 17057-0311

Devid J. NcGoff Division of Three mile Island programs NE-23 U.S. Department of Emergy Mashington, D.C. 20345

William Lochstet 104 Davey Laboretory Pennsylvania State University University Park, PA 16802

Randy Hyers, Editorial The Patriot B12 Market St. Marrisburg, PA 17105

Robert B. Borsum Robert B. Blorsum Ruclesr Power Generation Division Suite 220 7910 Woodmoant Ave. Bethesda, MD. 20214

Michael Churchhill, Esq. PILCOP 1315 Malmut St., Suite 1632 Philadelphia, PA 19107

Linda W. Little 5000 Hermitage DR. Raleign.WC 27612

Mervin I. Louis 6504 Bradford Terrace Philadelphia, PA 19149

Jane Lee 183 Valley Rd. Etters,PA 17319

J.B. Liberman, Esquire Berlack,Israels, Liberman 26 groadway New York, NY 10004

Malter W. Cohen, Consumer Advocate Department of Justice Strawbarry Square, 14th Floor Herrisburg, PA 17127

Edward O. Swartz Board of Supervisors LondondRrry Township RFD #1 Geyers Church Rd. Hiddletown, PA 17057

Robert L. Enupp, Esouire Assistant Solicitor Knupp and Andrews P.O. Bo: P 407 h. Front St. Narrisburg, PA 17108

John Levin, Esquire Pennsylvania Public Utilities Comm. P.O. Box 3265 Nerrisburg, PA 17120

Nonorable Mars Cohen 512 E-E Main Capital Building Marrisburg, PA 17120

Mr. Edwin Xintner Esecutive vice President General Public Utilities Muclear Corp. 100 Interpace Partmay Partippany, aj 07056

Ad Crable Lancaster New Era B West King Street Lancaster, PA 17602

ENCLOSURE

A REVIEW OF A CRITICALITY REPORT FOR THI-2

A letter from F. Standerfer, TMI-2, GPU Nuclear, to B. Snyder, NRC, dated November 8, 1984 enclosed a report, "Criticality Report for The Reactor Coolant System at TMI-2", October 1984. The purpose of the report was to "explain the criteria and rationale used for establishing a boron concentration for the RCS which supports a shutdown margin of at least one percent under any conceivable core configuration". This is a brief review of that report by the Core Performance Branch, NRR.

The report presents in reasonable detail discussions in the following areas involved in developing a selection of a moderator boron level to be specified for future TMI-2 operations (including defueling).

- A bounding approach ("infinite poison") to maintain subcriticality for all achievable configurations
- A criterion for a suitable boron concentration; one percent subcritical for "bounding" model with uncertainty
- "Bounding" physical model which is conservative compared to achievable configurations
- 4. Calculation methods and cross sections
- Search for and calculation of relevant nuclear experiments to check methods
- 6. Uncertainty determination for calculations from experimental comparisons
- 7. Determination of suitable fuel burnup and fission product characteristics

 Calculations for selected "bounding" model and other models for sensitivity studies

9. Results

We have examined the material presented in these areas and conclude (in brief) that appropriate and conservative approaches, criteria, physical models, calculational methods and data, experiments, uncertainty analyses and sensitivity analyses have been considered, selected and used, and the results and conclusions are acceptable. A brief elaboration or comment on these areas follows.

- 1. The approach selected is to use a sufficiently high boron level in the moderator ("infinite poison") to meet a subcritical criterion (see 2.) for any "reasonably" conceivable ("bounding", see 3.) fuel configuration. This is certainly a conservative approach (although somewhat dependent on the nature of the "bounding" configuration). The resulting "reasonably" conceivable configuration does not go as far as an infinite array of geometrically optimized, unburned, high enrichment fuel, but the "bounding" model does use all of the fuel in an appropriately maximized, conservative configuration (3). There will be more comments on the relation to an infinite array when we discuss results (9).
- 2. The shutdown criterion, i.e., sufficient boron to assure one percent shutdown for any state and fuel configuration (and specifically based on a "bounding" configuration) and including allowance for uncertainty in calculations, is somewhat arbitrary but reasonable and appropriate considering usual shutdown margin requirements. The "bounding" and uncertainty requirements should provide a much larger shutdown margin in any real condition. In the boron range of interest (4000-5000 ppm) the boron worth is about 300 ppm/% Ak and any boron dilution event would have to be extensive (from the criterion level of 4350 or the expected normal operating level of 5050 ppm) to reach critical.

- 3. The physical "bounding" model involving a lenticular core comprising all of the fuel, optimized fuel particle size and shape, optimized fuel/ moderator ratio, no structure or solid poison, a central core containing all of the high enrichment fuel with appropriate burnup (no burnup for other fuel) and an optimized stainless steel reflector is certainly highly conservative compared to any reasonably achievable configuration. It was the product of an extensive geometry and material reactivity sensitivity analysis. Our review indicates that it can be considered an appropriate "bounding" model, and it does not differ greatly in "reactivity from other more conservative models, e.g., spherical or infinite (see 9. for some quantitative comparisons to other configurations.
- 4. The computer codes used for calculations of reactivity or multiplication, primarily the Monte Carlo code KENO along with the transport code XSDRN (for sensitivity studies and parallel checks), and the cross section sets, are basic state of the art methodology with considerable background of use at ORNL (and elsewhere) for various criticality studies, and are fully acceptable.
- 5. Although the methods had been used for many criticality studies, it was felt that additional confirmation of the methodology for high density boron and close packed fuel arrays was needed. Extensive searches were done for relevant experiments and comparison calculations were made to develop additional confidence and quantitative uncertainty levels. Our review indicates that an impressive investigation of relevant experiments was conducted and a suitable analysis and confirmation of the methodology and uncertainty was carried out. Our review did not involve specific check calculations (e.g., by our BNL consultants), but we did compare some previous BNL results in this area (see reference 4 of the report) with some results from the report, using some of the sensitivity studies for extrapolation. They were in reasonable agreement. We expect

3

the calculation results given in the report to be reasonably correct.

- 6. The results of the specific experiment calculations and previous relevant calculations were examined and a conservative uncertainty of 2.5 percent delta k to be applied to results was determined. This process was discussed in detail in the report. Our review concludes that a suitably conservative uncertainty factor was determined and the result seems reasonable based on other similar work we have seen.
- 7. Credit was taken in the model for fuel burnup only for the central region high enrichment fuel. Other fuel was assumed unburned. (There was, of course, no burnable poison in the model.) Some fission product poison for the burned fuel was also used, but only after an extensive investigation of which isotopes would still be with the fuel. Also included were plutonium buildup and the decay of various isotopes since the event. We have concluded that a thorough study of burnup effects was done and a conservative model was used.
- 8. An extensive set of calculations was done to explore material configurations and the sensitivity of results to parameters such as boron level, fuel/moderator ratio, fuel burnup and isotopes present, temperature, and reflector. Our review indicates that, given the approach and model used, a complete and useful exploration was performed.
- 9. The "bounding" model (3.) meets the criterion (2.) with a boron content of 4350 ppm. The present TMI-2 boron content is about 5050 ppm and this is expected to continue during the defueling operations. The following table gives multiplication values (for the most part our estimates using report values and sensitivities) at 4350 and 5050 ppm for several configurations beginning with an ultimate maximum (an infinite array of high enrichment, optimum fuel pellets, at optimum moderator ratio), and leading by steps to the "bounding" model. This presents, briefly, some concept of sensitivities and margins involved.

Some steps have no listed k values since the information is not available, but are included to indicate full progression from maximum to chosen state.

		Calculated (or estimated) nominal k with B9		
		4350 ppm	<u>5050 ppr</u>	
1.	infinite array of high enrichment,			
	unburned, optimized fuel and moderator	1.007	0.985	
2.	sphere of (from center) high, medium, low enrichment fuel, SS reflector, with			
	radially "non uniform" optimized fuel and moderator		-	
3.	2. with uniform optimized rubble	•	•	
4.	3. with medium and low enrichment mixed	0.984	0.962	
5.	4. with high enrichment burned	0.968	0.946	
6.	5. with lenticular shape	0.965	0.943	
7.	6. with 2.5% uncertainty added	0.990	0.968	

We can note from the table that the change from sphere to lenticular is only 0.3 percent so that the "bounding" shape is not significantly far from optimum (in addition to being justifiably conservative). The use of burned high enrichment fuel is worth about 1.6 percent (about 500 ppm B), a significant amount, but is a known to exist phenomenon, conservatively calculated.

The change from the "bounding" type spherical geometry to an infinite array of high enrichment, about 2 percent, while significant, is sufficiently small to indicate no great importance to a radially non uniform moderator ratio (potential) problem. Even for an infinite array the system would be (nominally) subcritical with the expected 5050 boron level. To go from the "bounding" model to a "real" model would involve changes providing less optimum conditions (probably simultaneously) for the gross geometrical configuration, fuel enrichment geometrical arrangement, fuel amount, fuel particle size, moderator ratio, structural material present and solid poison present. Our review indicates that the "bounding" model is indeed satisfactory and conservative and that 4350 ppm boron should maintain subcriticality with sufficient margin.

We conclude that the work described in the report represents an excellent job in exploring the problems of criticality for TMI-2 defueling, including the areas of geometry selection, parameter selection, calculation methodology and uncertainty analysis. The resulting analysis leading to a selection of 4350 ppm boron as a minimum level for operation is fully satisfactory and should "ensure subcriticality through all reactor disassembly and defueling operations". In particular it should "assure at least one percent shutdown margin for an appropriate design basis fuel model."